



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

उत्तर क्षेत्रीय विद्युत समिति

Northern Regional Power Committee

No. उ.क्षे.वि.स./प्रचालन/102/01/2022/11949-11987

दिनांक: 07.12.2022


विषय: उत्तर क्षेत्रीय विद्युत समिति की एल.जी.बी.आर. उप-समिति की 28^{वीं} बैठक का कार्यवृत्त।

Subject: Minutes of 28th LGBR Sub-Committee meeting of NRPC.

उत्तर क्षेत्रीय विद्युत समिति की एल.जी.बी.आर. उप-समिति की 28^{वीं} बैठक दिनांक 06.12.2022 को आयोजित की गई। उक्त बैठक का कार्यवृत्त उत्तर क्षेत्रीय विद्युत समिति की वेबसाइट <http://164.100.60.165> पर उपलब्ध है। यदि कार्यवृत्त पर कोई टिप्पणी हो तो कार्यवृत्त के जारी करने के एक सप्ताह के अंदर उ.क्षे.वि.स. सचिवालय को सूचित करें।

28th LGBR Sub-Committee meeting of NRPC was held on 07.12.2022. The Minutes of this meeting has been uploaded on the NRPC website <http://164.100.60.165>. Any comments on the minutes may kindly be submitted to NRPC Sectt within a week of issuance of the minutes.

संलग्नक: यथोपरि


07/12/22
(संतोष कुमार)

अधीक्षण अभियंता (प्रचालन)

सेवा में,

उ.क्षे.वि.स. की एल.जी.बी.आर. उप-समिति के सदस्य

Minutes of the 28th LGBR Sub-Committee meeting

1. 28th LGBR Sub-Committee meeting was held on 06.12.2022 through Video Conference.
2. Member Secretary, NRPC extended a warm welcome to all participants in the meeting. He informed that this meeting is being conducted to review the planned maintenance schedule of generating units in April'23 and other peak demand months of northern region.
3. NRPC representative informed that 27th LGBR Sub-Committee meeting was held on 27.09.2022 and minutes of the meeting were issued on 29.09.2022.
4. It was mentioned that based on the deliberation held in the ministry during meeting held on Outage planning for next one year dated 22.11.2022, Ministry of Power has desired that planned outages in the month of April'23 should be minimum possible so as to have adequate thermal capacity available to meet non-solar peak demand.
5. Further NRPC representative apprised LGBR sub-committee that Chairperson, CEA during the meeting held on 02.12.2022 for finalization of outage planning for the year 2023-24, asked RPC's that the outages planned in the month of April-23 may please be shifted completely to the lean months periods due to high forecast of demand in this month in the country.
6. In this regard, LGBR sub-committee deliberated upon the list of thermal unit outages in NR for April'23 and other peak months of NR that were provisionally approved in the 27th LGBR Sub-Committee meeting and based on the discussion held in the meeting. the subsequent revised schedule is as below:

Station	Unit	Capacity (MW)	Revised Outage from	Revised Outage To	Duration (days)	Remarks
SINGRAULI STPS	7	500	15-Feb-23	31-Mar-23	45	Boiler+Turbine+Generator
MEJA STPP	1	660	15-Oct-23	13-Dec-23	60	Boiler+IPT+LPT+HP rotor & diaphragm repl & Vlv insp+Gen Insp
NABHA POWER LTD RAJPURA	1	700	27-Nov-23	22-Dec-23	25	FGD Interconnection / Boiler Inspection
MAHATMA GANDHI TPS	1	660	03-Mar-23	31-Mar-23	29	Boiler Overhauling

(CLP JHAJJAR)						
PANIPAT TPS	7	250	12-Mar-23	31-Mar-23	22	Annual Overhauling
DADRI-I (NCTPP)	2	210	16-Oct-23	05-Nov-23	20	Boiler o/h
TANDA TPS	2	110	16-Oct-23	25-Nov-23	40	Boiler+Turbine COH
SSCTPP SURATGARH	8	660	10-May-23	30-May-23	21	Annual Boiler Overhaul
CTPP CHHABRA	3	250	01-May-23	30-May-23	30	Annual Boiler Overhaul+ESP Repair work
RAJIV GANDHI TPS HISAR	1	600	01-May-23	05-Jul-23	65	Annual Overhauling
SSTPS SURATGARH	6	250	22-Aug-23	11-Sep-23	21	Annual Boiler Overhaul
SSTPS SURATGARH	5*	250	01-Aug-23	21-Aug-23	21	Annual Boiler Overhaul
KAWAI TPS (ADANI POWER)	1	660	01-Aug-23	05-Sep-23	35	Capital o/h

* In respect of **SSTPS SURATGARH**, RUVN representative requested sub-committee the outage of unit no. 5 in place of unit no.3 which was previously approved in 27th LGBR sub-committee and sub-committee agreed to RVUN request.

The meeting ended with vote of thanks to the chair.
