



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
उत्तर क्षेत्रीय विद्युत समिति
Northern Regional Power Committee

सं: उ.क्षे.वि.स./प्रचालन/106/01/2021/10685-10726

दिनांक: 17.11.2021

विषय: प्रचालन समन्वय उप-समिति की 189^{वीं} बैठक की कार्यसूची।
Subject: Agenda of 189th OCC meeting.

प्रचालन समन्वय उप-समिति की 189^{वीं} बैठक का आयोजन वीडियो कॉन्फ्रेंसिंग के माध्यम से दिनांक 23.11.2021 को 10:30 बजे से किया जायेगा। उक्त बैठक की कार्यसूची उत्तर क्षेत्रीय विद्युत् समिति की वेबसाइट <http://164.100.60.165/> पर उपलब्ध है।

बैठक में सम्मिलित होने के लिए लिंक व पासवर्ड सभी सदस्यों को ई-मेल द्वारा प्रदान किया जाएगा।

कृपया बैठक में उपस्थित होने की सुविधा प्रदान करें।

189th meeting of the Operation Co-ordination sub-committee will be conducted through Video Conferencing on 23.11.2021 from 10:30 Hrs. The agenda of this meeting has been uploaded on the NRPC web-site <http://164.100.60.165/>.

The link and password for joining the meeting will be e-mailed to respective e-mail IDs in due course.

Kindly make it convenient to attend the meeting.

-sd-

(सौमित्र मजूमदार)
अधीक्षण अभियंता (प्रचालन)

सेवामें : प्रचालन समन्वय उप समिति के सभी सदस्य।
To : All Members of OCC

1. Confirmation of Minutes

The minutes of the 188th OCC meeting which was held on 22.10.2021 through video conferencing were issued vide letter of even number dated 09.11.2021.

Sub-committee may deliberate and kindly confirm the Minutes.

2. Review of Grid operations of October 2021

2.1 Power Supply Position (Provisional) for October 2021

Anticipated Power Supply Position v/s Actual Power Supply Position (Provisional) of Northern Region during the month of October-2021 is as under:


| State / UT | Req. / Avl. | Energy (MU) | | | Peak (MW) | | |
|------------------|-------------|-------------|--------|-------------|-------------|--------|-------------|
| | | Anticipated | Actual | % variation | Anticipated | Actual | % variation |
| CHANDIGARH | (Avl) | 120 | 126 | 5.2% | 330 | 269 | -18.5% |
| | (Req) | 110 | 126 | 14.7% | 220 | 269 | 22.3% |
| DELHI | (Avl) | 3502 | 2661 | -24.0% | 5225 | 5391 | 3.2% |
| | (Req) | 2650 | 2662 | 0.4% | 4925 | 5391 | 9.5% |
| HARYANA | (Avl) | 4710 | 4615 | -2.0% | 10260 | 8803 | -14.2% |
| | (Req) | 4508 | 4728 | 4.9% | 8470 | 8811 | 4.0% |
| HIMACHAL PRADESH | (Avl) | 902 | 969 | 7.4% | 1545 | 1732 | 12.1% |
| | (Req) | 889 | 970 | 9.2% | 1551 | 1732 | 11.7% |
| J&K and LADAKH | (Avl) | 1230 | 1366 | 11.0% | 3320 | 2443 | -26.4% |
| | (Req) | 1490 | 1473 | -1.2% | 2480 | 2643 | 6.6% |
| PUNJAB | (Avl) | 4700 | 4866 | 3.5% | 9210 | 9629 | 4.5% |
| | (Req) | 4870 | 4987 | 2.4% | 9210 | 9629 | 4.5% |
| RAJASTHAN | (Avl) | 7590 | 7025 | -7.4% | 16740 | 12767 | -23.7% |
| | (Req) | 8080 | 7267 | -10.1% | 13610 | 12767 | -6.2% |
| UTTAR PRADESH | (Avl) | 11160 | 10362 | -7.1% | 21500 | 20174 | -6.2% |
| | (Req) | 11005 | 10562 | -4.0% | 21500 | 20174 | -6.2% |
| UTTARAKHAND | (Avl) | 970 | 1125 | 15.9% | 2640 | 2066 | -21.7% |
| | (Req) | 1160 | 1139 | -1.8% | 1960 | 2066 | 5.4% |
| NORTHERN REGION | (Avl) | 34884 | 33115 | -5.1% | 70200 | 57500 | -18.1% |
| | (Req) | 34762 | 33914 | -2.4% | 59900 | 57900 | -3.3% |


As per above, negative / significant variation ($\geq 5\%$) in Actual Power Supply Position (Provisional) vis-à-vis Anticipated figures is observed for the month of October-2021 in terms of Energy Requirement for Chandigarh, HP, UTs of J&K and Ladakh, Rajasthan, UP, and Uttarakhand and in terms of Peak Demand similar variation is noted for Chandigarh, Delhi, HP, UTs of J&K and Ladakh, Rajasthan, UP, and Uttarakhand. These states/UTs are requested to submit reason for such variations so that the same can be deliberated in the meeting.

All SLDCs are requested to furnish provisional and revised power supply position in prescribed formats on NRPC website portal by 2nd and 15th day of the month respectively for the compliance of Central Electricity Authority (Furnishing of Statistics, Returns and Information) Regulations, 2007.

2.2 Power Supply Position of NCR

NCR Planning Board (NCRPB) is closely monitoring the power supply position of National Capital Region. Monthly power supply position for NCR till the month of October-2021 is placed on NRPC website (<http://nrpc.gov.in/operationcategory/power-supply-position>). Power supply position during the current financial year is shown as under:





3. Maintenance Programme of Generating Units and Transmission Lines

3.1. Maintenance Programme for Generating Units

The meeting on proposed maintenance programme for Generating Units for the month of December-2021 is scheduled on 22-November-2021 via Video Conferencing.

3.2. Outage Programme for Transmission Elements

The meeting on proposed outage programme of Transmission elements for the month of December-2021 is scheduled on 22-November-2021 via Video conferencing.

4. Planning of Grid Operation

4.1. Anticipated Power Supply Position in Northern Region for December 2021

The Anticipated Power Supply Position in Northern Region for December 2021 is as under:

| State / UT | Availability / Requirement | Revised Energy (MU) | Revised Peak (MW) |
|---|----------------------------|---------------------|-------------------|
| CHANDIGARH | Availability | 110 | 230 |
| | Requirement | 120 | 270 |
| | Surplus / Shortfall | -10 | -40 |
| | % Surplus / Shortfall | -8.3% | -14.8% |
| DELHI | Availability | 2720 | 6210 |
| | Requirement | 2250 | 5300 |
| | Surplus / Shortfall | 470 | 910 |
| | % Surplus / Shortfall | 20.9% | 17.2% |
| HARYANA | Availability | 4790 | 10770 |
| | Requirement | 4160 | 7080 |
| | Surplus / Shortfall | 630 | 3690 |
| | % Surplus / Shortfall | 15.1% | 52.1% |
| HIMACHAL PRADESH (revised on 11.11.21) | Availability | 983 | 1870 |
| | Requirement | 968 | 1890 |
| | Surplus / Shortfall | 15 | -20 |

| State / UT | Availability / Requirement | Revised Energy (MU) | Revised Peak (MW) |
|--|----------------------------|---------------------|-------------------|
| | % Surplus / Shortfall | 1.5% | -1.1% |
| J&K and LADAKH | Availability | 1030 | 3650 |
| | Requirement | 2060 | 2920 |
| | Surplus / Shortfall | -1030 | 730 |
| | % Surplus / Shortfall | -50.0% | 25.0% |
| PUNJAB | Availability | 4710 | 9280 |
| | Requirement | 3850 | 7220 |
| | Surplus / Shortfall | 860 | 2060 |
| | % Surplus / Shortfall | 22.3% | 28.5% |
| RAJASTHAN | Availability | 8380 | 18710 |
| | Requirement | 8370 | 14710 |
| | Surplus / Shortfall | 10 | 4000 |
| | % Surplus / Shortfall | 0.1% | 27.2% |
| UTTAR PRADESH (revised on 16.11.21) | Availability | 9610 | 18200 |
| | Requirement | 9145 | 18200 |
| | Surplus / Shortfall | 465 | 0 |
| | % Surplus / Shortfall | 5.1% | 0.0% |
| UTTARAKHAND (revised on 03.11.21) | Availability | 1197 | 2250 |
| | Requirement | 1178 | 2287 |
| | Surplus / Shortfall | 19 | -37 |
| | % Surplus / Shortfall | 1.6% | -1.6% |
| NORTHERN REGION | Availability | 33529 | 64900 |
| | Requirement | 32101 | 54600 |
| | Surplus / Shortfall | 1428 | 10300 |
| | % Surplus / Shortfall | 4.4% | 18.9% |

SLDCs are requested to update the anticipated power supply position of their respective state / UT for the month of December-2021 and submit the measures proposed to be taken to bridge the gap between demand & availability, as well to dispose of the surplus, if any, in the prescribed format.

5. Submission of breakup of Energy Consumption by the states

The updated status on the submission of energy consumption breakup is presented below:

| State / UT | From | To |
|------------------|----------|----------|
| DELHI | Apr-2018 | Sep-2021 |
| HARYANA | Apr-2018 | Aug-2021 |
| HIMACHAL PRADESH | Apr-2018 | Aug-2021 |
| PUNJAB | Apr-2018 | Jul-2021 |

| State / UT | From | To |
|---------------|----------|----------|
| RAJASTHAN | Apr-2018 | Aug-2021 |
| UTTAR PRADESH | Apr-2018 | Jul-2021 |

All the remaining states/UTs viz., Uttarakhand, UTs of J&K and Ladakh and Chandigarh are again requested to submit the requisite data w.e.f. April 2018 as per the billed data information in the format given as under:

| Category→ | Consumption by Domestic Loads | Consumption by Commercial Loads | Consumption by Agricultural Loads | Consumption by Industrial Loads | Traction supply load | Miscellaneous / Others |
|-----------|-------------------------------|---------------------------------|-----------------------------------|---------------------------------|----------------------|------------------------|
| <Month> | | | | | | |

6. System Study for Capacitor requirement in NR for the year 2019-20

- 6.1 In the 45th TCC/ 48th NRPC meeting, it was decided that the study report for 2019-20 along with the guidelines for finding the capacitor requirement at 11/33 kV level in NR would be submitted by CPRI. In the meeting, CPRI representative had stated that as there were diversified network configurations at the level of DISCOMs, the guidelines to be provided would be generalized and may also include some empirical formula along with examples which may guide the DISCOMs for finding out the capacitor requirement.
- 6.2 Based on the above deliberation, CPRI submitted the system study report (enclosed in the agenda of 177th OCC meeting) and which was circulated among all the SLDCs and STUs vide e-mail dated 02.11.2020.
- 6.3 In the 177thOCC meeting, representatives of Punjab, Rajasthan, Delhi and Haryana stated that the capacitors considered in the study were far less than already installed. In the meeting, it was decided that states shall first analyze the PSSE file considered by CPRI in its study and bring out the locations wherein capacitors are already installed in the network, but are not modelled along with their comments.
- 6.4 The list of bus-wise available MVar and the additionally required MVar computed in the CPRI report was shared separately by NRPC Sectt with SLDCs of Punjab, Haryana, Rajasthan, Delhi and Uttarakhand on 07.01.2021 with the request to provide available MVar values in those buses. In 179thOCC meeting, it was decided that any submission of MVar data / feedback from the states would be allowed till 22.01.2021 and thereafter CPRI would conduct the modelling and simulation work for the purpose of final capacitor study report. Accordingly, feedbacks received from Punjab, Rajasthan, Haryana and Delhi was forwarded to CPRI for carrying out study and submission of report.
- 6.5 CPRI has submitted the revised report on 24.02.2021 and thereafter same was shared with the constituent states. The recommended capacitor compensation, additionally required as per the report is 352MVar. The report has brought out the additional requirement of 137MVar and 215MVar compensation for Punjab and J&K respectively. Moreover, empirical relationship for capacitor requirement against voltage profile at 11 kV, based on two configurations has been worked out in the report.

- 6.6 In the 45th TCC / 48th NRPC meeting, it was decided after the submission of report for 2019-20 and the guidelines, the same would be studied by the same Committee who had earlier recommended for guidelines and foreclosure of the contract. Based on Committee's recommendations, NRPC Sectt. can process the pending bills of Rs. 14 lakhs (Rs. 2 + 12 Lakhs), excluding taxes along with foreclosure of the contract. Accordingly, submitted report needs to be examined by the Committee.
- 6.7 In the 181st OCC meeting, the sub-group comprising of ten members was advised to study the CPRI report and submit its recommendation within two weeks.
- 6.8 NRPC Sectt. asked comments/observations on the CPRI report from all the states via e-mail. Comment from Delhi had been received. Rajasthan, HP, Punjab, Haryana had submitted NIL comment. Comment from rest of the members was not received.
- 6.9 In the 182nd OCC meeting, forum decided that a video-conferencing meeting may be held by members of sub-group to finalize the comments latest by 30th April, 2021 and compiled comments may be sent to CPRI for necessary correction in the report.
- 6.10 In the 183rd OCC, NRPC representative informed that the meeting of sub-group was held on 03.05.21 (in place of originally schedule meeting on 30.04.21, delayed as per request of some sub-group members due to health related concerns). Representative from Rajasthan could not attend as she was suffering from covid-19 while Uttarakhand representative informed in the meeting that there is an acute shortage of available officers at this time and they will agree to the remarks made by NRLDC. Further, PSSE file was requested from CPRI as per request of all sub-group members for better understanding and the same was shared with them.
- 6.11 NRPC representative requested for any other comments on the CPRI report, if remaining, from any of the members. Sub-group committee member from Rajasthan stated that since the CPRI report is for the year 2019-20, old data needs to be collected and then values in the CPRI report would be checked. It was further intimated that around 2-3 days time would be required for this task. Rajasthan representative was requested to send their observation/comments via e-mail to NRPC Sectt. at the earliest.
- 6.12 Forum decided that after receiving observations/comments from Rajasthan, the compiled observations/comments may be sent to CPRI so that necessary corrections may be done in the draft report.
- 6.13 In 184th OCC, forum was apprised that compiled comments have been mailed to CPRI vide email dated 28th May'21 with a request to submit the corrected report within two weeks' time. CPRI vide email dated 31st May'21 communicated that majority of comments are on the modeling of base case PSSE file. Since the file is given by NRPC and CPRI has not modeled it; so, they are not in position to make any comment on the accuracy & modeling of file. Forum decided that a reminder may be sent to CPRI for submission of corrected Report as two weeks has already passed.
- 6.14 In 185th OCC, NRPC representative intimated the forum that CPRI has submitted its point-wise reply on the observations of sub-group along with updated report on 28th June 2021.
- 6.15 MS, NRPC expressed concern over inordinate delay in finalizing the report. Forum decided that issues highlighted by the sub-group in the report and clarifications/comments thereon of CPRI need to be converged at the earliest and thus a video-conferencing meeting may be held between the sub-group and CPRI for

resolution of issues and enabling report finalization.

6.16 The meeting was held on 06.08.2021 at 11:00 a.m. under the chairmanship of MS, NRPC through Video Conferencing. It was attended by members of the sub-group (constituted for studying the CPRI report), CPRI representatives, and officials from NRPC Sectt & NRLDC.

6.17 In the meeting, comments of the sub-group on the latest version of CPRI report was deliberated in detail. After weighing the merits of the original & both revisions of the report, following were decided:

- First Report submitted by CPRI in September, 2020 shall be considered as the reference report. CPRI confirmed that the basecase of 11.07.2018 at 00:45 hrs. received from NRPC Sectt has been used for preparing September, 2020 report.
- Comments from all utilities and NRLDC on September 2020 report must be submitted to NRPC Sectt, latest by 24.08.2021.
- NRPC Sectt, after examination, shall share with CPRI the compiled comments of the utilities and NRLDC, latest by 31.08.2021.
- Thereafter, CPRI shall submit its reply on the compiled comments sent by NRPC Sectt, latest by 15.09.2021.

6.18 Base case file (11.07.2018 00:45 hrs) and CPRI September 2020 report has been e-mailed to all sub-group members on 10.08.2021 requesting to submit comments/observations thereon latest by 24.08.2021 as per decision of the meeting dtd. 06.08.2021.

6.19 In the 187th OCC, forum was apprised that although last date for submission of comments was 24.08.2021, NRPC Sectt. received comments from Himachal Pradesh, Punjab, Rajasthan, Delhi, and NRLDC vide mails dtd. 24.08.2021, 25.08.2021, 26.08.2021, 31.08.2021, and 03.09.2021 respectively. As the received comments were also on the base-case data, a meeting was held on 06.09.2021 among officers of NRPC Sectt, NRLDC and above four states for discussing comments before sending to CPRI. After detailed discussions, following were decided:

A. Himachal Pradesh:

- a) It was apprised by NRLDC that generation data of micro IPPs has not been modelled by them in base-case due to their small quantity. Further, Capacitor at Baddi needs to be removed from base-case.
- b) HP was requested to submit within 3 days data regarding (11.07.2018 00:45 HRS):
 - i. Generation break-up along with details of micro IPPs.
 - ii. Capacitors at 132 kV level.
 - iii. Nodes of major voltage profile mismatch
 - iv. Load factor of state (current scenario if data of past is not available)
- c) It was decided that after getting above data from HP, base-case will be tuned by NRLDC before sending to CPRI.

B. Punjab:

- a) All switched reactors/capacitors to be converted into fixed & net shunt capacitor value in the base-case to be corrected as per Punjab's comment.
- b) Punjab was requested to submit low voltage nodes (11.07.2018 00:45 HRS) within 3 days.
- c) Based on data from Punjab, initial tuning to be done by NRLDC for Q values of generators. CPRI may be required to do further tuning.

C. Rajasthan:

- a) Except low voltage points, power factor needs to be upgraded in the base-case.
- b) Rajasthan representative confirmed that most of the capacitors were off during the time for which modelling is done, so lumped capacitor at 132kV needs to be deleted.
- c) Rajasthan was requested to submit
 - i. List of bus-wise capacitors and their status (OFF/ON condition) on 11.07.2018 00:45 HRS.
 - ii. Voltage profile of generator buses.

D. Delhi:

- a) Delhi was requested to submit voltage profile of generator buses.

- 6.20 It was decided that after receiving data from above four states, NRLDC will tune the basecase initially and will also ensure that regional generators shall not absorb reactive power in the base-case and then base case will be sent to CPRI along with compiled comments.
- 6.21 In the meeting, UP representative stated that they will send reply on mail of NRPC Sectt. dtd. 10.08.2021 for submission of their comments.
- 6.22 It was decided that data received at NRPC Sectt. may be sent to NRLDC for tuning of base-case.
- 6.23 NRLDC representative stated that base-case tuning may be completed by 30.09.2021.
- 6.24 CPRI vide e-mail dtd. 23.09.2021, requested to send comments at the earliest. NRPC Sectt. vide e-mail dtd. 23.09.2021 apprised the CPRI that as per decisions of meeting dtd. 06.09.2021, tuning of base-case file is being done by NRLDC so that no new issue arises in future.
- 6.25 CPRI vide e-mail dtd. 24.09.2021 has requested that any change in loading & generation profile will be a new base case and this will be a fresh study for new base case. It will require an extensive time and efforts. CPRI has requested to ensure that load/generation profile in tuned PSSE should be same as was given to CPRI for PSSE base 11.7.2018 at 00.45.
- 6.26 In view of CPRI's request, NRLDC was requested vide e-mail dtd. 24.09.2021 to halt tuning of base-case till further discussion.
- 6.27 A meeting was held between NRPC Sectt. and NRLDC on 04.10.2021, wherein it was decided that without incorporating corrective comments of states, the report

is not acceptable w.r.t drawing any conclusion on requirement of capacitor. Accordingly, NRLDC was requested vide e-mail dtd. 08.10.2021 to complete tuning of base-case at the earliest.

- 6.28 In 188th OCC meeting, NRLDC representative informed that tuned base-case will be submitted by NRLDC by 28.10.2021. It was decided that the same will be sent to CPRI for necessary correction in report.
- 6.29 NRLDC vide e-mail dtd. 10.11.2021 submitted the tuned base-case to NRPC Sectt. mentioning that Basecase has been tuned considering the feedback/inputs received from states (Punjab, Delhi, Rajasthan, HP and UP) and considering NRLDC SCADA data of 11th July 2018.

Sub-Committee may kindly note.

7. Automatic Demand Management System

- 7.1 The status of ADMS implementation in NR, which is mandated in clause 5.4.2 (d) of IEGC by SLDC/SEB/DISCOMs is presented in the following table:

| State/ Utility | Status |
|-------------------|---|
| Punjab | Scheme not implemented. At SLDC level, remote tripping of 100 feeders at 66 kV is possible. At 11 kV feeder level, ADMS is to be implemented by Distribution Company. |
| Delhi | Fully implemented by TPDDL, BRPL and BYPL. NDMC implementation was scheduled to be completed by 31.03.2020 but got delayed due to some changes incorporated in the scheme. |
| Rajasthan | Under implementation. LoA placed on 12.12.2018 with an execution period of 18 months for ADMS at the level of 33 kV feeders at EHV Substation of RVPN under SCADA / EMS part of project. Supply is in progress. Work is under execution and likely to completed by June'2021. ADMS functionality at 11 kV feeders from 33/11 kV substation is under the jurisdiction of the DISCOMs. |
| UP | Scheme implemented by NPCL only. Remote operation of 50 feeders at 132 kV level being operated from SLDC. Further, the solution proposed by M/s Siemens was found to be non-economical and was not accepted by the management. Noida Power Company Ltd have implemented Intelligent Load Shedding (ILS) scheme, in compliance of IEGC requirements for automatic demand management. |
| Haryana | Scheme not implemented. More than 1700 feeders were tested from SLDC control room for |

| State/ Utility | Status |
|-------------------|--|
| | remote operation. Regarding the implementation of ADMS at DISCOM level, the matter is being taken up with the DISCOMs. |
| HP | Scheme not implemented. 02 feeders could be operated from SLDC through manual intervention. Letter has been sent by HPSEB to HP-SLDC for making its operation automatic. |

- 7.2 As decided in the 175th OCC meeting, the nominations for matter specific meeting has been received from HVPN, UHBVN/DHBVN, PSPCL, RVPN (SLDC & Automation), UPPTCL, KESCO (DISCOM-UP), NPCL (DISCOM-UP).
- 7.3 Meetings on ADMS implementation road map have been held with the officers of Haryana, Himachal Pradesh, Punjab and UP on 05.02.2021, 19.02.2021, 05.03.2021, and 14.07.2021 respectively. In these meetings, issues and apprehensions on ADMS were discussed along with vital aspects like addressing the commercial issues, basic architecture for scheme and funding possibilities for the scheme.
- 7.4 As per request of states for DPR of any state that has got PSDF support for ADMS, website link of PSDF Sectt. has been shared with Haryana, Himachal Pradesh, Punjab and Uttar Pradesh for accessing DPR. SLDCs were also requested to expedite the submission of pending nominations.
- 7.5 In-charge, NRLDC stated that as per IEGC, implementation of ADMS is mandatory. It helps in reducing DSM charges also. States must take it seriously.
- 7.6 MS, NRPC stated that non-implementation of ADMS by states is indistinguishably non-adherence to directions of CERC.
- 7.7 NRPC representative added that initial deadline for ADMS implementation was 1st January 2011 as per para 5.4.2 (d) of IEGC. Later, CERC has taken suo-motu cognizance of non-implementation of ADMS by states and given 31.06.2016 as deadline vide its order dtd. 31.12.2015 in petition no. 5/SM/2014. Implementation deadline given by the statutory and regulatory body need to be complied by concerned SLDC / SEB / distribution licensee as per regulation no. 5.4.2 (a) & (b) of IEGC. Moreover, hand holding process for project proposal preparation in respect of four NR states has already been done by NRPC.
- 7.8 Forum decided that NRLDC may file a report to CERC based on compiled status of ADMS implementation in states of Northern Region.
- 7.9 In 187th OCC meeting, NRLDC representative quoted the texts of CERC order dtd. 31.12.2015 in petition no. 5/SM/2014. He apprised the status of ADMS implementation till 2015. Further, he requested the states to update the status so that NRLDC may file petition in CERC on the basis of compiled status.
- 7.10 In the 188th OCC, NRLDC informed that it has not received comments from states in this matter. Accordingly, all SLDC/DISCOMs are requested to furnish the latest status of ADMS implementation in their respective control areas latest by 31st October 2021 to NRLDC. Status as received till 31.10.2021 would be reported to CERC by NRLDC.

Members may kindly note.

8. Follow-up of issues from previous OCC Meetings- Status update.

The updated status of agenda items is enclosed at **Annexure-A.I.**

All utilities are requested to update the status.

9. NR Islanding scheme

- 9.1. Based on the decisions taken in the meeting taken by Hon'ble Minister of State (IC) for Power and New & Renewable Energy on 28.12.2020, Islanding Schemes for NR have been continuously reviewed/discussed in various forums.
- 9.2. In 187th OCC, it was decided that respective states would submit MIS report before every OCC meeting so that same may be discussed. It was also highlighted that MoP has agreed for PSDF funding for implementation of islanding schemes and states were requested to prepare and submit DPR for the same.
- 9.3. Further, a sample DPR on implementation of Islanding scheme for PSDF funding has been already circulated vide email dated 07.10.2021. States can refer sample DPR, if PSDF funding is needed for implementation of Islanding schemes. In case PSDF funding is needed, it is requested to expedite the preparation of DPR on implementation of Islanding. A meeting was also held by Honourable Cabinet Minister (Power, New & Renewable Energy) on 07.10.2021 wherein emphasis was given on PSDF funding for Islanding schemes and DPR submission for the same.
- 9.4. In view of the above, states were requested to update the status of DPR, if PSDF funding is needed.
- 9.5. In 187th OCC, forum was apprised that a Standard Operating Procedure for Islanding schemes has been issued by NPC, CEA. Utilities are requested to refer and submit SOP for every Islanding scheme in their control area.
- 9.6. Minutes of the meeting held on 07.10.2021 under the chairmanship of Hon'ble Minister of Power and Renewable Energy is attached as **Annexure-A.II.**

Members may kindly deliberate.

10. Coal Supply Position of Thermal Plants in Northern Region

- 10.1. In 186th OCC meeting, it was agreed that coal stock position of generating stations in northern region may be reviewed in the OCC meetings on the monthly basis.
- 10.2. Accordingly, coal stock position of generating stations in northern region during current month (till 10th November 2021) is as follows:

| Station | Capacity (MW) | PLF % (prev. months) | Normative Stock Reqd (Days) | Actual Stock (Days) |
|---------------|---------------|----------------------|-----------------------------|---------------------|
| ANPARA C TPS | 1200 | 85.94 | 15 | 3.8 |
| ANPARA TPS | 2630 | 74.76 | 15 | 7.2 |
| BARKHERA TPS | 90 | 40.60 | 20 | 5.0 |
| CHHABRA TPP | 500 | 34.23 | 25 | 0.7 |
| DADRI (NCTPP) | 1820 | 42.76 | 30 | 16.3 |

| | | | | |
|-----------------------|------|-------|----|------------|
| GH TPS (LEH.MOH.) | 920 | 18.66 | 30 | 12.7 |
| GOINDWAL SAHIB TPP | 540 | 53.26 | 30 | 0.0 |
| HARDUAGANJ TPS | 605 | 56.35 | 30 | 16.4 |
| INDIRA GANDHI STPP | 1500 | 54.11 | 30 | 16.1 |
| KAWAI TPS | 1320 | 63.57 | 25 | 6.0 |
| KHAMBARKHE RA TPS | 90 | 37.01 | 20 | 5.0 |
| KOTA TPS | 1240 | 64.99 | 30 | 6.4 |
| KUNDARKI TPS | 90 | 67.96 | 25 | 7.9 |
| LALITPUR TPS | 1980 | 72.12 | 25 | 12.1 |
| MAHATMA GANDHI TPS | 1320 | 71.31 | 25 | 4.6 |
| MAQSOODPUR TPS | 90 | 53.70 | 20 | 13.0 |
| MEJA STPP | 1320 | 79.75 | 20 | 9.7 |
| OBRA TPS | 1094 | 47.16 | 20 | 4.1 |
| PANIPAT TPS | 710 | 31.02 | 30 | 4.7 |
| PARICHHA TPS | 1140 | 43.05 | 30 | 13.3 |
| PRAYAGRAJ TPP | 1980 | 69.87 | 20 | 2.8 |
| RAJIV GANDHI TPS | 1200 | 35.83 | 30 | 11.0 |
| RAJPURA TPP | 1400 | 69.39 | 25 | 4.1 |
| RIHAND STPS | 3000 | 80.25 | 15 | 9.6 |
| ROPAR TPS | 840 | 14.11 | 30 | 9.1 |
| ROSA TPP Ph-I | 1200 | 62.85 | 25 | 8.1 |
| SINGRAULI STPS | 2000 | 94.66 | 15 | 11.7 |
| SURATGARH TPS | 1500 | 19.84 | 30 | 3.9 |
| TALWANDI SABO TPP | 1980 | 49.05 | 25 | 6.9 |
| TANDA TPS | 1760 | 25.46 | 25 | 14.5 |
| UNCHA HAR TPS | 1550 | 57.93 | 25 | 10.9 |
| UTRAULA TPS | 90 | 57.07 | 20 | 6.6 |
| YAMUNA NAGAR TPS | 600 | 39.67 | 25 | 8.3 |

11. Declaration of spell of heavy rain fall and heavy snowfall during the period of 23rd and 24th Oct 2021 as state specific Natural disaster under SDRF Norms (Agenda by NR-2/POWERGRID)

11.1.NR-2 POWERGRID vide email dated 12.11.2021 submitted that there was spell of heavy rain fall and heavy snowfall during the period of 23rd and 24th Oct 2021 in Hilly terrain of Jammu and Kashmir and Department of Disaster management, Relief Rehabilitation and Reconstruction had declared it as STATE SPECIFIC NATURAL DISASTER under SDRF Norms for Udhampur, Kishtwar, Reasi, Samba, Kathua, Anantnag, Kulgam and Soplian Districts of J&K. Copy of order issues by Department of Disaster management, Relief Rehabilitation and Reconstruction UT of J&K attached as **Annexure-A.III**.

11.2.In view of above, outage of elements on 23rd and 24th Oct'2021 in the area declared as Natural disaster may please be considered outage under natural calamity.

Members may kindly deliberate.

12. Modification in SPS for reliable evacuation of power from 400/220kV Chamera Pooling (Chamba) Substation required for evacuation of power from 180 MW Bajoli-Holi HEP in interim arrangement (Agenda by HPPTCL)

12.1. HPPTCL vide email dated 12.11.2021 submitted that a meeting with CTU, POSOCO, HPPTCL, HPSEBL, GMR, Greenko, was held on 17-06-2021 under the Chairmanship of Chief Engineer (PSPA-1) CEA regarding the issues related to transmission system for evacuation of power from Bajoli-Holi HEP (180 MW). (Minutes of the above said meeting attached at **Annexure-A.IV**).

12.2. In this respect, it is intimated that HPPTCL had on 07-07-2020 commissioned the 220/33kV Substation at Lahal and 220kV S/C Lahal-Budhil Transmission Line for evacuation of power from Small HEPS coming at Lahal Substation.

12.3. The permission for commissioning of this system which is also part of interim evacuation system of Bajoli-Holi HEP was granted after the implementation of SPS by HPPTCL to avoid overloading of 2x315 MVA Transformer bank at Chamera-III and to avoid overloading of 220kV Transmission Line from Chamera-III to Chamera Pooling which was then on breakdown and only one ckt. was functioning through ERS with restricted power flow.

12.4. Now this transmission line has been restored to its full capacity. The SPS scheme was approved by NRLDC vide email dt. 29-06-2020 (copy of implemented SPS Scheme along with testing report is enclosed at **Annexure-A.V**).

12.5. In order to evacuate power from 180 MW Bajoli-Holi HEP through this interim arrangement 220 kV Bajoli-Holi Lahal Transmission Line is nearing completion and one ckt. of this line has already been test charged on 10.11.2021. HPPTCL has already filed a petition with Hon'ble UERC for evacuation of 26 MW power for SHP's & 60 MW of Bajoli Holi HEP till March 2022. With this interim arrangement the total power to be evacuated through 220kV S/C Budhil-Chamera Line shall be less than its capacity i.e. 180 MW.

12.6. In view of the above, the SPS scheme already implemented needs to be revised. A draft SPS scheme for the new proposed interim arrangement has been prepared and

a copy of the same is attached as **Annexure-A.VI**). This draft scheme was also shared with NRLDC and they have vide their email dt. 12th Nov 2021 conveyed their concurrence to the proposal.

- 12.7. It is requested that proposed modifications in the SPS scheme may please be considered & approved by Sub-Committee so that based on the final approval, work for implementation of the same can be taken up before commissioning of the Bajoli-Holi HEP.

Members may kindly deliberate.

13. Deemed availability of outage of Transmission lines for installation of Bird Diverter as per requirement of NGT (Agenda by NR-1/POWERGRID)

13.1 In the 183rd OCC meeting, POWERGRID brought agenda for considering the outage needed for installing Bird Diverters (under the NGT order) as deemed available. In the meeting, POWERGRID was advised to submit the details of estimated number of bird diverters required for each line and estimated outage days needed for each line in order to accomplish the said work.

13.2 Forum decided that since installation of bird diverters is being done on the direction of court and NGT, the number of outage days projected by POWERGRID for eleven lines (enclosed as Annexure-A-IV of 185th Agenda) may be considered as deemed available.

13.3 Now, POWERGRID vide letter dt. 02.11.2021 has submitted the details for installation of bird diverters in 2nd phase (enclosed as **Annexure-A.VII**) for consideration of deemed availability.

Members may kindly deliberate.

14. Installation of good quality bird flight diverter (BFD)

14.1 CEA has issued a letter dtd 10.11.2021 that they are getting various complaints on installation of poor-quality bird diverters. Sometimes disc of bird diverters are found strewn in land below transmission lines. It may be due to poor quality of product, inadequate design by manufacturer or improper installation.

14.2 CEA has issued technical specifications for bird diverter that may be complied by utilities for ensuring proper installation of bird diverters.

Members may kindly deliberate.

15. Review of SPS for evacuation of generation of Lalitpur TPS (Agenda by UP SLDC)

15.1 UP SLDC vide letter dated 15.11.2021 has submitted the proposed revised logic for SPS for evacuation of Lalitpur TPS in view of commissioning of 765kV Fatehabad – Greater Noida line. UP SLDC has submitted the old & the proposed logic along with the comments of Lalitpur TPS and requested for the approval of the revised scheme (copy of letter is attached at **Annexure-A.VIII**).

Members may kindly deliberate.

16. Procedure for Planning of Inter-State Transmission System (ISTS)

A Draft Procedure for planning of Inter-state Transmission System has been prepared in accordance with Electricity (Transmission System Planning, Development and Recovery of Inter-State Transmission Charges) Rules, 2021. This procedure shall be applicable to stakeholders such as Central Government, State Governments, Central Transmission Utility (CTU), Central Electricity Authority (CEA), Regional Power Committees (RPCs), State Transmission Utilities (STUs), Generation companies, System Operators (National, Regional, and State), Licensees, and any other person notified by the Central Government in this behalf. This Procedure shall come into effect from the date it is published on CTU website. The Draft Procedure is available at CTU website along with Annexures for observations of stakeholders. All utilities are requested to send their comments to CTU with copy to NRPC/NRLDC by 22.11.2021.

Members may like to discuss.

17. Grid Highlights for October 2021

In Oct'21, the Maximum energy consumption of Northern Region was 1238 Mus on 12th Oct'21 and it was 1 % lower than Oct' 2020 (1252 Mus 1st Oct'20)


In Oct'21, the Average energy consumption per day of Northern Region was 1070 Mus and it was 2 % lower than Oct'20 (1093 Mus per day)

In Oct'21, the Maximum Demand met of Northern Region was 57491 MW met on 12th Oct'21 @ 13:00 hours (Based on data submitted by Constituents) as compared to 57975 MW met on 1st Oct'20 @ 20:00 hours

Northern Region all time high value recorded in Oct' 21:

| Energy Generation | All Time High Record | | Previous Record (upto Sept-21) | |
|-------------------|----------------------|-------------|--------------------------------|-------------|
| | Value (MU) | Achieved on | Value (MU) | Achieved on |
| Solar Generation | 68.20 | 25.10.21 | 60.49 | 16.09.21 |

NR maximum solar generation of 9515MW achieved on 31.10.2021 at 12:51hrs.





Comparison of Average Energy Consumption (MUs/Day) of NR States for the Oct'2020 vs Oct '21

| Region/State | Oct- 2020 | Oct-2021 | % Of Variation |
|-----------------|-----------|----------|----------------|
| पंजाब | 152.42 | 157.30 | 3.20 |
| हरियाणा | 155.20 | 149.51 | -3.67 |
| राजस्थान | 242.28 | 226.56 | -6.49 |
| दिल्ली | 80.12 | 85.38 | 6.57 |
| उत्तर प्रदेश | 347.62 | 334.79 | -3.69 |
| उत्तराखंड | 36.53 | 36.88 | 0.95 |
| चंडीगढ़ | 3.65 | 4.07 | 11.53 |
| हिमाचल प्रदेश | 29.18 | 31.31 | 7.30 |
| जम्मू और कश्मीर | 46.34 | 44.05 | -4.93 |
| उत्तरी क्षेत्र | 1093.35 | 1069.85 | -2.15 |

In Oct'21, Frequency remained within IEGC band for 74.00% of the time.

Total average per day energy production by Northern region was 919.42 Mus in the month of Oct'21 in comparison of 782.46 Mus in Oct'20. The fuel wise share of generation is shown below.



In Oct'21, Frequency remained within IEGC band for only 74% of the time. Emergent contingency events during such times such as large generation outage, could result in further drop in frequency and therefore, overdrawals below 49.90 Hz must be controlled quickly in order to keep system secure.

| Freq. band | Oct 2020 | Nov 2020 | Dec 2020 | Jan 2021 | Feb 2021 | Mar 2021 | Apr 2021 | May 2021 | Jun 2021 | Jul 2021 | Aug 2021 | Sep 2021 | Oct 2021 |
|--------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| < 49.7 Hz(%) | 0.00 | 0.01 | 0.01 | 0.00 | 0.02 | 0.01 | 0.00 | 0.02 | 0.07 | 0.04 | 0.17 | 0.21 | 0.31 |

| | | | | | | | | | | | | | |
|-------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| <49.8 Hz(%) | 0.20 | 0.17 | 0.36 | 0.24 | 0.46 | 0.65 | 0.93 | 0.50 | 1.06 | 0.67 | 1.3 | 0.69 | 2.43 |
| <49.9 Hz(%) | 3.91 | 4.46 | 4.79 | 4.86 | 7.12 | 7.13 | 7.96 | 6.63 | 6.12 | 5.35 | 7.67 | 4.18 | 11.10 |
| 49.90-50.05 Hz(%) | 81.88 | 79.81 | 75.72 | 76.10 | 76.27 | 72.78 | 75.06 | 74.49 | 74.81 | 75.06 | 76.93 | 77.01 | 74.38 |
| 50.05-50.10 Hz(%) | 12.82 | 13.82 | 16.42 | 15.82 | 14.10 | 16.78 | 13.51 | 15.41 | 14.74 | 16.71 | 14.14 | 15.83 | 12.70 |
| >50.10 Hz(%) | 1.39 | 1.87 | 3.20 | 3.16 | 2.52 | 3.21 | 2.49 | 2.89 | 3.18 | 2.78 | 1.25 | 2.26 | 1.81 |
| >50.20 Hz(%) | 0.00 | 0.03 | 0.05 | 0.06 | 0.08 | 0.10 | 0.04 | 0.07 | 0.09 | 0.10 | 0.01 | 0.03 | 0.06 |
| औसत आवृत्ति | 50.00 | 50.00 | 50.00 | 50.00 | 50.00 | 50.00 | 50.00 | 50.00 | 50.00 | 50.01 | 50.00 | 50.00 | 49.99 |

During this month some of the NR states also had overdrawal contributing to low frequency operation. NRLDC has been continuously requesting all states to maintain its drawl within schedule during low frequency instances and also take necessary measures for revival of intrastate generating units

NR Constituents are once again requested to take initiatives to minimise sudden load changeovers at hourly boundaries and also monitor performance of generators under their jurisdiction when the frequency is having large excursions.

Members may like to discuss.

18. **Sharing of hourly Load shedding under different categories on NRLDC Reporting Software**

During a recent review of the country's power supply scenario, Secretary, Ministry of Power, emphasized the importance of ensuring accuracy of the hourly load shedding (MW) and energy not met (MU) figures being received from various SLDCs on daily basis in respect of their own states, and classifying them under different heads like low availability, transmission constraints, financial constraints, planned maintenance of transmission / distribution system within state, etc.

Although SLDCs are uploading the hourly load shedding figures of the previous day on the web-based reporting software of NRLDC the next day, but reason for the shedding or unserved demand at any hour is not segregated into the possible different categories.

In view of the above, it is requested to kindly classify the reason of shedding in the detail sheet of hourly load shedding, as per **Annexure-B.I**, in the daily power supply report, before uploading it to the web-based reporting software on daily basis.

Members may like to discuss.

19. **Action Plan for Winter Preparedness 2021-22**

In 187th and 188th OCC meeting, it was discussed that winter in Northern region is likely to start from mid of October till February end, and the challenges faced during these



months were also discussed in the meeting. With decreasing temperatures and festivals, winter also brings some severe challenges to NR grid operators. The challenges expected and actions to be taken by utilities were discussed in the meeting along with actions to be taken by respective utilities. However, details regarding actions taken by them are yet to be received.

a) *Load generation balance:*

- In line with section 5.3 of the IEGC, all constituents to have precise load forecasting & generation planning and forecast demand ramp on daily, weekly and monthly basis so that commensurate ramping of generation can also be planned (*Action by SLDCs*)
- SLDCs to optimally schedule hydro and gas generation to make sure that demand as well as ramp requirements are safely met (*Action by SLDCs*).
- Minimize generation to technical minimum as per IEGC guidelines /CERC directions during low demand (*Action by ISGS, intrastate generators, NRLDC, SLDCs*).
- Delay in charging the lines after issuance of code (in the morning hours) to be minimised (*Action by ISTS licensees/ STUs*)
- Hydro generators to ensure to declare their maximum DC particularly during non-solar period, to ensure better management of power portfolio by the beneficiaries. (*Action by ISGS, intrastate generators*)

b) *High voltage management:*

- Ensuring disconnection of capacitors. To be confirmed by all STUs and SLDCs (*Action by SLDCs/ STUs/DISCOMs*).
- Ensuring healthiness of all commissioned reactors in the system (*Action by ISTS licensees/ STUs*)
- Monitoring of reactive power of generators and exchange of reactive power with ISTS through SCADA displays (*Action by SLDCs*).
- Ensuring reactive power support (absorption) from generating stations by operating units upto their capability limits. (*Action by ISGS, intrastate generators, NRLDC, SLDCs*). To be discussed in detail in next agenda.
- Synchronous condenser operation especially of hydro units during night hours for dynamic voltage support. Some of the generators have already been tested successfully (Tehri, Chamera, Pong etc.) in synchronous condenser mode and shall be available for condenser mode of operation as and when required. ***Punjab SLDC to update the status of utilization of RSD as synchronous condenser.***
- ICT Tap Optimization at 400kV & above carried out by NRLDC. Same exercise needs to be carried out by SLDCs at 220kV & below levels. Scatter plots for these stations alongwith improvement observed are attached as **Annexure-B.II**. Improvement in voltage profile of some of the stations after tap change carried out at 400/220kV level is shown below:



- Haryana and UP requested in 188 OCC meeting, to check tap position change requirement at Panchkula(PG) and Rewa-road respectively. However, scatter plots of these stations as per NRLDC data do not suggest any need for tap change. Details attached as **Annexure-B.II. Utilities may present their case for tap change**. SLDCs are also requested to provide the tap change exercise carried out by them or proposed to be carried out before winter. (Action by SLDCs).

- All utilities are requested to go through the Reactive Power document available at NRLDC website and report if any incorrect or missing information is noticed. The document is being utilized in real-time operation by control room operators at NRLDC, and thus it is necessary that updated document is available.
- Additional manpower if required, may be placed at critical substations (**Action by ISTS licensees/ STUs**).

c) EHV line trip during fog/Smog

Utilities were requested to ensure:

- Priority wise cleaning & replacement of damaged insulators.
- Monitor progress of cleaning and replacement of porcelain insulator with polymer insulator and furnish updated status to NRPC/NRLDC. (**Action by ISTS licensees/ STUs**).

As agreed in 187th and 188th OCC meeting, utilities are requested to share action plan for measures to be taken by them for carrying out pre-winter maintenance activities and other actions agreed in 187th and 188th OCC meeting.

Members may please discuss.

20. MVAR support from generators

Following has been discussed and agreed in TCC /NRPC meetings and OCC meetings of the Northern region:

- All generators (including intrastate) shall absorb MVAR as per capability curve
- Reactive power support performance and MVAR telemetry issues will be reviewed in monthly OCC meetings.
- Reactive power capability testing will be carried out after discussion in OCC meeting.

Reactive power response of generating stations is being regularly discussed in OCC meetings.

Reactive power response in respect of MVAR vs Voltage for **past 30 days (15.10.2021 - 15.11.2021)** as per NRLDC SCADA data is enclosed as **Annexure-B.III.a** in agenda. Based on available data, it is observed that there are margins available as per capability curves for most of the generating stations. In addition, telemetry (sign and magnitude of MVAR) of various state generating station is yet to be corrected.

| S. No. | Station | Capacity | Geographical location | MVAR capacity as per capability curve | MVAR performance (-) Absorption (+) Generation | Voltage absorption above (in KV) |
|--------|----------------|----------|-----------------------|---------------------------------------|--|----------------------------------|
| 1 | Dadri NTPC | 980 | Delhi-NCR | -294 to | -300 to 100 | 415 |
| 2 | Singrauli NTPC | 2000 | UP | -600 to | -250 to 0 | 400 |
| 3 | Rihand NTPC | 2000 | UP | -600 to | -320 to -140 | 400 |

| S. No. | Station | Capacity | Geographical location | MVAR capacity as per capability curve | MVAR performance (-) Absorption (+) Generation | Voltage absorption above (in KV) |
|--------|----------------|----------|-----------------------|---------------------------------------|--|----------------------------------|
| 4 | Kalisindh RS | 1200 | Rajasthan | -360 to | -250 to 100 | Voltage data static |
| 5 | Rosa UP | 1200 | UP | -360 to | -100 to 300 | |
| 6 | Anpara C UP | 1200 | UP | -360 to | -200 to 100 | 765 |
| 7 | TalwandiSaboo | 1980 | Punjab | -594 to | -400 to 100 | 415 |
| 8 | Kawai RS | 1320 | Rajasthan | -396 to | -120 to 0 | 404 |
| 9 | Anpara TPS | 1630 | UP | -489 to | -100 to 150 | 406 |
| 10 | IGSTPP Jhajjar | 1980 | Haryana | -594 to | -200 to 200 | 410 |
| 11 | Tanda | 1320 | UP | -396 to | -100 to 300 | 415 |
| 12 | Rajpura (NPL) | 1400 | Punjab | -420 to 840 | 100 to 500 (seems MVAR data) | 410 |
| 13 | Khedar | 1200 | Haryana | -360 to | -150 to 100 | 410 |
| 14 | MGTPS | 1320 | Haryana | -396 to | -300 to 0 | 405 |
| 15 | Bawana | 1000 | Rajasthan | -300 to | -60 to 100 | 415 |
| 16 | Bara PPGCL | 1320 | UP | -396 to 792 | -50 to 80 | 778 |

UP SLDC has also shared MVAR plots developed at their end. UP SLDC letter in this regard is attached as **Annexure-B.III.b**.

It was agreed in previous OCC meetings that states shall also develop MVAR vs voltage plots for generators under their jurisdiction. This would also help to improve telemetry of MVAR data and eventually, more reliable MVAR vs voltage plots will be available and the generators can be instructed accordingly.

All generating stations are requested to resolve any issues related to telemetry and make sure that MVAR absorption is as per grid requirement and capability curve of machine. Generating stations need to make sure that the AVR settings and GT tap positions are optimized to achieve the reactive power performance as per grid requirements. It is also requested to share these details with NRLDC.

Members may like to discuss.

Capability of solar plant based inverters can be used to provide voltage support during critical system needs on continuous basis and during night the entire inverter capacity can be used for reactive power support.

It has already been deliberated in OCC meetings that PV inverters generally have three modes of operation selectable by the plant:

1. Voltage control mode in which voltage of the reference point is monitored by inverters/PPC and reactive power draw/ injection is varied accordingly w.r.t a voltage set point.
2. Reactive Power or Q-control mode in which inverter supplies/absorbs a fixed amount of reactive power from the grid.

3. Power Factor control mode is one in which inverter operates within a defined power factor range.

Plots depicting ISGS Solar reactive power performance is attached as Annexure-B.IV.

From data, it is being observed that the reactive power absorption of solar plant is increasing with increase in generated active power. Though the plant is keeping up with the recommended CEA connectivity standards by running within 0.95 limits but the effect of this plant along with other operating in same manner i.e. at lagging pf, is absorption of reactive power at POI proportional to real power output resulting in reduction of voltage to critically low levels during peak solar generation.

Moreover, numerous tripping have been reported related to RE generation in recent past suggesting possible non-compliance by RE generators. The details of these events are attached as **Annexure-B.IV**. As already discussed in TCC/NRPC meeting, subgroup formed at NRPC level to look after RE integration may immediately take up the issues at their level. Major areas for discussion include:

- Operation of solar plants in voltage control mode as per grid requirements
- Reactive power performance (absorption/generation) of solar plants during day & night time
- Harmonisation of settings among different solar plants including protection settings at lower voltage levels (within plant) to avoid unintended disconnection/ generation reduction
- LVRT/HVRT compliance in real-time grid events
- Installation of adequate reactive compensation before project commissioning stage as per CEA regulations.

Members may like to discuss.

21. TTC/ATC of state control areas for winter 2021-22

In 188th OCC meeting, it was discussed that most of the NR states except Uttarakhand, J&K U/T and Ladakh U/T and Chandigarh are sharing basecase and ATC/TTC assessment with NRLDC. SLDCs are once again requested to go through the tentative ATC/TTC limits for December 2021 (**Annexure-B.V**) and provide comments. However, ATC/TTC assessment has only been received only from HP so far. Rajasthan had shared ATC/TTC calculations with NRLDC on 22.10.2021. On 28.10.2021, NRLDC has shared their observations on basecase as well as simulation studies carried out by Rajasthan. If no comments are received, these limits will be assumed confirmed and uploaded on NLDC website. SLDCs are also requested to upload the limits for winter 2021-22 in their respective websites.

| State | Available Transfer Capability (ATC) (MW) (TTC-RM) | Limiting Constraints | Remarks |
|--------|---|---|--|
| Punjab | 7100 (Solar) 7400 (non-solar) | N-1 contingency of 400/220kV Rajpura, Nakodar, Moga and Ludhiana ICTs . | Punjab SLDC is requested to ensure sufficient intrastate generation on bar during winter months, which would help in providing the required MVAR |

| State | Available Transfer Capability (ATC) (MW) (TTC-RM) | Limiting Constraints | Remarks |
|-----------|---|---|--|
| | | | absorption to limit high voltages during winter months |
| UP | 13200 | N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Sarnath, Obra and Agra(PG) ICTs, 400/132kV Mau ICTs | UP is assessing its ATC on regular basis in consultation with NRLDC and uploading it at its website. SPS for Sohawal and Lucknow to be expedited. |
| Rajasthan | 5900 | <p>N-1 contingency of 400/220kV Chittorgarh, Merta, Jodhpur ICTs, Bhilwara and Ajmer ICTs</p> <p>Rajasthan SLDC is requested to take up the matter for implementation of SPS at Jodhpur and other stations with STU and ensure loading below N-1 contingency limit at constrained 400/220kV ICTs.</p> | <p>Rajasthan had shared ATC/TTC calculations with NRLDC on 22.10.2021. On 28.10.2021, NRLDC has shared their observations on basecase as well as simulation studies carried out by Rajasthan. NRLDC shared the latest basecase and suggested:</p> <ul style="list-style-type: none"> • While studying N-1 contingency of 400/220kV ICT at stations it is mentioned that ICTs at other stations are not overloaded even in case of outage of all ICTs at station due to N-1 non-compliance. It is requested to kindly check the loading of 220kV lines also for all such cases. • For controlling loading of 220kV Agra-Bharatpur, it is mentioned that bus-spit would be done at Bharatpur to control loading. It is requested to please share details of same and if possible also incorporate in basecase. Similarly, measures for controlling loading of other highly loaded 220kV lines may also be shared. • Low voltage at Hindaun, Alwar may also be considered as limiting constraint if voltages are getting low. • Keeping all above factors, it is requested that revised ATC/TTC limits be calculated and shared with NRLDC. |

| State | Available Transfer Capability (ATC) (MW) (TTC-RM) | Limiting Constraints | Remarks |
|----------------|---|--|--|
| Haryana | 7900 | N-1 contingency of 400/220kV ICTs at Deepalpur, Kurukshetra(PG), Sonapat(PG), Panipat | Haryana SLDC is once again requested to expedite implementation of SPS at 400/220kV Deepalpur and Kurukshetra (PG) to enhance their ATC/TTC limits at the earliest |
| Delhi | 6500 | N-1 contingency of 400/220kV Mundka and Bamnauli ICTs. | ATC is not being uploaded in website, only violation of ATC is being shown. Delhi SLDC to implement SPS at Mundka and Bamnauli to save supercritical loads under N-1 contingency of one ICT. |
| J&K and Ladakh | 1550 | N-1 contingency of 400/220kV Amargarh ICTs | Not assessing its ATC |
| HP | 1100 | N-1 contingency of 400/220kV Nallagarh ICTs and 220kV Nallagarh-Uperanangal D/C. HP SLDC has also shared that 132kV lines from Kangoo are also heavily loaded. | HP has started sharing its ATC assessment since last 3 months in consultation with NRLDC |
| Uttarakhand | 1500 | N-1 contingency of 400/220kV Dehradun and Kashipur ICTs | Uttarakhand has also shared its ATC assessment with NRLDC for winter 2021-22. |

J&K representatives had intimated during 47th TCC and 49th NRPC meeting that they would be sharing ATC/TTC assessment with NRLDC from October 2021, however the same is still awaited.

As discussed in last several OCC meetings, all SLDCs need to furnish ATC/TTC details of their control area at respective SLDC websites. Now, it is being observed that most of the SLDCs except Uttarakhand, J&K and Delhi (real-time violation available) are uploading ATC/TTC limits on their websites.

| SLDC | Link for ATC on website |
|--------------------|---|
| UP | https://www.upslcd.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde |
| Punjab | https://www.punjabslcd.org/downloads/ATC-TTC0321.pdf |
| Haryana | https://hvpn.org.in/#/atcttc |
| Delhi | NA (real-time violation reporting available) |
| Rajasthan | https://slcd.rajasthan.gov.in/rrvpnl/scheduling/downloads |
| HP | https://hpslcd.com/mrm_category/ttc-atc-report/ |
| Uttarakhand | NA |
| J&K and Ladakh U/T | NA |

J&K and Ladakh U/Ts are once again requested to advise the concerned officers to evaluate their ATC/TTC limits in coordination with NRLDC and share latest assessment with NRLDC and NRPC.

Plots depicting N-1 non-compliance at several 400/220kV ICTs is attached as **Annexure-B.VI**. It is again requested that SLDCs may ensure that loading of ICTs and lines are below their N-1 contingency limits.

As discussed during last meeting, since from October/ November, demand of most of the NR states starts changing, it is requested that the revised ATC/TTC limits for winter 2021 alongwith anticipated generation scenario may be timely shared with NRLDC.

All SLDCs are requested to share basecase as well as ATC/TTC assessment with NRLDC/NRPC on monthly basis as well as upload on their websites. Basecase and ATC assessment shall be shared with NRLDC by the 10th of every month. NRLDC will incorporate these changes in All India basecase and share the updated basecase as well as observations on ATC/TTC by the 20th of every month. Monthly/ quarterly online meetings will also be organized involving reliability coordinators of SLDCs/RLDC to discuss reliability issues and measures required. It is also requested that net scheduled power requested by states is within their ATC limits.

Members may like to discuss.

22. Grid operation related issues

(i) Long outage of transmission elements/ generating units

Reasons and revival date for elements under long outage are being discussed regularly in OCC meetings. Any update on the status of these elements from last OCC meeting may be shared with the forum (**Annexure-B.VII**).

All constituents are requested to obtain necessary CEA Clearance before putting up-request for charging of the elements wherever any additions/alterations of any electrical installations is involved. {as per Clause no. 43, CEA(Measures relating to safety and Electric Supply) Regulations 2010, it is mandatory to obtain the approval of CEA electrical inspector for any additions/alterations of any electrical installation}.

“The owner of any installation of voltage exceeding 650 V who makes any addition or alteration to his installation shall not connect to the supply his apparatus or electric supply lines., comprising the said alterations or additions unless and until such alteration or addition has been approved in writing by the Electrical Inspector”.

All utilities are requested to make it a practice to update status of elements under long outage in the NRLDC outage software portal. Utilities are requested to take necessary actions to revive elements which are under long outage.

After issuance of provisional approval for charging (format-IV), utilities shall ensure charging of elements within three days from issuance days.

It has been observed in few cases that after approval for first time charging, the elements were charged only through main bay without charging tie bay/ dia. This results in reduction of reliability of the transmission element. Hence, all utilities are requested to charge the element with complete dia. Trial operation certificates will be processed only after charging of the elements with complete dia.

Members may please discuss.

(ii) Information about new transmission elements/ generating units to be commissioned in next 45 days

In 176th OCC meeting, it was discussed that first time charging procedure is not being diligently followed by some entities. The documents are being submitted at the last minute

and thereafter it is being urged to NRLDC to give the code for charging. In the meeting it was also requested that utilities should inform about elements expected for first time charging in the next one month in advance in OCC meeting. This information would be helpful in carrying out studies, SPS requirement/modification etc in time.

Utilities are also requested to make sure that list of 220kV and underlying intra-state lines and ICTs is readily available with them, so that the same can be shared with NRLDC/NRPC as and when required. This data is to be shared with NRLDC/NRPC for timely updation of Powermaps, PSSeabasecase, Protection analysis etc.

In line with the above decisions, all utilities are requested to share the information about transmission elements/ generating units which are expected to be first time charged in the next 45 days.

(iii) MVAR flow from underlying network to 400kV grid:

Recently, it is being observed that there is MVAR flow from 220kV side to 400kV side due to high MVAR generation by lightly loaded lines. This leads to very high voltages in 400kV and 765kV grid and to manage these, even a large number of lines are being opened on regular basis. Based on SCADA data (Oct-2021) available at NRLDC (**Annexure-B.VIII**), the list of several such 400/220kV substations is shown below:

| S. No. | Location | Substation Name |
|--------|-----------|-----------------|
| 1 | Punjab | Malerkotla |
| 2 | | Makhu |
| 3 | | Muktsar |
| 4 | | Nakodar |
| 5 | Delhi | Mandola |
| 6 | | Maharanibagh |
| 7 | | Bamnauli |
| 8 | | Mundka |
| 9 | | Bawana |
| 10 | Haryana | Kirori |
| 11 | | Manesar |
| 12 | Rajasthan | Jaipur South |
| 13 | | Heerapura |
| 14 | UP | Kanpur (PG) |
| 15 | | Muradnagar |

Utilities are requested to analyse the reasons for MVAR flows from 220kV side to 400kV side and share their plan to mitigate this to minimize high voltages in the grid. Delhi, Haryana, Punjab and Rajasthan are requested to share action plan for high voltage management during winter 2021-22.

(iv) Modification of Anpara-Unnao SPS with commissioning of 765kV AnparaD-Unnao

765kV AnparaD-Unnao line was scheduled for commissioning in 2012 to facilitate evacuation from Anpara-D. Line was successfully charged on 01.11.2021 and has helped in providing one additional path for evacuation from the complex. As approved in 162 OCC meeting, SPS in Anpara-Unnao complex is as follows:

| Tripping of two ICT at 765/400kV Unnao | | | |
|--|---|--|--|
| Sl. No. | Real time flow on 765 kV Anpara-Unnao Line (X) (MW) prior to tripping | Proposed Scheme by UP (after 161 OCC) | NRLDC Remarks |
| 1 | $1200 < X \leq 1400$ | Tripping of one unit at Anpara-C or Anpara-D shall be carried out through SPS. (The logic shall be build such that in one such event tripping of unit shall take place at Anpara-C and in next such event at Anpara-D and so on) | Ok. It seems logic would be able to take care of contingency |
| 2 | $X > 1400$ | One unit each shall be tripped simultaneously at Anpara C and Anpara D. In addition to it, for safety of the powergrid, load-shedding of 600MW shall be carried out in UP power system | Ok. It seems logic would be able to take care of contingency. However, UP may clarify whether load-shedding will be automatic/manual |

| Tripping of three ICT at 765/400kV Unnao or 765kV Anpara C-Unnao line | | | |
|---|---|--|--|
| Sl. No. | Real time flow on 765 kV Anpara-Unnao Line (X) (MW) prior to tripping | Proposed Scheme by UP (after 161 OCC) | NRLDC Remarks |
| 1 | $X < 1100$ | No automatic backing down. UP SLDC shall take backing down actions if loadings on other lines are high | Ok. It seems logic would be able to take care of contingency |
| 2 | $1100 < X < 1400$ | Tripping of one unit at Anpara-C or Anpara-D shall be carried out through SPS. (The logic shall be build such that in one such event tripping of unit shall take place at Anpara-C and in next such event at Anpara-D and so on) | Ok. It seems logic would be able to take care of contingency |
| 3 | $X > 1400$ | One unit each shall be tripped simultaneously at Anpara C and Anpara D. In addition to it, for safety of the powergrid, load-shedding of 600MW shall be carried out in UP power system | Ok. It seems logic would be able to take care of contingency. However, UP may clarify whether load-shedding will be automatic/manual |

However, with the commissioning of 765kV AnparaD-Unnao, there is need to revise the SPS conditions for different possible contingencies. Study carried out by POSOCO in this regard is attached as **Annexure-B.IX**. Study suggest no major issue with outage of one of either 765kV AnparaC-Unnao or AnparaD-Unnao.

UP SLDC is requested to study and discuss the possible revisions in SPS of Anpara-Unnao complex with the commissioning of 765kV AnparaD-Unnao.

Members may like to discuss.

(v) Order of Commission for Air Quality Management in National Capital Region and Adjoining Areas

The Commission for Air Quality Management in National Capital Region and Adjoining Areas has issued a slew of directions to improve the air quality in Delhi and surrounding areas. Of the 11 thermal power plants located within 300 km radius of Delhi, only five should be allowed to schedule their operations while the rest have to remain inoperative at least till November 30, 2021.

The five plants which have been allowed operate are NTPC, Jhajjar; Mahatma Gandhi TPS, CLP Jhajjar; Panipat TPS, HPGCL; Nabha Power Ltd. TPS Rajpura and Talwandi Sabo TPS, Mansa.

For kind information to members. All SLDCs are advised to ensure load-generation balance

(vi) SPS Implementation at Bhadla (PG)

The SPS logic decided in the 45th TCC meeting and approved in the 48th NRPC meeting was The SPS logic decided in the 45th TCC meeting and approved in the 48th NRPC meeting was explained to OCC members in 181 OCC meeting. POWERGRID representative had intimated that QR for the SPS tender has already been finalized and NIT may be floated within next two weeks.

181 OCC: QR finalised, tender may be floated in next week

183 OCC: QR approved, tender documents being prepared

186 OCC: Tendering stage, likely to be awarded in Sep'2021

In 187 OCC meeting, POWERGRID representative stated that work is still in tendering stage and the Bid opening is scheduled on 23.09.2021.

POWERGRID to provide update on the latest status.

(vii) Calculation of Drawal points based on SLDC end data

As discussed in the 6th TeST meeting all SLDCs shall maintain its own drawal calculation (alternate calculation based on the SLDC drawal points) for proper monitoring and SLDC also shall be responsible for calculation of its own drawl based on their drawal points at their respective feeders/ICTS. SLDC shall use its own calculated value of monitoring real-time drawal from the grid along with ISTS drawal to ensure the correctness and corrective measures shall be taken accordingly. UP and Delhi are using their end calculation as primary calculation for monitoring of drawal whereas Rajasthan is entirely dependent on STU data.

However, Punjab, Haryana, Jammu and Kashmir, Uttarakhand are dependent on RLDC end drawal values. All concerned are requested to please compute drawal values at SLDC end also, so that same can be verified with NRLDC end value and any discrepancy can be rectified immediately. In 188th OCC meeting, MS NRPC expressed concern and asked all the states which are only dependent on RLDC end data to take necessary actions and compute drawl values at SLDC end also. It was also suggested that the agenda be continued in OCC meeting till resolution of issue by all states.

Members may like to discuss.

23. Frequent forced outages of transmission elements in the month of Oct'21:

The following transmission elements were frequently under forced outages during the month of **Oct'21**:

| S. NO. | Element Name | No. of forced outages | Utility/SLDC |
|--------|---|-----------------------|-----------------------|
| 1 | 400 KV Suratgarh(RVUN)-Ratangarh(RS) (RS) Ckt-2 | 5 | Rajasthan |
| 2 | 400 KV Agra-Unnao (UP) Ckt-1 | 3 | UP |
| 3 | 400 KV Alaknanda GVK(UPC)-Srinagar(UK) (UK) Ckt-1 | 3 | UP/Uttarakhand |
| 4 | 400 KV Kishenpur-NewWanpoh (PG) Ckt-3 | 3 | POWERGRID |
| 5 | 220 KV Alusteng(JK)-Drass(JK) (PDD JK) Ckt-1 | 4 | J&K |
| 6 | 220 KV Phozal(HP)-Nallagarh(PG) (ADHPL) Ckt-1 | 4 | HP/POWERGRID/AD Hydro |

The complete details are attached at **Annexure-B.X**. Frequent outages of such elements affect the reliability and security of the grid. Frequent outages of 400 KV Kishenpur-NewWanpoh (PG) Ckt-3 & 220 KV Alusteng(JK)-Drass(JK) (PDD JK) Ckt-1 affect the reliable power supply of Kashmir valley and Ladakh region respectively. Hence, utilities are requested to analyse the root cause of the trippings and share the remedial measures taken/being taken in this respect.

Members may like to discuss.

24. Multiple element tripping events in Northern region in the month of Oct'21

A total of **13** grid events occurred in the month of Oct'21 of which **5** are of GD-1 category. The preliminary report of all the events have been issued from NRLDC. A list of all these events along with the status of details received by 05-November-2021 is attached at **Annexure-B.XI**.

Further, despite persistent discussions/follow-up in various OCC/PCC meetings, the compliance of the regulations is still much below the desired level.

Maximum Fault Duration is **1800ms** in the event of multiple element tripping at 400/220 kV Bareilly (UP) on 23-Oct-21 at 16:28hrs.)

Delayed clearance of fault (more than 100ms for 400kV and 160ms for 220kV system) observed in total **5** events out of **13** grid events occurred in the month. In 4 number of events, fault signature couldn't be captured from PMU data.

Members may take necessary preventive measures to avoid such grid incidents / disturbances

In future and discuss the same. Moreover, utilities may impress upon all concerned for providing the Preliminary Report, DR/EL & Detailed Report of the events in line with the regulations.

Members may like to discuss.

25. Details of tripping of Inter-Regional lines from Northern Region for Oct'21

A total of 9 inter-regional lines tripping occurred in the month of Oct'21. The list is attached at **Annexure-B.XII**. Out of 9 number of tripping's, 2 tripping incidents are related to HVDC system. The status of receipt of preliminary reports, DR/EL within 24hrs of the event and fault clearing time as per PMU data has also been mentioned in the table. The non-receipt of DR/EL & preliminary report within 24hrs of the event is in violation of various regulations. As per regulations, all the utilities shall furnish the DR/EL, flag details & preliminary report to RLDC/RPC within 24hrs of the event. They shall also furnish the detailed investigation report within 7 days of the event if fault clearance time is higher than mandated by CEA (Grid Standard) Regulations.

Members may please note and advise the concerned for taking corrective action to avoid such tripping as well as timely submission of the information.

26. Status of submission of DR/EL and tripping report of utilities for the month of Oct'21

The status of receipt of DR/EL and tripping report of utilities for the month of Oct 2021 is attached at **Annexure-B.XIII**. It is to be noted that as per the IEGC provision under clause 5.2 (r), detailed tripping report along with DR & EL has to be furnished within 24 hrs of the occurrence of the event. However, it is evident from the submitted data that reporting status is not satisfactory and needs improvement. Also, it is observed that reporting status has been improved from POWERGRID NR2, Delhi, HP, Rajasthan and Haryana in Oct, 2021 compared to the previous month.

Members may please note and advise the concerned for timely submission of the information. It is requested that DR/EL of all the trippings shall be **uploaded on Web Based Tripping Monitoring System “<http://103.7.128.184/Account/Login.aspx>”** within 24 hours of the events as per IEGC clause 5.2.r and clause 15.3 of CEA grid standard. Apart from prints of DR outputs, the corresponding COMTRADE files may please also be submitted in tripping portal / through email.

27. Frequency response characteristic:

One FRC based event has occurred in the month of **Oct-2021**. Description of the event is as given below:

| S. No. | Event Date | Time (In hrs.) | Event Description | Starting Frequency (in Hz) | End Frequency (in Hz) | Δf |
|--------|------------|----------------|---|----------------------------|-----------------------|------------|
| 1 | 21-Oct-21 | 14:32hrs | At 13:47 Hrs Dated 21st Oct 2021,400KV Teesta III-Kishanganj tripped on Y-B fault, further 400KV-Teesta III-Dikchu line tripped at 14:32 Hrs on B-N fault causing loss of evacuation path from Teesta-III and resulted in | 49.87 | 49.85 | -0.02 |

| | | | | | |
|--|--|---|--|--|--|
| | | Generation loss of 1086 MW at Teesta-III. | | | |
|--|--|---|--|--|--|

The Hon'ble CERC approved procedure has already been shared with all concerned during previous OCC meetings. FRC observed for each state control area on the basis of SCADA data for the event is tabulated below:

| States | 21-Oct-21 event | Remarks |
|----------------------------|-----------------|---------|
| PUNJAB | 240% | |
| HARYANA | 188% | |
| RAJASTHAN | -32% | |
| DELHI | 181% | |
| UTTAR PRADESH | -33% | |
| UTTARAKHAND | -49% | |
| CHANDIGARH | -56% | |
| HIMACHAL PRADESH | -66% | |
| JAMMU & KASHMIR | 119% | |
| NR | 35% | |

FRC calculation of ISGS stations based on NRLDC SCADA data is tabulated below:

| Generator | 21-Oct-21 event | Generator | 21-Oct-21 event |
|--------------------|----------------------|-----------------|----------------------|
| Singrauli TPS | -111% | Salal HEP | -10% |
| Rihand-1 TPS | -139% | Tanakpur HEP | No generation |
| Rihand-2 TPS | 76% | Uri-1 HEP | 50% |
| Rihand-3 TPS | -119% | Uri-2 HEP | 73% |
| Dadri-1 TPS | -24% | Dhauliganga HEP | Suspected SCADA data |
| Dadri -2 TPS | -31% | Dulhasti HEP | 113% |
| Unchahar TPS | No generation | Sewa-II HEP | No generation |
| Unchahar stg-4 TPS | 372% | Parbati-3 HEP | No generation |
| Jhajjar TPS | 92% | Jhakri HEP | 1% |
| Dadri GPS | -52% | Rampur HEP | Suspected SCADA data |
| Anta GPS | -18% | Tehri HEP | 37% |
| Auraiya GPS | 36% | Koteswar HEP | 256% |
| Narora APS | 45% | Karcham HEP | No generation |
| RAPS-B | 42% | Malana-2 HEP | Suspected SCADA data |
| RAPS-C | -68% | Budhil HEP | No generation |
| Chamera-1 HEP | No generation | Bhakra HEP | 2% |
| Chamera-2 HEP | No generation | Dehar HEP | No generation |
| Chamera-3 HEP | No generation | Pong HEP | No generation |
| Bairasiul HEP | Suspected SCADA data | Koldam HEP | No generation |
| | | AD Hydro HEP | No generation |

FRC calculation of major state generators based on NRLDC SCADA data is tabulated below:

| Generator | 21-Oct-21 event | Generator | 21-Oct-21 event |
|--------------------|----------------------|------------------|----------------------|
| PUNJAB | | UP | |
| Ropar TPS | No generation | Obra TPS | Suspected SCADA data |
| L.Mohabbat TPS | No generation | Harduaganj TPS | No generation |
| Rajpura TPS | 248% | Paricha TPS | No generation |
| T.Sabo TPS | 405% | Rosa TPS | 101% |
| Goindwal Sahib TPS | 654% | Anpara TPS | 17% |
| Ranjit Sagar HEP | -62% | Anpara C TPS | Suspected SCADA data |
| Anandpur Sahib HEP | No generation | Anpara D TPS | 2% |
| HARYANA | | Bara TPS | 13% |
| Panipat TPS | Suspected SCADA data | Lalitpur TPS | 14% |
| Khedar TPS | Suspected SCADA data | Meja TPS | -116% |
| Yamuna Nagar TPS | No generation | Vishnuprayag HEP | Suspected SCADA data |
| CLP Jhajjar TPS | -10% | Alaknanda HEP | -15% |
| Faridabad GPS | No generation | Rihand HEP | -5% |
| RAJASTHAN | | Obra HEP | -55% |
| Kota TPS | 55% | UTTARAKHAND | |
| Suratgarh TPS | 10% | Gamma Infra GPS | No generation |
| Kalisindh TPS | Suspected SCADA data | Shravanti GPS | No generation |
| Chhabra TPS | No generation | Ranganga HEP | No generation |
| Chhabra stg-2 TPS | Suspected SCADA data | Chibra HEP | Suspected SCADA data |
| Kawai TPS | -28% | Khodri HEP | -133% |
| Dholpur GPS | No generation | Chilla HEP | No generation |
| Mahi-1 HEP | Suspected SCADA data | HP | |
| Mahi-2 HEP | No generation | Baspa HEP | 5% |
| RPS HEP | No generation | Malana HEP | No generation |
| JS HEP | -100% | Sainj HEP | -23% |
| DELHI | | Larji HEP | 16% |
| Badarpur TPS | No generation | Bhabha HEP | -38% |
| Bawana GPS | Suspected SCADA data | Giri HEP | -20% |
| Pragati GPS | 75% | J&K | |
| | | Baglihar-1&2 HEP | 3% |
| | | Lower Jhelum HEP | No generation |

Status of Data received of FRC for the event at Teesta III on 21st Oct 2021:

| Data Received from | | Data Not Received from | |
|--------------------|----------------|------------------------|---------------|
| UP | Singrauli NTPC | HP | Rihand NTPC |
| | NJHPC | UK | Dadri-1 TPS |
| | NHPC | J&K | Rampur HEP |
| | Tehri HEP | Punjab | APCPL Jhajjar |
| | Koteshwar HEP | BBMB | ADANI (Kawai) |
| | CTPP Chhabra | Haryana | Others |
| | | Rajasthan | |
| | | Delhi | |

Primary Frequency Response by Generators (as per generator data) during Grid Event at Teesta III on 21st Oct 2021



| Sr. No | Generating stations | FRC as per generator data (in %) | Response category/Remark |
|--------|---------------------|----------------------------------|--|
| 1 | Dhauliganga HEP | 42.46 | Unsatisfactory response |
| 2 | N. Jhakri Unit 2 | 34.04 | Early die out of response |
| 3 | Singrauli Unit 7 | 307.73 | Satisfactory response |
| 4 | Anpara A & C | 0 | Poor response (Field raw data not received) |
| 5 | Obra B & H | 0 | Poor response (Field raw data not received) |
| 6 | Lalitpur | 14 | Unsatisfactory response (Field raw data not received) |
| 7 | Koteshwar HEP | 220.35 | Satisfactory response (Field raw data not received) |

In line with the decisions taken during various OCC meetings, the time and date of the FRC events were e-mailed to respective utilities. **Constituents may submit the FRC of their control areas for the above event and reason of poor response, if observed.**

FRC information has been received from NHPC, NJPC, Tehri, Singrauli, & UP control area. Utilities are requested to submit field data as per the measurement in generating plant.

Other utilities are also requested to kindly share the FRC calculations and further action taken at their end.

28. Status of PSS tuning/ re-tuning and Step Response Test of generator

In 180th, 181st, 182nd, 183rd, 184th, 185th, 186th, 187th & 188th OCC meeting, this point was discussed and Utilities were requested to submit the present status of PSS tuning/re-tuning and Step Response Test of their respective generators as per the below mentioned format.

| S. No. | Name of the Generating Station | Date of last PSS tuning / re-tuning performed (in DD/MM/YYYY format) | Date of last Step Response Test performed (in DD/MM/YYYY format) | Report submitted to NRLDC (Yes/ No) | Remarks (if any) |
|--------|--------------------------------|---|---|-------------------------------------|------------------|
| | | | | | |

Status report in above format updated till 08th November 2021 is attached as **Annexure-B.XIV**.

It may be noted that except Anpara-A U-3, Parichha-C U-5, Baspa U-2, Unchahar-II U-1, Jhakri U-1&3, all units of Tehri and Koteshwar, and all units of Rampur HPS, PSS of other major units were last tuned several years ago. Therefore, once again all utilities are requested to arrange exciter step-response test or tuning of their respective units and submit the report of PSS tuning/ re-tuning/ Step Response Test through email to NRPC and NRLDC at seo-nrpc@nic.in and nrldcso2@gmail.com respectively.

Members may kindly Accord due priority in this regard and update about their future plan for PSS tuning by 30th November, 2021 as there is no progress despite including this agenda in every OCC meeting.

29. Mock black start exercises in NR:

As per Indian Electricity Grid Code (IEGC) clause 5.8(b) "Mock trial runs of the procedure for different sub-systems shall be carried out by the Users/ CTU/ STU at least once every six months under intimation to the RLDC".

Mock Black-start exercise of power stations therefore needs to be carried out in-order to ensure healthiness of black start facility. The winter months are off peak hydro period and therefore good time to carry out such exercises.

Therefore, the schedule of mock exercise dates for different hydro & Gas power station was discussed in last OCC meeting and agreed. The power stations may confirm and inform to all the concerned persons of control centre/ substations to facilitate the exercise.

The proposed schedule for the Mock Black start exercise is as follows:

Hydro Power Stations:

| Date | Name of stations |
|-----------|--|
| 26-Nov-21 | * Uri-I, II HEP, Lower Jhelum HEP, Pampore GT's, Upper Sindh and Kishanganga |
| 01-Dec-21 | * Dhauliganga |
| 04-Dec-21 | Bairasiul |
| 08-Dec-21 | *Sewa-2 |
| 10-Dec-21 | * N. Jhakri and Rampur |
| 15-Dec-21 | Karcham and Baspa |
| 17-Dec-21 | *Budhil |
| 22-Dec-21 | Parbati-3 and Sainj |
| 24-Dec-21 | *Salal |
| 29-Dec-21 | *Chamera-3 |
| 31-Dec-21 | Koteshwar |
| 05-Jan-22 | Chamera-1 and Chamera-2 |
| 08-Jan-22 | Malana-2, AD Hydro and Phozal |

| | |
|-----------|--------|
| 12-Jan-22 | Tehri |
| 15-Jan-22 | Koldam |

* Mock Black start exercise not carried out during Year 2020-21

Mock Black start procedure circulated during last exercise/ previous year may be used. The unit selection may be changed from the one taken during last year exercise. Also **Constituents are requested to adhere to the finalized schedule of mock exercises during the season.**

Gas Power Stations:

| Date | Name of stations |
|-----------|------------------|
| 19-Jan-22 | Anta GPS |
| 21-Jan-22 | *Auraiya GPS |
| 28-Jan-22 | *Dadri GPS |

As informed by Bawana GPS, it does not have black start capability.

SLDC's may also carryout mock black-start of station in their respective control area & inform the tentative dates to the OCC as well as outcome of these exercises. The proposed Hydro Power Stations to undergo the exercise are as follows:

| S. NO. | Utility | Hydro Power Station | Installed Capacity(MW) | |
|--------|----------------------|---------------------|------------------------|--------|
| 1 | J&K | Baglihar | 3x150 | |
| 2 | | Baglihar stage-2 | 3x150 | |
| 3 | | Lower Jhelum | 3x35 | |
| 4 | | Upper Sindh | 2x11+3x35 | |
| 5 | | Larji | 3x42 | |
| 6 | | Bhabha | 3x40 | |
| 7 | | Malana -I | 2x43 | |
| 8 | | Baspa | 3x100 | |
| 9 | Punjab | Anandpur Sahib | 4x33.5 | |
| 10 | | Ranjit Sagar | 4x150 | |
| 11 | Rajasthan | Mahi-I&II | 2x25+2x45 | |
| 12 | | Rana Pratap Sagar | 4x43 | |
| 13 | | Jawahar Sagar | 3x33 | |
| 14 | | Gandhi Sagar | 5x23 | |
| 15 | | Dholpur GPS | 3x110 | |
| 16 | | Ramgarh GPS | 1x35.5+2x37.5+1x110 | |
| 17 | | UP | Rihand | 6x50 |
| 18 | Obra | | 3x33 | |
| 19 | Vishnuprayag | | 4x100 | |
| 20 | Srinagar (Alaknanda) | | | 4x82.5 |
| 21 | | | | |
| 22 | Uttarakhand | Gamma Infra | 2x76+1x73 | |
| 23 | | Shravanti | 6x75 | |
| 24 | | Ramganga | 3x66 | |
| 25 | | Chibro | 4x60 | |
| 26 | | Khodri | 4x30 | |
| 27 | | Chilla | 4x36 | |
| 28 | | Maneri Bhali-I&II | 3x30+4x76 | |

| | | | |
|----|---------|---------------|-------------------|
| 28 | Delhi | IP Extn GTs | 6x30+3x30 |
| 29 | | Pragati GPS | 2x104.6+1x121.2 |
| 30 | | Rithala | 3x36 |
| 31 | Haryana | Faridabad GPS | 2x137.75+1x156.07 |

During last winter, SLDCs had been requested to carry out mock drills and share their reports. However, the report of such exercises was not received except for Rihand Hydro in Uttar Pradesh. The information may please be shared by SLDCs and program for this year's mock black start exercises shall also be shared.

SLDCs shall submit the reports of black start exercise in their respective control area. SLDCs may also identify further generating stations/unit for black start exercise.

Members may please discuss.

30. Revision of document for Reactive Power Management and System Restoration Procedure (SRP) for Northern Region:

Reactive Power Management document for Northern region has been revised on 31st Dec 2020 & updated document link is as below:

<https://nrlcdc.in/download/nr-reactive-power-management-2021/>.

NRLDC letter in this regard is attached as **Annexure-B.XV**.

Document is password protected and password was already informed to all the NR constituents through letter dated 31st Dec 2020.

System restoration procedure document for Northern region has been revised on 31stJan 2021& updated document link is as below:

[https://nrlcdc.in/wp-content/uploads/2021/01/System-Restoration-Procedure NR 2021.pdf](https://nrlcdc.in/wp-content/uploads/2021/01/System-Restoration-Procedure_NR_2021.pdf)

Document is password protected and for password request can be sent to nrlcdcso2@gmail.com Constituents are requested to go through the document and provide any modification/addition in respect of their system. SLDC/Generating utilities are requested to kindly update and share the restoration procedure in respect of their state/generating station.

All the NR constituent may please go through these document and provide the feedback, suggestion if any. All the state SLDCs are also requested to kindly prepare these documents for their own control area.

Follow up issues from previous OCC meetings

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|--|---|--|--|--|---|------------|---------------|---|-------|----------|---|---------|----------|---|----|----------|---|----------------|---------------|---|--------|----------|---|-----------|----------|---|----|----------|---|--------------|----------|
| 1 | Sub-stations likely to be commissioned by next two years. | All the concerned states had been requested in past OCC meetings to submit the details of the downstream network associated specially with POWERGRID substations along with the action plan of their proposed / approved networks. | Status details of downstream networks mentioned in Annexure-A.I.I. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Progress of installing new capacitors and repair of defective capacitors | Information regarding installation of new capacitors and repair of defective capacitors is to be submitted to NRPC Secretariat. | <p>Data upto following months, received from various states / UTs:</p> <table border="1" data-bbox="874 864 1388 1312"> <tr> <td>⊙</td> <td>CHANDIGARH</td> <td>Sep-2019</td> </tr> <tr> <td>⊙</td> <td>DELHI</td> <td>Oct-2021</td> </tr> <tr> <td>⊙</td> <td>HARYANA</td> <td>Apr-2021</td> </tr> <tr> <td>⊙</td> <td>HP</td> <td>Mar-2021</td> </tr> <tr> <td>⊙</td> <td>J&K and LADAKH</td> <td>Not Available</td> </tr> <tr> <td>⊙</td> <td>PUNJAB</td> <td>Mar-2021</td> </tr> <tr> <td>⊙</td> <td>RAJASTHAN</td> <td>Sep-2021</td> </tr> <tr> <td>⊙</td> <td>UP</td> <td>Sep-2021</td> </tr> <tr> <td>⊙</td> <td>UTTARAKHAN D</td> <td>Oct-2021</td> </tr> </table> <p>All States/UTs are requested to furnish updated status on monthly basis.</p> | | | ⊙ | CHANDIGARH | Sep-2019 | ⊙ | DELHI | Oct-2021 | ⊙ | HARYANA | Apr-2021 | ⊙ | HP | Mar-2021 | ⊙ | J&K and LADAKH | Not Available | ⊙ | PUNJAB | Mar-2021 | ⊙ | RAJASTHAN | Sep-2021 | ⊙ | UP | Sep-2021 | ⊙ | UTTARAKHAN D | Oct-2021 |
| ⊙ | CHANDIGARH | Sep-2019 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | DELHI | Oct-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | HARYANA | Apr-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | HP | Mar-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | J&K and LADAKH | Not Available | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | PUNJAB | Mar-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | RAJASTHAN | Sep-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | UP | Sep-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | UTTARAKHAN D | Oct-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | Healthiness of defence mechanism: Self-certification | Report of mock exercise for healthiness of UFRs carried out by utilities themselves on quarterly basis is to be submitted to NRPC Secretariat and NRLDC. All utilities were advised to certify specifically, in the report that "All the UFRs are checked | <p>Data upto following months, received from various states / UTs:</p> <table border="1" data-bbox="874 1570 1388 1971"> <tr> <td>⊙</td> <td>CHANDIGARH</td> <td>Not Available</td> </tr> <tr> <td>⊙</td> <td>DELHI</td> <td>Sep-2021</td> </tr> <tr> <td>⊙</td> <td>HARYANA</td> <td>Sep-2021</td> </tr> <tr> <td>⊙</td> <td>HP</td> <td>Oct-2021</td> </tr> <tr> <td>⊙</td> <td>J&K and LADAKH</td> <td>Not Available</td> </tr> <tr> <td>⊙</td> <td>PUNJAB</td> <td>Mar-2021</td> </tr> <tr> <td>⊙</td> <td>RAJASTHAN</td> <td>Sep-2021</td> </tr> <tr> <td>⊙</td> <td>UP</td> <td>Sep-2021</td> </tr> </table> | | | ⊙ | CHANDIGARH | Not Available | ⊙ | DELHI | Sep-2021 | ⊙ | HARYANA | Sep-2021 | ⊙ | HP | Oct-2021 | ⊙ | J&K and LADAKH | Not Available | ⊙ | PUNJAB | Mar-2021 | ⊙ | RAJASTHAN | Sep-2021 | ⊙ | UP | Sep-2021 | | | |
| ⊙ | CHANDIGARH | Not Available | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | DELHI | Sep-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | HARYANA | Sep-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | HP | Oct-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | J&K and LADAKH | Not Available | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | PUNJAB | Mar-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | RAJASTHAN | Sep-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ⊙ | UP | Sep-2021 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | | | | |
|----|--|--|--|--|
| | | and found functional”. | <input type="radio"/> UTTARAKHAN D <input type="radio"/> BBMB | Mar-2021 Sep-2021 |
| | | | All States/UTs are requested to furnish updated status on monthly basis. | |
| 4 | Status of FGD installation vis-à-vis installation plan at identified TPS | List of FGDs to be installed in NR was finalized in the 36th TCC (special) meeting dt. 14.09.2017. All SLDCs were regularly requested since 144th OCC meeting to take up with the concerned generators where FGD was required to be installed. Further, progress of FGD installation work on monthly basis is monitored in OCC meetings. | Status of the information submission (month) from states / utilities is as under: <input type="radio"/> HARYANA Feb-2021 <input type="radio"/> PUNJAB Sep-2021 <input type="radio"/> RAJASTHAN Oct-2021 <input type="radio"/> UP Sep-2021 <input type="radio"/> NTPC May-2021 | |
| | | | FGD status details are enclosed as Annexure-A.I.II. All States/utilities are requested to furnish updated status of FGD installation progress on monthly basis. | |
| 5 | Information about variable charges of all generating units in the Region | The variable charges detail for different generating units are available on the MERIT Order Portal. | All states/UTs are requested to submit daily data on MERIT Order Portal timely. | |
| 6 | Reactive compensation at 220 kV/ 400 kV level at 15 substations | | | |
| | State / Utility | Substation | Reactor | Status |
| i | POWERGRID | Kurukshetra | 500 MVAR TCR | Anticipated commissioning: Dec'2021 (delay due to pending supplies by GE) |
| ii | DTL | Peeragarhi | 1x50 MVAR at 220 kV | PO awarded to M/s Kanohar Electricals Ltd. Drawings approved and under stage inspection. GIS Bay is already available. Work expected to be completed by Dec.21 |

| | | | | |
|------|-----------|---------------|--|---|
| iii | DTL | Harsh Vihar | 2x50 MVAR at 220 kV | PO awarded to M/s Kanohar Electricals Ltd. Drawings approved and under stage inspection. GIS Bay is already available. Work expected to be completed by Dec.21 |
| iv | DTL | Mundka | 1x125 MVAR at 400 kV & 1x25 MVAR at 220 kV | Bay work awarded to M/s. Ethos. Bay work is expected to be completed by Dec.21. Reactor part tender is dropped and at present same is under revision. |
| v | DTL | Bamnauli | 2x25 MVAR at 220 kV | Bay work awarded to M/s. Ethos. Bay work is expected to be completed by Dec.21. Reactor part tender is dropped and at present same is under revision. |
| vi | DTL | Indraprastha | 2x25 MVAR at 220 kV | Bay work awarded to M/s. Ethos. Bay work is expected to be completed by Dec.21. Reactor part tender is dropped and at present same is under revision. |
| vii | DTL | Electric Lane | 1x50 MVAR at 220 kV | Under Re-tendering due to Single Bid |
| viii | PUNJAB | Dhuri | 1x125 MVAR at 400 kV & 1x25 MVAR at 220 kV | 400kV Reactors – LOA issued on dated. 17.08.2021 and date of completion of project is 18 months from the date of LOA. 220kV Reactors - LOA issued on dated 19.07.2021 and date of completion of project is 18 months from the date of LOA. |
| ix | PUNJAB | Nakodar | 1x25 MVAR at 220 kV | 220kV Reactors - LOA issued on dated 19.07.2021 and date of completion of project is 18 months from the date of LOA. |
| x | PTCUL | Kashipur | 1x125 MVAR at 400 kV | Already submitted to PSDF. On hold due to policy decision |
| xi | RAJASTHAN | Akal | 1x25 MVAR | LOA placed on dt. 4.1.2021. Agreement signed on dt. 8.02.2021. Case for 2nd installment would be forwarded to NLDC, POSOCO. The target date is Nov'2021. |

| | | | | |
|----------|-----------|-----------------|------------|--|
| xii | RAJASTHAN | Bikaner | 1x25 MVar | LOA placed on dt. 4.1.2021. Agreement signed on dt. 8.02.2021. Case for 2nd installment would be forwarded to NLDC, POSOCO. The target date is Nov'2021. |
| xii i | RAJASTHAN | Suratgarh | 1x25 MVar | LOA placed on dt. 4.1.2021. Agreement signed on dt. 8.02.2021. Case for 2nd installment would be forwarded to NLDC, POSOCO. The target date is Nov'2021. |
| xi v | RAJASTHAN | Barmer & others | 13x25 MVar | Agreement signed on dt. 22.06.2020. Grant of Ist Installment received on dt.19.02.21. Technical bid opened on 22.10.2021 |
| xv | RAJASTHAN | Jodhpur | 1x125 MVar | Agreement signed on dt. 22.06.2020. Grant of Ist Installment received on dt.19.02.21. Technical bid opened on 22.10.2021 |

| Sl. No. | Substation | Downstream network bays | Commissioning status of ICTs / Bays | Planned 220 kV system | Revised Target | Remarks |
|---------|--|---|---|--|----------------|--|
| 1 | Shahjahanpur, 2x315 MVA 400/220 kV | 4 Nos. of 220 kV bays to be utilized | <u>Commissioning of ICT</u> <u>Commissioning of Bays</u> Jun/Sep'14 | Shahjahanpur-Azimpur D/C line | | Connected to load on 28.07.2021 |
| | | | | LILO of 220kV Shahjahanpur - Sitapur at Shahjahanpur PG | Dec'21 | Updated in 188th OCC |
| 2 | Hamirpur 400/220 kV 2x 315 MVA S/s (Augmentation by 3x105 MVA ICT) | 2 nos. bays utilized under ISTS. Balance 6 nos to be utilized | <u>Commissioning of ICT</u> 1st -Dec'13 2nd - Mar'14 3rd - Mar'19 <u>Commissioning of Bays</u> 4 bays - Dec'13 2 bays - Mar'14 2 bays - Mar'19 | 220 kV D/C Hamirpur-Dehan line. Original schedule: Dec' 2020 | Dec'21 | Updated in 188th OCC |
| 3 | Sikar 400/220kV, 1x 315 MVA S/s | 2 Nos. of 220 kV bays | Commissioned (date not available) | Not available | Sep'21 | Work order was placed on dt. 13.04.2020 to M/s A to Z Ltd. Works start on dt. 4.12.2020. S/S-32/32, T/E-31/32 (T/E at 27 no. location is pending due to Rajasthan High Court stay), T/S-2.09/8.12 2 km completed. Targeted to be completed |

| | | | | | | |
|---|-------------------------------|----------------------|-----------------------------------|--|--------|---|
| | | | | | | by June'2021 |
| 4 | Bhiwani 400/220kV S/s | 6 nos. of 220kV bays | Commissioned (date not available) | 220kV Bhiwani (PG) - Isherwal (HVPNL) D/c line | Dec'21 | Delayed due to RoW issue |
| 5 | 400/220kV Tughlakabad GIS | 10Nos. of 220kV bays | Commissioned (date not available) | RK Puram – Tughlakabad (UG Cable) 220kv D/c line | Jul'22 | PO for supply and ETC of D/C UG cable awarded. |
| | | | | Masjid Mor – Tughlakabad 220kv D/c line | Mar'22 | PO for supply and ETC of D/C UG cable awarded. |
| 6 | 400/220kV Kala Amb GIS (TBCB) | 6 Nos. of 220kV bays | Commissioned in Jul'2017 | 220kV D/c line from Kala Amb 400/220kV S/s to 220/132kV Kala Amb S/s | Dec'21 | Details for utilizing remaining 4 bays is not available |

FGD Status

Updated status of FGD related data submission

NTPC (16.06.2021)

MEJA Stage-I

RIHAND STPS

SINGRAULI STPS

TANDA Stage-I

TANDA Stage-II

UNCHAHAR TPS

UPRVUNL (20.10.2021)

ANPARA TPS

HARDUAGANJ TPS

OBRA TPS

PARICHHA TPS

PSPCL (22.10.2021)

GGSTP, Ropar

GH TPS (LEH.MOH.)

RRVUNL (14.10.2021)

CHHABRA SCPP

CHHABRA TPP

KALISINDH TPS

KOTA TPS

SURATGARH SCTPS

SURATGARH TPS

Updated status of FGD related data submission

Adani Power Ltd. (28.10.2021)

KAWAI TPS

**Lalitpur Power Gen. Co. Ltd.
(22.10.2021)**

Lalitpur TPS

**Lanco Anpara Power Ltd.
(22.10.2021)**

ANPARA-C TPS

**Rosa Power Supply Company
(22.10.2021)**

Rosa TPP Phase-I

**Prayagraj Power Generation
Company Ltd. (22.10.2021)**

Prayagraj TPP

APCPL (17.08.2021)

INDIRA GANDHI STPP

Pending submissions

GVK Power Ltd.

GOINDWAL SAHIB

HGPCL

PANIPAT TPS

RAJIV GANDHI TPS

YAMUNA NAGAR TPS

NTPC

DADRI (NCTPP)

Talwandi Sabo Power Ltd.

TALWANDI SABO TPP

L&T Power Development Ltd.

Nabha TPP (Rajpura TPP)

Target Dates for FGD Commissioning (Utility-wise)

| | |
|-------------------------|---|
| Adani Power Ltd. | KAWAI TPS U#1 (Target: 31-12-2024), KAWAI TPS U#2 (Target: 31-12-2024) |
| APCPL | INDIRA GANDHI STPP U#1 (Target: 31-12-2021), INDIRA GANDHI STPP U#2 (Target: 31-03-2022), INDIRA GANDHI STPP U#3 (Target: 30-06-2022) |
| GVK Power Ltd. | GOINDWAL SAHIB U#1 (Target: 30-04-2020), GOINDWAL SAHIB U#2 (Target: 29-02-2020) – initial target |
| HGPCL | PANIPAT TPS U#6 (Target: 30-04-2021), PANIPAT TPS U#7 (Target: 28-02-2021), PANIPAT TPS U#8 (Target: 31-12-2020), RAJIV GANDHI TPS U#1 (Target: 30-04-2022), RAJIV GANDHI TPS U#2 (Target: 28-02-2022), YAMUNA NAGAR TPS U#1 (Target: 31-12-2021), YAMUNA NAGAR TPS U#2 (Target: 31-10-2021) – initial target |

| | |
|-------------|---|
| NTPC | DADRI (NCTPP) U#1 (Target: 31-12-2020), DADRI (NCTPP) U#2 (Target: 31-10-2020), DADRI (NCTPP) U#3 (Target: 31-08-2020), DADRI (NCTPP) U#4 (Target: 30-06-2020), DADRI (NCTPP) U#5 (Target: 30-04-2020), DADRI (NCTPP) U#6 (Target: 29-02-2020), RIHAND STPS U#1 (Target: 28-02-2022), RIHAND STPS U#2 (Target: 31-12-2021), RIHAND STPS U#3 (Target: 31-12-2023), RIHAND STPS U#4 (Target: 31-12-2023), RIHAND STPS U#5 (Target: 30-06-2023), RIHAND STPS U#6 (Target: 30-06-2023), SINGRAULI STPS U#1 (Target: 31-08-2022), SINGRAULI STPS U#2 (Target: 31-08-2022), SINGRAULI STPS U#3 (Target: 31-08-2022), SINGRAULI STPS U#4 (Target: 31-08-2022), SINGRAULI STPS U#5 (Target: 31-08-2022), SINGRAULI STPS U#6 (Target: 31-08-2022), SINGRAULI STPS U#7 (Target: 31-08-2022), UNCHAHAR TPS U#1 (Target: 30-09-2023), UNCHAHAR TPS U#2 (Target: 30-09-2023), UNCHAHAR TPS U#3 (Target: 30-09-2023), UNCHAHAR TPS U#4 (Target: 30-09-2023), UNCHAHAR TPS U#5 (Target: 30-09-2023), UNCHAHAR TPS U#6 (Target: 31-03-2023), MEJA Stage-I U#1 (Target: 31-03-2022), MEJA Stage-I U#2 (Target: 31-03-2022), TANDA Stage-I U#1 (Target:), TANDA Stage-I U#2 (Target:), TANDA Stage-II U#3 (Target: 31-12-2022), TANDA Stage-II U#4 (Target: 31-12-2022) |
|-------------|---|

| | |
|--|--|
| L&T Power Development Ltd (Nabha) | Nabha TPP (Rajpura TPP) U#1 (Target: 30-04-2021), Nabha TPP (Rajpura TPP) U#2 (Target: 28-02-2021) – initial target |
| Lalitpur Power Gen. Company Ltd. | LALITPUR TPS U#1 (Target: 31-12-2024), LALITPUR TPS U#2 (Target: 30-09-2024), LALITPUR TPS U#3 (Target: 30-06-2024) |
| Lanco Anpara Power Ltd. | ANPARA C TPS U#1 (Target: 31-12-2023), ANPARA C TPS U#2 (Target: 31-12-2023) |
| Prayagraj Power Generation Company Ltd. | PRAYAGRAJ TPP U#1 (Target: 31-12-2024), PRAYAGRAJ TPP U#2 (Target: 31-12-2024), PRAYAGRAJ TPP U#3 (Target: 31-12-2024) |
| PSPCL | GH TPS (LEH.MOH.) U#1 (Target: 31-12-2024), GH TPS (LEH.MOH.) U#2 (Target: 31-12-2024), GH TPS (LEH.MOH.) U#3 (Target: 31-12-2024), GH TPS (LEH.MOH.) U#4 (Target: 31-12-2024), GGSSTP, Ropar U#3 (Target: 31-03-2022), GGSSTP, Ropar U#4 (Target: 31-05-2022), GGSSTP, Ropar U#5 (Target: 31-07-2022), GGSSTP, Ropar U#6 (Target: 30-09-2022) |

| | |
|----------------------------------|---|
| Rosa Power Supply Company | ROSA TPP Ph-I U#1 (Target: 31-12-2024), ROSA TPP Ph-I U#2 (Target: 31-12-2024), ROSA TPP Ph-I U#3 (Target: 31-12-2024), ROSA TPP Ph-I U#4 (Target: 31-12-2024) |
| RRVUNL | KOTA TPS U#5 (Target: 31-12-2022), KOTA TPS U#6 (Target: 31-12-2022), KOTA TPS U#7 (Target: 31-12-2022), SURATGARH TPS U#1 (Target: 31-12-2024), SURATGARH TPS U#2 (Target: 31-12-2024), SURATGARH TPS U#3 (Target: 31-12-2024), SURATGARH TPS U#4 (Target: 31-12-2024), SURATGARH TPS U#5 (Target: 31-12-2024), SURATGARH TPS U#6 (Target: 31-12-2024), SURATGARH SCTPS U#7 (Target: 31-12-2024), SURATGARH SCTPS U#8 (Target: 31-12-2024), CHHABRA TPP U#1 (Target: 31-12-2024), CHHABRA TPP U#2 (Target: 31-12-2024), CHHABRA TPP U#3 (Target: 31-12-2024), CHHABRA TPP U#4 (Target: 31-12-2024), CHHABRA SCPP U#5 (Target: 31-12-2024), CHHABRA SCPP U#6 (Target: 31-12-2024), KALISINDH TPS U#1 (Target: 31-12-2024), KALISINDH TPS U#2 (Target: 31-12-2024) |
| Talwandi Sabo Power Ltd. | TALWANDI SABO TPP U#1 (Target: 28-02-2021), TALWANDI SABO TPP U#2 (Target: 31-12-2020), TALWANDI SABO TPP U#3 (Target: 31-10-2020) – initial target |
| UPRVUNL | ANPARA TPS U#1 (Target: 31-10-2022), ANPARA TPS U#2 (Target: 31-08-2022), ANPARA TPS U#3 (Target: 30-06-2022), ANPARA TPS U#4 (Target: 30-04-2022), ANPARA TPS U#5 (Target: 28-02-2022), ANPARA TPS U#6 (Target: 30-06-2021), ANPARA TPS U#7 (Target: 30-04-2021), HARDUAGANJ TPS U#8 (Target: 31-12-2021), HARDUAGANJ TPS U#9 (Target: 31-12-2021), OBRA TPS U#9 (Target: 31-08-2022), OBRA TPS U#10 (Target: 31-10-2022), OBRA TPS U#11 (Target: 31-12-2022), OBRA TPS U#12 (Target: 30-06-2022), OBRA TPS U#13 (Target: 30-04-2022), PARICHHA TPS U#3 (Target: 30-04-2022), PARICHHA TPS U#4 (Target: 30-04-2022), PARICHHA TPS U#5 (Target: 28-02-2022), PARICHHA TPS U#6 (Target: 31-12-2021) |



सं. 22-1306/37/2020-ओएम

भारतसरकार

Government of India

विद्युत् मंत्रालय

Ministry of Power

श्रमशक्तिभवन, रफीमार्ग, नयीदिल्ली-110 001

Shram Shakti Bhawan, Rafi Marg, New Delhi-110 001


Dated 09th November, 2021

OFFICE MEMORANDUM

Subject:- Minutes of the Meeting on "Status of Islanding Scheme" held on 7th October, 2021 under the Chairmanship of Hon'ble Minister of Power and New & Renewable Energy -reg.

Please find enclosed herewith a copy of the minutes of the meeting on the above subject held on 07.10.2021 under the Chairmanship of Hon'ble Minister of Power and New & Renewable Energy for necessary action.

Encl: as above


(Raja Ramaswamy)
Under Secretary to Govt. of India
Telefax: 23719229
Email: opmonitor-power@nic.in

Distribution: As per list annexed

Copy to:

PS to Hon'ble Minister/ Sr.PPS to Secretary/Sr. PPS to JS (OM)/ PS to DS(OM)

Minutes of the Meeting on “Status of Islanding Scheme” held on 7th October, 2021 under the Chairmanship of Hon’ble Minister of Power and New & Renewable Energy

1. A Meeting on “Status of Islanding Scheme” was held on 7th October, 2021 under the Chairmanship of Hon’ble Minister of Power and New & Renewable Energy. The list of participants is given at **Annexure**.

2. Shri Ghanshyam Prasad, Joint Secretary, Ministry of Power introducing the subject of discussion said that during the meeting under the Chairmanship of Secretary, Ministry of Power, Central Electricity Authority (CEA) was entrusted with the task of operationalizing the existing Islanding Schemes and formulating new Islanding Schemes where they are required. Ms. Rishika Saran, Chief Engineer, Central Electricity Authority then made a Presentation on the Status of Islanding Scheme.

3. After a detailed discussion, the following action points emerged , which are required to be completed :

(i) Islanding Scheme operates during extreme emergency situations so that electricity continues to flow uninterruptedly. This principle must be adhered to by all utilities while designing the Islanding Scheme. Cost of electricity should not be an impediment in such extreme conditions.

[Action: CEA/POSOCO/ States]

(ii) Regarding Mumbai Islanding Scheme, all the planned additional infrastructure and the additional sub-station in Navi Mumbai is to be commissioned by July, 2023. Shri S.Satyanaryan, Member Secretary, WRPC was asked by Hon’ble Minister to brief him about the matter separately.

[Action: PGCIL, CEA, **Member-Secretary, WRPC**]

(iii) During exigencies like the recent power outage in Mumbai, there should not be any hesitation to clip the non-critical loads so that the essential services like railways and health services are not affected. Hon’ble Minister directed that the possibility of carrying out rehearsals and drills in all major cities in this context and bringing out a mechanism that will inform people of such activities be explored.

[Action: **MoP, CEA**]

(iv) Hon’ble Minister directed that while considering Islanding Schemes, consultations should also be held with the Engineering Branch of Ministry of Defence. Hon’ble Minister also said that he will hold consultation with the Chiefs of the Air Staff and the Army Staff about the requirement for strengthening of power system in any area.

[Action: **MOP**]

(v) Regarding funding of the projects, it was suggested that the funding may be done through Power System Development Fund (PSDF). In this context, Hon’ble Minister has directed that if there are problems with allocation of the funds, other sources of funds can be identified for the purpose.

[Action: **MoP (OM), CEA, NLDC**]

4. The Meeting ended with thanks to the Chair.

List of Participants

| | |
|----|---|
| 1. | Hon'ble Minister of Power and New & Renewable Energy – Chairman |
| | Ministry of Power |
| 1. | Shri Ghanshyam Prasad, Joint Secretary |
| 2. | Shri Devashis Bose, Deputy Secretary |
| 3. | Shri Arun Kumar Garg, Deputy Secretary |
| | Central Electricity Authority |
| 1. | Shri Dinesh Chandra, Chairperson |
| 2. | Shri B.K. Arya, Member |
| 3. | Ms. Rishika Sharan, Chief Engineer |
| | Western Regional Power Committee |
| 1. | Shri S. Satyanaryan, Member-Secretary |
| | Eastern Regional Power Committee |
| 1. | Shri N.S. Mondal, Member-Secretary |
| | Southern Regional Power Committee |
| 1. | Shri N.R.L.K. Prasad, Member-Secretary |
| | Northern Regional Power Committee |
| 1. | Shri Naresh Bhandari, Member-Secretary |
| | Northern Regional Load Despatch Centre |
| 1. | Shri N. Nallasaran, In-Charge |
| | Southern Regional Load Despatch Centre |
| 1. | Shri V. Suresh, Executive Director |
| | POSOCO |
| 1. | Shri K.V.S. Baba, CMD |
| 2. | Shri S.R. Narashiman, Director (Systems Operation) |
| | PGCIL |
| 1. | Shri K. Sreekant, CMD |

**Government of Jammu and Kashmir,
Department of Disaster Management, Relief, Rehabilitation & Reconstruction
Civil Secretariat, Jammu**

Subject:- Declaration of the spell of heavy rainfall/heavy snowfall during the period of 23rd and 24th October, 2021 as State Specific Natural Disaster under SDRF Norms.

**Government Order No.: 77-JK-DMRRR of 2021
D a t e d: 31 - 10 - 2021**

Sanction is hereby accorded to the following:-

1. Declaration of the spell of heavy rainfall/heavy snowfall during the period of 23rd and 24th of October, 2021 as "State Specific Calamity" in-terms of para 3 (ii) of State Disaster Response Fund (SDRF) guidelines issued by MHA, Gol, vide no.33-5/2015-NDM-I dated 30.07.2015; for purpose of providing relief to the affected families and Departments from SDRF.
2. Districts covered under above declaration for spell of heavy Rainfall/Snowfall are Anantnag, Kulgam, Shopian of Kashmir Division and Jammu, Udhampur, Kishtwar, Reasi, Samba and Kathua, of Jammu Division.

By order of the Government of Jammu and Kashmir.

Sd/-
(Nazim Zai Khan)JKAS
Secretary to Government
Department of DMRRR
Dated: 31.10.2021

No:DMRRR-ER /86/2021

Copy to the:-

1. All Financial Commissioners.
2. Principal Secretary to Hon'ble Lieutenant Governor.
3. All Principal Secretaries to the Government.
4. Joint Secretary (J&K), Ministry of Home Affairs. Gol, New Delhi.
5. All Commissioner/Secretaries to the Government.
6. Divisional Commissioner, Jammu/Kashmir.
7. All concerned Deputy Commissioners.



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत प्रणाली योजना एवं मूल्यांकन-I प्रभाग

Power System Planning & Appraisal-I Division

सेवा में / To,

1. COO, CTUIL, Saudamini, Plot no. 2, Sector -29, Gurgaon-122 001
2. CMD, POWERGRID, Saudamini, Plot no. 2, Sector -29, Gurgaon-122 001
3. Director (System Operation), POSOCO, B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi- 110010
4. Managing Director, HPPTCL, Himfed Bhawan, New ISBT Road, Panjari, Shimla-171005
5. Managing Director, HPSEBL, Vidyut Bhawan, Shimla- 171004
6. GM, GMR Bajoli Holi Hydro Power Private Limited, Airport Building, 302, 1st Floor, New Shakti Bhawan, Near Terminal 3, IGI Airport, New Delhi-37
7. SVP, M/s Greenko Budhil HEP, 1131/A, Sai Square Building, Road No. 36, Jubilee Hills, Hyderabad- 500033
8. Vice President, JSW Energy, JSW Centre, Bandra Kurla Complex, Bandra (East)-400051
9. SGM, AD Hydro Power Limited, Bhilwara Towers, A-12, Sector 1, Noida-201301

विषय /Subject: Minutes of the meeting held on 17.06.2021 through video conferencing to discuss issues related with transmission projects in Himachal Pradesh

Madam/Sir,

Please find enclosed the minutes of the meeting held on 17.06.2021 through video conferencing to discuss issues related to transmission projects in Himachal Pradesh.

भवदीय / Yours faithfully,

(मंजरी चतुर्वेदी/Manjari Chaturvedi)

निदेशक/Director

Minutes of the meeting held on 17.06.2021 through video conferencing to discuss issues related with transmission projects in Himachal Pradesh

List of participants is enclosed at **Annex-I**.

Chief Engineer (PSPA-I), CEA, welcomed the participants and requested Director (PSPA-I), CEA, to take up the agenda of the meeting.

1: Construction of 220/33 kV, 31.5 MVA Substation in AD Hydro Switchyard at Prini by HPPTCL


- (i) Director (PSPA-I), CEA, stated that AD Hydro Power Ltd. has developed 192 MW project at Prini in Himachal Pradesh. In order to evacuate power from the project, CTU had granted connectivity to ADHPL at 400/220 kV Nalagarh Substation through 220 kV D/C Prini to Nalagarh Line of ADHPL. AD Hydro had also agreed to provide space for one additional 220 kV bay in its Switchyard at Prini for injection & drawl of power at Prini by HP.

She added that HPPTCL had established 220/33 kV, 100 MVA Phojal Substation by S/c LILO of 220 kV D/c AD Hydro - Nalagarh line. Further, HPTTCL had informed that to facilitate injection of power from Small Hydro Electric Projects, AD hydro has also agreed for construction of 220/33 kV, 31.5 MVA substation in the switch yard of AD Hydro at Prini. The substation had been planned to facilitate injection of power from Small Hydro Electric Projects (SHEPs) in summers and to provide drawl of power to Manali area in winter. Currently power from the small hydro projects is being evacuated through 220/33 kV, 100 MVA Phojal Substation of HPPTCL. HPPTCL had informed that due to constraints in 33 kV system of HPSEBL, the SHEPs have to back down during peak generation period i.e. Summer. With the construction of 220/33 kV, 31.5 MVA Prini Substation, SHEPs will be able to inject power directly at Prini Substation. This will result in shifting of peak summer injection from Phojal S/Stn to Prini Substation & similarly winter drawl of Manali area will shift from Phojal S/Stn to Prini S/Stn.

The peak injection and drawl at Prini and Phojal S/s as intimated by HPPTCL is given below:

| Sl. No. | Name of Substation | Peak Injection (MW) (Summer) | Peak Drawl (MW) (Winter) |
|---------|----------------------------------|------------------------------|--------------------------|
| 1. | 220/33 kV, 31.5 MVA Prini S/Stn. | 24 | 24 |
| 2. | 220/33 kV, 100 MVA Phojal S/Stn. | 30 | 8 |
| | Total | 54 | 32 |

I/16394/2021



(ii) Director (PSPA-I), CEA, further stated that the matter was deliberated in the 3rd meeting of NRPC(TP) held on 19.02.2021 wherein members agreed to the above proposal of HPPTCL and it was decided that the commercial arrangements for usage of the line may be settled mutually between HPPTCL and M/s AD Hydro Power Ltd (ADHPL). However, ADHPL had requested CEA to convene a meeting to discuss the issues associated with the proposed substation of HPPTCL. Then, she requested ADHPL to elaborate their issues.

(iii) Representative of ADHPL raised the following issues:

- Representative of ADHPL stated there is neither any clearance including forest, environment, TEC approval etc. nor any order of the Apex Court which has directed ADHPL for any obligation to transmit power of any other generation project through its dedicated transmission line, except the approval of CEA during the meeting held on 1st March 2016 for use of ADHPL's dedicated transmission line by HPPTCL so that power of small IPPs in the valley does not get bottled up, based on which Phojal Sub-station of HPPTCL had been connected to ADHPL's dedicated transmission line. Further, connectivity of Phojal substation had been agreed only on interim basis
- He further stated that agreement had been signed in 2016 between ADHPL and HPPTCL for transmission of 11.4 MW power of HPSEBL utilising the dedicated transmission line of ADHPL. In the 156th NRPC OCC meeting held in February 2019, HPPTCL admitted connectivity of more number of small hydro projects and transmission of 27 MW power of HPSEBL through the dedicated line of ADHPL. However, HPPTCL and HPSEBL revised their Transmission Agreement from 11.4 MW to 27 MW w.e.f. December 2020 only. Even after signing of the agreement for revised capacity of 27 MW, it has been revealed through RTI that against 27 MW, about 33 MW capacity projects are connected and actual power flowing is in the range of 35-40 MW, either for drawl or injection. The Transmission Agreement between ADHPL and HPPTCL is yet to be revised corresponding to the increased quantum of power flow.
- ADHPL also raised the issue that HPPTCL has proposed shifting of small hydro projects from Phojal to Prini substation and stated that as per the single line diagram of 33/220 kV, 31.5 MVA Prini Sub-Station under construction, there are 5 nos. of 33 kV bays which comprise of 1 no. incomer bay from 31.5 MVA, 220/33 kV transformer, 2 nos.

I/16394/2021

bays of HPSEBL through underground cables and another 2 nos. of bays for 33 kV D/c transmission line from Palchan HPPTCL to Prini for the injection of power of small HEPs which are situated upstream of 192 MW Allain Duhangan HEP. With this arrangement, it won't be possible to shift the generation capacity from Phojal sub-station to Prini sub-station.

- ADHPL highlighted that in a meeting held in CEA in March, 2016, connectivity of Phojal substation to the dedicated line of ADHPL had been agreed only as an interim measure. If the dedicated line of ADHPL is to be used for transfer of power from small HEPs on permanent basis, the same need to be deliberated. ADHPL stated that as mentioned by HPPTCL, the load drawl would be floating between Prini and Phojal substation; ADHPL- Nallagarh line being a radial line, floating use of this line may create bottlenecks for transmission of ADHPL power. Therefore, there is a need for two separate Transmission Agreements for the two separate contracted capacities which are connected at these two substations because apart from the HPSEBL injection/drawl feeders, there are two feeders of 33 kV terminating at Prini sub-station for the injection of power of small HEPs which are situated upstream of 192 MW Allain Duhangan HEP.
- ADHPL representative further stated that the total capacity of 33/220 kV 100 MVA Phojal sub-station which is connected to ADHPL dedicated transmission line is 90 MW and total capacity of 31.50 MVA 33/220 kV Prini substation which is proposed to be connected to ADHPL dedicated transmission line is approximately 29 MW. Hence, the total capacity of the HPPTCL's sub-stations which have been proposed to be connected to dedicated transmission line of ADHPL is approximately 120 MW. ADHPL requested that HPSEBL/HPPTCL must clearly indicate the quantum of power to be injected in the dedicated transmission line (ADHPL-Nalagarh) by HPSEBL and ensure that transmission charges are paid to ADHPL for the said quantum of power.

(iv) MD, HPSEBL stated that though the 220 kV D/c line from AD Hydro to Nallagarh is a dedicated line of AD Hydro, this line was also to be used for evacuation of power from small HEPs in the valley, based on which Phojal and Prini substations have been planned.

Regarding the issue of more power flow than agreed capacity of 27 MW, HPSEBL stated that as per existing regulation, the transmission charges towards over injection upto 20% from the contracted capacity in any time block shall be payable at the same rate and beyond this limit, additional transmission charges shall be payable, which shall be 25% higher than the yearly transmission charge calculated pro-rata for the block.

Regarding shifting of load from Phojal to Prini, HPSEBL clarified that Prini substation has been designed not to shift the entire load of Phojal sub-station. But since these are interconnected at 33 kV level, sometimes the load would be shifted to Phojal and sometimes to Prini.

- (v) Chief Engineer (PSPA-I), CEA, stated that as the ADHPL- Nalagarh 220 kV D/c line is a dedicated line of AD Hydro, therefore, HPSEBL and HPPTCL need to discuss and resolve the operational and commercial issues regarding the use of this line with ADHPL.
- (vi) MD, HPPTCL, stated that the commercial and operational issues raised by ADHPL would be discussed and sorted out mutually between ADHPL, HPPTCL and HPSEBL.

I/16394/2021

- (vii) NRLDC representative stated that under N-1 contingency, injection on the line would need to be restricted by HPSEBL/HPPTCL. NRLDC representative further stated that metering and other requirements at Prini would be similar to the arrangement at Phojal and the same may be discussed with concerned team of NRLDC.
- (viii) After deliberations, it was decided that as suggested by MD, HPPTCL, all the operational and commercial issues related to the use of ADHPL's dedicated transmission line (ADHPL- Nalagarh line) by HPSEBL/HPPTCL would be discussed and mutually sorted out by HPPTCL and HPSEBL with ADHPL. Regarding metering arrangement, ADHPL, HPPTCL and HPSEBL need to approach NRLDC.

2: Grant of Connectivity to Kutehr HEP (240 MW) by S/C LILO of 400 kV D/C (Twin Moose) line from 400/220 kV, 2 x 315 MVA, Lahal Sub-Station to 400/220 kV Chamera P.S. of PGCIL at Rajera.

- (i) Director (PSPA-I), CEA, stated that following system is under implementation for evacuation of power from Hydro Projects in Ravi Basin-
- 400/220 kV, 2 x315 MVA Sub-Station at Lahal.
 - 400 kV D/C (Twin Moose) line from 400/220 kV, 2 x315 MVA, Lahal Sub-Station to 400/220 kV Chamera P.S. of PGCIL at Rajera.
 - 220 kV D/C (Twin Moose) line from Bajoli Holi to Lahal.

Kutehr HEP (240 MW) of M/s JSW was originally granted connectivity at 220 kV level at 400/220 kV, 2x315 MVA Lahal Substation in the year 2012 by HPPTCL. In the meantime, HPPTCL had received Long Term Access Applications from Bajoli Holi HEP (180 MW) and four Small HEPs with aggregate capacity of 51 MW, thus about 230 MW of capacity out of 315 MVA available at Lahal Substation had been committed. Further, additional 25 to 30 MW of Small Hydro Potential is also planned to be evacuated through Lahal Substation. Thus, total injection on 220 kV Bus at Lahal Substation would be around 260 MW.

In view of the capacity constraints envisaged at Lahal substation, HPPTCL had conveyed to M/s JSW regarding requirement for review of evacuation arrangement for Kutehr HEP (240 MW) by changing connectivity from 220 kV level to 400 kV level. Subsequently, it was conveyed to M/s JSW that Kutehr HEP (240 MW) would be provided connectivity through LILO of one circuit of 400 kV D/C (Twin Moose) line from 400/220 kV, 2 x315 MVA, Lahal Sub-Station to 400/220 kV Chamera P.S. of PGCIL at Rajera.

- (ii) Director, CEA, further stated the matter had been deliberated in the 3rd meeting of NRPC(TP) held on 19.02.2021 wherein HPPTCL had requested to approve the evacuation system of Kutehr HEP (240 MW) by S/C LILO of 400 kV D/C (Twin Moose) line from 400/220 kV, 2 x315 MVA, Lahal Sub-Station to 400/220 kV Chamera P.S. of PGCIL at Rajera. HPPTCL further intimated that JSW had started the work of Kutehr HEP. However, as JSW was not represented in the meeting, no decision regarding change in connectivity could be finalized in the meeting.

I/16394/2021

- (iii) Representative of JSW submitted that they have no issue with revised connectivity at 400kV by S/c LILO of 400 kV D/c (Twin Moose) Lahal to Chamera line of HPPTCL and the revised connectivity has already been issued by HPPTCL.
- (iv) Director, CEA further highlighted that there is an issue of high voltage in the area which has also been raised by POSOCO, for which HPPTCL had been requested to explore the possibility of installation of bus reactor at Lahal substation
- (v) Representative of HPPTCL stated that there is space constraint as well as transportation issue for bus reactor installation at Lahal substation and therefore, they have proposed installation of bus reactor at Kutehr substation. CEA stated that the issue of transportation can be handled by considering single phase units of reactors instead of three phase units.
- (vi) JSW stated that considering the small length of the line between Kutehr to Lahal, no reactor was envisaged at Kutehr and as such no provision of reactor has been kept at their switchyard. Further, considering the space constraints, it would not be possible to install any reactor.
- (vii) CTU stated that this kind of issue of non- availability of space for installation of reactors at substations has been witnessed in many instances and same needs to be addressed as it is very crucial for stability of the grid. CTU further suggested that for safety of switchyard equipment and as per system requirement, reactor is mandatorily required in the complex. This would help in limiting damages to the equipments due to High Voltage. On a query from CTU regarding the beneficiary of the power from Kutehr HEP, JSW representative clarified that power from Kutehr HEP would be exported outside HP. CTU stated that in that case, though connectivity of Kutehr HEP has been issued by HPPTCL, JSW needs to apply to CTU for LTA. JSW agreed for the same.
- (viii) Regarding issue of space constraint for installation reactor at Lahal/ Kutehr substations, CTU and POSOCO suggested that a site visit may be carried out to explore the feasibility of installing reactor at Lahal/ Kutehr substations.
- (ix) After deliberations, following was agreed:
- Kutehr HEP (240 MW) will be connected to the grid through LILO of one circuit of 400 kV D/C (Twin Moose) line from Lahal Sub-Station to Chamera (Rajera) Pooling station.
 - JSW to apply for LTA to CTU for evacuation of power from Kutehr HEP (240 MW).
 - A site visit to be carried out at Lahal and Kutehr substations to explore the feasibility of installing bus reactor at either Lahal or Kutehr substation.

3: Evacuation arrangement for Bajoli Holi HEP (180 MW)

- (i) Director (PSPA-I), CEA, stated that the transmission system for evacuation of power of Bajoli Holi HEP comprises of following elements under implementation by HPPTCL:
- 33/220/400 kV GIS substation at Lahal
 - 220 kV D/c line (Twin Moose) from Bajoli Holi HEP to 33/220/400 kV Lahal substation.
 - Lahal- Chamera PS (PGCIL) 400 kV D/c line

I/16394/2021

HPPTCL has intimated that Lahal substation has been commissioned, 220 kV Bajoli Holi HEP- Lahal D/c line is nearing completion and would be commissioned in the matching timeframe of Bajoli Holi HEP whereas Lahal- Chamera 400 kV D/c line is delayed.

She further stated that GMR vide its letter dated 09.06.2021 has intimated that Bajoli Holi HEP is in advanced stage of construction with approx. 98% work completed and is expected to be commissioned in August 2021. In view of the delay of Lahal- Chamera 400 kV D/c line, GMR has requested for an interim arrangement for power evacuation through Lahal- Budhil- Chamera III- Chamera PS 220 kV line, till the commissioning of Lahal- Chamera 400 kV D/c line.

- (ii) Director (PSPA-I), CEA, further stated that earlier HPPTCL had requested for evacuation of 24 MW power from small HEPs which are getting connected at Lahal substation and they are also proposed to be evacuated through Lahal- Budhil- Chamera III- Chamera PS 220 kV line as an interim arrangement till the commissioning of Lahal- Chamera 400 kV D/c line. System studies have been carried out considering the 24 MW power from small HEPs and 2 units of Bajoli Holi HEPs (60 MW each) getting connected at Lahal substation can be evacuated till commissioning of Lahal- Chamera 400 kV D/c line through following existing lines with implementation of SPS at Bajoli Holi HEP:
- Lahal- Budhil 220 kV S/c line
 - Budhil- Chamera III 220 kV S/c line
 - Chamera III- Chamera PS 220 kV D/c line
- (iii) CTU enquired the revised schedule of Lahal- Chamera 400 kV D/c line which was intimated by HPPTCL as December 2021.
- (iv) Chief Engineer (PSPA-I), CEA, stated that following constraints are observed in the proposed interim arrangement:
- Budhil to Chamera III line is a 220 kV S/c line and the total power that is being planned to be evacuated through this line would be 274 MW (180 MW of Bajoli Holi HEP, 24 MW of small HEPs at Lahal substation and 70 MW of Budhil HEP), which exceeds the capacity of the line.
 - N-1 contingency issue of 400/220 kV ICTs at Chamera PS.

Chief Engineer (PSPA-1) suggested that to address the above issues, the generation from Bajoli Holi HEP and small HEPs connected at Lahal substation would need to be restricted.

- (v) Greenko stated that Budhil- Chamera III 220 kV S/c line is a dedicated line of Greenko and loading capacity of the line is 180 MW only. Further, since Budhil has LTA for supplying its full capacity to Uttarakhand, it should have the first priority for evacuation through the constrained corridor. There is a need for SPS to ensure that under n-1 contingency of 400/220 kV ICT at Chamera PS, Budhil generation can be safely evacuated. Also, as Budhil- Chamera III 220 kV S/c line is under regulation of UERC, HPPTCL needs to file petition in UERC for the quantum of power planned to be evacuated through this path. At present, UERC has agreed for evacuation of 26 MW SHEP from Lahal till Sep'2021.
- (vi) NRLDC stated that total injection from 220kV side of the 2x315MVA ICTs at Chamera PS would be nearly 650MW under full generation in the complex and accordingly SPS

I/16394/2021

would need to be revised. NRLDC further requested HPPTCL to expedite the Lahal-Chamera 400 kV D/c line.

- (vii) CTU suggested that many small HEPs are coming up in the area. Therefore, keeping in the view the difficulty in implementation of EHV corridors, option to disperse the power from small HEPs at distribution level may be explored by HPPTCL and HPSEBL.
- (viii) GMR representative requested for allowing evacuation of 180 MW power from their hydro plant if margin is available for evacuation through this path, for only 4 hours a day during the lean hydro period till the commissioning of 400 kV Lahal-Chamera PS line. It was informed that these operational issues need to be decided in real time by the load dispatcher, depending on the dispatch of Budhil HEP and Chamera-III HEP, and the available margin.
- (ix) After deliberations, following was agreed:
 - a. Evacuation of power from Bajoli Holi HEP may be allowed only with SPS through Lahal- Budhil- Chamera III- Chamera PS 220 kV line as an interim arrangement till the commissioning of Lahal- Chamera 400 kV D/c line Also, first priority of power evacuation through the existing lines is of Budhil HEP and Chamera III HEP. It is worth mentioning that the Budhil- Chamera III 220 kV S/c line is a dedicated line of Greenko for Budhil HEP.
 - b. Injection of power from Bajoli Holi HEP and small hydro stations connected at Lahal should be such that it does not overload the 220kV S/c line from Budhil to Chamera –III HEP considering the injection of power from Budhil HEP. In case of outage of one ICT at Chamera Pooling Station, the generation projects connected at Lahal need to be backed down.
 - c. HPPTCL needs to file petition in UERC for the quantum of power planned to be evacuated through this path.

4: Evacuation arrangement for small hydro projects in Himachal Pradesh:

- (i) Director (PSPA-I), CEA, stated that HPPTCL vide letter dated 09.6.2021 has proposed some interim arrangement for evacuation of 51 MW power from small HEPs in Bharmour Valley in Rabi Basin of Himachal Pradesh. The original system planned for evacuation of 51 MW power from small HEPs in Bharmour Valley is through Heiling substation of HPPTCL which is to be implemented through LILO of one circuit of 220 kV Bajoli Holi HEP- Lahal D/c line.
- (ii) Director (PSPA-I) further stated that HPPTCL has intimated that at present, 24 MW of small HEPs have been commissioned. However, Heiling substation is delayed, due to which, the power from small HEPs are being evacuated through 33 kV lines of HPSEBL at Lahal with constraints. As full power of Bajoli Holi HEP can be evacuated only after commissioning of Lahal- Chamera 400 kV D/c line, HPPTCL has proposed to charge one circuit of 220 kV Bajoli Holi – Lahal D/c line at 33 kV level which shall be utilized for evacuation of small HEPS and power of Bajoli Holi HEP shall be evacuated through 2nd circuit of the line. In the event of outage of this circuit, solid tap at 1st circuit charged at 33 kV shall be removed and this circuit shall be charged at 220 kV to take care of N-1 contingency of Bajoli Holi HEP. This interim arrangement is proposed till the commissioning of Heiling substation, the revised schedule of which is December 2022.

I/16394/2021

- (iii) CTU stated that in case of contingency in 2nd circuit from Bajoli Holi HEP to Lahal, changing taps at 1st circuit charged at 33 kV to charge at 220 kV would take some time and the system cannot be termed as N-1 compliant.
- (iv) GMR stated that as the interim arrangement is proposed beyond the commissioning of Lahal- Chamera 400 kV D/c line till the commissioning of Heiling substation, in case of any contingency in the line, the arrangement to change the voltage level of 1st circuit from 33 kV to 220 kV would take time and as a result considerable generation loss of their HEP could occur. Therefore, they need to consult their top management to take decision on the issue.
- (v) After deliberations, it was decided that GMR would discuss the interim arrangement proposed by HPPTCL for evacuation of 51 MW power from small HEPs in Bharmour Valley with their management and convey the decision to CEA and HPPTCL.

Meeting ended with the thanks to the chair.

Annexure I

List of participants:

| S.No. | Name | Designation |
|---|-------------------------|------------------|
| CEA | | |
| 1 | Ishan Sharan | Chief Engineer |
| 2 | Manjari Chaturvedi | Director |
| 3 | Nitin Deswal | Asst. Director |
| 4 | Kanhaiya Singh Kushwaha | Asst. Director |
| CTUIL | | |
| 5 | Ashok Pal | CGM |
| 6 | Kashish Bhambhani | SR DGM |
| 7 | Ankita Singh | Chief Manager |
| POSO | | |
| 8 | Alok Kumar | GM, NRLDC |
| 9 | Gaurav Malviya | DM, NRLDC |
| POWERGRID | | |
| 10 | Tarun Bajaj | CGM |
| HPPTCL | | |
| 11 | Ranvir Singh Jalta | MD |
| HPSEBL | | |
| 12 | R. K. Sharma | MD |
| AD Hydro | | |
| 13 | Sumit Garg | SGM |
| JSW | | |
| 14 | Pritpal Singh | Sr. Manager |
| Greenko Budhil Hydro Power Private Limited | | |
| 15 | Y K Sehgal | ED |
| GMR Bajoli Holi | | |
| 16 | Gopendra Saraswat | Head Tr. Project |



HP POWER
TRANSMISSION
CORPORATION
LIMITED

ANNEXURE-A

Parikshit Pal <dmprojects2@hpptcl.in>

Annexure-A.V

Fwd: Interim evacuation arrangements for evacuation of 26 MW Small HEPs through 220 kV Lahal-Budhil S/C line of Greenko in Himachal Pradesh-Regarding

Vijay Singh <gmprojects@hpptcl.in>
To: Parikshit Pal <dmprojects2@hpptcl.in>

Mon, Oct 18, 2021 at 1:39 PM

----- Forwarded message -----

From: **Vipan Pal Singh** <md@hpptcl.in>

Date: Mon, Jun 29, 2020 at 11:14 AM

Subject: Fwd: Interim evacuation arrangements for evacuation of 26 MW Small HEPs through 220 kV Lahal-Budhil S/C line of Greenko in Himachal Pradesh-Regarding

To: Madan Lal Sharma <dgmchamba@hpptcl.in>, Rajinder Sharma <dgmdesign@hpptcl.in>, Bhupesh Uppal <gmprojects@hpptcl.in>

----- Forwarded message -----

From: **Alok Kumar (आलोक कुमार)** <alok.kumar@posoco.in>

Date: Mon, 29 Jun 2020 at 11:07

Subject: RE: Interim evacuation arrangements for evacuation of 26 MW Small HEPs through 220 kV Lahal-Budhil S/C line of Greenko in Himachal Pradesh-Regarding

To: Sandeep Kumar Sharma <gmcd@hpptcl.in>, goutamroy.cea@nic.in <goutamroy.cea@nic.in>, mkhanna@powergridindia.com <mkhanna@powergridindia.com>

Cc: Vipan Pal Singh <md@hpptcl.in>, Keshav Singh Attri <directorpc@hpptcl.in>, Gaurav Malviya (गौरव मालवीय) <gauravmalviya@posoco.in>, S. S. Barpanda (एस. एस. बरपंडा) <ssbarpanda@posoco.in>, N Nallarasani (एन नल्लारासन) <nallarasani@posoco.in>, Manoj Kumar Agarwal (मनोज कुमार अग्रवाल) <mkagarwal@posoco.in>, M M Hassan (एम एम हसन) <mm.hassan@posoco.in>, H K Chawla (एच के चावला) <hkchawla@posoco.in>, Nitin Yadav (नितिन यादव) <nitinyadav@posoco.in>, ms-nrpc@nic.in <ms-nrpc@nic.in>, seo-nrpc@nic.in <seo-nrpc@nic.in>

Sir

Please find attached inputs of NRLDC regarding SPS.

With Regards

Alok Kumar
Sr.DGM, NRLDC
09999039321

From: Sandeep Kumar Sharma [gmcd@hpptcl.in]

Sent: Saturday, June 27, 2020 12:23 PM

To: H K Chawla (एच के चावला); Manoj Kumar Agarwal (मनोज कुमार अग्रवाल); Alok Kumar (आलोक कुमार); Nitin Yadav (नितिन यादव); goutamroy.cea@nic.in; mkhanna@powergridindia.com

Cc: Vipan Pal Singh; Keshav Singh Attri

Subject: Interim evacuation arrangements for evacuation of 26 MW Small HEPs through 220 kV Lahal-Budhil S/C line of Greenko in Himachal Pradesh-Regarding

Sir,

PFA HPPTCL letter dated 27.6.2020 along with enclosures on the subject matter for information and necessary action plz.

Regards

GM (C & D)
HPPTCL, Shimla

* This e-mail is an official email of Power System Operation Corporation Ltd (POSOCO), is confidential and intended to use by the addressee only. If the message is received by anyone other than the addressee, please return the

message to the sender by replying to it and then delete the message from your computer. Internet e-mails are not necessarily secure. The Power System Operation Corporation Ltd.(POSOCO) does not accept responsibility for changes made to this message after it was sent. Whilst all reasonable care has been taken to avoid the transmission of viruses, it is the responsibility of the recipient to ensure that the onward transmission, opening or use of this message and any attachments will not adversely affect its systems or data. No responsibility is accepted by the POSOCO in this regard and the recipient should carry out such virus and other checks as it considers appropriate. Visit our website at www.posoco.in *

--

MD HPPTCL
SHIMLA

--

Thanks & Regards

(Er. Vijay Singh Thakur)
General Manager (Projects),
HPPTCL, Himfed Bhawan, Panjari,
Shimla-, 171005.



NRLDC input Lahal SPS_Final.docx
131K

NRLDC input for SPS logic to be implemented by HP (Himachal Pradesh) for evacuation of small hydro generation from 220 kV Lahal-Budhil-Chamera3-Chamba section


In the complex of Chamera-III HEP, Budhil HEP and Chamba pooling station, existing generation and transformation capacity is as below:

1. Chamera-3 HEP: 3 units of 77 MW, total 254 MW including 10% overload
2. Budhil HEP: 2 units of 35 MW, total 77 MW including 10% overload
3. Karian SHEP: 34 MW capacity (directly connected at Chamba)
4. Chamba station: 2*315 MVA 400/220 kV ICTs

Additional Generation to be allowed:

5. SHEP at Lahal: 26 MW capacity (Allowed on opportunity basis)

SPS logic submitted by HP (Himachal Pradesh) is as below:



In this logic condition 1 "transformer loading more than 65%" is not required. Only second logic of tripping of feeders in case of ICTs loading more than 90% of its capacity on any of the transformers will suffice for taking care of transformers loading.

Apart from above, logic of line loading of 220 kV Chamba (Chamera Pool)-Chamera 3 ckt-1 (healthy ckt on ERS tower) more than 360MVA also to be added in this SPS scheme.

Tripping of 220 kV Budhil-Lahal ckt at both end needs to be planned instead of 33 kV feeders as it may be resulted into some additional time delay in final tripping.

Final Logic can be devised like:

Condition A. Loading on 400/220 kV 315 MVA ICT1 more than 408A (90% of 454 A full load current at 400 kV side of ICT-1) for 2 seconds

OR Logic

Condition B. Loading on 400/220 kV 315 MVA ICT2 more than 408A (90% of 454 A full load current at 400 kV side of ICT-2) for 2 seconds


(Output of above two conditions- **C**)

Condition D. Loading on 220 kV Chamera3-Chamba ckt-1 more than 360 MW for 1.5 seconds than output is **E**

On the basis of outcome **C=1**: Tripping of 220 kV Chamba-Karian ckt at Chamba (Chamera pooling station) end (34 MW Generation will be tripped at Karian)

If **C=1** Logical OR **E=1** than output is **F=1**

On the basis of outcome **F=1**: Tripping of 220 kV Budhil-Lahal ckt from both ends (26 MW Generation will be tripped at Lahal)



Other points for consideration:

- SPS tripping shall be achieved within 100ms of SPS initiation.
- As approved in earlier NRPC meeting, Any New SPS scheme is being implemented than its signal shall be wired in station SoE (Sequence of Event recorder) or SAS based event logger. Accordingly, SPS signal shall be wired at Chamba (Chamera pooling station) station SoE, Budhil HEP station SoE and Lahal station SoE. In case of actual operation these details shall be shared with NRPC/ NRLDC
- SPS will be reviewed after charging of 220 kV Chamera3-Chamba ckt-2 and removal of ERS tower in 220 kV Chamera3-Chamba ckt-1. In that case, only condition D (line loading) could be removed but SPS for Chamba ICTs need to continue till installation of 3rd ICT at Chamba station.
- Any modification in SPS scheme shall be approved in OCC/NRPC meeting.
- Power evacuation shall only be allowed after successful implementation of SPS scheme along with mock trial operation.



HIMACHAL PRADESH POWER TRANSMISSION CORPORATION
(A State Govt. under taking)

HPPTCL PIU, Chamba, Distt. Chamba (H.P.)-176318. Tel. /Fax no.01899-220830
Head Office: -HPPTCL, Himfed Bhawan Shimla-171005, www.hpptcl.gov.in

Dated: 08.07.2020

**(Detailed Report regarding providing special protection scheme
implementation and testing thereof.)**

As per the minutes of meeting held on Dated. 03.01.2020 with CEA under the chairmanship of Chief Engineer (PSPA1), wherein it was decided that HPPTCL shall implement SPS (Special protection scheme) to avoid overloading of ICTS (400/220 kV 2x 315 MVA) installed at 400/220 Chamera III Pooling s/station (PGCIL). In response, it is intimated that final modified/approved special protection scheme by NRLDC and duly vetted by Chief General Manager (AM) PGCIL Jammu has been successfully tested and implemented at the PGCIL Chamera III pooling station.

The scheme envisages the following provisions:

- I. If the load/current of ICT1 or ICT2 or both exceeds 90% of full load i.e. 744 amps of 315 MVA, 220 kV S/C Lahal Budhil transmission line as well as 220 kV S/C Karian-Rajera transmission line shall be tripped as per approved logic.
- II. If the current of 220 kV Chamera III-PGCIL Rajera transmission line Ckt I exceeds 942 amps corresponding to 360 MW load, the CB's of both ends of 220 kV S/C Lahal Budhil transmission line shall trip.

The sequence wise testing carried out on dated 8.07.2020 after taking necessary testing code from NRLDC and observing all the codal formalities is discussed below:

- 1) The trip signal was temporarily made high by reducing the setting in ICT-1 BCU with time delay of 2 seconds. This signal was transmitted from power grid end and received at Lahal and Budhil end relays causing the tripping of relays provided at both ends. As far as 220 kV S/C Karian Rajera transmission line is concerned signal was only checked but no real tripping was issued.
- 2) The same procedure was adopted for generating direct trip in respect of load exceeding in ICT-2 also.
- 3) The signal from REL670 relay provided at PGCIL end of 220 kV Chamera III –PGCIL Line Ckt-1 was made high by temporarily reducing settings. The tripping signal so generated tripped the relays of both ends of 220 kV Lahal Budhil transmission line. The time of issuance and receiving/tripping of the relays at Lahal/Budhil line ends are under:

Issuance time:

12.59.21.578

Receiving/tripping time at Lahal/Budhil

12.59.21.657

The PLCC transmit/receive i.e. Tx/Rx Chart showing the initial counter readings and subsequent counter readings, consequent upon the testing is also enclosed for ready reference. From the perusal of this chart, it is evident that there is no cross interference of the intended signal to be received at Budhil via Chamera III HEP PLCC cabinets/panels.

The testing sequence is supported by DR (Disturbance record) of PGCIL Chamera III pooling station and HPPTCL 400/220/33 kV GIS S/station Lahal.

From the ongoing discussions it is certified that all the intended conditions have been met and tested accordingly.

PLCC Counter Record

Budhil (At Chamera End)

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After Load testing | |
|------|----------------|----|---------------------|----|---------------------|----|--------------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 49 | 28 | 49 | 28 | 49 | 28 | 49 | 28 |
| B | 49 | 69 | 49 | 69 | 49 | 69 | 49 | 69 |
| C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| D | 1 | 0 | 2 | 0 | 3 | 0 | 4 | 0 |

220 KV Chamera Line-1 at Chamera end

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After testing-3 | |
|------|----------------|----|---------------------|----|---------------------|----|-----------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 0 | 27 | 0 | 27 | 0 | 27 | 0 | 27 |
| B | 0 | 15 | 0 | 15 | 0 | 15 | 0 | 15 |
| C | 12 | 69 | 12 | 69 | 12 | 69 | 12 | 69 |
| D | 13 | 34 | 13 | 34 | 13 | 34 | 13 | 34 |

220 Kv Chamera Line-2 at Chamera end

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After Load testing | |
|------|----------------|----|---------------------|----|---------------------|----|--------------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 0 | 22 | 0 | 22 | 0 | 22 | 0 | 22 |
| B | 0 | 3 | 0 | 3 | 0 | 3 | 0 | 3 |
| C | 13 | 35 | 13 | 35 | 13 | 35 | 13 | 35 |
| D | 4 | 9 | 4 | 10 | 4 | 11 | 4 | 12 |

AT Budhil HEP

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After Load testing | |
|------|----------------|----|---------------------|----|---------------------|----|--------------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 26 | 42 | 26 | 42 | 26 | 42 | 26 | 42 |
| B | 77 | 42 | 77 | 42 | 77 | 42 | 77 | 42 |
| C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| D | 0 | 0 | 0 | 1 | 0 | 2 | 0 | 3 |

Disturbance Short Report

Disturbance Recordings Information

Device Information

| | |
|--------------|---------------|
| Recorder ID | 1 |
| IED type | REL670 |
| IED version | 1p1r25 |
| Station name | GIS CHAMBA |
| Object name | 220 KV LINE-1 |
| IED name | Unit name |

Fault Information

| | |
|--------------------------|--------------------------|
| Trig date and time | 7/8/2020 12:59:20.066 PM |
| Trigger signal name | SPS_TRIP_STAR |
| Recording number | 172 |
| Total recording time | 4499 ms |
| Pre-trig recording time | 500 ms |
| Post trig recording time | 0 ms |
| Max. recording time | 4000 ms |

General Recordings Information


| | |
|---------------------------------------|-----------|
| Disturbance recorder | Installed |
| Event recorder | Installed |
| System frequency | 50 Hz |
| Sampling frequency | 1 kHz |
| Active setting group during recording | 1 |

Fault Location Information

| | |
|-----------------------------|----------------|
| Fault loop type | Not applicable |
| Fault location | Not applicable |
| Status of fault calculation | Not applicable |
| Fault direction | Not applicable |

Analog Time Diagram


Trig Date Time: 7/8/2020 12:59:20.066 PM





Binary Time Diagram


Trig Date Time: 7/8/2020 12:59:20.066 PM




Vector Diagrams

Calculation Time Period : 0 ms to 19 ms

Currents



Voltages



| No. | Name | RMS | Angle | No. | Name | RMS | Angle |
|-----|--------------|-------------|--------|-----|--------|----------------|--------|
| 1 | I-R PH | 1106.364(A) | 38.7° | 1 | V-R PH | 181691.188 (V) | 341.6° |
| 2 | I-Y PH | 1115.379(A) | 63.4° | 2 | V-Y PH | 182229.297 (V) | 306.9° |
| 3 | I-B PH | 1133.409(A) | 114.9° | 3 | V-B PH | 181927.641 (V) | 318.4° |
| 4 | I-N PH | 39.453(A) | 63.4° | 4 | V-N | 6176.001(V) | 4.9° |
| 5 | //LINE M CTN | 5.556(A) | 200.9° | | | | |

Events List

| Channel Number | Name | Status | Time |
|----------------|---------------|--------|--------------------------|
| 35 | SPS_TRIP_STAR | On | 7/8/2020 12:59:20.066 PM |
| 30 | SPS_TRIP_LAHA | On | 7/8/2020 12:59:21.578 PM |

Printed by Server on 2020-07-08 16:09:21

| Date | Orign | Description | Message | Support Quality | Command Origin | Gravity |
|-------------------------|--|---------------------------|----------------------|---------------------|----------------|---------|
| 2020-07-08 12:39:38.490 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | 08A TRIP RELAY | RESET | Valid | | 0 |
| 2020-07-08 12:39:38.490 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | 08A TRIP | RESET | Valid | | 2 |
| 2020-07-08 12:39:38.489 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_GOOSE | 08A TRIP RELAY | RESET | Valid | | 2 |
| 2020-07-08 12:39:38.391 | LAHAL / 220KV / 206 BUDHIL LINE1 / PROTECTION | 08A TRIP RELAY | ORDER SENT RESET | Valid | OISERVN | 0 |
| 2020-07-08 12:39:00.906 | SUPERVISION / HMI / OISERVN | STATUS | a ACKNOWLEDGED ALL | Valid | OISERVN | 0 |
| 2020-07-08 12:38:56.065 | SUPERVISION / HMI / OISERVN | STATUS | a CLEARED ALL ALARMS | Valid | OISERVN | 0 |
| 2020-07-08 12:38:50.872 | SUPERVISION / HMI / OISERVN | STATUS | a LOGGED IN | Valid | OISERVN | 0 |
| 2020-07-08 12:35:29.264 | LAHAL / SWITCH / EFS-A1 / PS | Port 04 Status | Connected | Valid | | 0 |
| 2020-07-08 12:35:53.392 | LAHAL / SWITCH / EFS-A1 / PS | Port 04 Status | Disconnected | Valid | | 1 |
| 2020-07-08 12:35:36.061 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 1 |
| 2020-07-08 12:35:17.009 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | | | 1 |
| 2020-07-08 12:35:01.146 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 1 |
| 2020-07-08 12:34:42.103 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:34:03.922 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:33:44.825 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:27:19.517 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 1 |
| 2020-07-08 12:25:51.228 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:25:38.805 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 1 |
| 2020-07-08 12:25:15.535 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:22:27.009 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 1 |
| 2020-07-08 12:22:10.518 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | CB R PH OPEN | RESET | Valid | | 0 |
| 2020-07-08 12:22:10.518 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | MAIN-2 PROTECTION | RESET | Valid | | 0 |
| 2020-07-08 12:22:10.515 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | DIRECT TRIP SP8 FROM 21M1 | NOT RECEIVED | Valid | | 0 |
| 2020-07-08 12:22:10.496 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | DIRECT TRIP SP8 FROM 21M2 | NOT RECEIVED | Valid | | 0 |
| 2020-07-08 12:22:07.974 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:22:07.864 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | CB R PH OPEN | SET | Valid | | 1 |
| 2020-07-08 12:22:07.858 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | MAIN-2 PROTECTION | OPERATED | Valid | | 1 |
| 2020-07-08 12:22:07.858 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | DIRECT TRIP SP8 FROM 21M1 | RECEIVED | Valid | | 1 |
| 2020-07-08 12:22:07.858 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | DIRECT TRIP SP8 FROM 21M2 | RECEIVED | Valid | | 1 |
| 2020-07-08 12:20:51.861 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 1 |
| 2020-07-08 12:19:42.799 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:19:40.567 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | OISERVN | 1 |
| 2020-07-08 12:18:49.875 | LAHAL / SWITCH / EFS-A1 / PS | Port 04 Status | Connected | Valid | OISERVN | 0 |
| 2020-07-08 12:18:36.481 | LAHAL / SWITCH / EFS-A1 / PS | Port 04 Status | Connected | Valid | | 0 |
| 2020-07-08 12:18:23.967 | LAHAL / SWITCH / EFS-A1 / PS | Port 04 Status | Connected | Valid | | 0 |
| 2020-07-08 12:18:00.793 | LAHAL / SWITCH / EFS-A1 / PS | Port 04 Status | Disconnected | Valid | | 0 |
| 2020-07-08 12:16:50.637 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | CONNECTED | Valid | OISERVN | 0 |
| 2020-07-08 12:16:38.006 | LAHAL / 220KV / 206 BUDHIL LINE1 / METERING_TVM1 | R-PHASE VOLTAGE | Normal 127.023378 | OldData | | 0 |
| 2020-07-08 12:16:19.004 | SBUS / BCU206 / MODOU / SECURE_M / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | | 0 |
| 2020-07-08 12:15:18.774 | LAHAL / 220KV / 206 BUDHIL LINE1 / METERING_TVM1 | R-PHASE VOLTAGE | Normal 127.015848 | OldData | | 0 |
| 2020-07-08 12:15:16.189 | SBUS / BCU206 / MODOU / SECURE_M / DEVICE LINK | DEVICE LINK | DISCONNECTED | Valid | | 0 |
| 2020-07-08 12:15:14.822 | LAHAL / AUXILIARY / AUXILIAR BCU3 / MBB-1A BC | BUS COUPLER OFF | SET | Valid | | 1 |
| 2020-07-08 12:15:14.820 | LAHAL / AUXILIARY / AUXILIAR BCU3 / MBB-1A BC | BUS COUPLER ON | RESET | Valid | | 1 |
| 2020-07-08 12:15:14.816 | LAHAL / 220KV / 206 BUDHIL LINE1 / METERING_TVM1 | Y PHASE VOLTAGE | LowLowLow0 | Valid (Low,Low,Low) | | 0 |
| 2020-07-08 12:15:14.816 | LAHAL / AUXILIARY / AUXILIAR BCU3 / MBB-1A VC-2 | INCOMER-2 OFF | SET | Valid | | 0 |
| 2020-07-08 12:15:14.812 | LAHAL / AUXILIARY / AUXILIAR BCU3 / MBB-1A VC-2 | INCOMER-2 ON | RESET | Valid | | 0 |
| 2020-07-08 12:15:14.810 | LAHAL / AUXILIARY / AUXILIAR BCU3 / MBB-1A VC-2 | BIG BREAKER CLOSS | SET | Valid | | 0 |
| 2020-07-08 12:15:14.805 | LAHAL / AUXILIARY / AUXILIAR BCU3 / AMP PANEL | MAIN-1 BREAKER OFF | SET | Valid | | 0 |
| 2020-07-08 12:15:14.805 | LAHAL / AUXILIARY / AUXILIAR BCU3 / AMP PANEL | BIG BREAKER OPEN | RESET | Valid | | 0 |
| 2020-07-08 12:15:14.805 | LAHAL / AUXILIARY / AUXILIAR BCU3 / AMP PANEL | MAIN-1 BREAKER ON | RESET | Valid | | 0 |
| 2020-07-08 12:15:14.805 | LAHAL / AUXILIARY / AUXILIAR BCU3 / AMP PANEL | BATTERY CHARGER-2 OFF | RESET | Valid | | 0 |
| 2020-07-08 12:15:14.805 | LAHAL / AUXILIARY / AUXILIAR BCU3 / AMP PANEL | BATTERY CHARGER-2 ON | RESET | Valid | | 0 |

Event List

Printed by Server on 2020-07-08 16:09:21

| Date | Origin | Description | Message | Signal Quality | Command Origin | Group |
|------------------------------------|---|---------------------------------------|---------------------|----------------|----------------|-------|
| 2020-07-08 12:00:24.936 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | 86A TRIP RELAY | OPERATED | and | | |
| 2020-07-08 12:00:24.936 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | 86A TRIP | OPERATED | and | | |
| 2020-07-08 12:00:24.937 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_GOOSE | 86A TRIP RELAY | OPERATED | and | | |
| 2020-07-08 12:00:24.923 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | 86A TRIP RELAY SUPERVISION | FAULTY | and | | |
| 2020-07-08 12:00:24.923 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | MAIN-2 PROTECTION | OPERATED | and | | |
| 2020-07-08 12:00:24.921 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | 86B TRIP RELAY | OPERATED | and | | |
| 2020-07-08 12:00:24.921 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | CB R PH OPEN | SET | and | | |
| 2020-07-08 12:00:24.918 | LAHAL / 220KV / 206 BUDHIL LINE1 / A/R MANUAL | A/R BLOCK | SET | and | | |
| 2020-07-08 12:00:24.917 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M1_SYST | 86B TRIP RELAY SUPERVISION | RECEIVED | and | | |
| 2020-07-08 12:00:24.909 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | 86B TRIP RELAY SUPERVISION | FAULTY | and | | |
| 2020-07-08 12:00:24.909 | LAHAL / 220KV / 206 BUDHIL LINE1 / 21M2_SYST | 86B TRIP RELAY SUPERVISION | RECEIVED | and | | |
| 2020-07-08 11:58:56.222 | SBUS / BCU404 / DEVICE LINK | DEVICE LINK | DISCONNECTED | and | DISCON | |

HIMACHAL PRADESH POWER TRANSMISSION CORPORATION LTD
 (A State Govt. under taking)
 HPPTCL PIU LAHAL -176809 E-mail-smlahal@hpptcl.in

No: HPPTCL/DGM-4/2020-21-411
 To

Dated: 02/07/2020

The GM (E),
 NHPC, Chamera-III
 Chamba.

Subject: Energisation of 220kV & 33kV GIS a/w 220/33kV, 63.5 MVA T/F on No load at 400/220/33kV GIS S/Stn at Lahal (relay coordination parameter).

Sir,

With reference to the subject cited matter, it is informed that HPPTCL intends to charge 220kV & 33kV GIS a/w 220/33kV, 63.5MVA transformer on No Load at 400/220/33kV GIS S/Stn Lahal. The transformer is being charged through 220kV Lahal Budhil transmission line. The relay settings (over-current and earth fault) of Lahal-Budhil line and Budhil Chamera line are studied and found that over-current setting of Budhil-Chamera line at Budhil end need to be revised.

The present and proposed relay settings are hereby mentioned as below:

| Ref | Present setting at lahal | | | Present setting at Budhil | Proposed setting for Budhil | Present setting at Chamera |
|------------------------------|---------------------------------|---------------------------------|--------------------------|---------------------------|-----------------------------|----------------------------|
| | Budhil Line Feeder Main-1 relay | Budhil Line Feeder Main-2 relay | 63.5MVA trafo -87T relay | | | |
| Diff. setting: | | | | | | |
| F Diff | Enabled | Enabled | Enabled | | | |
| 1 in P.U | 0.2 | 0.2 | 0.2 | | | |
| | 30% | 30% | 30% | | | |
| 2 in P.U | 1 | 1 | 1 | | | |
| | 150% | 80% | 70% | | | |
| ff | 0s | 0s | 0s | | | |
| Over current setting: | | | | | | |
| ratio | 1000/1A | 1000/1A | 300/1A | 1200/1A | 1200/1A | 1800/1A |
| er current | DISABLED | DISABLED | Enabled | Enabled | Enabled | |
| | NA | NA | 0.6 | 0.254 | 0.6A | 3A |
| ectionality | NA | NA | Directional-forward | Non-directional | Directional-forward | |



HIMACHAL PRADESH POWER TRANSMISSION CORPORATION LTD

(A State Govt. under taking)

HPPTCL PIU LAHAL -176309 E-mail-smlahal@hpptcl.in

| Curve | NA | NA | IDMT | DT | IDMT (SI) (Note:-if DT selected time delay must be minimum 1sec and 2nd stage will be disabled) | DT |
|------------------|----|----|-----------------|----|--|------|
| TMS / Time delay | NA | NA | 0.2 | 0 | 0.3 | 1.2s |
| I>2 | NA | NA | 4.69 | NA | 1.5A | NA |
| Directionality | NA | NA | Non-directional | NA | -- | |
| Curve | NA | NA | DT | NA | DT | |
| Time delay | NA | NA | 0s | NA | 100ms | |

Earth fault setting:

| IN>1 | 0.2A | 0.2A | 0.15A | 0.254A | 0.254A | 30.00% |
|------------------|---------------------|---------------------|---------------------|-----------------|-----------------|---------------------|
| Directionality | Directional-forward | Directional-forward | Directional-forward | Non-directional | Non-directional | Directional-forward |
| Curve | DT | DT | IDMT SI | DT | DT | DT |
| TMS / Time delay | 0 | 0 | 0.32 | 0s | 0.6s | 1s |
| IN>2 | DISABLED | DISABLED | 4.69A | NA | NA | NA |
| Curve | NA | NA | DT | NA | NA | |
| TMS / Time delay | NA | NA | 0s | NA | NA | |

It is therefore requested to kindly vet the relay coordination parameters at Budhil, and Chamera-III end with respect to lahal end settings . It is for your information and necessary action please.

Yours faithfully,

[Signature]
 AGM (Projects)
 HPPTCL Chamba Zone



HIMACHAL PRADESH POWER TRANSMISSION CORPORATION LTD
 (A State Govt. under taking)
 HPPTCL Chamba Zone, Chamba E-mail: dgmchamba@hpptcl.in

No: HPPTCL/CBA/DGM-09/2020-21-480-85

Dated: 13/07/2020

To

The Managing Director,
 HPSLDC, Govt of HP,
 SLDC Complex, Totu Shimla-11.

Subject: Relay Coordination of 220 kV Lahal-Budhil and 220 kV Budhil-Chamera Transmission Lines.

Sir,

With reference to the subject cited matter, it is informed that HPPTCL has charged 220/33kV GIS, 220/33kV 63.5MVA transformer a/w 33kV Bharmour Transmission line. The relay settings (over-current and earth fault) of Lahal-Budhil line and Budhil-Chamera line are studied and found that over-current setting of Budhil-Chamera line at Budhil end are set at lower side and need to be revised.

The present relay settings are hereby mentioned as below:

| Ref | Present setting at Lahal. | | | Present setting at Budhil | Present setting at Chamera |
|------------------------------|---------------------------------|---------------------------------|-------------------------|---------------------------|----------------------------|
| | Budhil Line Feeder Main-1 relay | Budhil Line Feeder Main-2 relay | 63.5MVA trafo-87T relay | | |
| Diff. setting: | | | | | |
| T/F Diff | Enabled | Enabled | Enabled | | |
| 1s1 in P.U | 0.2 | 0.2 | 0.2 | | |
| k1 | 30% | 30% | 30% | | |
| 1s2 in P.U | 1 | 1 | 1 | | |
| k2 | 150% | 80% | 70% | | |
| tdiff | 0s | 0s | 0s | | |
| Over current setting: | | | | | |
| CT ratio | 1000/1A | 1000/1A | 300/1A | 1200/1A | 1800/1A |
| Over current | DISABLED | DISABLED | Enabled | Enabled | |
| I>1 | NA | NA | 0.6 | 0.254 A | 3A |



HIMACHAL PRADESH POWER TRANSMISSION CORPORATION
(A State Govt. under taking)

HPPTCL PIU, Chamba, Distt. Chamba (H.P.)-176318. Tel./Fax no.01899-220830
Head Office: -HPPTCL, Himfed Bhawan Shimla-171005, www.hpptcl.gov.in

Dated: 08.07.2020

**(Detailed Report regarding providing special protection scheme
implementation and testing thereof.)**

As per the minutes of meeting held on Dated. 03.01.2020 with CEA under the chairmanship of Chief Engineer (PSPA1), wherein it was decided that HPPTCL shall implement SPS (Special protection scheme) to avoid overloading of ICTS (400/220 kV 2x 315 MVA) installed at 400/220 Chamera III Pooling s/station (PGCIL). In response, it is intimated that final modified/approved special protection scheme by NRLDC and duly vetted by Chief General Manager (AM) PGCIL Jammu has been successfully tested and implemented at the PGCIL Chamera III pooling station.

The scheme envisages the following provisions:

- I. If the load/current of ICT1 or ICT2 or both exceeds 90% of full load i.e. 744 amps of 315 MVA, 220 kV S/C Lahal Budhil transmission line as well as 220 kV S/C Karian-Rajera transmission line shall be tripped as per approved logic.
- II. If the current of 220 kV Chamera III-PGCIL Rajera transmission line Ckt I exceeds 942 amps corresponding to 360 MW load, the CB's of both ends of 220 kV S/C Lahal Budhil transmission line shall trip.

The sequence wise testing carried out on dated 8.07.2020 after taking necessary testing code from NRLDC and observing all the codal formalities is discussed below:

- 1) The trip signal was temporarily made high by reducing the setting in ICT-1 BCU with time delay of 2 seconds. This signal was transmitted from power grid end and received at Lahal and Budhil end relays causing the tripping of relays provided at both ends. As far as 220 kV S/C Karian Rajera transmission line is concerned signal was only checked but no real tripping was issued.
- 2) The same procedure was adopted for generating direct trip in respect of load exceeding in ICT-2 also.
- 3) The signal from REL670 relay provided at PGCIL end of 220 kV Chamera III -PGCIL Line Ckt-1 was made high by temporarily reducing settings. The tripping signal so generated tripped the relays of both ends of 220 kV Lahal Budhil transmission line. The time of issuance and receiving/tripping of the relays at Lahal/Budhil line ends are under



HIMACHAL PRADESH POWER TRANSMISSION CORPORATION LTD
 (A State Govt. under taking)

HPPTCL Chamba Zone, Chamba E-mail: demchamba@hpptcl.in

| | | | | | |
|-----------------------------|---------------------|---------------------|---------------------|-----------------|---------------------|
| Directionality | NA | NA | Directional-forward | Non-directional | |
| Curve | NA | NA | IDMT | DT | DT |
| TMS / Time delay | NA | NA | 0.2 | 0 | 1.2s |
| I>2 | NA | NA | 4.69 | NA | NA |
| Directionality | NA | NA | Non-directional | | |
| Curve | NA | NA | DT | | |
| Time delay | NA | NA | 0s | | |
| Earth fault setting: | | | | | |
| I>1 | 0.2A | 0.2A | 0.15A | 0.254A | 30.00% |
| Directionality | Directional-forward | Directional-forward | Directional-forward | Non-directional | Directional-forward |
| Curve | DT | DT | IDMT SI | DT | DT |
| TMS / Time delay | 0 | 0 | 0.32 | 0s | 1s |
| I>2 | DISABLED | DISABLED | 4.69A | NA | NA |
| Curve | NA | NA | DT | | |
| TMS / Time delay | NA | NA | 0s | | |

Whereas due to DT (zero lag) settings of relay at Budhil, the faults of 33 KV Feeder connected at Lahal Sub-Station may back travel and trip the breaker of Budhil-Chamera Line at Budhil. Today at 12:30 PM a severe over-current earth fault on 33 KV Bharmour Line 1 has tripped the breaker of 33 KV Line at Lahal Sub-Station and simultaneously breaker of Budhil-Chamera Line at Budhil GIS also got tripped.

This matter of relay coordination has been discussed by this office with Budhil HEP many times but could not succeeded to resolve the issue. Therefore, it is requested that necessary directions may be got issued to Budhil HEP to coordinate the relay settings to avoid disruptions in the system please.

Yours faithfully,

AGM (Projects)
 HPPTCL Chamba Zone

Issuance time:

12.59.21.578


Receiving/tripping time at Lahal/Budhil

12.59.21.657

The PLCC transmit/receive i.e. Tx/Rx Chart showing the initial counter readings and subsequent counter readings, consequent upon the testing is also enclosed for ready reference. From the perusal of this chart, it is evident that there is no cross interference of the intended signal to be received at Budhil via Chamera III HEP PLCC cabinets/panels.

The testing sequence is supported by DR (Disturbance record) of PGCIL Chamera III pooling station and HPPTCL 400/220/33 kV GIS S/station Lahal.

From the ongoing discussions it is certified that all the intended conditions have been met and tested accordingly.


(Er. M.L. Sharma)
Dy. Chief engineer/AGM (P)
HPPTCL Zone Chamba

Disturbance Short Report

Disturbance Recordings Information

Device Information

Recorder ID 1
IED type REL670
IED version 1p1r26
Station name GIS CHAMBA
Object name 220 KV LINE-1
IED name
Unit name

Fault Information

Trig date and time 7/8/2020 12:59:20.066 PM
Trigger signal name SPS_TRIP_STAR
Recording number 172
Total recording time 4499 ms
Pre-trig recording time 600 ms
Post trig recording time 0 ms
Max. recording time 4000 ms

General Recordings Information


Disturbance recorder Installed
Event recorder Installed
System frequency 50 Hz
Sampling frequency 1 kHz
Active setting group during recording 1

Fault Location Information

Fault loop type Not applicable
Fault location Not applicable
Status of fault calculation Not applicable
Fault direction Not applicable

Analog Time Diagram

Trig Date Time: 7/8/2020 12:59:20.066 PM



[Handwritten signature]


[Handwritten signature]
20/07/2020

[Handwritten signature]
08/07/2020



Binary Time Diagram


Trig Date Time: 7/8/2020 12:59:20.066 PM




Vector Diagrams

Calculation Time Period: 0 ms to 10 ms

Currents



Voltages



| No. | Name | RMS | Angle | No. | Name | RMS | Angle |
|-----|--------------|-------------|--------|-----|--------|----------------|--------|
| 1 | I-R PH | 1106.364(A) | 38.7° | 1 | V-R PH | 181691.188 (V) | 341.6° |
| 2 | I-Y PH | 1115.379(A) | 63.4° | 2 | V-Y PH | 182229.297 (V) | 306.9° |
| 3 | I-B PH | 1133.409(A) | 114.9° | 3 | V-B PH | 181927.641 (V) | 318.4° |
| 4 | I-N PH | 39.453(A) | 63.4° | 4 | V-N | 6176.001(V) | 4.9° |
| 5 | I/LINE M CTN | 5.556(A) | 200.9° | | | | |

Events List

| Channel Number | Name | Status | Time |
|----------------|---------------|--------|--------------------------|
| 35 | SPS_TRIP_STAR | On | 7/8/2020 12:59:20.066 PM |
| 30 | SPS_TRIP_LAHA | On | 7/8/2020 12:59:21.578 PM |

[Handwritten signature]

[Handwritten signature]
08/07/2020

[Handwritten signature]
08/07/2020
Dinesh Kumar
POWERGRID CHAMBA

PLCC Counter Record

Budhil (At Chamera End)

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After Load testing | |
|------|----------------|----|---------------------|----|---------------------|----|--------------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 49 | 28 | 49 | 28 | 49 | 28 | 49 | 28 |
| B | 49 | 69 | 49 | 69 | 49 | 69 | 49 | 69 |
| C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| D | 1 | 0 | 2 | 0 | 3 | 0 | 4 | 0 |

220 KV Chamera Line-1 at Chamera end

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After testing-3 | |
|------|----------------|----|---------------------|----|---------------------|----|-----------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 0 | 27 | 0 | 27 | 0 | 27 | 0 | 27 |
| B | 0 | 15 | 0 | 15 | 0 | 15 | 0 | 15 |
| C | 12 | 69 | 12 | 69 | 12 | 69 | 12 | 69 |
| D | 13 | 34 | 13 | 34 | 13 | 34 | 13 | 34 |

220 Kv Chamera Line-2 at Chamera end

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After Load testing | |
|------|----------------|----|---------------------|----|---------------------|----|--------------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 0 | 22 | 0 | 22 | 0 | 22 | 0 | 22 |
| B | 0 | 3 | 0 | 3 | 0 | 3 | 0 | 3 |
| C | 13 | 35 | 13 | 35 | 13 | 35 | 13 | 35 |
| D | 4 | 9 | 4 | 10 | 4 | 11 | 4 | 12 |

AT Budhil HEP

| | Before testing | | After ICT-1 testing | | After ICT-2 testing | | After Load testing | |
|------|----------------|----|---------------------|----|---------------------|----|--------------------|----|
| Code | Tx | Rx | Tx | Rx | Tx | Rx | Tx | Rx |
| A | 26 | 42 | 26 | 42 | 26 | 42 | 26 | 42 |
| B | 77 | 42 | 77 | 42 | 77 | 42 | 77 | 42 |
| C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| D | 0 | 0 | 0 | 1 | 0 | 2 | 0 | 3 |

[Handwritten signature]

[Handwritten signature]
 08/07/2020
 GAGANDEEP SHYAM
 A.M. POWER


[Handwritten signature]
 08/07/2020
 Dinash Kumar

ANNEXURE-B**PROPOSED MODIFICATION TO SPS SCHEME**

| Case | Contingency (Existing) | Contingency (Proposed to be modified) | Action (Existing) | Actions (Proposed to be Modified) |
|---|---|--|--|--|
| Case-1 (Modification) | Loading on either of 400/220 kV 315 MVA ICTs exceeds 408A (90% of 454 A full load current at 400 kV side of ICTs) for 2 seconds | -No Change- | <p>1. Trip of 220 kV S/C Chamba (Chamera pooling station)-Karian(HPPTCL) end</p> <p>2. Trip 220 kV S/c Budhil (Greenko)-Lahal(HPPTCL) TL</p> | <p>1. Trip 220 kV S/C Chamba (Chamera pooling station)-Karian (HPPTCL) end</p> <p>2. Trip all 3 Units of Bajoli-Holi HEP</p> <p>3. Trip all 33kV Feeders at Lahal Substation</p> <p>4. In case of failure of SPS action <u>2</u> within 100ms of initiation of SPS, Trip both circuits of 220kV Bajoli-Holi-Lahal TL</p> <p>5. In case of failure of SPS action <u>3</u> within 100ms of initiation of SPS, trip 220/33kV Transformer at Lahal</p> |
| Case-2 (Proposed to be removed) | Loading on 220 kV Chamera-III(NHPC)-Chamba(Chamera-Pooling) Ckt-I more than 360 MW for 1.5 seconds | Since the then deployed ERS on 220kV Chamera-III-Chamba TL has been removed and Twin Moose TL has been restored to its full capacity, this SPS case is not required and hence proposed to be removed - | 1. Trip 220 kV S/c Budhil (Greenko)-Lahal(HPPTCL) TL | -SPS case Proposed to be removed- |

SLD- LAHAL-BUDHIL-CHAMERA POWER EVACUATION SYSTEM (CHAMBA H.P.)

**60x3 MW Bajoli
Holi HEP**



LAHAL 220kV

10005
LAHAL




**35X 2 MW
BUDHIL HEP
220kV**

172000
UDHIL



**70X3 MW
CHAMERA-3**

72020
MER-3




KARIAN (HPPTCL) 220kV

1.04
228.1




**CHAMBA POOLING
220kV**



2014
POL



174004
CHAM-POL



1.00
220.0



LAHAL 400kV

400006
KUTEHAR




CHAMBA POOLIN

400kV



Draft Logic Scheme: Modification in SPS for reliable evacuation of power from 400/220kV Chamba (Chamera Pooling) to include Bajoli-Holi HEP:



Ref:- NI/AM/NRPC 2914

 Date :- 2nd November'2021

Member Secretary

 Northern Regional Power Committee
 18-A, Qutab Institutional Area
 Shaheed Jeet Singh Marg
 Katwaria Sarai
 New Delhi-110 016


Subject :- Outage of Transmission lines required for installation of Bird Diverters in 2nd phase as per requirement of NGT in POWERGRID, NRI

This has reference to 185th OCC meeting, wherein it was agreed that the outage to be availed of installation of bird diverters as per NGT requirement in following line shall be considered as deemed available.

- i) 765KV Ajmer – Bikaner
- ii) 765KV Bikaner – Moga
- iii) 765KV Bhadla – Bikaner
- iv) 765KV Banaskantha – Chittorgarh
- v) 765KV Jhatikara – Kanpur
- vi) 400KV Bhadla – Bikaner
- vii) 400KV Bhadla (POWERGRID) – Bhadla (RRVPL)
- viii) 400KV Ajmer – Ajmer
- ix) 400KV Agra – Bhiwadi

In this regard, Bird Diverters has been supplied at site and we are in the process of installation of the same. Accordingly, shutdown requirement is being applied progressively against aforesaid lines.

Meanwhile, the additional requirement of Bird Diverters has been envisaged in following other transmission lines as well in 2nd phase.

| Sl. No. | Name of Lines | Unit | No. of Bird Diverter planned for installation in 2 nd phase | Shutdown required for no. of Days |
|---------|--|------|--|---|
| | | | | <i>Considering 1 gang can able to do installation of 40 Bird Diverter in a day and considering 8 gangs shall be deployed for the work</i> |
| i) | 765KV Fatehgarh2-Bhadla2 | No. | 14679 | 46 |
| ii) | 765KV Fatehgarh2-Fatehgarh1 – Loop IN | No. | 3134 | 10 |
| iii) | 765KV Fatehgarh2 – Fatehgarh1 – Loop Out | No. | 3246 | 10 |
| iv) | 400KV Bhadla1 - Bhadla2 | No. | 3751 | 12 |
| | Total | No. | 24810 | |

29/11/21

Accordingly, the shutdown requirement of transmission lines for installation of Bird Diverters in 2nd phase w.r.t. NR1 has been worked out and tabulated above considering 1 gang can able to do installation of 40 Bird Diverters in day & POWERGRID is planning to deploy 10 difference gangs in different stretch (*considering required T&P i.e. special type of chair / canopy*).

As bird diverters are available at site, shutdown shall be available w.e.f. 3rd week of Novemeber'2021 progressively. May kindly allow.

Further, it is also to be mentioned here that in line with discussion had in 185th OCC meeting the shutdown availed for installation of Bird Diverters in 2nd phase as well may kindly be considered under ***Deemed Availability***.

Thanking Your,

Your's faithfully

21/11/2021
02/11/2021

(A. K. Behera)

Chief GM(AM), NR1

Copy for kind information please:-

- i) ED, NR1
- ii) ED(AM), CC

उत्तर प्रदेश राज्य भार प्रेषण केन्द्र

उपरोक्त ट्रांसमिशन कारपोरेशन लि०

(उत्तर प्रदेश सरकार का उपक्रम)

यू०पी०एस०एल०डी०सी० परिसर, विभूति खण्ड- II

गोमती नगर, लखनऊ-226010

दूरभाष:

ई-मेल : cepso@upslcd.org



U.P. State Load Despatch Centre **Annexure-A-VIII**

U.P. Power Transmission Corporation Ltd.

(A U.P. Govt. Undertaking)

UPSLDC Complex, Vibhuti Khand – II

Gomti Nagar, Lucknow- 226010

Phone:

E-mail: cepso@upslcd.org

No: -2755 /CE(PSO)/SE(R&A)/EE-II/SPS

Dated: - 15-11-2021

**Member Secretary,
NRPC 18-A, SJSS Marg,
Katwaria Sarai, New Delhi – 110016**

Subject: - Regarding review of SPS scheme for evacuation of generation at Lalitpur TPS.

Kindly find enclosed herewith revised SPS logic for evacuation of generation from Lalitpur TPS following the commissioning of 765kV Fatehabad-Gr Noida line. It is requested to kindly approve the logic so that the same may be implemented.

Encl: Old and New Logic
Simulation study details
Comment of M/s Lalitpur on Logic

Emaduddin Khan
12.11.21
(Emaduddin Khan)
Chief Engineer (PSO)

No: -2755 /CE(PSO)/SE(R&A)/EE-II/SPS

Dated: - 15-11-2021

Copy forwarded to following for information and necessary action:-

1. Director (SLDC), Vibhuti Khand – II, Gomti Nagar, Lucknow.
2. Director (Technical), UPRVUNL, 8th Floor, Shakti Bhawan Extension, Lucknow.
3. Chief Engineer (C&S), UPSLDC, Vibhuti Khand – II, Gomti Nagar, Lucknow.
4. Chief Engineer, (Trans South west), U.P. Power Transmission Corporation Ltd., 64, Khambha, By pass Road, Agra -282007 (cets@upptcl.org).
5. Superintending Engineer (T&C) Circle, 64 Khambha Bypass Road, Agra -282007.
6. Superintending Engineer (System Control), UPSLDC, Vibhuti Khand – II, Gomti Nagar, Lucknow.
7. M/s Lalitpur Power Generating Company Ltd, TC-13, Vibhuti Khand, near JSV Hyundai Service center Gomti Nagar, Lucknow 226010 (scr1pgcl.ltp@lpgcl.com)

Emaduddin Khan
(Emaduddin Khan)
Chief Engineer (PSO)

| SN. | OLD LOGIC | | REVISED LOGIC | | |
|-----|--|---|--|---|--|
| | CONDITION | ACTION | CONDITION OF CONTINGENCY | ANTECEDENT CONDITION | ACTION |
| 1 | <p>Case-1: If the total loads on 765KV Lalipur - Fatehabad (Agra) (UP) circuit - I & II is below 1400MW and both 1500MVA ICTs are in service at Fatehabad (UP) and one ICT gets tripped.</p> | <p>Action- In this situation generation at Lalipur TPS available machines should not exceed 1400MW and 'Generation Raise Command' be blocked at 1400MW.</p> | <p>Case-1: Both 1500MVA ICTs at Fatehabad (UP) tripped OR 765 KV Fatehabad-Gr Noida line AND Any one of two 1500MVA ICTs at Fatehabad (UP) tripped OR One of the two 765 KV Lalipur - Fatehabad line tripped</p> | <p>Both 765KV Lalipur - Fatehabad (Agra) (UP) circuit - I & II are in service and carry load below 1400MW AND Both 1500MVA ICTs at Fatehabad (UP) are in service AND 765 KV Fatehabad-Gr Noida line is in service</p> | <p>Action- In this situation generation at Lalipur TPS available machines should not exceed 1400MW and 'Generation Raise Command' be blocked at 1400MW.</p> |
| 2 | <p>Case-2: If the total loads on 765KV Lalipur TPS- Fatehabad (UP) circuit - I & II is more than 1400MW and one ICT gets tripped at 765KV sub-station Fatehabad.</p> | <p>Action: In case of total load on 765KV Lalipur TPS-Fatehabad (UP) circuit - I & II is more than 1400MW and both ICTs (1500MVA each) are in circuit, the total load on both ICTs may be more than 1500MVA. In such situation if one of the ICTs got tripped, it would lead to overloading of the remaining ICT. To avoid such situation:</p> <p>In this condition if three machines are in operation at Lalipur TPS, SPS be designed so that one of the machines should come on house load at once. Generation Raise command should be blocked at 1400MW.</p> | <p>Case-2: 765 KV Fatehabad- Gr Noida line AND Any one of two 1500MVA ICTs at Fatehabad (UP) tripped</p> | <p>Both 765KV Lalipur - Fatehabad (Agra) (UP) circuit - I & II are in service and carry above 1400MW AND Both 1500MVA ICTs at Fatehabad (UP) are in service AND 765 KV Fatehabad-Gr Noida line is in service</p> | <p>In this condition if three machines are in operation at Lalipur TPS, SPS be designed so that one of the machines should come on house load at once. Generation Raise command should be blocked at 1400MW.</p> |

ok
M. Rajiv
Ravi Kumar

| | | | | | |
|---|--|---|--|--|---|
| 3 | <p>Case-3: If both 1500MVA ICTs at Fatehabad (UP) or both 765KV Lalipur TPS-Fatehabad (UP) circuit -I & II got tripped at 765KV sub-station Fatehabad.</p> | <p>Action: In this condition, to safe guard the running units of Lalipur TPS, it will be essential to bring down the generation immediately of running units to house load. Both 220KV circuits of i.e. 220KV Jhansi & Lalipur should also get opened from Lalipur TPS end. In this regard it is suggested that Lalipur TPS should be considered to be taken into 'Islanding Scheme'.</p> | <p>Case-3: Both 1500MVA ICTs at Fatehabad (UP) tripped OR One of the two 765 KV Lalipur - Fatehabad line tripped</p> | <p>Both 765KV Lalipur -Fatehabad (Agra) (UP) circuit - I & II are in service and carry above 1400MW AND Both 1500MVA ICTs at Fatehabad (UP) are in service AND 765 KV Fatehabad- Gr Noida line is in service</p> | <p>In this condition if three machines are in operation at Lalipur TPS, SPS command must be initiated to Lalipur TPS to bring down generation to 1400 MW as soon as possible and 'Generation Raise Command' be blocked at 1400MW.</p> |
| 4 | <p>Case-4: If load on any 400KV line emanating from 765KV substation Fatehabad (UP) exceeds 800MW.</p> | <p>Action: SPS command must be initiated to Lalipur TPS to bring down generation so that the subject line loading comes below 800MW</p> | <p>Case-4: Both 765KV Lalipur TPS-Fatehabad (UP) circuit -I & II get tripped OR If both 1500MVA ICTs at Fatehabad (UP) AND 765 KV Fatehabad- Gr Noida line get tripped</p> | <p>Both 765KV Lalipur -Fatehabad (Agra) (UP) circuit - I & II are in service AND Both 1500MVA ICTs at Fatehabad (UP) are in service AND 765 KV Fatehabad- Gr Noida line is in service</p> | <p>Action: In this condition, to safe guard the running units of Lalipur TPS, it will be essential to bring down the generation immediately of running units to house load. Both 220KV circuits of i.e. 220KV Jhansi & Lalipur should also get opened from Lalipur TPS end. In this regard it is suggested that Lalipur TPS should be considered to be taken into 'Islanding Scheme'.</p> |
| | <p>Case-5: If load on any 400KV line emanating from 765KV substation Fatehabad (UP) exceeds 800MW.</p> | <p>Action: SPS command must be initiated to Lalipur TPS to bring down generation so that the subject line loading comes below 800MW</p> | <p>Case-5: If load on any 400KV line emanating from 765KV substation Fatehabad (UP) exceeds 800MW.</p> | <p>Both 765KV Lalipur -Fatehabad (Agra) (UP) circuit - I & II are in service AND Both 1500MVA ICTs at Fatehabad (UP) are in service AND 765 KV Fatehabad- Gr Noida line is in service</p> | <p>Action: SPS command must be initiated to Lalipur TPS to bring down generation so that the subject line loading comes below 800MW</p> |

o/c
TW

Resingh
Kumar

Loading scenario as per PSSE Study

| Sl. No. | Total Generation of Lalitpur | Cases | Detail of Contingency | Loading on 765KV Lalitpur-Fatehabad DC line | Loading on 765KV Fatehabad - Gr. Noida line | Loading on 220KV Lalitpur TPS- Lalitpur (220KV) DC line | Loading on Lalitpur (TP5)-Jhansi DC line | Loading on 1500MVA ICT-1 at 765KV Fatehabad | Loading on 1500MVA ICT-2 at 765KV Fatehabad | Whether loading on 400KV lines emanating from 765KV Fatehabad is more than 800MW |
|---------|-------------------------------|--------|---|---|---|---|--|---|---|--|
| 1 | 1400 MW | Case-1 | No Contingency | 675 MW each | 562 MW | 26 MW each | 2 MW (negative) each | 390 MW | 390 MW | NO |
| | | | Both 1500MVA ICTs at Fatehabad (UP) tripped | 662 MW each | 1319 MW | 26 MW each | 11 MW each | NA | NA | NO |
| | | | 765 KV Fatehabad- Gr Noida line AND Any one of two 1500MVA ICTs at Fatehabad (UP) tripped | 656 MW each | NA | 26 MW each | 17 MW each | NA | 1307 MW | NO |
| 2 | 1875 MW 1875 MW 1250 MW | Case-2 | One of the two 765 KV Lalitpur -Fatehabad line tripped | 1300 MW | 540 MW | 26 MW each | 17 MW each | 380 MW | 380 MW | NO |
| | | | No Contingency | 900 MW each | 785 MW | 26 MW each | 9 MW each | 500 MW | 500 MW | NO |
| | | | 765 KV Fatehabad- Gr Noida line AND Any one of two 1500MVA ICTs at Fatehabad (UP) tripped | 875 MW each | NA | 26 MW each | 36 MW each | 1738 MW | NA | NO |
| 3 | 1875 MW | Case-3 | Both 1500MVA ICTs at Fatehabad (UP) tripped | 885 MW each | 1760 MW | 26 MW each | 26 MW each | NA | NA | NO |
| | | | One of the two 765 KV Lalitpur -Fatehabad line tripped | 1750 MW | 753 MW | 26 MW each | 36 MW each | 480 MW | 490 MW | NO |
| | | | | | | | | | | |

Rishi

Revised SPS scheme for evacuation of Lalitpur TPS generation

R. N. Bedi <rnbedi.ltp@lpgcl.com>

Tue, Nov 2, 2021 at 10:27 AM

To: "Superintending Engineer (R&A)" <sera@upslcd.org>

Cc: Alhad Narayan Sar <ansar.ltp@lpgcl.com>, Manoj Mehta <manojm.ltp@lpgcl.com>, Avinash Kumar <avinashkumar.ltp@lpgcl.com>, Vikash Kumar Sharma <vksharma.ltp@lpgcl.com>, SCR LPGCL Lalitpur <scrplpgcl.ltp@lpgcl.com>

Dear Sir

Please refer to our email dated 01.07.2021 for the subject. The final approved SPS scheme may please be in line with our comments furnished vide email dated 01.07.2021.

Our email dated 01.07.2021 is reproduced below for your reference please. Requested to arrange a meeting with NRLDC, if required.

" This has reference to your letter no 1528/CE(PSO)/SE(R&A)/EE-II/SPS dated 28-06-2021.

Our point wise reply to the MOM on revised SPS scheme for evacuation of Generation of Lalitpur TPS is as furnished below.

SI no-1, Case-1:

LPGCL Reply: Acceptable

SI no-2, Case-2:

As mentioned in the MOM, when the Ex-bus power is above 1400MW (all three machines are in service), if 765KV Fatehabad-Greater Noida line trips & any one out of two ICTs trips then action required is to bring one machine at house load condition along with command block to raise load.

LPGCL Reply: Instead of bringing one machine to house load condition, it is recommended to trip one selected machine (in view to prevent un-desirable severe thermal stresses on machine from full load to house load operation) and the command block is not required as the ex-bus power of two remaining machines will be max 1237.5MW.

SI no-3, Case-3:

As mentioned in the MOM, when Ex-bus power is above 1400MW, both 1500MVA ICTs at Fatehabad tripped or one of the 765KV Lalitpur-Fatehabad line tripped, it is recommended to implement the logic to bring down Ex-bus power to 1400MW through automatic back down in case SPS is actuated

LPGCL Reply: As checked at LPGCL end, implementation of Run back through SPS signal is not at all a desirable option as it may lead to unstable condition of boiler and result in tripping of the unit.

a) In case Both 1500MVA ICTs at Fatehabad tripped, power is getting evacuated through both Lalitpur Fatehabad lines and Fatehabad Greater Noida line. Hence there will not be any case of over loading in Fatehabad-Greater Noida line for shortest span of time

b) In case One of the 765KV Lalitpur-Fatehabad line tripped, power is getting evacuated through one no Lalitpur Fatehabad line, two ICTs and Fatehabad Greater Noida line. Hence there will not be any case of over loading in Fatehabad-Greater Noida line for shortest span of time.

Hence it is recommended to reduce load manually at LPGCL end within shortest time period.

SI no-4, Case-4:

LPGCL Reply: Acceptable

SI no-5, Case-5:

LPGCL Reply: Implementation of logic based on N number of 400KV lines tripping at Fatehabad is not possible. Hence the load limiting in Unit-3 from 660MW to 456MW is sufficient to take care the overloading in any of the 400KV lines in case of tripping of one no of 400KV lines at Fatehabad end. Further in case of Unit-3 is not in service, the

पावर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड
(भारत सरकार का उद्यम)
POWER SYSTEM OPERATION CORPORATION LIMITED
(A Govt. of India Enterprise)



उत्तरी क्षेत्रीय भार प्रेशण केन्द्र / **NORTHERN REGIONAL LOAD DESPATCH CENTRE**
कार्यालय : 18-ए, शहीद जीत सिंह सनसनवाल मार्ग, कटवारिया सराय, नई दिल्ली- 110016
OFFICE : 18-A, Shaheed Jeet Singh Sansanwal Marg, Katwaria Sarai, New Delhi- 110016
CIN : U40105DL2009GOI188682, Website : www.nrlc.org, www.nrlc.in, Tel.: 011- 26519406, 26523869, Fax : 011- 26852747

Ref. No.: NRLDC /MIS/2020-21/02

Date :22-10-2021

To,

As per Distribution list.

Sub: Sharing of hourly Load shedding under different categories on NRLDC Reporting Software

Sir,

During a recent review of the country's power supply scenario, Secretary, Ministry of Power, emphasized the importance of ensuring accuracy of the hourly load shedding (MW) and energy not met (MU) figures being received from various SLDCs on daily basis in respect of their own states, and classifying them under different heads like low availability, transmission constraints, financial constraints, planned maintenance of transmission / distribution system within state, etc.

Although SLDCs are uploading the hourly load shedding figures of the previous day on the web-based reporting software of NRLDC the next day, but reason for the shedding or unserved demand at any hour is not segregated into the possible different categories.

In view of the above, it is requested to kindly classify the reason of shedding in the detail sheet of hourly load shedding, as per **Annexure-I**, in the daily power supply report, before uploading it to the web-based reporting software on daily basis.

Your kind cooperation in this regard is earnestly solicited.

Thanking you,

Yours faithfully,

(Surajit Banerjee)

Chief General Manager (SO-II)

NRLDC, POSOCO

Copy to: 1 Chief General Manager(I/C), NRLDC, POSOCO-For kind information please
2 Executive Director, NLDC, POSOCO-For kind information please
3 Chief General Manager (SO), NLDC, POSOCO -For kind information please



Distribution List

State Load Despatch Centre



1. Chief Engineer,
Punjab SLDC Ablowal, Patiala, SLDC Building,
Near 220KV Grid Substation, PSTCL, Ablowal,
Patiala-147001
2. Chief Engineer,
Haryana SLDC, HVPNL, Sewah Panipat,
XEN/LD & PC, SLDC Complex, Behind 400KV BBMB Power House,
Sewah, Panipat-132108
3. Chief Engineer,
HP Load Dispatch Society, SLDC complex,
Totu, Shimla-171011
4. Chief Engineer,
J&K Gladni, Jammu, SLDC Building,
220 kV Grid Station Narwal,
Jammu, Jammu/ Kashmir-180007
5. Chief Engineer,
State Load Despatch Centre,
Rajasthan Rajya Vidyut Prasaran Nigam Limited,
Ajmer Road, Heerapura,
Jaipur-302024
6. Chief Engineer,
Power System,
UP Power Transmission Corporation Ltd.,
5th Floor, Shakti Bhawan, 14 Ashok Marg,
Lucknow-226001
7. Chief Engineer,
Vidyut Bhawan Saharanpur Road Majra,
Near ISBT Dehradun-248001
Uttarakhand, INDIA
8. General Manager,
Delhi, SLDC, 33kV, Sub Station Building,
Minto Road, New Delhi-110002
9. Chief Engineer (SO),
System Load Despatch Centre,
Bhakra Beas Management Board,
SLDC Complex, Industrial Area, Phase-I,
Madhya Marg, Chandigarh-160002

Scatter Plots for October 2021


Stations at which tap position changed in Oct'2021




Scatter Plots for October 2021





Scatter Plots for October 2021




Tap changes to be done




Scatter Plots for October 2021




Scatter Plots for October 2021




Haryana and UP requested in 188 OCC meeting, to check tap position change requirement at Panchkula(PG) and Rewa-road respectively. However, scatter plots of these stations as per NRLDC data do not suggest any need for tap change.




Scatter Plots for October 2021






Rajpura

MVAr Vs Voltage




Tanda 400

MVAr Vs Voltage




IGSTPP Jhajjar

MVAr Vs Voltage




Anpara C

MVAr Vs Voltage




Bawana

MVAr Vs Voltage



Anpara

MVAr Vs Voltage



उत्तर प्रदेश राज्य भार प्रेषण केन्द्र

उ०प्र०पॉवर ट्रांसमिशन कारपोरेशन लि०

(उत्तर प्रदेश सरकार का उपक्रम)

यू०पी०ए०स०एल०डी०सी० परिसर, विभूति खण्ड-11

गोमती नगर, लखनऊ-226010

दूरभाष:

ई-मेल : cepso@upsldc.org



U.P. State Load Despatch Centre

U.P. Power Transmission Corporation Ltd.

(A U.P. Govt. Undertaking)

UPSLDC Complex, Vibhuti Khand – II

Gomti Nagar, Lucknow- 226010

Phone:

E-mail: cepso@upsldc.org

No: - 2754 /CE(PSO)/SE(R&A)/EE-II/OCC

Dated: - 15-11-2021

| | | |
|--|---|---|
| Chief Engineer (Thermal Operation), UPRVUNL, 14 th Floor, Shakti Bhawan Extn., Lucknow. (cgm.to@uprvunl.org) | President, M/s Prayag Raj Thermal Power Plant, Village-Khansemra, PO-Lohgara, Tehsil-Bara, Distt-Allahabad 212107. | M/s Rosa Power Supply, Company Limited, 520, F – Block, 5th Floor, Kasmanda House, 02 Park Road, Hazratganj, Lucknow 226001) |
| M/s LANCO – Anpara Power Ltd, 411/09 River Side Apartment, New Hyderabad Lucknow-226007 (arun.tholia@lancogroup.com) | General Manager, Meja Thermal Power Plant Meja Tehsil, Allahabad. | M/s Lalitpur Power Generating Company Ltd, TC-13, Vibhuti Khand, near JSV Hyundai Service center Gomti Nagar, Lucknow 226010 (sclpgecl.ltp@lpgecl.com) |

Subject:- Regarding Reactive Power Performance of Generator.

In view of upcoming winter and high voltage in the grid, generator should absorb the Reactive Power as per respective capability curve. In this regard scattered plot of voltage & MVar is attached herewith.

It is requested to manage reactive power of generator depending upon voltage of the grid in your jurisdiction. In addition to this voltage & MVar data at Rosa TPS and Lanco TPS is intermittent which may be resolved at earliest.

Encl: As Above

(Emaduddin khan)
Chief Engineer (PSO)

No: - 2754 /CE(PSO)/SE(R&A)/EE-II/OCC

Dated: - 15-11-2021

Copy forwarded to following for information and necessary action:-

1. Director (SLDC), Vibhuti Khand – II, Gomti Nagar, Lucknow.
2. Director (Operation), UPPTCL, 11th Floor, Shakti Bhawan Extn., Lucknow. (director_op@upptcl.org)
3. Chief Engineer (C&S), UPSLDC, Vibhuti Khand – II, Gomti Nagar, Lucknow.
4. General Manager, NRLDC 18-A, SJSS Marg, Katwaria Sarai, New Delhi – 110016
5. Superintending Engineer (System Control), UPSLDC, Vibhuti Khand – II, Gomti Nagar, Lucknow.
6. Superintending Engineer (SCADA & IT), UPSLDC, Vibhuti Khand – II, Gomti Nagar, Lucknow.
7. Superintending Engineer (Operation), NRPC, 18 – A SJSS Marg, Katwaria Sarai, New Delhi, 110016.

(Emaduddin khan)
Chief Engineer (PSO)

Reactive Power performance between 01.09.2021 to 20.10.2021

| Sr. No. | Name of the Generating Station | Unit No. | MVAR VS V GRAPH STATUS |
|---------|--------------------------------|-----------------|------------------------------------|
| 1 | Anpara-A | (Unit1#210) | Not satisfactory needs improvement |
| 2 | | Unit2#210 | Not satisfactory needs improvement |
| 3 | | Unit3 #210 | Not satisfactory needs improvement |
| 4 | Anpara-B | (Unit4#500) | Satisfactory |
| 5 | | (Unit5#500) | Satisfactory |
| 6 | ANPARA-C | (Unit1# 600) | Data is not healthy |
| 7 | | (Unit2# 600) | Data is not healthy |
| 8 | Anpara-D | (Unit6#500) | Not satisfactory needs improvement |
| 9 | | (Unit7#500) | Not satisfactory needs improvement |
| 10 | Obra-B | (Unit9#200) | Satisfactory but need improvement |
| 11 | | (Unit10#200) | Satisfactory but need improvement |
| 12 | | (Unit11#200) | Satisfactory but need improvement |
| 13 | | (Unit12#200) | Satisfactory but need improvement |
| 14 | | (Unit13#200) | Under Shutdown |
| 15 | Parichha-C | (Unit5#250) | Satisfactory |
| 16 | | (Unit6#250) | Satisfactory |
| 17 | Harduaganj | (Unit7#105) | Data is not healthy |
| 18 | | (Unit8#250) | Satisfactory |
| 19 | | (Unit9#250) | Satisfactory |
| 20 | ROSA A TPS | Unit1 #300 | Data is not healthy |
| 21 | | Unit2 #300 | Data is not healthy |
| 22 | ROSA B TPS | Unit3 #300 | Data is not healthy |
| 23 | | Unit4 #300 | Data is not healthy |
| 24 | LALITPUR TPS | (Unit 1 # 660) | Not satisfactory needs improvement |
| 25 | | (Unit 2 # 660) | Not satisfactory needs improvement |
| 26 | | (Unit 3 # 660) | Not satisfactory needs improvement |
| 27 | Meja Urja Nigam | Unit-1 #660 | Not satisfactory needs improvement |
| 28 | | Unit-2 #660 | Satisfactory but need improvement |
| 29 | Bara | (Unit-1# 660) | Satisfactory but need improvement |
| 30 | | (Unit-2 # 660) | Satisfactory but need improvement |
| 31 | | (Unit-3 # 660) | Satisfactory but need improvement |

o/c
N. Singh

Prakash



*Large RE Generation Outage
Apr'19-Oct'21*

| S. No | Date & Time | Event Description | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|----------------------------|---|---|----------------------------|---|---|
| 1 | At 13:10 Hrs on 13.10.2021 | As reported, 33kV feeders at solar generations connected at 400/220kV Fatehgarh2 (PG) tripped due to sudden high voltage at 33kV level. As per SCADA SOE at NRLDC, no switching operation is observed/reported during antecedent condition. | Connected at 220kV Fatehgarh2(PG): AHEJOL solar RENEW Jharkhand3 solar RENEW SUNWAVE solar | Approx. 650MW | Tripping of feeders and transformers is observed at RENEW Jharkhand3 solar. No tripping of feeders reported from other solar plants | Voltage at 220kV bus was in permissible limit. Other solar plants connected to the same bus didn't trip during the event. So, it seems that tripping occurred due to sensitive over voltage protection settings of feeders and non compliance of HVRT. |

13-Oct-21/13:10hrs, Solar generation loss connected at Fatehgarh2(PG)

PMU Plot of phase voltage magnitude at Fatehgarh2(PG)

13:09hrs/13-Sept-21





| S. No | Date & Time | Event Discreption | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|--------------------------------------|--|---|---|--|--|
| 2 | At 13:06Hrs & 13:49Hrs on 13.09.2021 | <p>At 13:06 Hrs, 765kV Bhadla_2-Ajmer ckt-1 was charged from Bhadla_2 end only, resulted into sudden shoot up of voltage at Bhadla_2(PG). Due to over voltage, 765 KV Bhadla_2 - Fatehgarh_2 (PG) Ckt-1 tripped on over voltage stage-1 operation at Bhadla_2(PG) end & DT received at Fatehgarh_2(PG) end. At the same time, solar generation loss of approx. 500MW connected to Fatehgarh2(PG) is observed.</p> <p>Again at 14:49Hrs, 765kV Bhadla_2-Ajmer ckt-1 was charged from Bhadla_2 end which might have led to sudden shoot up of voltage resulted into loss of 700MW solar generation connected at Fatehagr2(PG).As per PMU, no fault is observed and voltage shoot up is observed.</p> | Renew Jharkhand3 Solar Renew Sunwave Solar | Approx. 500MW at 13:06Hrs & Approx. 750MW at 14:49Hrs | Tripping of feeders and transformers is observed at RENEW Jharkhand3 solar. No tripping of feeders reported from other solar plants | <p>Voltages at 220kV & 765kV Bus at Fatehgarh_2 were in permissible. Voltages at 220kV & 765kV Bus at Fatehgarh_2 were in permissible range 229kV & 788kV Respectively.</p> <p>Other solar plants connected to the same bus didn't trip during the event. So, it seems that tripping occurred due to sensitive over voltage protection settings of feeders and non compliance of HVRT.</p> |

13-Sept-21/13:06hrs, Solar generation loss connected at Fatehgarh2(PG)

PMU Plot of phase voltage magnitude at 400kV Fatehgarh2(PG)

13:06hrs/13-Sept-21





| S. No | Date & Time | Event Discreption | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|----------------------------|--|--|----------------------------|--|---|
| 3 | At 11:13 Hrs on 26.08.2021 | As reported, 765 KV Bhadla-Bikaner (PG) ckt-1 tripped due to over voltage at Bhadla during opening of line reactor of 765kV Bikaner-Bhadla2(PG) Ckt-1 at Bikaner(PG) at 11:13 hrs, DT received at Bikaner end. At the same time, solar generation loss of approx. 1700MW connected at 765/400/220kV Bhadla(PG) and 400kV Fatehgarh2(PG) occurred on over voltage | Connected at 220kV Fatehgarh2(PG): EDEN solar RENEW Sunwave solar AHEJOL solar Connected at 765/400/220kV Bhadla(PG): MRPL Solar ACME solar Azure Power 34 Solar ESSEL solar | Approx. 1700MW | In some plants feeders at 33kV side tripped on over voltage stage 1 protection operation and in some plants solar blocks also tripped. | Voltage at 220kV bus was in permissible limit. Other solar plants connected to the same bus didn't trip during the event. So, it seems that tripping occurred due to sensitive over voltage protection settings of feeders and non compliance of HVRT. |

26-Aug-21/11:13hrs, Solar generation loss connected at Fatehgarh2(PG) & Bhadla(PG)

PMU Plot of phase voltage magnitude at Bhadla2(PG)

11:13hrs/26-Aug-21




| S. No | Date & Time | Event Discreption | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|----------------------------|---|---|----------------------------|---|---|
| 4 | At 10:23 Hrs on 20.07.2021 | As reported at 10:23 Hrs, 220 KV Akal-Dangri Ckt-1 & Ckt-2 tripped from Akal end on R-Y phase to phase fault. At the same time, wind generation loss of approx. 1550MW is observed from the 220kV feeders connected at 220kV Akal(Raj) due to tripping from remote end. | 220kV Wind generation feeders connected at Akal: Mada, Rajgarh, Amarsagar Jajia, Bhu 1&2, Mulana & Bhensda. | Approx. 1550MW | No tripping of feeders other than Dangri Ckt-1&2 observed from 220kV Akal(Raj) end. | It seems that wind generation loss occurred due to LVRT no compliance of the wind generators connected to 400/220 Akal S/s. |

20-Jul-21/10:23hrs, Wind generation loss connected at Akal(Raj)


PMU Plot of phase voltage magnitude at Jodhpur(RS)

10:25hrs/20-July-21



Rajasthan Wind generation during tripping

WIND GENERATION




| S. No | Date & Time | Event Discreption | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|----------------------------|---|--|----------------------------|--|---|
| 5 | At 16:02 Hrs on 11.06.2021 | As reported, 220kV Akal-Bhu ckt-1 & Ckt-2 both tripped due to snapping of B-ph jumper. 400MW wind generation loss occurred due to tripping of Akal-Bhu D/C and 800MW wind generation loss occur due to may be non compliance of LVRT. At the same time, 400kV Barmer-Jaisalmer-2 Ckt-1 & Ckt-2 tripped on overvoltage may be due to loss of wind generation. 300MW solar generation also tripped connected at 400/220kV Jaisalmer-2 during the voltage dip. | 220kV Wind generation feeders connected at Akal: Mada, Rajgarh, Amarsagar, Jajia, Bhu 1&2, Mulana & Bhensda. | Approx. 1200MW | No tripping of feeders other than Bhu Ckt-1&2 observed from 220kV Akal(Raj) end. | It seems that wind generation loss occurred due to LVRT no compliance of the wind generators connected to 400/220 Akal S/s. |


11-June-21/16:02hrs, Wind generation loss connected at Akal(Raj)

PMU Plot of phase voltage magnitude at Jodhpur(RS)

16:02hrs/11-June-21



Rajasthan Wind generation during tripping




| S. No | Date & Time | Event Discreption | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|----------------------------|--|--|----------------------------|---|---|
| 6 | At 13:50 Hrs on 06.08.2020 | As reported, 400 KV Akal-Jodhpur (RS) Ckt-1 tripped due to DT received at Jodhpur end. At the same time, 400/220kV 315 MVA ICT 1 & 315 MVA ICT 2 at Barmer(RS) also tripped. As per PMU, R-Y fault with delayed clearance is observed in the system. In antecedent conditions, 400 KV Akal-Jodhpur (RS) Ckt-1 carrying 229MW. Wind generation loss of around 1250MW is observed as per SCADA data. | 220kV Wind generation feeders connected at Akal: Akal 1&2, Dangri 1&2, Mada, Amarsagar, Rajgarh, Jajia, Bhu 1&2, Mulana & Bhensda. | Approx. 1250MW | No tripping of feeders observed from 220kV Akal(Raj) end. | It seems that wind generation loss occurred due to LVRT no compliance of the wind generators connected to 400/220 Akal S/s. |


06-Aug-20/13:50hrs, Wind generation loss connected at Akal(Raj)

PMU Plot of phase voltage magnitude at Jodhpur(RS)

13:50hrs/06-Aug-20



WIND GENERATION





| S. No | Date & Time | Event Discription | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|-----------------------------|--|---|----------------------------|---|--|
| 7 | At 10:39 Hrs on 16.06.20 20 | As reported, 765kV Bhadla-Bikaner ckt 2 auto-reclose successful at 10:39 hrs on R-N fault. Further 220kV Saurya Urja - Bhadla(PG) ckt 1&2 tripped at 10:39 hrs from Saurya Urja end only due to this transient fault. RE-generation loss is 450 MW is reported by Saurya-Urja(Bhadla). | Saurya Urja Solar connected at Bhadla(PG) | Approx. 450MW | There was no fault in 220kV Saurya urja - Bhadla(PG) ckt 1&2. | Similar incident of solar generation loss at Saurya Urja occurred on 17th May 2020 and 13th & 14th June 2020. It seems that loss of solar generation occurred due to may be LVRT non compliance. |

16-June-20/10:39hrs, Solar generation loss connected at Bhadla(PG)

PMU Plot of phase voltage

10:39hrs/16-Jun-19




| S. No | Date & Time | Event Discreption | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|----------------------------|--|---|----------------------------|---|--|
| 8 | At 12:56 Hrs on 16.09.2019 | As reported, due to voltage dip in Y-phase during Y-N phase to earth fault in POWERGRID substation, solar generation loss from 220kV feeders of TPREL, Mahoba Solar, Saurya Urja and Azure Power occurred. | Mahoba Solar TRPEL Solar Saurya Urja Solar Azure Power Solar | Approx. 1050MW | Fault was not on the feeders of Solar generation. | It seems that loss of solar generation occurred due to may be LVRT non compliance. |


16-Sept-19/12:56hrs, Solar generation loss connected at Bhadla(PG)

PMU Plot of phase voltage magnitude at Jodhpur(RS)

12:56hrs/16-Sept-19



SOLAR GENERATION




| S. No | Date & Time | Event Discreption | Major plants affected | Solar/wind generation loss | Observations | Remark |
|-------|----------------------------|---|---|----------------------------|--|--|
| 9 | At 11:34 Hrs on 07.05.2019 | As reported, 400kV Bikaner-Bhadla-II tripped on Y-B phase to phase fault (at the same time, 400kv Bikaner-Sikar ckt-I & II have also tripped) but other lines from 400-kV Bhadla (Rai) and Bikaner remained in service. From the phasor Measurement unit (PMU) data, it has been observed that fault clearance was less than 100ms. Solar generation loss of around 1000 MW is observed during the event. | Solar generation connected at Bhadla(PG): SB Energy Solar Azure Power | Approx. 1000MW | The generation at these locations had picked up only after 2-3 minutes even though faults clearance and thus voltage revival was within 100ms. | This large outage of solar generation could be interpreted as failure of Fault Ride Through or LVRT capability of solar plants at these locations. |


07-May-19/11:34hrs, Solar generation loss connected at Bhadla(PG)

PMU Plot of phase voltage

11:34hrs/07-May-19



SOLAR GENERATION




Plants not operated in voltage control mode

- Adani Bhadla (Bhadla-PG)
- SBSR (Bikaner-PG)
- Azure 43 (Bikaner-PG)
- ACME (Bhadla-PG)

21 Oct -5Nov 2021 Plots

- Mahoba Solar

P(MW) Vs Q(MVAR) at POI of Mahoba Solar plant_300MW_Bhadla(PG)



Voltage(kV) Vs Q(MVAR) at POI of Mahoba Solar plant_300MW_Bhadla(PG)






Chart Title



P and Q plots

Series1 Series2

Chart Title




V and Q plots


Series2 Series1

Acme Bhadla

Power factor control




Voltage(kV) Vs Q(MVAR) at POI of ACME Solar plant_250MW_Bhadla(PG)




TPREL Bhadla


P(MW) Vs Q(MVAR) at POI of TPREL_300MW_Bhadla(PG)




Voltage(kV) Vs Q(MVAR) at POI of TPREL_300MW_Bhadla(PG)




P(MW) Vs Q(MVAR) at POI of 220kV Adani-Bhadla ckt-1&2_250MW_Bhadla(PG)




Voltage(kV) Vs Q(MVAR) at POI 220kV Adani-Bhadla ckt-1&2_250MW_Bhadla(PG)




P(MW) Vs Q(MVAR) at POI of MRPL_250MW_Bhadla(PG)




Voltage(kV) Vs Q(MVAR) at POI of MRPL_250MW_Bhadla(PG)




P(MW) Vs Q(MVAR) at POI of Eden Solar plant_300MW_Fatehgarh-II(PG)



Voltage(kV) Vs Q(MVAR) at POI of Eden Solar Plant_300MW_Fatehgarh-II(PG)




P(MW) Vs Q(MVAR) at POI of AHEJOL_390MW_Fatehgarh-II(PG)



Voltage(kV) Vs Q(MVAR) at POI of AHEJOL_390MW_Fatehgarh-II(PG)

Voltage control



National Load Despatch Centre
Import of Uttar Pradesh Transfer Capability for December 2021

Issue Date: 16-11-2021

Issue Time: 1600

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|---|--------------------------------|---|--|--|--|---|
| 1st December 2021 to 31st December 2021 | 00-24 | 00-24 | 600 | 13200 | 8490 | 4710 | | https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde |
| Limiting Constraints | | N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs | | | | | | |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import of Rajasthan Transfer Capability for December 2021

Issue Date: 16-11-2021

Issue Time: 1600

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|---|--------------------------------|---|--|--|--|---|
| 1st December 2021 to 31st December 2021 | 00-24 | 6200 | 300 | 5900 | 3400 | 2500 | | https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads |
| Limiting Constraints | | N-1 contingency of 400/220kV Chittorgarh, Jodhpur ICTs and Ajmer ICTs | | | | | | |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import of Haryana Transfer Capability for December 2021

Issue Date: 16-11-2021

Issue Time: 1600

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|--|--------------------------------|---|--|--|--|---|
| 1st December 2021 to 31st December 2021 | 00-24 | 8500 | 600 | 7900 | 3000 | 4900 | | https://hvpn.org.in/#/atcttc |
| Limiting Constraints | | N-1 contingency of 400/220kV ICTs at Deepalpur and Kurukshetra(PG) | | | | | | |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import of Delhi Transfer Capability for December 2021

Issue Date: 16-11-2021

Issue Time: 1600

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|--|--------------------------------|---|--|--|--|-----------------|
| 1st December 2021 to 31st December 2021 | 00-24 | 6800 | 300 | 6500 | 4180 | 2320 | | |
| Limiting Constraints | | N-1 contingency of 400/220kV Mundka and Bamnauli ICTs. | | | | | | |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import of HP Transfer Capability for December 2021

Issue Date: 16-11-2021

Issue Time: 1600

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|--|-------------------------|--|---|---|-------------------------------------|---|
| 1st December 2021 to 31st December 2021 | 00-24 | 1200 | 100 | 1100 | 1400 | -300 | | https://hpslhc.com/mrm_category/ttc-atc-report/ |
| Limiting Constraints | | N-1 contingency of 400/220kV Nallagarh ICTs. 132kV lines from Kangoo are also heavily loaded | | | | | | |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import of Uttarakhand Transfer Capability for December 2021



Issue Date: 16-11-2021



Issue Time: 1600

Revision No. 0


| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|--|--------------------------------|---|--|--|--|-----------------|
| 1st December 2021 to 31st December 2021 | 00-24 | 1600 | 100 | 1500 | 1200 | 300 | | |
| Limiting Constraints | | N-1 contingency of 400/220kV Nallagarh ICTs. 132kV lines from Kangoo are also heavily loaded | | | | | | |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages






Merta ICT loading



Chittorgarh ICT loading





LONG OUTAGES REPORT AS ON 14-10-22021



Annexure-B.VII

| S. No` | Element Name | Type | Owner | Outage Date and Time | Outage days | Reason / Remarks |
|----------|---|------|-----------|----------------------|-------------|---|
| A | LINE | | | | | |
| 1 | 220 KV Kishenpur(PG)-Ramban(PDD) (PDD) Ckt-1 | Line | PDD JK | 31-03-2020 | 16:43 | 595 Due to heavy land slide near village Dalwas at Ramban damages occurred to 220 KV D/C KPTL at Location No :-187,188 &189 and there is every apprehension of collapsing Tower Loc No 189 . |
| 2 | 220 KV New Tanda (UP)-Sohawal(PG) (UP) Ckt-1 | Line | UPPTCL | 06-09-2021 | 23:37 | 71 Phase to phase fault Y-B Fault current ly 4.28kA, Ib 4.24kA, Dist. 39.3km from new Tanda end.Tower damage reported. |
| 3 | 220 KV New Tanda (UP)-Sohawal(PG) (UP) Ckt-2 | Line | UPPTCL | 06-09-2021 | 23:37 | 71 Phase to earth fault B-N , Fault current 2.49kA, Dist. 35.6 km from new Tanda end. Tower damage reported. |
| 4 | 400 KV Kishenpur-NewWanpoh (PG) Ckt-3 | Line | POWERGRID | 23-10-2021 | 10:05 | 25 Phase to earth fault R-N , Dist. 47.3km, Fault current 5.14kA from Kishenpur & Dist. 82km, Fault current 2.7kA from New Wanpoh. Line tripped during heavy rain & lightening. Tower collapsed at loc. no. 145. |
| 5 | 220 KV Sohawal(PG)-Gonda(UP) (UP) Ckt-1 | Line | UPPTCL | 12-08-2021 | 09:00 | 97 Emergency shutdown of line taken, as tower no. 34 is affected by flood. |
| 6 | 220 KV Sohawal(PG)-Bahraich(UP) (UP) Ckt-1 | Line | UPPTCL | 12-08-2021 | 09:12 | 97 Emergency shutdown of line taken, as tower no. 34 is affected by flood. |
| 7 | 400 KV BASSI-BHIWADI (PG) CKT-1 | Line | POWERGRID | 10-10-2021 | 08:33 | 38 S/D for Shifting/Diversion work of due to NHAI |
| 8 | 400 KV UNNAO-PANKI (UP) CKT-1 | Line | UPPTCL | 11-10-2021 | 10:02 | 37 Shutdown required due to PTPS Panki (Diversion work due to Extension of PTPS Panki. |
| 9 | 765 KV ORAI-ALIGARH (PG) CKT-1 | Line | POWERGRID | 28-10-2021 | 10:08 | 20 for diversion work due to construction of Bundelkhand Expressway |
| 10 | 765 KV ORAI-ALIGARH (PG) CKT-2 | Line | POWERGRID | 28-10-2021 | 10:40 | 20 for diversion work due to construction of Bundelkhand Expressway |
| B | BAYS | | | | | |
| 1 | 419 MAIN BAY - 50 MVAR BUS REACTOR NO 1 AT 400KV AMARGARH(NRSS XXIX) AND 400KV BUS 2 AT AMARGARH(NRSS XXIX) | BAY | NRSS XXIX | 07-07-2020 | 09:34 | 498 CEA clearance awaited |
| 2 | 40452B MAIN BAY - 400KV SURATGARH(RVUN)-RATANGARH(RS) (RS) CKT-1 AT Ratangarh(RS) | BAY | RRVNL | 25-12-2020 | 17:05 | 326 Emergency shutdown for refilling of SF6 gas in R-phase of Circuit Breaker. Later leakage found. Revival delayed due to non-availability of required spare parts. |
| 3 | 400 KV Kadarpur (GPTL) - Bus 1 | BUS | GPTL | 17-04-2021 | 13:18 | 213 E/S/D taken due to abnormal humming sound observed from 400KV B-phase BUS-1 CVT at Kadarpur. |
| 4 | 402 TIE BAY - 400KV KURUKSHETRA-SONIPAT (PG) CKT-2 AND FUTURE AT Sonipat(PG) | BAY | POWERGRID | 29-10-2021 | 12:38 | 18 For attending CB trouble alarm in 402 tie bay. |
| 5 | 70452B MAIN BAY - 765 KV AJMER(PG)-PHAGI(RS) (PG) CKT-2 AT PHAGI (POWERGRID) | BAY | POWERGRID | 30-10-2021 | 13:35 | 17 For attending sudden SF6 gas leakage detected in G-42 compartment (Y-phase CT). |
| 6 | 704-52A MAIN BAY - 765 KV ANTA-PHAGI (RS) CKT-1 (RRVNL) AT 765KV ANTA(RS) | BAY | RRVNL | 23-09-2021 | 18:04 | 54 Mechanical fault in the main Circuit Breaker 704-52A at Anta(RS). |


| S.No | Element Name | Type | Owner | Outage | | Outage days | Reason / Remarks |
|----------|---|------|-----------|------------|--------|-------------|--|
| C | ICT | | | | | | |
| 1 | 400/220 kV 315 MVA ICT 1 at Bhilwara(rs) | ICT | RRVNL | 12-05-2019 | 23:42 | 919 | Oil leakage in transformer. Expected revival in Dec-2021. |
| 2 | 400/220 kV 315 MVA ICT 1 at Muradnagar_1(UP) | ICT | UPPTCL | 13-03-2020 | 02:46 | 614 | Bucholz relay alarm and Local Breaker Backup protection operated. Tripped along with Hapur-Muradnagar line. Flags are not reset because of cable flashover. To be replaced by 500 MVA ICT. Expected revival in Dec-2021. |
| 3 | 400/220 kV 315 MVA ICT 2 at Bawana(DV) | ICT | DTL | 30-03-2021 | 17:35 | 231 | 400kV side B-phase bushing blasted. Tripped on differential protection, REF protection. ICT catches fire and damaged. |
| 4 | 400/220 kV 500 MVA ICT 2 at Noida Sec 148(UP) | ICT | UPPTCL | 19-08-2020 | 16:30 | 455 | 500 MVA ICT-I also got damaged due to fire in ICT-II, for protection testing. Expected revival in Oct-2021. |
| 5 | 400/220 kV 315 MVA ICT 2 at Mundka(DV) | ICT | DTL | 20-09-2019 | 00:419 | 789 | Due to fire in ICT. |
| 6 | 400/220 kV 315 MVA ICT 2 at Parbati Pooling Banala(PG) | ICT | POWERGRID | 31-10-2021 | 15:50 | 16 | DGA violation has found in 400/220KV 315MVA ICT-2 (B-Phase) at GIS Banala. During testing of transformer oil Acetylene (17.7ppm) and Hydrogen (132ppm) have increased beyond the violation limits. |
| 7 | 400/220 KV 315 MVA ICT 2 AT BHILWARA(RS) | ICT | RRVNL | 01-11-2021 | 10:24 | 16 | For Necessary testing of transformer by protection wing |
| D | BUS REACTOR | | | | | | |
| 1 | 80 MVAR Bus Reactor No 1 at 400KV Nathpa Jhakri(SJ) | BR | SJVNL | 17-10-2019 | 12:58 | 761 | Flashover/Fault in 80MVAR Bus Reactor cleared by Bus Bar Protection. Expected revival in Nov-2021. |
| E | FSC | | | | | | |
| 1 | FSC(40%) of 400 KV Kanpur-Ballabgarh (PG) Ckt-2 at Ballabgarh(PG) | FSC | POWERGRID | 23-10-2021 | 13:37 | 24 | Bypassed due to operation of R-phase capacitor unbalance protection. |

| F | GENERATING UNITS | | | | | |
|------|--------------------------------|-------|--|-------------|-------------|--------------------------|
| S.No | Station | Owner | Outage Reason | Outage Date | Outage Time | Outage duration(in days) |
| 1 | 40 MW Sewa-II HPS - UNIT 2 | NHPC | Excessive leakage in HRT between audit-II and Dam. Expected by Jan-2022. | 25-09-2020 | 00:00 | 418 |
| 2 | 40 MW Sewa-II HPS - UNIT 3 | NHPC | Excessive leakage in HRT between audit-II and Dam. Expected by Jan-2022. | 25-09-2020 | 00:00 | 418 |
| 3 | 40 MW Sewa-II HPS - UNIT 1 | NHPC | Excessive leakage in HRT between audit-II and Dam. Expected by Jan-2022. | 25-09-2020 | 00:00 | 418 |
| 4 | 600 MW RGTPP (Khedar) - UNIT 2 | HVPNL | Capital Overhauling. Expected date to be confirmed from HVPNL. Expected by Dec-2021. | 02-03-2021 | 00:00 | 260 |
| 5 | 66 MW Pong HPS - UNIT 4 | BBMB | Failure of compressed air system of Breaking. Expected by Oct-2021 end. | 28-07-2021 | 15:00 | 111 |
| 6 | 250 MW Chhabra TPS - UNIT 4 | RRVNL | Due to ESP structure damage | 09-09-2021 | 00:47 | 69 |
| 7 | 250 MW Chhabra TPS - UNIT 3 | RRVNL | Due to ESP Structure damage | 09-09-2021 | 03:00 | 69 |
| 8 | 210 MW Unchahar TPS - UNIT 2 | NTPC | Over hauling | 10-10-2021 | 00:35 | 38 |
| 9 | 270 MW Goindwal(GVK) - UNIT 2 | PSPCL | Coal Shortage | 17-10-2021 | 00:00 | 31 |





Mundka_DTL FOR OCTOBER-2021




ZOOM

DATE

SCROLL

Bawana_DTL FOR OCTOBER-2021




ZOOM

DATE

SCROLL

Bamnoli_DTL FOR OCTOBER-2021




ZOOM

DATE

SCROLL

Sikar_PG FOR OCTOBER-2021




ZOOM

DATE

SCROLL

Kanpur_PG

Kanpur_PG FOR OCTOBER-2021





ZOOM

DATE

SCROLL

Hissar_PG

Hissar_PG FOR OCTOBER-2021



ZOOM


DATE

SCROLL

Jaipur South_PG

Jaipur South_PG FOR OCTOBER-2021

MW MVAR 400 KV 220 KV 765 KV



ZOOM


DATE

SCROLL

Kanpur_PG

Kanpur_PG FOR OCTOBER-2021

MW MVAR 400 KV 220 KV 765 KV





ZOOM

DATE

SCROLL

Maharani Bagh_PG

Maharani Bagh_PG FOR OCTOBER-2





ZOOM

DATE

SCROLL

Malerkotla_PG



Malerkotla_PG FOR OCTOBER-2021



ZOOM

DATE

SCROLL



REFERENCE FOR MAJOR CONTINGENCIES IN ANPARA COMPLEX


STUDY ASSUMPTIONS:

- All India Peak case has been used for the study.
- The case was scaled to match with the real-time loadings during peak hours in present scenario.
- The base case generation of stations at Anpara Complex is given here

| Generating Station | Base Case Generation (MW) |
|--------------------|---------------------------|
| Anpara – A & B | 1360 |
| Anpara – C | 1100 |
| Anpara – D | 950 |
| Singrauli | 1800 |
| Rihand – I & II | 1830 |
| Obra | 495 |

- HVDC Vindhyachal kept in blocked condition in base case.
- HVDC Rihand – Dadri – 1500 MW

CONTINGENCY STUDY:



- The sensitivity of all generations at Anpara Complex on the major line loadings is given here under the base case scenario. The same can be referred to, in real time, for managing the line loadings at Anpara Complex.

| TRANSMISSION ELEMENT | SENSITIVITY OF GENERATION & HVDC | | | | | | | |
|--|----------------------------------|-----------|----------------|------------|---------|------------|---------------------|--------------------------|
| | RIHAND - III | SINGRAULI | ANPARA - A & B | ANPARA - C | OBRA | ANPARA - D | RIHAND - DADRI HVDC | HVDC Vindhyachal (NR-WR) |
| 400kV Singrauli-Anpara | 40.5% | 4.6% | -79.8% | -2.5% | 66.7% | -18.9% | -39.9% | -45.0% |
| 400kV Singrauli-Lucknow | 5.5% | 0.4% | -3.3% | -0.2% | -4.8% | 1.3% | -5.5% | -6.0% |
| 400 kV Singrauli - Allahbad 1 | 7.2% | 1.8% | -4.8% | 0.5% | -11.5% | 3.8% | -6.8% | -9.0% |
| 400 kV Singrauli - Allahbad 2 | 8.1% | 1.8% | 18.5% | -17.6% | -12.1% | 3.4% | -7.5% | -9.5% |
| 400 kV Singrauli - Allahbad 3 | 7.4% | 1.8% | -4.8% | 0.4% | -11.5% | 5.9% | -7.1% | -9.3% |
| 400 kV Singrauli - Rihand D/C (Each Circuit) | -37.4% | 8.1% | 35.4% | 0.4% | -7.9% | -47.8% | -21.3% | -6.0% |
| 400 kV Rihand - Allahbad D/C (Each Circuit) | 11.8% | -5.5% | -3.3% | 0.4% | -7.9% | 2.3% | -11.7% | -6.5% |
| 400kV Anpara-Obra | 8.8% | 1.3% | 5.7% | 1.6% | -102.4% | 33.3% | -8.9% | -10.0% |
| 400kV Anpara-Mau | 5.5% | 0.4% | 1.9% | 0.9% | -18.2% | 5.1% | -4.5% | -5.8% |
| 400kV Anpara-Sarnath-D/C (Each Ckt) | 5.9% | 0.7% | 2.4% | 0.9% | -21.2% | 6.1% | -5.1% | -6.5% |
| 765kV Anpara C - Unnao | 7.0% | 0.7% | 3.6% | 8.4% | -49.7% | 14.1% | -7.5% | -7.8% |
| 765kV Anpara D - Unnao | 6.8% | 0.7% | 3.3% | 7.8% | -47.3% | 14.3% | -7.5% | -7.5% |
| 400kV Obra- Rewa Road | 3.1% | 0.7% | 2.9% | 0.7% | -2.4% | 0.0% | -3.2% | -3.8% |
| 400kV Obra-Sultanpur1 | 3.3% | 0.2% | 1.0% | 1.3% | -4.2% | -0.2% | -3.1% | -3.5% |
| 765/400kV Unnao ICT-1,2 & 3 (Each ICT) | 4.6% | 0.2% | 2.4% | 5.3% | -31.5% | 9.3% | -4.9% | -5.0% |

(+ve sensitivity indicate reduction in generation or HVDC Power Order will reduce the line flows, whereas -ve sensitivity indicate reduction in reduction in generation or HVDC Power Order will increase the line flows)

Load flow study was conducted for some worst contingencies is given here & observations are summarized after it.

| TRANSMISSION LINE FLOW | BASE CASE LOADING | HVDC RIHAND DADRI SINGLE POLE OUTAGE | HVDC RIHAND DADRI BOTH POLES OUTAGE | 765 kV ANPARA - C - UNNAO TRIPPING ALONG WITH OUTAGE OF HVDC RIHAND DADRI BOTH POLES | 765 kV ANPARA - C - UNNAO & ANPARA D - UNNAO TRIPPING ALONG WITH OUTAGE OF HVDC RIHAND DADRI BOTH POLES | 765 kV ANPARA D - UNNAO WITH 2 ICTS AT UNNAO TRIPPING ALONG WITH OUTAGE OF HVDC RIHAND DADRI BOTH POLES |
|--|-------------------|--------------------------------------|-------------------------------------|--|---|---|
| HVDC RIHAND - DADRI | 1500 | 750 | 0 | 0 | 0 | 0 |
| 400kV Singrauli-Anpara | 129 | 428 | 728 | 506 | -215 | -405 |
| 400kV Singrauli-Lucknow | 295 | 336 | 376 | 415 | 485 | 433 |
| 400 kV Singrauli - Allahbad 1 | 298 | 349 | 409 | 442 | 488 | 457 |
| 400 kV Singrauli - Allahbad 2 | 330 | 386 | 453 | 490 | 541 | 506 |
| 400 kV Singrauli - Allahbad 3 | 310 | 363 | 426 | 460 | 508 | 476 |
| 400 kV Singrauli - Rihand D/C (Each Circuit) | 66 | 226 | 521 | 498 | 251 | 487 |
| 400 kV Rihand - Allahbad D/C (Each Circuit) | 229 | 317 | 405 | 428 | 430 | 438 |
| 400kV Anpara-Obra | 560 | 627 | 694 | 816 | 1071 | 872 |
| 400kV Anpara-Mau | 344 | 378 | 412 | 467 | 604 | 491 |
| 400kV Anpara-Sarnath-D/C (Each Ckt) | 441 | 479 | 516 | 576 | 727 | 604 |
| 765kV Anpara C - Unnao | 834 | 890 | 947 | 0 | 0 | 1107 |
| 765kV Anpara D - Unnao | 821 | 877 | 934 | 1351 | 0 | 0 |
| 400kV Obra- Rewa Road | 289 | 313 | 337 | 383 | 480 | 404 |
| 400kV Obra-Sultanpur1 | 346 | 369 | 393 | 463 | 526 | 456 |
| 765/400kV Unnao ICT-1,2 & 3 (Each ICT) | 548 | 585 | 622 | 445 | 0 | 1097 |

1. Outage of HVDC Rihand Dadri Poles

- In case of tripping of one or both poles of HVDC Rihand – Dadri, no constraint was found to have hit in base case. Whereas, in real-time the loading of lines can be regulated by deciding suitable power order of HVDC Vindhyachal as per the sensitivity table given above.

2. Outage of HVDC Rihand Dadri Poles & contingency at 765 kV Level

- In case of 765 Kv Anpara - C - Unnao tripping along with outage of HVDC Rihand Dadri both Poles, the loading of lines at Anpara complex were found to be remaining within the (N-1) limits in base case. However, under real-time conditions, loading may be controlled by regulating HVDC flows.
- In case of 765 Kv Anpara - C - Unnao & Anpara D - Unnao tripping along with outage of HVDC Rihand Dadri both Poles, loading of 400 kV Anpara - Mau, Anpara – Sarnath D/C, Anpara – Obra was found to be breaching (N-1) limits.

- Under this case, generation backdown in proposed at Anpara A & B, Anpara C & Anpara D stations. The generation backdown at these stations can be done on pro-rata basis in order to bring down the line loadings.

| Transmission Line | Sensitivity on line loading of Generation at Anpara A & B, Anpara C & Anpara D |
|-----------------------------|--|
| 400 kV Anpara – Mau | 12% |
| 400 kV Anpara – Sarnath D/C | 12% |
| 400 kV Anpara - Obra | 22% |

- c) In case of 765 kV Anpara D - Unnao with 2 ICTs at Unnao tripping along with HVDC Rihand Dadri both Poles, loading of 400 kV Anpara - Mau, Anpara – Sarnath D/C, Anpara – Obra & 765/400 kV ICT at Unnao was found to be breaching (N-1) limits.

- Under this case, generation backdown in proposed at Anpara A & B, Anpara C & Anpara D stations. The generation backdown at these stations can be done on the basis of sensitivity table given below in order to bring down the line loadings.

| Transmission Line | Sensitivity on line loading of Generation at Anpara A & B | Sensitivity on line loading of Generation at Anpara C & Anpara D |
|-------------------------|---|--|
| 400 kV Anpara – Mau | 10% | 10% |
| 400 kV Anpara – Sarnath | 10% | 10% |
| 400 kV Anpara - Obra | 20% | 20% |
| 765/400 kV ICT at Unnao | 10% | 15% |

3. Outage of HVDC Rihand Dadri Poles & contingency at 400 kV Level

| SERIAL NO. | TRIPPED ELEMENTS | OVERLOADED ELEMENTS (N-1) | SUGGESTED ACTION |
|------------|---|---|---|
| 1 | 400 kV Anpara – Sarnath one circuit along with outage of Rihand – Dadri Both Poles | Not Observed in base case | Action may be taken depending upon real-time grid conditions |
| 2 | 400 kV Anpara – Mau along with outage of Rihand – Dadri Both Poles | Not Observed in base case | Action may be taken depending upon real-time grid conditions |
| 3 | 400 kV Rihand – Allahabad S/C along with outage of Rihand – Dadri Both Poles | Not Observed in base case | Action may be taken depending upon real-time grid conditions |
| 4 | 400 kV Singrauli – Allahabad S/C along with outage of Rihand – Dadri Both Poles | 400 kV Anpara - Singrauli | Generation Backdown at Singrauli (Sensitivity = 54%) & Rihand (Sensitivity = 48%) |
| 5 | Two circuits of 400 kV Singrauli – Allahabad along with outage of Rihand – Dadri Both Poles | 400 kV Anpara - Singrauli | Generation Backdown at Singrauli (Sensitivity = 54%) & Rihand (Sensitivity = 48%) |
| 6 | 400 kV Rihand - Allahabad along with outage of Rihand – Dadri Both Poles | 400 kV Anpara - Singrauli | Generation Backdown at Rihand (Sensitivity = 48%) |
| 7 | 400 kV Singrauli - Allahabad along with outage of Rihand – Dadri Both Poles | 400 kV Anpara – Singrauli & 400 kV Rihand – Singrauli D/C | Generation Backdown at Rihand (Sensitivity of 42% & 49% on the line loadings) |
| 8 | 400 kV Anpara – Sarnath D/C along with outage of Rihand – Dadri Both Poles | 400 kV Anpara - Obra | Generation Backdown at Anpara – A & B (20%), Anpara – C (15%), Anpara – D (15%) |
| 9 | 400 kV Anpara – Sarnath S/C, 400 kV Anpara - Mau along with outage of Rihand – Dadri Both Poles | 400 kV Anpara - Obra | Generation Backdown at Anpara – A & B (22%), Anpara – C (15%), Anpara – D (15%) |

| Sr No | Element Name | Outage Date | Outage Time | Reason |
|-------|---|-------------|-------------|--|
| 1 | 400 KV Suratgarh(RVUN)-Ratangarh(RS) (RS) Ckt-2 | 15-Oct-21 | 23:06 | Overvoltage. As per PMU, No fault observed. |
| | | 16-Oct-21 | 1:29 | Overvoltage. As per PMU, No fault observed. |
| | | 17-Oct-21 | 18:13 | B-N fault. As per PMU, Y-N fault occurred, no auto-reclosing observed. |
| | | 18-Oct-21 | 18:03 | B-N fault, fault Current- 6.228 kA, 42.53 Km from suratgarh end. As per PMU, Y-N fault occurred, no auto-reclosing observed. |
| | | 20-Oct-21 | 2:57 | R-N fault. As per PMU, Y-N fault occurred, no auto-reclosing observed. |
| 2 | 400 KV Agra-Unnao (UP) Ckt-1 | 18-Oct-21 | 12:51 | CB Pole discrepancy , CB trip ckt 1/2 faulty. No Flag in relay. As per PMU, No fault observed. |
| | | 28-Oct-21 | 22:27 | R-N Fault, Fault current 18.43kA, Dist. 0.340km from Agra end. As per PMU, R-N fault occurred, no auto-reclosing observed. |
| | | 31-Oct-21 | 21:16 | R-N Fault, Fault current 5.074kA, Dist. 63.28km from Agra end. As per PMU, R-N fault and unsuccessful auto-reclosing observed. |
| 3 | 400 KV Alaknanda GVK(UPC)-Srinagar(UK) (UK) Ckt-1 | 15-Oct-21 | 12:44 | Tripped only from Srinagar end. As per PMU, No fault observed. |
| | | 16-Oct-21 | 16:16 | DT received at Srinagar end. Line remained charged from Alaknanda end. As per PMU, No fault observed. |
| | | 17-Oct-21 | 6:14 | D T Received, 86A 86B oprtd. at Srinagar. As per PMU, B-N fault occurred, no auto-reclosing observed. |
| 4 | 400 KV Kishenpur-NewWanpoh (PG) Ckt-3 | 11-Oct-21 | 2:06 | R-N fault. As per PMU, R-N fault and unsuccessful auto-reclosing observed. |
| | | 23-Oct-21 | 9:36 | R-N fault. As per PMU, R-N fault and unsuccessful auto-reclosing observed. |
| | | 23-Oct-21 | 10:05 | R-N fault. As per PMU, R-N fault and unsuccessful auto-reclosing observed. |
| 5 | 220 KV Alusteng(JK)-Drass(JK) (PDD JK) Ckt-1 | 17-Oct-21 | 1:05 | R-N fault. As per PMU, R-N fault occurred, no auto-reclosing observed. |
| | | 26-Oct-21 | 2:06 | R-N fault. As per PMU, R-N fault occurred, no auto-reclosing observed. |
| | | 26-Oct-21 | 3:26 | R-N fault, Dist. 38.16km, Fault current 0.435kA from Drass. As per PMU, R-N fault occurred, no auto-reclosing observed. |

| | | | | |
|---|---|-----------|-------|---|
| | | 26-Oct-21 | 4:03 | R-N fault. As per PMU, R-N fault occurred, no auto-reclosing observed. |
| 6 | 220 KV Phozal(HP)-Nallagarh(PG) (ADHPL) Ckt-1 | 5-Oct-21 | 8:31 | Tripped from Phozal end due to alarm of low SF6 gas pressure (in GIS). As per PMU, No fault observed. |
| | | 9-Oct-21 | 20:14 | R-N fault. As per PMU, R-N fault occurred, no auto-reclosing observed. |
| | | 10-Oct-21 | 19:11 | False Alarm false alarm/tripping of low SF6 gas pressure in breaker chamber of Bay no 201 Phojal -ADHPL. As per PMU, No fault observed. |
| | | 15-Oct-21 | 9:21 | R-N fault. As per PMU, R-N fault occurred, no auto-reclosing observed. |

| Generation Loss(MW) | Load Loss(MW) | Category as per CEA Grid Standards | Energy Unserved (in MU) | Preliminary Report receipt status | | | DR/EL receipt status | | | Detailed Report receipt status | | Fault Clearance time (in ms) |
|---------------------|---------------|------------------------------------|-------------------------|-----------------------------------|----------------|---|----------------------|-------------------|---|---|--------------|------------------------------|
| | | | | within 24Hours | after 24Hours | Not Received | within 24Hours | after 24Hours | Not Received | Received | Not Received | |
| 0 | 0 | GI-2 | 0 | | | Y(PG) Y(EDEN) (AHEJOL) Y(RSWPL) Y(RSJ3PL) | | | Y(PG) Y(EDEN) (AHEJOL) Y(RSWPL) Y(RSJ3PL) | Y(PG) Y(EDEN) (AHEJOL) Y(RSWPL) Y(RSJ3PL) | NA | |
| 0 | 0 | GI-1 | 0 | Y(Raj) | Y(NTPC) | | | Y(Raj) Y(NTPC) | | Y(Raj) Y(NTPC) | 320 | |
| 150 | 0 | GD-1 | 0 | Y(SJVNL), Y(PG) | | | Y(SJVNL), Y(PG) | | | Y(SJVNL) | 80 | |
| 0 | 0 | GI-2 | 0 | Y(NTPC) | | Y(UP) | | Y(NTPC) | Y(UP) | Y(NTPC) Y(UP) | 920 | |
| 0 | 0 | GI-2 | 0 | | Y(PG) Y(UP) | Y(NTPC) | Y(PG) | Y(UP) | Y(NTPC) | Y(PG) Y(UP) | 80 | |

| Generation Loss(MW) | Load Loss(MW) | Category as per CEA Grid Standards | Energy Unserved (in MU) | Preliminary Report receipt status | | | DR/EL receipt status | | | Detailed Report receipt status | | Fault Clearance time (in ms) |
|---------------------|---------------|------------------------------------|-------------------------|-----------------------------------|---------------------------|--------------|----------------------|---------------------------|--------------|--------------------------------|--------------|------------------------------|
| | | | | within 24Hours | after 24Hours | Not Received | within 24Hours | after 24Hours | Not Received | Received | Not Received | |
| 0 | 0 | GI-2 | 0 | | Y(UP) | | | Y(UP) | | Y(UP) | | 80 |
| 0 | 95 | GD-1 | 0.18 | Y(Pun) | Y(PG) | | | Y(PG) | Y(Pun) | Y(PG) | | NA |
| 0 | 0 | GI-2 | 0 | | Y(UP) | | | Y(UP) | | Y(UP) | | 80 |
| 270 | 0 | GD-1 | 0.27 | | Y(UP) Y(NHPC) Y(PG) | Y(Utt) | | Y(UP) Y(NHPC) Y(PG) | Y(Utt) | Y(UP) | | 1800 |
| 0 | 0 | GI-2 | 0 | Y(UP) | | | Y(UP) | | | Y(UP) | | 320 |
| 0 | 0 | GI-2 | 0 | Y(Har) | | Y(PG) | | Y(Har) | Y(PG) | Y(Har) | Y(PG) | 400 |

| Generation Loss(MW) | Load Loss(MW) | Category as per CEA Grid Standards | Energy Unserved (in MU) | Preliminary Report receipt status | | | DR/EL receipt status | | | Detailed Report receipt status | | Fault Clearance time (in ms) |
|---------------------|---------------|------------------------------------|-------------------------|-----------------------------------|------------------|--------------|----------------------|---------------|--------------|--------------------------------|--------------|------------------------------|
| | | | | within 24Hours | after 24Hours | Not Received | within 24Hours | after 24Hours | Not Received | Received | Not Received | |
| 100 | 0 | GD-1 | 0 | Y(UP) | | | Y(UP) | | | Y(UP) | | NA |
| 60 | 0 | GD-1 | 0.3 | | Y(NHPC) Y(HP) | Y(BBMB) | | Y(NHPC) | | Y(NHPC) | | NA |

Northern Regional inter regional lines tripping for October-21

Annexure-I

| S. No. | Name of Transmission Element Tripped | Owner/ Utility | Outage | | Load Loss/ Gen. Loss | Brief Reason (As reported) | Category as per CEA Grid standards | Restoration | | # Fault Clearance Time (>100 ms for 400 kV and 160 ms for 220 kV) | *FIR Furnished (YES/NO) | DR/EL provided in 24 hrs (YES/NO) | Other Protection Issues and Non Compliance (inference from PMU, utility details) | Suggestive Remedial Measures | Remarks |
|--------|--|----------------|-----------|-------|----------------------|--|------------------------------------|-------------|-------|---|-------------------------|-----------------------------------|--|--|--|
| | | | Date | Time | | | | Date | Time | | | | | | |
| 1 | 800 KV HVDC Kurukshetra(PG) Pole-2 | POWERGRID | 1-Oct-21 | 9:20 | Nil | Pole-2 blocked at instability detection due to tap hunting in transformer. | NA | 1-Oct-21 | 9:58 | NA | Yes(After 24Hrs) | Yes(After 24Hrs) | | | From PMU, three phase fault is observed in the system. |
| 2 | 400 KV Gorakhpur(PG)-Muzaffarpur(PG) (POWERLINK) Ckt-1 | POWERLINK | 2-Oct-21 | 8:22 | Nil | Over voltage. | NA | 2-Oct-21 | 9:33 | NA | NO | NO | Details of the tripping yet to be received. | Voltage and time grading of 400kV lines for Stage-I overvoltage tripping from Gorakhpur & Muzaffarpur station needs to be checked. | From PMU, No fault observed in the system. |
| 3 | 800 KV HVDC Agra-Bishwanath Chariali (PG) Ckt-1 | POWERGRID | 2-Oct-21 | 12:06 | Nil | DC line earth fault,FD=1560.3km from Agra(NER Jurisdiction). | NA | 2-Oct-21 | 13:38 | NA | NO | NO | | Details of the tripping yet to be received. | From PMU, No AC system fault observed. |
| 4 | 400 KV Balia-Patna (PG) Ckt-2 | POWERGRID | 3-Oct-21 | 16:50 | Nil | Y-N fault. | GI-2 | 3-Oct-21 | 17:31 | NO | Yes(After 24Hrs) | Yes(After 24Hrs) | No auto-reclosing observed. | A/R needs to be checked and corrected. | From PMU, Y-N fault is observed in the system and auto-reclosing not observed. |
| 5 | 765 KV Phagi(RS)-Gwalior(PG) (PG) Ckt-2 | POWERGRID | 5-Oct-21 | 13:17 | Nil | Y-N fault, Zone-1, Dist. 186.2km, Fault current 3.5kA from Phagi end. | GI-2 | 5-Oct-21 | 14:40 | NO | Yes(After 24Hrs) | NO | | | From PMU, Y-N fault is observed in the system and unsuccessful auto-reclosing is observed. |
| 6 | 220 KV Sahupuri(UP)-Pusauli(BS) (UP) Ckt-1 | UPPTCL | 6-Oct-21 | 11:08 | Nil | R-B fault. | NA | 6-Oct-21 | 16:30 | NO | Yes(After 24Hrs) | Yes(After 24Hrs) | | | From PMU, R-B fault is observed in the system. |
| 7 | 220 KV Auraiya(NT)-Mehgaon(MP) (PG) Ckt-1 | POWERGRID | 12-Oct-21 | 2:40 | Nil | R-N fault. | NA | 12-Oct-21 | 4:42 | NO | Yes | Yes | No auto-reclosing observed. | A/R needs to be checked and corrected. | From PMU, R-N fault is observed in the system and auto-reclosing not observed. |
| 8 | 400 KV Vindhyachal(PG)-Vindhyachal(NT) (PG) Ckt-2 | POWERGRID | 18-Oct-21 | 20:28 | Nil | Over voltage. | NA | 19-Oct-21 | 1:33 | NA | Yes(After 24Hrs) | Yes(After 24Hrs) | | Voltage and time grading of 400kV lines for Stage-I overvoltage tripping from Vindhyachal station needs to be checked. | From PMU, No fault observed in the system. |
| 9 | 765 KV Chittorgarh-Banaskantha (PG) Ckt-1 | POWERGRID | 26-Oct-21 | 13:01 | Nil | Tripped on operation of over voltage Protection stage 1 at 765kv Chittorgarh . | GI-2 | 26-Oct-21 | 16:00 | NA | NO | NO | Details of the tripping yet to be received. | Voltage and time grading of 765kV lines for Stage-I overvoltage tripping from Chittorgarh station needs to be checked. | From PMU, No fault observed in the system. |

Fault Clearance time has been computed using PMU Data from nearest node available and/or DR provided by respective utilities (Annexure- II)

*Yes, if written Preliminary report furnished by constituent(s)

R-Y-B phase sequencing (Red, Yellow, Blue) is used in the list content.All information is as per Northern Region unless specified.

^^ tripping seems to be in order as per PMU data, reported information. However, further details may be awaited.

Reporting of Violation of Regulation for various issues for above tripping

| | | |
|---|---|--|
| 1 | Fault Clearance time(>100ms for 400kV and >160ms for 220kV) | 1. CEA Grid Standard-3.e 2. CEA Transmission Planning Criteria |
| 2 | DR/EL Not provided in 24hrs | 1. IEGC 5.2(r) 2. CEA Grid Standard 15.3 |
| 3 | FIR Not Furnished | 1. IEGC 5.9.6.a 2. CEA Grid Standard 12.2 (Applicable for SLDC, ALDC only) |
| 4 | Protection System Mal/Non Operation | 1. CEA Technical Standard of Electrical Plants and Electric Lines: 43.4.A 2. CEA (Technical Standards for connectivity to the Grid) Regulation, 2007: Schedule Part 1. (6.1, 6.2, 6.3) |
| 5 | A/R non operation | 1. CEA Technical Standard of Electrical Plants and Electric Lines: 43.4.C 2. CEA Technical Planning Criteria |

| S. No. | Utility | 1st Oct 2021 - 31st Oct 2021 | | | | | | | | | | | |
|--------|------------------------|------------------------------|---|-----|-------------------------------------|--|-------------------------------------|-----------------------------|--|-----------------------------|--------------------------------|---|--------------------------------|
| | | Total No. of tripping | First Information Report (Not Received) | | Disturbance Recorder (Not Received) | Disturbance Recorder (NA) as informed by utility | Disturbance Recorder (Not Received) | Event Logger (Not Received) | Event Logger (NA) as informed by utility | Event Logger (Not Received) | Tripping Report (Not Received) | Tripping Report (NA) as informed by utility | Tripping Report (Not Received) |
| | | | Value | % | Value | % | Value | % | Value | % | Value | % | |
| 1 | ACME | 1 | 1 | 100 | 1 | 0 | 100 | 1 | 0 | 100 | 1 | 0 | 100 |
| 2 | AD HYDRO | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 3 | AHEJOL | 2 | 2 | 100 | 2 | 0 | 100 | 2 | 0 | 100 | 2 | 0 | 100 |
| 4 | ANTA-NT | 8 | 1 | 13 | 1 | 2 | 17 | 1 | 3 | 20 | 1 | 0 | 13 |
| 5 | APTFI | 1 | 1 | 100 | 1 | 0 | 100 | 1 | 0 | 100 | 1 | 0 | 100 |
| 6 | AURAIYA-NT | 5 | 2 | 40 | 2 | 0 | 40 | 3 | 0 | 60 | 1 | 0 | 20 |
| 7 | BAIRASUIL-NH | 4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 8 | BBMB | 14 | 4 | 29 | 6 | 5 | 67 | 6 | 5 | 67 | 5 | 0 | 36 |
| 9 | BUDHIL | 3 | 3 | 100 | 2 | 0 | 67 | 2 | 0 | 67 | 2 | 0 | 67 |
| 10 | CHAMERA-III-NH | 2 | 0 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 0 | 0 |
| 11 | CHAMERA-II-NH | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 12 | CPCC1 | 45 | 25 | 56 | 24 | 5 | 60 | 25 | 7 | 66 | 25 | 4 | 61 |
| 13 | CPCC2 | 53 | 2 | 4 | 9 | 2 | 18 | 2 | 3 | 4 | 25 | 0 | 47 |
| 14 | CPCC3 | 41 | 10 | 24 | 10 | 6 | 29 | 9 | 5 | 25 | 10 | 2 | 26 |
| 15 | DADRI-NT | 1 | 1 | 100 | 1 | 0 | 100 | 1 | 0 | 100 | 1 | 0 | 100 |
| 16 | DHAULIGANGA-NH | 2 | 0 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 0 | 0 |
| 17 | DULHASTI-NH | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 18 | EDEN (ERCPL) | 1 | 1 | 100 | 1 | 0 | 100 | 1 | 0 | 100 | 1 | 0 | 100 |
| 19 | KISHENGANGA-NH | 1 | 0 | 0 | 0 | 1 | 0 | 0 | 1 | 0 | 0 | 0 | 0 |
| 20 | KOLDAM-NT | 2 | 2 | 100 | 2 | 0 | 100 | 2 | 0 | 100 | 2 | 0 | 100 |
| 21 | NAPP | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 22 | NJPC | 2 | 1 | 50 | 1 | 0 | 50 | 1 | 0 | 50 | 2 | 0 | 100 |
| 23 | RAMPUR | 4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 24 | RAPPA | 6 | 3 | 50 | 6 | 0 | 100 | 5 | 0 | 83 | 6 | 0 | 100 |
| 25 | RAPPB | 3 | 2 | 67 | 2 | 0 | 67 | 2 | 0 | 67 | 2 | 0 | 67 |
| 26 | RENEW SUN WAVES(RSWPL) | 1 | 1 | 100 | 1 | 0 | 100 | 1 | 0 | 100 | 1 | 0 | 100 |
| 27 | RSEJ3PL | 1 | 1 | 100 | 1 | 0 | 100 | 1 | 0 | 100 | 1 | 0 | 100 |
| 28 | SALAL-NH | 2 | 0 | 0 | 0 | 1 | 0 | 0 | 2 | 0 | 0 | 0 | 0 |
| 29 | SAURYA | 2 | 2 | 100 | 2 | 0 | 100 | 2 | 0 | 100 | 2 | 0 | 100 |
| 30 | SBSRPC-11 | 2 | 2 | 100 | 2 | 0 | 100 | 2 | 0 | 100 | 2 | 0 | 100 |
| 31 | SEWA-2-NH | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 32 | SLDC-CHD | 1 | 1 | 100 | 1 | 0 | 100 | 1 | 0 | 100 | 1 | 0 | 100 |
| 33 | SLDC-DV | 14 | 1 | 7 | 7 | 1 | 54 | 7 | 1 | 54 | 7 | 0 | 50 |
| 34 | SLDC-HP | 15 | 0 | 0 | 0 | 7 | 0 | 0 | 7 | 0 | 0 | 1 | 0 |
| 35 | SLDC-HR | 15 | 3 | 20 | 5 | 2 | 38 | 5 | 2 | 38 | 3 | 0 | 20 |
| 36 | SLDC-JK | 19 | 5 | 26 | 5 | 14 | 100 | 5 | 14 | 100 | 8 | 5 | 57 |
| 37 | SLDC-PS | 21 | 4 | 19 | 11 | 4 | 65 | 11 | 4 | 65 | 19 | 0 | 90 |
| 38 | SLDC-RS | 49 | 0 | 0 | 28 | 0 | 57 | 28 | 0 | 57 | 27 | 0 | 55 |
| 39 | SLDC-UK | 19 | 14 | 74 | 13 | 1 | 72 | 19 | 0 | 100 | 16 | 0 | 84 |
| 40 | SLDC-UP | 130 | 25 | 19 | 32 | 21 | 29 | 35 | 27 | 34 | 29 | 1 | 22 |
| 41 | INDIGRID | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3 | 0 | 100 |

| S. No. | Name of the Generating Station (Capacity in MW) | Date of last PSS tuning / re-tuning performed (in DD/MM/YYYY format) | Date of last Step Response Test performed (in DD/MM/YYYY format) | Report submitted to NRLDC/NRPC (Yes/ No) | Remarks (if any) | Tentative schedule for PSS tuning / re-tuning in FY 2021-22 |
|----------------|---|---|---|--|---|---|
| 1 THDC | | | | | | |
| | TEHRI HPS(4 * 250) | 07/01/2019 to 10/01/2019 | 07/01/2019 to 10/01/2019 | Yes | (Report shared vide email dt.19.01.2019) | |
| | KOTESHWAR HPS(4 * 100) | 17/03/2019 to 19/03/2019 | 17/03/2019 to 19/03/2019 | Yes | (Report shared vide email dt.11.02.2021) | |
| 2 SJVNL | | | | | | |
| | NATHPA-JHAKRI HPS(Unit1 #250) | 10.03.2020 | - | No | Excitation system upgraded in 2020 | |
| | NATHPA-JHAKRI HPS(Unit2 #250) | 14.03.2013 | - | No | The existing excitation system is very old and obsoleted forwhich support for PSS tuning is not available from OEM (Mls Voith Hydro), although NJHPS, SJVN has placed work order on 08/12/2015. Further being the critical component, it is not possible"to get the PSS tuning done from any other vender except OEM (Mls Voith Hydro) being the system and software specific job. Therefore, prposal for upgradation of the excitation system of this unit is under process and PSS tuning shall be carried out during upgradation of excitation system. | 3rd Quarter |
| | NATHPA-JHAKRI HPS(Unit3 #250) | 03.03.2020 | - | No | Excitation system upgraded in 2020 | |
| | NATHPA-JHAKRI HPS(Unit4 #250) | 14.03.2013 | - | NO | The existing excitation system is very old and obsoleted forwhich support for PSS tuning is not available from OEM (Mls Voith Hydro), although NJHPS, SJVN has placed work order on 08/12/2015. Further being the critical component, it is not possible"to get the PSS tuning done from any other vender except OEM (Mls Voith Hydro) being the system and software specific job. Therefore, prposal for upgradation of the excitation system of this unit is under process and PSS tuning shall be carried out during upgradation of excitation system. | 3rd Quarter |
| | NATHPA-JHAKRI HPS(Unit5 #250) | 14.05.2016 | 14.05.2016 | NO | Excitation system upgraded in 2013 | 3rd Quarter |
| | NATHPA-JHAKRI HPS(Unit6 #250) | 14.05.2017 | 14.05.2017 | NO | Excitation system upgraded in 2013 | 3rd Quarter |
| | RAMPUR HEP(6 * 68.67) | 29.11.2014 | 27.10.2020,10.02.2012 1 | YES | PSS tuning was done at the time of commissioning of Excitation System by OEM (M/s BHEL). Since then response of PSS is checked regularly and found satisfactory. | |
| 3 HVPNL | | | | | | |
| | PANIPAT TPS(unit1# 250) | 29.03.2016 | 29.03.2016 | YES | -- | 3rd Quarter |
| | PANIPAT TPS(unit2# 250) | 15.01.2018 | 15.01.2018 | YES | -- | 3rd Quarter |
| | DCRTPP (YAMUNA NAGAR)(unit1#300) | 12/19/2018 | 12/19/2018 | YES | (Report attached) | 3rd Quarter |
| | DCRTPP (YAMUNA NAGAR)(unit1#300) | | | | Will be carried out shortly | |
| | RGTPP(KHEDAR) (2*600) | 5th to 6th July 2013 | 5th to 6th July 2013 | Report attached. Previous record being looked into | No MW capacity addition after 2013 at RGTPP Khedar. No new line addition in vicinity of station | |
| | JHAJJAR(CLP) (2*660) | 5/20/2017 | 5/20/2017 | YES | -- | 3rd Quarter |
| 4 NTPC | | | | | | |
| | Rihand (Unit1#500) | 3/3/2017 | 3/3/2017 | YES | Next test will be done during re-commissioning of unit after O/H | 3rd Quarter |
| | Rihand (Unit2#500) | 7/2/2016 | 7/2/2016 | YES | Next test will be done during re-commissioning of unit after O/H | 3rd Quarter |
| | Rihand (Unit3#500) | 8/15/2015 | 8/15/2015 | YES | Next test will be done during re-commissioning of unit after O/H | 3rd Quarter |
| | Rihand (Unit4#500) | 5/25/2017 | 5/25/2017 | YES | Next test will be done during re-commissioning of unit after O/H | 3rd Quarter |

| | | | | | | |
|----------|--|-------------|-------------|-----|---|-------------|
| | Rihand (Unit4#500) | 12/11/2014 | 12/11/2014 | YES | Next test will be done during re-commissioning of unit after O/H | 3rd Quarter |
| | Rihand (Unit5#500) | 12/11/2014 | 12/11/2014 | YES | Next test will be done during re-commissioning of unit after O/H | 3rd Quarter |
| | SINGRAULI STPS(Unit1#200) | - | - | - | Not done in last three years | |
| | SINGRAULI STPS(Unit2#200) | - | - | - | Not done in last three years | |
| | SINGRAULI STPS(Unit3#200) | - | - | - | Not done in last three years | |
| | SINGRAULI STPS(Unit4#200) | - | - | - | Not done in last three years | |
| | SINGRAULI STPS(Unit5#200) | - | - | - | Not done in last three years | |
| | SINGRAULI STPS(Unit6#500) | 02.05.2018 | 02.05.2018 | NO | -- | 3rd Quarter |
| | SINGRAULI STPS(Unit7#500) | 15.07.2018 | 15.07.2018 | NO | -- | 3rd Quarter |
| | UNCHAHAR I(2 * 210) | 3/29/2016 | 3/29/2016 | YES | -- | 3rd Quarter |
| | UNCHAHAR II TPS(unit1# 210) | 7/13/2019 | 7/13/2019 | YES | -- | |
| | UNCHAHAR II TPS(unit2# 210) | 8/10/2018 | 10-08-2018 | YES | -- | 3rd Quarter |
| | UNCHAHAR UNIT6#500 | - | 31.03.2017 | YES | -- | 3rd Quarter |
| | KOLDAM HPS(4 * 200) | 7/1/2015 | 7/1/2015 | YES | -- | 3rd Quarter |
| | DADRI GPS(2 * 154.51) (ST- Steam Turbine) | - | 11/18/2015 | YES | -- | 3rd Quarter |
| | ANTA GPS(3 * 88.71)(GT- Gas Turbine) | 8/8/2014 | 8/8/2014 | YES | -- | 3rd Quarter |
| | ANTA GPS(1 * 153.2)(ST- Steam Turbine) | 8/8/2014 | 8/8/2014 | YES | -- | 3rd Quarter |
| 5 | Aravali Power Company Private Ltd | | | | | |
| | ISTPP (JHAJJAR)(3 * 500) | - | 8/25/2015 | YES | -- | 3rd Quarter |
| 6 | NHPC | | | | | |
| | CHAMERA HPS (3*180) | 8/6/2020 | 12/27/2019 | YES | -- | |
| | CHAMERA II HPS(3 * 100) | 10/11/2015 | 10/11/2015 | NO | Replacement of Excitation system in two units | 3rd Quarter |
| | CHAMERA III HPS(Unit1#77) | 10/29/2015 | 1/7/2012 | YES | -- | 3rd Quarter |
| | CHAMERA III HPS(Unit2,3#77) | 10/29/2015 | 6/19/2012 | YES | -- | 3rd Quarter |
| | PARBATI III HEP (Unit1# 130) | 1/21/2016 | 1/21/2016 | YES | Have been done recetly. The report on PSS turning shall be submitted seperately. | 3rd Quarter |
| | DULHASTI HPS(Unit2#130) | 1/21/2020 | 1/21/2020 | YES | -- | |
| | DULHASTI HPS(Unit1#130) | 12/29/2019 | 12/29/2019 | YES | -- | |
| | URI HPS(Unit3# 120) | 1/10/2021 | 1/10/2021 | YES | -- | |
| | URI HPS(Unit4# 120) | 2/15/2021 | 2/15/2021 | YES | -- | |
| | URI HPS(Unit2# 120) | 3/7/2016 | 3/7/2016 | YES | -- | 3rd Quarter |
| | URI-II HPS(4 * 60) | Mar-14 | Mar-14 | | Re-tunning& Step response test shall be carriedout in 2021-22 | |
| | SALAL HPS (Unit-3,4,5,6 # 115) | 12/16/2014 | 12/16/2014 | YES | -- | 3rd Quarter |
| | KISHANGANGA(3 * 110) | 18-05-20 18 | 18-05-20 18 | YES | -- | 3rd Quarter |
| | BAIRASIUL HPS(3 * 60) | 7/30/2015 | 7/30/2016 | YES | -- | 3rd Quarter |
| | SEWA-II HPS(3 * 40) | 7/9/2016 | 7/9/2016 | YES | -- | 3rd Quarter |
| | PARBATI III HEP(4 * 130) | 12/16/2016 | 12/16/2016 | YES | -- | 3rd Quarter |
| | TANAKPUR HPS(Unit1# 31.42) | 1/9/2015 | 1/9/2015 | YES | -- | 3rd Quarter |
| | TANAKPUR HPS(Unit2,3#31.4) | 5/24/2014 | 5/24/2014 | YES | -- | 3rd Quarter |
| | DHAULIGANGA HPS(Unit1 ,2# 70) | 5/4/2014 | 4/17/2018 | YES | -- | 3rd Quarter |
| | DHAULIGANGA HPS(Unit3,4# 70) | 6/26/2014 | 4/17/2018 | YES | -- | 3rd Quarter |
| 7 | PUNJAB | | | | | |
| | RAJPURA(NPL) TPS(2 * 700) | 4/22/2014 | 4/22/2014 | YES | -- | 3rd Quarter |
| 8 | Rajasthan | | | | | |
| | KAWAI TPS(Unt1# 660) | 8/8/2014 | 8/8/2014 | YES | -- | 3rd Quarter |
| | KAWAI TPS(Unt2# 660) | 10/9/2014 | 10/9/2014 | YES | -- | 3rd Quarter |
| | KOTA TPS (2*110+2*195+3*210) | 4/17/2015 | 4/17/2015 | YES | This is date of last test performed on unit 4 and 5 ,other units test were performed at earlier date. | 3rd Quarter |
| | CHHABRA TPS(Unit 1#250) | 5/22/2018 | 5/22/2018 | NO | -- | 3rd Quarter |

| | | | | | | |
|----------|----------------------------------|---|------------|-----|---|-------------|
| | CHHABRA TPS(Unit 2,3,4#250) | 10/4/2015 | 10/4/2015 | NO | -- | 3rd Quarter |
| | CHHABRA TPS(Unit5# 660) | 2/10/2016 | 2/10/2016 | YES | -- | 3rd Quarter |
| | CHHABRA TPS(Unit6# 660) | 7/28/2018 | 7/28/2018 | YES | -- | 3rd Quarter |
| | KALISINDH TPS(Unit1# 600) | 2/10/2016 | 2/10/2016 | YES | -- | 3rd Quarter |
| | KALISINDH TPS(Unit2# 600) | 2/8/2016 | 2/8/2016 | YES | -- | 3rd Quarter |
| | KOTA TPS(Unit1#110) | 1/2/2015 | 1/2/2015 | NO | | 3rd Quarter |
| | KOTA TPS(Unit2#110) | 9/16/2014 | 9/16/2014 | NO | -- | 3rd Quarter |
| | KOTA TPS(Unit3#195) | 10/14/2019 | 10/14/2019 | NO | -- | |
| | KOTA TPS(Unit4#195) | 3/6/2020 | 3/6/2020 | NO | -- | |
| | KOTA TPS(Unit2#110) | 9/18/2014 | 9/18/2014 | NO | -- | 3rd Quarter |
| | KOTA TPS(Unit2#110) | 9/16/2014 | 9/16/2014 | NO | -- | 3rd Quarter |
| | KOTA TPS(Unit2#110) | 9/16/2014 | 9/16/2014 | NO | -- | 3rd Quarter |
| | SURATGARH TPS (Unit1#250) | 3/14/2019 | 3/14/2019 | NO | -- | |
| | SURATGARH TPS (Unit2#250) | 2/6/2016 | 2/6/2016 | Yes | -- | 3rd Quarter |
| | SURATGARH TPS (Unit3,4,5,6#250) | 1/12/2016 | 1/12/2016 | Yes | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit1# 135) | 4/26/2016 | 4/26/2016 | No | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit2# 135) | 7/14/2016 | 7/14/2016 | No | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit3# 135) | 1/3/2014 | 1/3/2014 | No | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit4# 135) | 11/3/2015 | 11/3/2015 | No | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit5# 135) | 9/21/2014 | 9/21/2014 | No | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit6# 135) | 8/14/2014 | 8/14/2014 | No | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit7# 135) | 2/20/2016 | 2/20/2016 | No | -- | 3rd Quarter |
| | RAJWEST (IPP) LTPS(Unit8# 135) | 6/11/2014 | 6/11/2014 | No | | 3rd Quarter |
| 9 | UTTAR PRADESH | | | | | |
| | ANPARA-C TPS(Unit1# 600) | 8/22/2015 | 8/22/2015 | Yes | -- | 3rd Quarter |
| | ANPARA-C TPS(Unit2# 600) | 3/8/2016 | 3/8/2016 | Yes | -- | 3rd Quarter |
| | ROSA TPS(Unit1 #300) | 2/3/2017 | 2/3/2017 | Yes | -- | 3rd Quarter |
| | ROSA TPS(Unit2# 300) | 18/2/2018 | 18/2/2018 | Yes | -- | 3rd Quarter |
| | ROSA TPS(Unit3 # 300) | 2/3/2017 | 2/3/2017 | Yes | -- | 3rd Quarter |
| | ROSA TPS(Unit4# 300) | 2/3/2017 | 2/3/2017 | Yes | -- | 3rd Quarter |
| | Anpara-A (Unit1#210) | 01.05.2016 | 19.02.2021 | No | -- | 3rd Quarter |
| | Anpara-A(Unit2#210) | 17.11.2017 | 17.11.2017 | No | -- | 3rd Quarter |
| | Anpara-A(Unit3#210) | 25.09.2020 | 25.09.2020 | No | -- | 3rd Quarter |
| | Anpara-B(Unit4#500) | 07.12.2014 | 07.12.2014 | Yes | Overhauling is overdue since 2014 and is proposed in Nov., 2021 PSS tuning/SRT will be done at same time. | 3rd Quarter |
| | Anpara-B (Unit5#500) | 17.08.2014 | Dec., 2019 | Yes | -- | |
| | Anpara-D(Unit6#500) | 15.11.2016 | 15.11.2016 | No | -- | 3rd Quarter |
| | Anpara-D (Unit7#500) | 15.04.2017 | 15.04.2017 | No | -- | 3rd Quarter |
| | Obra-B(Unit9#200) | 22.03.2016 | 22.03.2016 | Yes | Report enclosed. | 3rd Quarter |
| | Obra-B(Unit10#200) | 28.06.2016 | 20.06.2016 | Yes | Report enclosed. | 3rd Quarter |
| | Obra-B (Unit11#200) | 21.01.2017 | 21.01.2017 | Yes | Report enclosed. | 3rd Quarter |
| | Obra-B (Unit12#200) | Unit taken on load after R&M on 22 January, | | - | PSS tuning and SRT scheduled in April, 2021. | |
| | Obra-B(Unit13#200) | Unit closed under R&M. | | - | PSS tuning and SRT scheduled in April, 2021. | |
| | Parichha-B(Unit3#210) | 08.01.2016 | 08.01.2016 | Yes | -- | 3rd Quarter |
| | Parichha-B (Unit4#210) | 08.01.2016 | 08.01.2016 | Yes | -- | 3rd Quarter |
| | Parichha-C (Unit5#250) | 08.02.2020 | 08.02.2020 | No | -- | |
| | Parichha-C(Unit3#250) | 09.01.2016 | 09.01.2016 | No | -- | 3rd Quarter |
| | Harduaganj (Unit8#250) | 20.08.2015 | 20.08.2015 | No | -- | 3rd Quarter |
| | Harduaganj (Unit3#250) | 13.04.2016 | 13.04.2016 | No | -- | 3rd Quarter |
| | Harduaganj(Unit7#105) | 16.07.2021 | 16.07.2021 | yes | -- | |

| | | | | | | |
|-----------|-------------------------------|------------|------------|-----|---|-------------|
| | Harduaganj(Unit9#250) | 16.07.2021 | 16.07.2021 | yes | -- | |
| | LALITPUR TPS(Unit1# 660) | 19.05.2017 | 19.05.2017 | yes | -- | 3rd Quarter |
| | LALITPUR TPS(Unit1# 660) | 30.03.2021 | 30.03.2021 | yes | -- | |
| | LALITPUR TPS(Unit1# 660) | 24.08.2017 | 24.08.2017 | yes | -- | 3rd Quarter |
| | ALAKHANANDA HEP(Unit1# 82.5) | 12.072017 | 12.072017 | No | -- | 3rd Quarter |
| | ALAKHANANDA HEP(Unit2# 82.5) | 12.072017 | 12.072017 | No | -- | 3rd Quarter |
| | ALAKHANANDA HEP(Unit3# 82.5) | 12.072017 | 12.072017 | No | -- | 3rd Quarter |
| | ALAKHANANDA HEP(Unit4# 82.5) | 12.072017 | 12.072017 | No | -- | 3rd Quarter |
| | MEJA TPS(Unit1#660) | 16.10.2018 | 05.09.2017 | yes | -- | 3rd Quarter |
| | MEJA TPS(Unit2#660) | 16.01.2021 | 18.05.2020 | yes | -- | |
| 10 | BBMB | | | | | |
| | BHAKRA HPS(Unit1#108) | -- | -- | No | PSS is not provided ,shall be provided in ongoing RM&U | |
| | BHAKRA HPS(Unit1#108) | 24.07.2015 | 24.07.2015 | No | -- | 3rd Quarter |
| | BHAKRA HPS(Unit3#126) | -- | -- | No | PSS is not provided ,shall be provided in ongoing RM&U | |
| | BHAKRA HPS(Unit4#126) | -- | -- | No | -- | |
| | BHAKRA HPS(Unit5#126) | -- | -- | No | -- | |
| | BHAKRA HPS(Unit6#157) | -- | -- | No | The original Rusian excitation system is under replacement PO issued Hence,PSS not got tuned. | |
| | BHAKRA HPS(Unit7#157) | -- | -- | No | The original Rusian excitation system is under replacement PO issued Hence,PSS not got tuned. | |
| | BHAKRA HPS(Unit7#157) | -- | -- | No | The original Rusian excitation system is under replacement PO issued Hence,PSS not got tuned. | |
| | BHAKRA HPS(Unit7#157) | 18.02.2016 | 18.02.2016 | No | -- | 3rd Quarter |
| | BHAKRA HPS(Unit7#157) | 18.02.2017 | 18.02.2017 | No | -- | 3rd Quarter |
| | DEHAR HPS(Unit#1 165) | 08.08.2017 | 08.08.2017 | No | -- | 3rd Quarter |
| | DEHAR HPS(Unit#2 165) | 08.08.2018 | 08.08.2018 | No | -- | 3rd Quarter |
| | DEHAR HPS(Unit#3 165) | 08.08.2019 | 08.08.2019 | No | -- | |
| | DEHAR HPS(Unit#4 165) | 02.07.2017 | 02.07.2017 | No | -- | 3rd Quarter |
| | DEHAR HPS(Unit#5 165) | 08.08.2019 | 08.08.2019 | No | -- | |
| | DEHAR HPS(Unit#6 165) | 02.07.2017 | 02.07.2017 | No | -- | 3rd Quarter |
| | PONG HPS(6 * 66) | -- | -- | -- | PSS not provided.RM&U agenda under considration. | |

पावर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड
(भारत सरकार का उद्यम)
POWER SYSTEM OPERATION CORPORATION LIMITED
(A Govt. of India Enterprise)



उत्तरी क्षेत्रीय भार प्रेशण केन्द्र / NORTHERN REGIONAL LOAD DESPATCH CENTRE
कार्यालय : 18-ए, शहीद जीत सिंह सनसनवाल मार्ग, कटवारिया सराय, नई दिल्ली- 110016
OFFICE : 18-A, Shaheed Jeet Singh Sansanwal Marg, Katwaria Sarai, New Delhi- 110016
CIN : U40105DL2009GOI188682, Website : www.nrldc.org, www.nrldc.in, Tel.: 011- 26519406, 26523869, Fax : 011- 26852747

संदर्भ संख्या: NRLDC/SO-II/TS-13/

दिनांक: 28 अक्टूबर 2021

सेवा मे,

वितरण सूची के अनुसार

विषय: Reactive resources data compilation regarding.

महोदय,

Reactive Power document of Northern Region needs to be reviewed/updated in consultation with all users, STU, SLDC, CTU and RPC secretariat. Document was last updated in December 2020. Subsequently, there has been addition of several new generation and transmission elements in Northern Regional Grid. Therefore, the document is due for revision. The same has also been discussed in recent 188th OCC meeting as well.

Please find attached the details available with NRLDC on the above subject in respect of your organization/control area under following groups (Details format/data is given at **Annexure-I**).

- 1) List of HVDC, 765kV, 400kV and 220kV transmission line
- 2) List of Line reactors
- 3) List of Bus Reactors
- 4) List of FSC/TCSC & SVC
- 5) List of tertiary reactors on 33kV side of 400/ 220/ 33 kV ICT's.
- 6) List of shunt capacitors
- 7) Tap changer details of ICT's or GT's
- 8) List of Over Voltage setting of 400kV & above transmission line
- 9) Cable information of 220 kV and above transmission line (with MVA generation)
- 10) Generator reactive power capability curve for Generating stations including renewable generators (Check the existing details in the document)
- 11) Complete details are available at the link
<https://docs.google.com/spreadsheets/d/16fxC5MJb17oiKbQDv5Jz9vSJD7hxpL-7/edit?usp=sharing&ouid=101952646418859842988&rtpof=true&sd=true>

The present version of Reactive Power Document of NRLDC is available at following URL:

<https://nrldc.in/download/nr-reactive-power-management-2021/?wpdmdl=8772>

The document is password protected with following password: **nrrpm@2021**

It is requested that the concerned may please be advised to go through the above list and corrections/deletions/additions if any, be advised to us along with the data for new facilities expected to be available during 2020-21 & 2021-22 in same format, by 30th नवम्बर 2021.

The information, feedback & comments may please also be e-mailed to: nrldcso2@posoco.in, nrldcso2@gmail.com

धन्यवाद,

भवदीय,
आलोक
(आलोक कुमार)
महाप्रबंधक

Annexure-1

Formats

1) Details of 765kV, 400kV & 220kV lines

| Sl.No. | Utility | Name of Line | Ckt | KM | Conductor |
|--------|---------|--------------|-----|----|-----------|
| | | | | | |
| | | | | | |

2) Details of Line reactor

| Sl.No | Utility | Name of Line | Ckt | Rating of reactor (MVAR) | Installed at Station | Switchable ** | Provision to use as bus reactor | Healthiness |
|-------|---------|--------------|-----|--------------------------|----------------------|---------------|---------------------------------|-------------|
| | | | | | | | | |
| | | | | | | | | |

**** Switchable means provision of separate breaker for reactor other than line circuit breaker**

3) Details of Bus reactor

| Sl.No | Utility | Name of Substation | Rating of reactor (MVAR) | Healthiness |
|-------|---------|--------------------|--------------------------|-------------|
| | | | | |
| | | | | |

4) Details of FSC/TCSC& SVC

| Sl. No. | Utility | Line on which FSC/TCSC is installed | Substation | Make | Capacity | % compensation | kV rating of Bus on which capacitor is installed |
|---------|---------|-------------------------------------|------------|------|----------|----------------|--|
| | | | | | | | |
| | | | | | | | |

| S.No. | SVC Located at | ID | Rating MVAR | Remarks |
|-------|----------------|----|-------------|---------|
| 1 | | | | |
| 2 | | | | |

5) Details of shunt capacitor

9) Cable information of 220 kV and above transmission line:

| S. No. | Voltage level | Name of line | Length | Charging MVAR |
|---------------|----------------------|---------------------|---------------|----------------------|
| | | | | |
| | | | | |

Distribution list:

1. Managing Director, Delhi Transco Ltd., Shakti Sadan Building Kotla Road, New Delhi-110 002
2. General Manager (SLDC), Delhi Transco Ltd., SLDC Building, 33kV Substation Building, Minto Road, New Delhi-110 002.
3. Chairman & Managing Director, Rajasthan Rajya Vidyut Prasaran Nigam Limited, Vidyut Bhawan, Janpath, Jaipur- 302005
4. Chief Engineer(LD), State Load Despatch Centre, Rajasthan Rajya Vidyut Prasaran Nigam Ltd., Ajmer Road, Heerapura, Jaipur-302024
5. Chairman & Managing Director, Punjab State Transmission Corporation Ltd. Regd. Office, PSEB Head office, The Mall, Patiala-147 001.
6. Chief Engineer (SLDC), SLDC Building, near 220KV grid substation, PSTCL, Ablowal, Patiala-147001.
7. Managing Director, PTCUL, Vidyut Bhawan, Near I.S.B.T. crossing, Sharanpur Road, Majra, Dehradun-248 001.
8. Chief Engineer(SLDC), Vidyut Bhawan, Saharanpur Road, Majra, Near ISBT, Dehradun-248001, Uttarakhand
9. Managing Director, HPSEB Limited, Kumar House, Vidyut Bhawan, Shimla-171 004Himachal Pradesh.
10. Director (SLDC), HP State Load Dispatch Centre, Totu, Shimla-171 001.
11. Chairman & Managing Director, Haryana Vidyut Prasaran Nigam Ltd., Shakti Bhawan, Sector-6, Panchkula, Distt. Ambala, Haryana-134 109.
12. Chief Engineer (SO & SLDC), Haryana Vidyut Prasaran Nigam Ltd., Shakti Bhawan, Sector-6, Panchkula, Distt. Ambala, Haryana-134 109. Ph: 0172-2560547.
13. Chief Engineer (Power System), 5th-floor Uttar Pradesh Power transmission Corporation Ltd., Shakti Bhawan, 14-Ashok Marg, Lucknow-226 001.Ph: 2287879.
14. Chairman & Managing Director, Uttar Pradesh Power transmission Corporation Ltd., Shakti Bhawan, 14-Ashok Marg, Lucknow-226 001.
15. Director (SLDC), Vibhuti Khand, Phase-2, Gomti Nagar, Lucknow-226010, Uttar Pradesh
16. Development Commissioner, Power Development Department (J&K),Lottery Building, Behind Civil Secretariat, Srinagar, J&K Pin code: 190009
17. Development Commissioner, Power Development Department (J&K), Grid Station Complex, janipur, Jammu. 0191-2530265
18. Executive Engineer, SLDC Building, 220kV Gladini Grid Station Complex, Narwal Bala, Gladini-180016, J&K.
19. Chief Engineer, UT of Chandigarh (Elec. Deptt. 1st Floor), Sector 9-D, Chandigarh-160019.
20. Superintending Engineer (Elect. Op), UT of Chandigarh (Elec. Deptt. 5th Floor), Sector 9-D, Chandigarh-160019.
21. Director (Operation), Nuclear Power Corporation of India Ltd, 16th Floor, Centre-I, World Trade Centre, Cuffe Parade, Colaba, Mumbai - 400 005, India.
22. Station Director, Narora Atomic Power Station, Narora, Distt.- Bulandshahar, Uttar Pradesh-202389
23. Station Director, Rajasthan Atomic Power Station (B & C), Anu Shakti via Kota, Anu Shakti, Rajasthan-323303
24. Executive Director (OS), NTPC, Core-6, Scope Complex, Lodhi Road-110003, New Delhi
25. Regional Executive Director (NC), NTPC, NCR Headquarters, EOC Building, 11th Floor, OS Dept., Plot No.-8A, Sector-24, Noida, Uttar Pradesh-201301.
26. Regional Executive Director (NR), NTPC, Northern Region Headquarters, TC 33/V-1, Vibhuti Khand, Gomti Nagar, Lucknow-226010.
27. Executive Director (O&M) NHPC Ltd., NHPC Office Complex, Sector-33, Faridabad-121003, Haryana.
28. Chairman and Manager Director, SJVN Ltd, Shakti Sadan, Corporate Office Complex, Shanana, Shimla-171006, Himachal Pradesh.

29. General Manager (OMS, QA & Safety), THDC India Ltd., Pragatipuram, ByPass Road, Rishikesh-249201, Uttarakhand
30. Head of the plant, Karcham Wangtoo Hydro Electric Project (KWHEP), Sholto colony, Post office- Tapri, Tehsil-Nichar, District-Kinnaur (HP), Pincode-172104
31. Chairman, Bhakra Beas Management Board, sector-19-B, Madhya Marg, Chandigarh-160019
32. CEO, Power links Transmission Ltd. 10th Floor, DLF Tower A, District Centre Jasola, New Delhi -110025.
33. CEO, Jaypee Powergrid Ltd., JA House, 63, Basant Lok, Vasant Vihar, New Delhi-110057.Fax: +91 11 26148890, 26142726
34. Executive Director (NR-1), POWERGRID, B-9, Qutub institutional area, Katwaria Sarai, New Delhi-110016
35. Executive Director (NR-2), POWERGRID, Grid Bhawan, Rail Head Complex, Jammu-180012.
36. Executive Director, NR-3, POWERGRID, 12, Maharana Pratap Marg, Near Sikandar Bag Chauraha, Lucknow-226001
37. Director, Adani Power Ltd, Adani House, Plot No.83, Institutional Area, Sector 32, Gurgaon, Haryana-122001
38. Head Plant, Greenko Budhil Hydro Power Project, Village- Thalla, P.O.- Ghared, Tehsil- Bharmour, Distt.-Chamba, Himachal Pradesh-176315.
39. General Manager, Shree Cement TPS, Bangur Nagar, Post Box No. 33, Beawar-305901, Distt.-Ajmer (Rajasthan)
40. Chairman & Managing Director, Parbati Koldam Transmission Company Ltd., JMD Galleria 5th floor, plot no. 12-D, Sector 48, Sohna road Gurgaon-122001
41. Adani Transmission (I) Ltd, 7-A, Sambhav building, Judges Bungalow Road, Bodakdev, Ahmedabad- 380015
42. General Manager, JAYPEE POWERGRID Limited, JA House, 63, Basant Lok, Vasant Vihar, New Delhi-110057
43. The Sr. Manager, RENEW SOLAR POWER Pvt. Ltd, Commercial Block-1, Zone 6, Golf Course Road, DLF City phase-V, Gurugram 122009, Haryana
44. The Vice President, O&M, Azure Power India Pvt Ltd. (Bhadla SPD), 3rd Floor, Asset 301-304 &307, Word Mark-3, Aerocity, New Delhi 110037
45. The Vice President, O&M, SB Energy Four Limited, 1st Floor, Wordmark-2, Asset Area-8 Hospitality, Aerocity, NH-8, Delhi-110037
46. Associate Vice President (BD- HOD), Mahoba Solar (UP) Pvt Ltd, 4th floor, South Wing, Adani Corporate House, Shantigram, Near Vaishnav Devi Circle, SG Highway, Ahmedabad 382421, Gujarat
47. The Project Head, Tata Power Renewable Energy Ltd. , Corporate Centre, A Block, 34, Sant Tukaram Road, Camac Bunder, Mumbai – 400009
48. Manager, O&M Solar, ACME Chittorgarh Solar Energy Pvt. Ltd. Plot #152, Sector - 44, Gurgaon, Haryana-122002
49. AGM, Renew Solar Power Pvt Ltd, Rnew Hub, Commercial Block-1, Zone-6, Golf Course Road, DLF City Phase V, Gurugram-122002 (Haryana)
50. Azure Power Thirty Four Pvt. Ltd, 3rd Floor, Asset 301-304 and 307, World Mark-3, Aerocity, New Delhi - 110037

Copy to:

51. Member Secretary, NRPC, 18-A, SJSS Marg, Katwaria Sarai, Delhi-110016