

Proposed Outage Program of 219th OCC meeting of NRPC

Sr No	Reference Number	OCC Number	Name of Requesting Agency	Element Type	Element Name	Owner	Daily/Continuous	Reason	Requested From Date	Requested From Time	Requested To Date	Requested To Time	Requester Remarks	Request Type	Shutdown Status	NLDC/RLDC Comments
1	RQ177912	OCC_219	tehris_sd	GENERATING UNIT	250 MW TEHRI HPS - UNIT 2	THDC	C	Due to River joining works of Tehri PSP	01/Jun/2024	08:00	30/Jun/2024	23:59	Due to River joining works of Tehri PSP	PLANNED	Requested	
2	RQ177911	OCC_219	tehris_sd	GENERATING UNIT	250 MW TEHRI HPS - UNIT 1	THDC	C	Due to River joining works of Tehri PSP	01/Jun/2024	08:00	30/Jun/2024	23:59	Due to River joining works of Tehri PSP	PLANNED	Requested	
3	RQ177913	OCC_219	tehris_sd	GENERATING UNIT	250 MW TEHRI HPS - UNIT 3	THDC	C	Due to River joining works of Tehri PSP	01/Jun/2024	08:00	30/Jun/2024	23:59	Due to River joining works of Tehri PSP	PLANNED	Requested	
4	RQ177914	OCC_219	tehris_sd	GENERATING UNIT	250 MW TEHRI HPS - UNIT 4	THDC	C	Due to River joining works of Tehri PSP	01/Jun/2024	08:00	30/Jun/2024	23:59	Due to River joining works of Tehri PSP	PLANNED	Requested	
5	RQ177371	OCC_219	koteshwar_sd	GENERATING UNIT	100 MW KOTESHWAR HPS - UNIT 2	THDC	C	Annual Maintenance of Unit-2	01/Jun/2024	10:00	30/Jun/2024	18:00		PLANNED	Requested	
6	RQ177704	OCC_219	koteshwar_sd	GENERATING UNIT	100 MW KOTESHWAR HPS - UNIT 4	THDC	C	Tehri PSP river joining work and removal of existing protection wall at TRT of PSP	01/Jun/2024	08:00	30/Jun/2024	18:00	Plant S/D of Koteshwar HEP is required for Tehri PSP river joining work from 15.05.24 to 30.06.24	PLANNED	Requested	
7	RQ177703	OCC_219	koteshwar_sd	GENERATING UNIT	100 MW KOTESHWAR HPS - UNIT 3	THDC	C	Tehri PSP river joining work and removal of existing protection wall at TRT of PSP	01/Jun/2024	08:00	30/Jun/2024	18:00	Plant S/D of Koteshwar HEP is required for Tehri PSP river joining work from 15.05.24 to 30.06.24	PLANNED	Requested	
8	RQ177702	OCC_219	koteshwar_sd	GENERATING UNIT	100 MW KOTESHWAR HPS - UNIT 2	THDC	C	Tehri PSP river joining work and removal of existing protection wall at TRT of PSP	01/Jun/2024	08:00	30/Jun/2024	18:00	Plant S/D of Koteshwar HEP is required for Tehri PSP river joining work from 15.05.24 to 30.06.24	PLANNED	Requested	
9	RQ177701	OCC_219	koteshwar_sd	GENERATING UNIT	100 MW KOTESHWAR HPS - UNIT 1	THDC	C	Tehri PSP river joining work and removal of existing protection wall at TRT of PSP	01/Jun/2024	08:00	30/Jun/2024	18:00	Plant S/D of Koteshwar HEP is required for Tehri PSP river joining work from 15.05.24 to 30.06.24 .	PLANNED	Requested	
10	RQ177640	OCC_219	ntpcos_sd	GENERATING UNIT	210 MW UNCHAHAR TPS - UNIT 1	NTPC	C	Boiler License Renewal	01/Jun/2024	00:00	05/Jun/2024	23:59	Boiler License valid upto 04.06.2024	PLANNED	Requested	
11	RQ177884	OCC_219	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC AGRA-BISHWANATH CHARIALI (PG) CKT-1		C	Diversion work of 800 KV HVDC BNC-AGRA LINE infringing to Lucknow-Kanpur green Express way of NHAI	23/Jun/2024	08:00	30/Jun/2024	18:00		PLANNED	Requested	
12	RQ177885	OCC_219	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC AGRA-BISHWANATH CHARIALI (PG) CKT-2		C	Diversion work of 800 KV HVDC BNC-AGRA LINE infringing to Lucknow-Kanpur green Express way of NHAI	23/Jun/2024	08:00	30/Jun/2024	18:00		PLANNED	Requested	
13	RQ177972	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-GWALIOR (PG) CKT-1	POWERGRID	D	A/R Non Auto mode required For attending shutdown defects in 765KV-SATNA-ORAI-1 by WR-2	24/Jun/2024	07:00	24/Jun/2024	18:00	A/R non auto mode only	PLANNED	Requested	
14	RQ177971	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-SATNA (PG) CKT-1	POWERGRID	D	To Fix 4 Disc in a string of Loc. 238 and Other Maintenance Work, For Switching of Spare with R-ph (For taking R-ph in Service) by WR-2. Dia to be kept open at Both end	24/Jun/2024	07:00	24/Jun/2024	18:00		PLANNED	Requested	
15	RQ177970	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-JABALPUR (PG) CKT-1	POWERGRID	D	A/R Non Auto mode required For attending shutdown defects in 765KV-JABALPUR-ORAI-2	23/Jun/2024	07:00	23/Jun/2024	18:00	a/r non auto only	PLANNED	Requested	
16	RQ177968	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-JABALPUR (PG) CKT-2	POWERGRID	D	For pilot installation work in line by WR-2 with a/r non auto of ckt-1. Dia to be kept open at Both end.	23/Jun/2024	07:00	23/Jun/2024	18:00		PLANNED	Requested	
17	RQ178527	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH-BANASKANTHA (PG) CKT-2	POWERGRID	D	For attending shutdown defects, Dia to be kept open at both ends.	22/Jun/2024	08:00	22/Jun/2024	18:00	SD by WR2	PLANNED	Requested	
18	RQ178526	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH-BANASKANTHA (PG) CKT-1	POWERGRID	D	A/R Non Auto mode For attending shutdown defects in 765KV-BANASKANTHA-CHITTORGARH-2	22/Jun/2024	08:00	22/Jun/2024	18:00	non auto	PLANNED	Requested	
19	RQ177880	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-JABALPUR (PG) CKT-1	POWERGRID	D	AMP Work	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested	
20	RQ177772	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHPUR-SASARAM (PG) CKT-1	POWERGRID	D	AMP Work	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested	
21	RQ178524	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH-BANASKANTHA (PG) CKT-1	POWERGRID	D	For attending shutdown defects, Dia to be kept open at both ends.	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested	
22	RQ178525	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH-BANASKANTHA (PG) CKT-2	POWERGRID	D	A/R Non Auto mode For attending shutdown defects in 765KV-BANASKANTHA-CHITTORGARH-1	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested	
23	RQ177878	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-SATNA (PG) CKT-1	POWERGRID	D	AMP Work	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
24	RQ177959	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-SATNA (PG) CKT-1	POWERGRID	D	A/R Non Auto mode required For attending shutdown defects in 765KV-SATNA-GWALIOR-2 by WR-2	10/Jun/2024	09:00	10/Jun/2024	18:00	A/R non auto to facilitate shutdown of	PLANNED	Requested	
25	RQ177960	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-GWALIOR (PG) CKT-1	POWERGRID	D	A/R Non Auto mode required For attending shutdown defects in 765KV-SATNA-GWALIOR-2 by WR-2	10/Jun/2024	09:00	10/Jun/2024	18:00	Auto reclose non auto mode only	PLANNED	Requested	
26	RQ177879	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-GWALIOR (PG) CKT-1	POWERGRID	C	Replacement of PDM sensor for arrestersS6 leakage in 707-10R Gas compartments	09/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	

27	RQ177964	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-GWALIOR (PG) CKT-2	POWERGRID	D	A/R in Non-Auto Mode for Tower Strengthening Member fixing work by WR-2. Line will be in Service.	08/Jun/2024	08:00	14/Jun/2024	18:00	A/R in Non-Auto Mode Only	PLANNED	Requested
28	RQ177958	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-GWALIOR (PG) CKT-1	POWERGRID	D	AMP works of Line by WR-2, Dia to be Kept open at both ends	07/Jun/2024	09:00	07/Jun/2024	18:00		PLANNED	Requested
29	RQ177685	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BALIA-GAYA (PG) CKT-1	POWERGRID	D	Insulator Replacement Work	05/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested
30	RQ178523	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-GWALIOR(PG) (PG) CKT-2	POWERGRID	D	AMP works of Line, Dia to be Kept open at both ends.	05/Jun/2024	08:00	05/Jun/2024	18:00	SD request by WR@2	PLANNED	Requested
31	RQ177962	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-GWALIOR (PG) CKT-1	POWERGRID	D	A/R in Non-Auto Mode for Tower Strengthening Member fixing work by WR-2. Line will be in Service.	01/Jun/2024	09:00	07/Jun/2024	18:00	A/R non auto mode only	PLANNED	Requested
32	RQ177955	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-JABALPUR (PG) CKT-1	POWERGRID	D	A/R non auto For OPGW stringing under live line condition by WR-2	01/Jun/2024	07:00	30/Jun/2024	18:00	A/R non auto for liveline OPGW work	PLANNED	Requested
33	RQ177877	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAHUPURI(UP)-BIHARSHARIFF(PG) (PG) CKT-2	POWERGRID, UPPTCL	D	ERLDC RTU UPGRADATION WORK UNDER SIEMENS Y PACKAGE by ER-1	26/Jun/2024	09:00	26/Jun/2024	17:30		PLANNED	Requested
34	RQ177869	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAHUPURI(UP)-BIHARSHARIFF(PG) (PG) CKT-1	POWERGRID, UPPTCL	D	ERLDC RTU UPGRADATION WORK UNDER SIEMENS Y PACKAGE by ER-1	08/Jun/2024	09:00	08/Jun/2024	17:30		PLANNED	Requested
35	RQ177867	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-SASARAM (PG) CKT-1	POWERGRID	D	LBB retrofitting works and SCADA validation for Bay 404, 405 & 404R, 01 Day for Each Bay by ER-1	25/Jun/2024	08:00	28/Jun/2024	20:00		PLANNED	Requested
36	RQ177868	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV VARANASI-SASARAM (PG) CKT-1	POWERGRID	D	LBB retrofitting works and SCADA validation for Bay 401, 402 & 401R, 01 Day for Each Bay by ER-1	20/Jun/2024	08:00	22/Jun/2024	20:00		PLANNED	Requested
37	RQ177740	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-VINDHYACHAL(PG) (PG) CKT-2	POWERGRID	C	Replacement of line CVT at Vindhyaachal under ADD-CAP	12/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
38	RQ177695	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV VARANASI-SASARAM (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	11/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested
39	RQ177794	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-MOTIHARI(BS) (PG) CKT-2	POWERGRID	D	Rectification of S/D nature defects	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
40	RQ177739	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-VINDHYACHAL(PG) (PG) CKT-1	POWERGRID	C	Replacement of line CVT at Vindhyaachal under ADD-CAP	10/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
41	RQ177694	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-SASARAM (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	09/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
42	RQ177676	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-MOTIHARI(BS) (PG) CKT-2	POWERGRID	D	A/R into Non-Auto mode for PID testing	08/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
43	RQ177870	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-BIHARSHARIFF (PG) CKT-2	POWERGRID	D	ERLDC RTU UPGRADATION WORK UNDER SIEMENS Y PACKAGE AT BIHARSHARIF & For rectification of Shutdown nature TL defects. by ER-1 with A/R non auto mode of ckt-1	07/Jun/2024	09:00	07/Jun/2024	17:30		PLANNED	Requested
44	RQ177871	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-BIHARSHARIFF (PG) CKT-1	POWERGRID	D	ERLDC RTU UPGRADATION WORK UNDER SIEMENS Y PACKAGE AT BIHARSHARIF & Replacement of Porcelain by Polymer insulator at major Crossing in TL by ER-1, with A/R non auto mode of ckt-2	05/Jun/2024	09:00	05/Jun/2024	17:30		PLANNED	Requested
45	RQ177682	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-BIHARSHARIFF (PG) CKT-2	POWERGRID	D	RTU Upgradation work by ER-1	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested
46	RQ177681	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-BIHARSHARIFF (PG) CKT-1	POWERGRID	D	RTU Upgradation work by ER-1	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested
47	RQ177675	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-MOTIHARI(BS) (PG) CKT-1	POWERGRID	D	A/R into Non-Auto mode for PID testing	01/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
48	RQ177679	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-PATNA (PG) CKT-2	POWERGRID	D	RTU Upgradation work by ER-1	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested
49	RQ177932	OCC_219	stupp_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAHUPURI(UP)-NEW KARAMNASHA (BS) (BSEB) CKT-1	BSEB	C	* Lilo of 132kv sahpuri karmnasha line at 132kv s/s chandauli as per agreement no date28.03.2023	03/Jun/2024	06:00	08/Jun/2024	18:00		PLANNED	Requested
50	RQ177700	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-BALIA (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	29/Jun/2024	08:00	29/Jun/2024	18:00		PLANNED	Requested
51	RQ177635	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	765 KV MOGA-MEERUT (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects in line.	27/Jun/2024	08:00	29/Jun/2024	18:00	kindly approve	PLANNED	Requested
52	RQ177712	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BAREILLY_2-LUCKNOW_2 (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	24/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested
53	RQ177777	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-FATEHPUR (PG) CKT-2	POWERGRID	D	Rectification of S/D nature defects	21/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested
54	RQ177776	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-FATEHPUR (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
55	RQ177691	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-FATEHPUR (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	18/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
56	RQ177881	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-ALIGARH (PG) CKT-1	POWERGRID	D	AMP Work	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
57	RQ177687	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BALIA-LUCKNOW_2 (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
58	RQ178439	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KANPUR_GIS-ALIGARH (PG) CKT-1	POWERGRID	D	CSD Tuning of Line Reactor	08/Jun/2024	10:00	08/Jun/2024	18:00		PLANNED	Requested

59	RQ177732	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-KANPUR_GIS (PG) CKT-2	POWERGRID	D	Rectification of S/D nature defects	05/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
60	RQ177838	OCC_219	slcrs_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-BHIWANI(PG) (PG) CKT-2	POWERGRID	D	Maintenance line bay Equipments i.e. CVT, WT & line Isolator. alongwith line reactor at Phagi	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
61	RQ177731	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-KANPUR_GIS (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	03/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested
62	RQ178080	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV MOGA-BHIWANI (PG) CKT-1		D	For attending S/D nature defects	29/Jun/2024	08:00	29/Jun/2024	20:00		PLANNED	Requested
63	RQ178163	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KHETRI (PKTSL)-JHATIKARA(PG) (PKTSL) CKT-2		D	Stringing of 765 KV D/C Khetri-Narela TL	29/Jun/2024	07:00	30/Jun/2024	19:00		PLANNED	Requested
64	RQ178162	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KHETRI (PKTSL)-JHATIKARA(PG) (PKTSL) CKT-1		D	Stringing of 765 KV D/C Khetri-Narela TL	29/Jun/2024	07:00	30/Jun/2024	19:00		PLANNED	Requested
65	RQ178066	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-2		D	for AMP works	27/Jun/2024	14:00	29/Jun/2024	23:59		PLANNED	Requested
66	RQ178062	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-1		D	for AMP works	24/Jun/2024	14:00	26/Jun/2024	23:59		PLANNED	Requested
67	RQ177991	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER-BHADLA_2 (PG) CKT-2		D	For S/D nature defect rectification	22/Jun/2024	14:00	22/Jun/2024	18:00	For S/D nature defect rectification	PLANNED	Requested
68	RQ177990	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER-BHADLA_2 (PG) CKT-1		D	For S/D nature defect rectification	21/Jun/2024	14:00	21/Jun/2024	18:00	For S/D nature defect rectification	PLANNED	Requested
69	RQ178074	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-1		D	Rectification of Shutdown nature defects in transmission line.	20/Jun/2024	17:30	21/Jun/2024	23:30	S/D Type defect rectification work	PLANNED	Requested
70	RQ177993	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER-CHITTORGARH (PG) CKT-2		D	For S/D nature defect rectification	20/Jun/2024	14:00	20/Jun/2024	18:00	A/R of Ajmer-Chittor CK1 to be kept in non Auto mode	PLANNED	Requested
71	RQ177992	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER-CHITTORGARH (PG) CKT-1		D	For S/D nature defect rectification	19/Jun/2024	14:00	19/Jun/2024	18:00	A/R of Ajmer-Chittor CK2 to be kept in non Auto mode	PLANNED	Requested
72	RQ178083	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-GWALIOR(PG) (PG) CKT-1		D	For attending S/D nature defects	19/Jun/2024	09:00	20/Jun/2024	18:00		PLANNED	Requested
73	RQ178115	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-2		D	Attending shutdown nature defects	19/Jun/2024	06:00	20/Jun/2024	18:00		PLANNED	Requested
74	RQ178067	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-2		D	For ladder logic and interlock checking for spare reactor commissioning	18/Jun/2024	14:00	25/Jun/2024	23:59		PLANNED	Requested
75	RQ178015	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-GWALIOR(PG) (PG) CKT-2		D	To attend shutdown nature defects	17/Jun/2024	09:00	18/Jun/2024	18:00		PLANNED	Requested
76	RQ178114	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-1		D	Attending shutdown nature defects	17/Jun/2024	06:00	18/Jun/2024	18:00		PLANNED	Requested
77	RQ178183	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA-BIKANER (PG) CKT-2		D	Installation of Bird Diverter	16/Jun/2024	08:00	30/Jun/2024	18:00	NON-AUTO OF OTHER CKT	PLANNED	Requested
78	RQ178181	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER-BHADLA_2 (PG) CKT-2		D	Installation of Bird Diverter	16/Jun/2024	08:00	30/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested
79	RQ178185	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER-BHADLA_2 (PG) CKT-2		D	Installation of Bird Diverter	16/Jun/2024	08:00	30/Jun/2024	18:00	NON-AUTO OF OTHER CKT	PLANNED	Requested
80	RQ178187	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-2		D	Installation of Bird Diverter	16/Jun/2024	08:00	30/Jun/2024	18:00	NON-AUTO OF OTHER CKT	PLANNED	Requested
81	RQ178068	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-2		D	Attending shutdown nature defects by Khetri group & Gantry Tower jumper insulator replacement works	15/Jun/2024	14:00	27/Jun/2024	23:59		PLANNED	Requested
82	RQ178131	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KOTESHWAR-MEERUT (PG) CKT-2		C	For shifting of tower number 79 in to safe location	15/Jun/2024	09:00	30/Jun/2024	18:00		PLANNED	Requested
83	RQ178075	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-2		D	Rectification of Shutdown nature defects in transmission line.	13/Jun/2024	17:30	14/Jun/2024	23:30	S/D Type defect rectification work	PLANNED	Requested
84	RQ178087	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-BHIWANI(PG) (PG) CKT-1		D	For attending S/D nature defects	13/Jun/2024	09:00	14/Jun/2024	18:00		PLANNED	Requested
85	RQ178031	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV MEERUT-BHIWANI (PG) CKT-1		D	RECTIFICATION OF SHUT DOWN DEFECTS	13/Jun/2024	08:00	14/Jun/2024	18:00	S/D Type defect rectification work	PLANNED	Requested
86	RQ178113	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER(PG)-PHAGI(RS) (PAPTL) CKT-2		D	Attending shutdown nature defects	12/Jun/2024	06:00	13/Jun/2024	18:00		PLANNED	Requested
87	RQ178063	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-1		D	Attending shutdown nature defects by Khetri group & For ladder logic and interlock checking for spare reactor commissioning	11/Jun/2024	14:00	18/Jun/2024	23:59		PLANNED	Requested
88	RQ178065	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-1		D	Stringing and erection works of Bhadla 2 ckt 3 & 4, Reactor firewall construction activity	10/Jun/2024	14:00	17/Jun/2024	23:59		PLANNED	Requested
89	RQ178088	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-BHIWANI(PG) (PG) CKT-2		D	For attending S/D nature defects	10/Jun/2024	09:00	11/Jun/2024	18:00		PLANNED	Requested
90	RQ178030	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV JHATIKARA-BHIWANI (PG) CKT-1		D	RECTIFICATION OF SHUT DOWN DEFECTS	10/Jun/2024	08:00	12/Jun/2024	18:00	S/D Type defect rectification work	PLANNED	Requested
91	RQ178112	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER(PG)-PHAGI(RS) (PAPTL) CKT-1		D	Attending shutdown nature defects	10/Jun/2024	06:00	11/Jun/2024	18:00		PLANNED	Requested

92	RQ178070	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-2		D	For ladder logic and interlock checking for spare reactor commissioning/ FOR AMP WORKS	07/Jun/2024	14:00	14/Jun/2024	23:59		PLANNED	Requested	
93	RQ178090	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-JHATIKARA (PG) CKT-1		D	shutdownrelated defect rectification	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested	
94	RQ178034	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA-BIKANER (PG) CKT-1		D	CSD FINE TUNING OF THE REACTOR BAY CSD	06/Jun/2024	18:00	06/Jun/2024	23:30	LINE WITH REACTOR SHUTDOWN REQUIRED	PLANNED	Requested	
95	RQ178064	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-1		D	Gantry Tower jumper insulator replacement works	05/Jun/2024	14:00	15/Jun/2024	23:59		PLANNED	Requested	
96	RQ178130	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KOTESHWAR-MEERUT (PG) CKT-2		D	For wire termination and testing of DTPC	05/Jun/2024	09:00	05/Jun/2024	18:00		PLANNED	Requested	
97	RQ178091	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV JHATIKARA-ALIGARH (PG) CKT-1		D	shutdownrelated defect rectification	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested	
98	RQ178035	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER-BHADLA_2 (PG) CKT-1		D	AMP OF LINE BAY EQUIPMENTS ALONG WITH REACTOR BAY	04/Jun/2024	18:00	04/Jun/2024	23:30	LINE WITH REACTOR SHUTDOWN REQUIRED	PLANNED	Requested	
99	RQ178129	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KOTESHWAR-MEERUT (PG) CKT-1		D	For wire termination and testing of DTPC	04/Jun/2024	09:00	04/Jun/2024	18:00		PLANNED	Requested	
100	RQ178069	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-1		D	For ladder logic and interlock checking for spare reactor commissioning/ FOR AMP WORKS	03/Jun/2024	14:00	10/Jun/2024	23:59		PLANNED	Requested	
101	RQ178014	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-GWALIOR(PG) (PG) CKT-2		D	Non-auto mode for tower tightening & missing tower member fixing above waist level	01/Jun/2024	09:00	30/Jun/2024	18:00		PLANNED	Requested	
102	RQ178013	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-GWALIOR(PG) (PG) CKT-1		D	Non-auto mode for tower tightening & missing tower member fixing above waist level	01/Jun/2024	09:00	30/Jun/2024	18:00		PLANNED	Requested	
103	RQ178182	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA-BIKANER (PG) CKT-1		D	Installation of Bird Diverter	01/Jun/2024	08:00	15/Jun/2024	18:00	NON-AUTO OF OTHER CKT	PLANNED	Requested	
104	RQ178184	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER-BHADLA_2 (PG) CKT-1		D	Installation of Bird Diverter	01/Jun/2024	08:00	15/Jun/2024	18:00	NON-AUTO OF OTHER CKT	PLANNED	Requested	
105	RQ178186	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-1		D	Installation of Bird Diverter	01/Jun/2024	08:00	15/Jun/2024	18:00	NON-AUTO OF OTHER CKT	PLANNED	Requested	
106	RQ178180	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER-BHADLA_2 (PG) CKT-1		D	Installation of Bird Diverter	01/Jun/2024	08:00	15/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested	
107	RQ178032	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER-MOGA (PG) CKT-1		C	Line Diversion work due to infringement with Amritsar-Jamnagar National Highway	01/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested	
108	RQ178033	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER-MOGA (PG) CKT-2		C	Line Diversion work due to infringement with Amritsar-Jamnagar National Highway	01/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested	
109	RQ177843	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANTA-PHAGI (RS) CKT-2		D	Installation, Configuration and Commissioning of New/Repaired line distance protection M-1 Relay (ABB REL 670) by Srevice Engineer in place of existing defective relay. And Half Yearly Maintenance work at both end alongwith 240 MVAR line reactors.	18/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
110	RQ177842	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANTA-PHAGI (RS) CKT-1	RRVPNL	D	Maintenance line bay Equipments i.e. CVT, WT & line Isolator.	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested	
111	RQ177353	OCC_219	stuurp_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA FATEHBAD(UP)-GR.NOIDA_2(UPC) (GTL) CKT-1	RRVPNL	D	For Line AMP works and 80 Mvar reactor spare changeover activity at Fatehabad(Agra) end.	13/Jun/2024	10:00	13/Jun/2024	14:00		PLANNED	Requested	
112	RQ177352	OCC_219	stuurp_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA FATEHBAD(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1	GTL	D	For installation of energy meters under SAMAST project execution by UPPTCL at Fatehabad (Agra) end	12/Jun/2024	10:00	12/Jun/2024	13:00		PLANNED	Requested	
113	RQ177831	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER(PG)-PHAGI(RS) (PAPTL) CKT-1	PAPTL	D	Maintenance line bay Equipments i.e. CVT, WT & line Isolator.	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	
114	RQ178516	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-1	POWERGRID, FBTL	D	for critical jumper rectification work.	01/Jun/2024	17:00	04/Jun/2024	23:00	SD required in 15.05.2024 to 19.05.2024	PLANNED	Requested	
115	RQ178319	OCC_219	cpcc1_sd	BUS	765 KV FATEHGARH_II(PG) - BUS 2		D	for AMP works	20/Jun/2024	14:00	22/Jun/2024	23:00		PLANNED	Requested	
116	RQ178327	OCC_219	cpcc1_sd	BUS	765 KV FATEHGARH_II(PG) - BUS 1		D	Jumpering and bay extension work by M/s TATA for TBCB package SS-01, SS-63 A1 & B1, commissioning works of Bus bar integration work of bay extensions	15/Jun/2024	14:00	28/Jun/2024	23:00		PLANNED	Requested	
117	RQ178318	OCC_219	cpcc1_sd	BUS	765 KV FATEHGARH_II(PG) - BUS 1		D	for AMP works	08/Jun/2024	14:00	12/Jun/2024	23:00		PLANNED	Requested	
118	RQ178328	OCC_219	cpcc1_sd	BUS	765 KV FATEHGARH_II(PG) - BUS 2		D	Jumpering and bay extension work by M/s TATA for TBCB package SS-01, SS-63 A1 & B1, commissioning works of Bus bar integration work of bay extensions	01/Jun/2024	14:00	14/Jun/2024	23:00		PLANNED	Requested	
119	RQ178384	OCC_219	cpcc1_sd	BUS	765 KV BHADLA(PG) - BUS 1	POWERGRID	D	For AMP work	10/Jun/2024	19:00	10/Jun/2024	23:00		PLANNED	Requested	
120	RQ178385	OCC_219	cpcc1_sd	BUS	765 KV BHADLA(PG) - BUS 2	POWERGRID	D	For AMP work	10/Jun/2024	19:00	10/Jun/2024	23:00		PLANNED	Requested	
121	RQ178364	OCC_219	cpcc1_sd	BUS	765 KV BHADLA_2 (PG) - BUS 2	POWERGRID	D	Jumpering and testing works for Bay Extension	07/Jun/2024	17:00	12/Jun/2024	23:00		PLANNED	Requested	

122	RQ178398	OCC_219	cpcc1_sd	BUS	765 KV BIKANER(PG) - BUS 1	POWERGRID	D	AMP Work	04/Jun/2024	15:00	04/Jun/2024	23:00		PLANNED	Requested
123	RQ178363	OCC_219	cpcc1_sd	BUS	765 KV BHADLA_2 (PG) - BUS 1	POWERGRID	D	Jumpering and testing works for Bay Extension	01/Jun/2024	17:00	06/Jun/2024	22:00		PLANNED	Requested
124	RQ178383	OCC_219	cpcc1_sd	BUS	765 KV KHETRI (PG) - BUS 2	PKTSL	D	BAY EXTENSION WORK UNDER PNTL- Jumpering and bus bar stability test of 765KV Bus-II	04/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
125	RQ178382	OCC_219	cpcc1_sd	BUS	765 KV KHETRI (PG) - BUS 1	PKTSL	D	BAY EXTENSION WORK UNDER PNTL- Jumpering and bus bar stability test of 765KV Bus-I	01/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested
126	RQ177365	OCC_219	stuup_sd	BUS	765 KV GHATAMPUR_TP(SUP) - BUS 2	NUPPL	C	The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	it may considered as 31.05.2024	PLANNED	Requested
127	RQ177364	OCC_219	stuup_sd	BUS	765 KV GHATAMPUR_TP(SUP) - BUS 1	NUPPL	C	The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	it may considered as 31.05.2024	PLANNED	Requested
128	RQ177659	OCC_219	stuup_sd	BUS	765 KV JAWAHARPUR_TP(SUP) - BUS 1	UPRVUNL	C	Gas leakage rectification work in compartment G-13 of Bay-710(attached to 765KV GIS Bus-A).	01/Jun/2024	08:00	05/Jun/2024	18:00	There will be no effect on the LILO line, it will keep going through Tie breaker (Bay- 708).	PLANNED	Requested
129	RQ178421	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 1 AT 765KV BHIWANI(PG)	POWERGRID	D	AMP WORK	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
130	RQ178430	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	Ladder logic commissioning with spare reactor logic scheme checking	19/Jun/2024	14:00	25/Jun/2024	23:00		PLANNED	Requested
131	RQ178431	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	Ladder logic commissioning with spare reactor logic scheme checking	15/Jun/2024	14:00	20/Jun/2024	18:00		PLANNED	Requested
132	RQ178432	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	For final testing/fine tuning of CSD Relay of 765KV Reactor	08/Jun/2024	14:00	12/Jun/2024	22:00	during fine tuning of CSD. 4 to 5 on load operations of Reactor will be done from each bay	PLANNED	Requested
133	RQ178434	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	For final testing/fine tuning of CSD Relay of 765KV Reactor	07/Jun/2024	14:00	12/Jun/2024	23:00	during fine tuning of CSD. 4 to 5 on load operations of Reactor will be done from each bay	PLANNED	Requested
134	RQ178429	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	04/Jun/2024	13:00	04/Jun/2024	23:00		PLANNED	Requested
135	RQ178428	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	03/Jun/2024	14:00	03/Jun/2024	23:00		PLANNED	Requested
136	RQ178412	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 2 AT 765 KV KHETRI (PKTSL)	PKTSL	C	For internal inspection and oil leakage attending and CSD fine tuning	13/Jun/2024	08:00	18/Jun/2024	18:00	(Minimum 5 open & close on load operations of Bus Reactor will be carried out during fine tuning of the CSD relay)	PLANNED	Requested
137	RQ178413	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 1 AT 765 KV KHETRI (PKTSL)	PKTSL	C	For internal inspection and oil leakage attending and CSD fine tuning	07/Jun/2024	08:00	12/Jun/2024	18:00	(Minimum 5 open & close on load operations of Bus Reactor will be carried out during fine tuning of the CSD relay)	PLANNED	Requested
138	RQ178458	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 @FATEHGARH_II(PG)	PFTL	D	Ladder logic commissioning with spare reactor logic scheme checking	26/Jun/2024	15:00	28/Jun/2024	23:00		PLANNED	Requested
139	RQ178459	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 @FATEHGARH_II(PG)	PFTL	D	Ladder logic commissioning with spare reactor logic scheme checking	13/Jun/2024	15:00	15/Jun/2024	23:00		PLANNED	Requested
140	RQ178455	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 @FATEHGARH_II(PG)	PFTL	D	AMP WORKS	06/Jun/2024	15:00	08/Jun/2024	23:00		PLANNED	Requested
141	RQ178463	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 @FATEHGARH_II(PG)	PFTL	D	For final testing/fine tuning of CSD Relay of 765KV Reactor	06/Jun/2024	15:00	12/Jun/2024	23:00		PLANNED	Requested

142	RQ178454	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 @FATEHGARH_III(PG)	PFTL	D	AMP WORKS	05/Jun/2024	15:00	07/Jun/2024	22:00			PLANNED	Requested
143	RQ178462	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 @FATEHGARH_III(PG)	PFTL	D	For final testing/fine tuning of CSD Relay of 765KV Reactor	05/Jun/2024	15:00	12/Jun/2024	23:00			PLANNED	Requested
144	RQ178464	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 @FATEHGARH_III(PG)	PFTL	D	Firewall erection works of bhadla 2 ckt 3 & 4	01/Jun/2024	15:00	05/Jun/2024	23:00			PLANNED	Requested
145	RQ178457	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II-BHADLA (PG) CKT-2 @FATEHGARH_III(PG)	POWERGRID	D	Ladder logic commissioning with spare reactor logic scheme checking	23/Jun/2024	15:00	25/Jun/2024	23:00			PLANNED	Requested
146	RQ178456	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-1 @FATEHGARH_III(PG)	POWERGRID	D	Ladder logic commissioning with spare reactor logic scheme checking	20/Jun/2024	15:00	22/Jun/2024	23:00			PLANNED	Requested
147	RQ178445	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BIKANER-BHADLA_2 (PG) CKT-2 @BHADLA_2 (PG)	POWERGRID	D	AMP OF LINE BAY EQUIPMENTS ALONG WITH REACTOR BAY	08/Jun/2024	17:00	08/Jun/2024	23:00			PLANNED	Requested
148	RQ178446	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BIKANER-BHADLA_2 (PG) CKT-1 @BHADLA_2 (PG)	POWERGRID	D	AMP OF LINE BAY EQUIPMENTS ALONG WITH REACTOR BAY	07/Jun/2024	18:00	07/Jun/2024	23:00			PLANNED	Requested
149	RQ178450	OCC_219	cpcc1_sd	LINE REACTOR	330 MVAR SWITCHABLE LR ON 765 KV AJMER-BHADLA_2 (PG) CKT-1 @BHADLA_2 (PG)	POWERGRID	D	AMP OF LINE BAY EQUIPMENTS ALONG WITH REACTOR BAY	06/Jun/2024	18:00	06/Jun/2024	23:00			PLANNED	Requested
150	RQ178447	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA-BIKANER (PG) CKT-1 @BIKANER(PG)	POWERGRID	D	CSD Fine Tuning of 240MVar Line reactor of 765kv Bhadla-Bikaner ckt-1	06/Jun/2024	18:00	06/Jun/2024	23:00			PLANNED	Requested
151	RQ178461	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II-BHADLA (PG) CKT-2 @FATEHGARH_III(PG)	POWERGRID	D	For final testing/fine tuning of CSD Relay of 765KV Reactor	06/Jun/2024	15:00	09/Jun/2024	23:00			PLANNED	Requested
152	RQ178449	OCC_219	cpcc1_sd	LINE REACTOR	330 MVAR SWITCHABLE LR ON 765 KV AJMER-BHADLA_2 (PG) CKT-2 @BHADLA_2 (PG)	POWERGRID	D	AMP OF LINE BAY EQUIPMENTS ALONG WITH REACTOR BAY	05/Jun/2024	18:00	05/Jun/2024	23:00			PLANNED	Requested
153	RQ178453	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II-BHADLA (PG) CKT-2 @FATEHGARH_III(PG)	POWERGRID	D	AMP WORKS	04/Jun/2024	15:00	06/Jun/2024	23:00			PLANNED	Requested
154	RQ178448	OCC_219	cpcc1_sd	LINE REACTOR	330 MVAR SWITCHABLE LR ON 765 KV BIKANER-BHADLA_2 (PG) CKT-1 @BIKANER(PG)	POWERGRID	D	AMP OF LINE BAY EQUIPMENTS ALONG WITH REACTOR BAY	04/Jun/2024	15:00	04/Jun/2024	23:00			PLANNED	Requested
155	RQ178460	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-1 @FATEHGARH_III(PG)	POWERGRID	D	For final testing/fine tuning of CSD Relay of 765KV Reactor	03/Jun/2024	15:00	06/Jun/2024	23:00			PLANNED	Requested
156	RQ178452	OCC_219	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(PG)-BHADLA(PG) (FBTL) CKT-1 @FATEHGARH_III(PG)	POWERGRID	D	AMP WORKS	03/Jun/2024	08:00	05/Jun/2024	18:00			PLANNED	Requested

157	RQ177366	OCC_219	stuup_sd	LINE REACTOR	189 MVAR SWITCHABLE LR ON 765 KV AGRA FATEHBAD(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1 @GHATAMPUR_TP S(UP)		C	The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	1.Jumpering at Take-up tower inside Ghatampur TPS has been kept open for 765kV Agra-Ghatampur including 189MVAr Line Reactor to charge the Line for Anti-Theft charging Purpose.At present Line is Anti-theft charged with 132kV 2. It may considered as 31.05.2024	PLANNED	Requested	
158	RQ178491	OCC_219	cpcc1_sd	BAY	716 MAIN BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	AMP WORK	28/Jun/2024	15:00	29/Jun/2024	23:00		PLANNED	Requested	
159	RQ178489	OCC_219	cpcc1_sd	BAY	717 TIE BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG) (POWERGRID) AND 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	AMP WORK	26/Jun/2024	16:00	27/Jun/2024	23:00		PLANNED	Requested	
160	RQ178488	OCC_219	cpcc1_sd	BAY	710 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	24/Jun/2024	14:00	25/Jun/2024	23:00		PLANNED	Requested	
161	RQ178488	OCC_219	cpcc1_sd	BAY	713 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	22/Jun/2024	15:00	23/Jun/2024	23:00		PLANNED	Requested	
162	RQ178487	OCC_219	cpcc1_sd	BAY	714 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG) (POWERGRID) AND 240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(PG) AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	AMP WORK	20/Jun/2024	15:00	21/Jun/2024	23:00		PLANNED	Requested	
163	RQ178474	OCC_219	cpcc1_sd	BAY	720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AND 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	For erection works of SS-63 A1, B1 & TBCB bay extension.	20/Jun/2024	15:00	27/Jun/2024	23:00		PLANNED	Requested	
164	RQ178486	OCC_219	cpcc1_sd	BAY	707 MAIN BAY - 240 MVAR BUS REACTOR NO.2 AT 765 KV FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	18/Jun/2024	15:00	19/Jun/2024	23:00		PLANNED	Requested	
165	RQ178494	OCC_219	cpcc1_sd	BAY	715 MAIN BAY - 240 MVAR BUS REACTOR NO.1 AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	AMP WORK	18/Jun/2024	15:00	19/Jun/2024	23:00		PLANNED	Requested	
166	RQ178485	OCC_219	cpcc1_sd	BAY	712 MAIN BAY - 765 KV FATEHGARH_II-BHADLA (PG) CKT-1 (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	16/Jun/2024	14:00	17/Jun/2024	23:00		PLANNED	Requested	
167	RQ178484	OCC_219	cpcc1_sd	BAY	712R MAIN BAY - 240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II-BHADLA (PG) CKT-1 @FATEHGARH_II(P G) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	14/Jun/2024	14:00	15/Jun/2024	23:00		PLANNED	Requested	
168	RQ177636	OCC_219	cpcc3_sd	BAY	706 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT LUCKNOW_2(PG) (POWERGRID)	POWERGRID	D	AMP Work	14/Jun/2024	10:00	14/Jun/2024	18:00		PLANNED	Requested	
169	RQ178493	OCC_219	cpcc1_sd	BAY	718 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 (POWERGRID)	POWERGRID	D	AMP WORK	13/Jun/2024	15:00	14/Jun/2024	23:00		PLANNED	Requested	

170	RQ178483	OCC_219	cpcc1_sd	BAY	711 TIE BAY - 765 KV FATEHGARH_II-BHADLA (PG) CKT-1 (POWERGRID) AND 765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG) AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	AMP WORK	12/Jun/2024	15:00	13/Jun/2024	23:00			PLANNED	Requested
171	RQ177634	OCC_219	cpcc1_sd	BAY	708 TIE BAY - 765KV LUCKNOW_2-BAREILLY (PG) CKT-1 AND 240 MVAR BUS REACTOR NO 1 AT 765KV LUCKNOW_2(PG)	POWERGRID	D	AMP Work	12/Jun/2024	10:00	12/Jun/2024	18:00			PLANNED	Requested
172	RQ178482	OCC_219	cpcc1_sd	BAY	709 MAIN BAY - 765 KV FATEHGARH_II-BHADLA (PG) CKT-2 (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	10/Jun/2024	15:00	11/Jun/2024	23:00			PLANNED	Requested
173	RQ178481	OCC_219	cpcc1_sd	BAY	708 TIE BAY - 765 KV FATEHGARH_II-BHADLA (PG) CKT-2 (POWERGRID) AND 240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG) AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	AMP WORK	09/Jun/2024	14:00	10/Jun/2024	22:00			PLANNED	Requested
174	RQ178475	OCC_219	cpcc1_sd	BAY	719 MAIN BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	For erection works of SS-63 A1, B1 & TBCB bay extension.	08/Jun/2024	15:00	15/Jun/2024	23:00			PLANNED	Requested
175	RQ178480	OCC_219	cpcc1_sd	BAY	709R MAIN BAY - 240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II-BHADLA (PG) CKT-2 @FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	07/Jun/2024	14:00	08/Jun/2024	22:00			PLANNED	Requested
176	RQ177459	OCC_219	cpcc2_sd	BAY	709 MAIN BAY - 765/400KV 1500 MVA ICT 1 AT MOGA(PG)	POWERGRID	D	Replacement of SF6 Density Monitor of CB	07/Jun/2024	10:00	07/Jun/2024	18:00	Kindly approve		PLANNED	Requested
177	RQ178492	OCC_219	cpcc1_sd	BAY	721 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-1 (POWERGRID)	POWERGRID	D	AMP WORK	06/Jun/2024	14:00	07/Jun/2024	23:00			PLANNED	Requested
178	RQ177873	OCC_219	cpcc3_sd	BAY	705 TIE BAY - 240 MVAR BUS REACTOR NO 1 AT 765 KV BAREILLY_2(PG) (POWERGRID) AND FUTURE AT 765 KV BAREILLY_2(PG) (POWERGRID)	POWERGRID	D	AMP Work	06/Jun/2024	08:00	06/Jun/2024	18:00			PLANNED	Requested
179	RQ178479	OCC_219	cpcc1_sd	BAY	719 MAIN BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	05/Jun/2024	15:00	06/Jun/2024	23:00			PLANNED	Requested
180	RQ178495	OCC_219	cpcc1_sd	BAY	713 MAIN BAY - 765KV MOGA-BHIWANI (PG) CKT-1 AT BHIWANI(PG)	POWERGRID	D	AMP Work	05/Jun/2024	08:00	05/Jun/2024	18:00			PLANNED	Requested
181	RQ177872	OCC_219	cpcc3_sd	BAY	706 MAIN BAY - 240 MVAR BUS REACTOR NO 1 AT 765 KV BAREILLY_2(PG) (POWERGRID)	POWERGRID	D	AMP Work	04/Jun/2024	08:00	04/Jun/2024	18:00			PLANNED	Requested
182	RQ177458	OCC_219	cpcc2_sd	BAY	707 MAIN BAY - 765KV MOGA-MEERUT (PG) CKT-1 AT MOGA(PG)	POWERGRID	C	Attending SF6 Leakage in CB (B-ph) Attending SF6 Leakage in CB (B-ph)	04/Jun/2024	08:00	06/Jun/2024	18:00	Kindly approve		PLANNED	Requested
183	RQ178478	OCC_219	cpcc1_sd	BAY	720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AND 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	AMP WORK	03/Jun/2024	15:00	04/Jun/2024	23:00			PLANNED	Requested
184	RQ178476	OCC_219	cpcc1_sd	BAY	721 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-1 (POWERGRID)	POWERGRID	D	For erection works of SS-63 A1, B1 & TBCB bay extension.	01/Jun/2024	15:00	07/Jun/2024	22:00	at FATEHGARH_II (PG)		PLANNED	Requested

185	RQ178477	OCC_219	cpcc1_sd	BAY	725 MAIN BAY - 765/400 KV 1500 MVA ICT 6 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	AMP WORK	01/Jun/2024	14:00	02/Jun/2024	23:00		PLANNED	Requested
186	RQ177360	OCC_219	stuup_sd	BAY	801 MAIN BAY - 765 KV AGRA FATEHBAD(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1 (NUPPL) AT 765 KV GHATAMPUR_TPS(UP)	NUPPL	C	The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	1. It may considered as 31.05.2024 2. Jumpering at Take-up tower inside Ghatampur TPS has been kept open for 765kV Agra-Ghatampur including 189MVA Line Reactor to charge the Line for Anti-Theft charging Purpose. At present Line is Anti-theft charged with 132kV 2.	PLANNED	Requested
187	RQ177359	OCC_219	stuup_sd	BAY	802 TIE BAY - 765 KV AGRA FATEHBAD(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1 (NUPPL) AND 765 KV HAPUR(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1 AT 765 KV GHATAMPUR_TPS(UP) (NUPPL)	NUPPL	C	The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	It may considered as 31.05.2024	PLANNED	Requested
188	RQ177361	OCC_219	stuup_sd	BAY	803 MAIN BAY - 765 KV HAPUR(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1 (NUPPL) AT 765 KV GHATAMPUR_TPS(UP)	NUPPL	C	The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	It may considered as 31.05.2024	PLANNED	Requested
189	RQ177506	OCC_219	stuup_sd	BAY	810 MAIN BAY - 765 KV GHATAMPUR_TPS(UP) - BUS 1 (NUPPL) AT 765 KV GHATAMPUR_TPS(UP)	NUPPL	C	The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	please considered s/d period from 31.05.2024 to 20.06.2024	PLANNED	Requested
190	RQ177917	OCC_219	stuup_sd	BAY	802 TIE BAY - 765 KV AGRA FATEHBAD(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1 (NUPPL) AND 765 KV HAPUR(UP)-GHATAMPUR_TPS(UP) (GTL) CKT-1 AT 765 KV GHATAMPUR_TPS(UP) (NUPPL)	NUPPL	C	1. It may consider as 31.05.2024 2. The Element is already under shutdown as approved at 213th, 214th, 215th, 216th, 217th & 218th OCC meeting. Requested to extend the shutdown upto 20.06.2024 to complete the Erection activities of Hapur Line Bay 803 & its reactor Bay 803R.	01/Jun/2024	17:00	20/Jun/2024	17:00	Jumpering at Take-up tower inside Ghatampur TPS has been kept open for 765kV Agra-Ghatampur including 189MVA Line Reactor to charge the Line for Anti-Theft charging Purpose. At present Line is Anti-theft charged with 132kV	PLANNED	Requested
191	RQ177767	OCC_219	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHPUR(PG)	POWERGRID	D	AMP Work	26/Jun/2024	09:00	26/Jun/2024	18:00		PLANNED	Requested
192	RQ177460	OCC_219	cpcc2_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT MOGA(PG)	POWERGRID	D	For taking Hot-Spare ICT into service with 765 kv ICT-2 B-ph.	14/Jun/2024	09:00	14/Jun/2024	16:00	Kindly approve	PLANNED	Requested
193	RQ177626	OCC_219	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT BALIA(PG)	POWERGRID	D	Relay testing work	12/Jun/2024	10:00	12/Jun/2024	18:00		PLANNED	Requested
194	RQ177623	OCC_219	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT BALIA(PG)	POWERGRID	D	Relay testing work	11/Jun/2024	10:00	11/Jun/2024	18:00		PLANNED	Requested
195	RQ177765	OCC_219	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT KANPUR_GIS(PG)	POWERGRID	D	CSD Tuning	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested
196	RQ177764	OCC_219	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT KANPUR_GIS(PG)	POWERGRID	D	CSD Tuning and to attend SF6 gas leakage	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
197	RQ178222	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	24/Jun/2024	14:00	28/Jun/2024	23:00		PLANNED	Requested
198	RQ178221	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	22/Jun/2024	14:00	25/Jun/2024	23:00		PLANNED	Requested
199	RQ178285	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT KHETRI (PKTSL)		D	For attending oil leakage	21/Jun/2024	09:00	22/Jun/2024	17:00		PLANNED	Requested
200	RQ178232	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 6 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 765KV ICT	20/Jun/2024	14:00	27/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested
201	RQ178227	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 6 AT FATEHGARH_II(PG)		D	Ladder logic commissioning with spare ICT logic scheme checking. Commissioning of RTCC	20/Jun/2024	14:00	27/Jun/2024	23:00		PLANNED	Requested
202	RQ178284	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT KHETRI (PKTSL)		D	For internal inspection due to DGA violation and attending oil leakage	19/Jun/2024	09:00	20/Jun/2024	17:00		PLANNED	Requested
203	RQ178219	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	18/Jun/2024	14:00	21/Jun/2024	23:00		PLANNED	Requested
204	RQ178220	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	18/Jun/2024	14:00	21/Jun/2024	23:00		PLANNED	Requested

205	RQ178297	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 4 AT KOTESHWAR(PG)		D	For implementation of updated mechanical protection settings.	17/Jun/2024	09:00	17/Jun/2024	18:00		PLANNED	Requested	
206	RQ178231	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 765KV ICT	15/Jun/2024	14:00	24/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested	
207	RQ178226	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG)		D	Ladder logic commissioning with spare ICT logic scheme checking. Commissioning of RTCC	15/Jun/2024	14:00	24/Jun/2024	23:00		PLANNED	Requested	
208	RQ178298	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1000 MVA ICT 3 AT BHIWANI(PG)		D	For Charging of B phase (M/s BHEL) unit	15/Jun/2024	09:00	15/Jun/2024	17:00		PLANNED	Requested	
209	RQ178296	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 3 AT KOTESHWAR(PG)		D	For implementation of updated mechanical protection settings. And to attend oil leakage issue from NCT.	14/Jun/2024	09:00	14/Jun/2024	18:00		PLANNED	Requested	
210	RQ178295	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 2 AT KOTESHWAR(PG)		D	For implementation of updated mechanical protection settings. And to attend oil leakage issue from NCT.	13/Jun/2024	09:00	13/Jun/2024	18:00		PLANNED	Requested	
211	RQ178230	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 765KV ICT	12/Jun/2024	14:00	19/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested	
212	RQ178225	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG)		D	Ladder logic commissioning with spare ICT logic scheme checking. Commissioning of RTCC	12/Jun/2024	14:00	19/Jun/2024	23:00		PLANNED	Requested	
213	RQ178234	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 6 AT FATEHGARH_II(PG)		D	Tie bay 726 LBB protection testing works & erection works in tie bay	12/Jun/2024	14:00	21/Jun/2024	23:00		PLANNED	Requested	
214	RQ178294	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 1 AT KOTESHWAR(PG)		D	For implementation of updated mechanical protection settings.	12/Jun/2024	09:00	12/Jun/2024	18:00		PLANNED	Requested	
215	RQ178276	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT MEERUT_PMSTL (UP)		C	SF6 Gas density monitor body replacement	10/Jun/2024	07:00	11/Jun/2024	18:00		PLANNED	Requested	
216	RQ178267	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT BIKANER(PG)		D	FOR CSD FINE TUNING OF THE ICT, Minimum 5 Open & Close on-load operations will be performed	08/Jun/2024	18:00	08/Jun/2024	23:30		PLANNED	Requested	
217	RQ178233	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG)		D	For Erection works of SS-63 A1 package 765 kv ICT-5 B phase unit	07/Jun/2024	14:00	12/Jun/2024	23:00		PLANNED	Requested	
218	RQ178239	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 6 AT FATEHGARH_II(PG)		D	For Erection works of SS-63 A1 package 765 kv ICT-5 R phase unit	07/Jun/2024	14:00	12/Jun/2024	23:00		PLANNED	Requested	
219	RQ178275	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT MEERUT_PMSTL (UP)		C	SF6 Gas density monitor body replacement	07/Jun/2024	07:00	08/Jun/2024	18:00		PLANNED	Requested	
220	RQ178229	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 765KV ICT	05/Jun/2024	14:00	13/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested	
221	RQ178224	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG)		D	Ladder logic commissioning with spare ICT logic scheme checking. Commissioning of RTCC	05/Jun/2024	14:00	13/Jun/2024	23:00		PLANNED	Requested	
222	RQ178268	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT BHADLA_2 (PG)		D	Commissioning of 720 Bay	03/Jun/2024	17:00	06/Jun/2024	23:00		PLANNED	Requested	
223	RQ178278	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG)		D	AMP Work	02/Jun/2024	17:00	02/Jun/2024	23:00		PLANNED	Requested	
224	RQ178277	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT BHADLA_2 (PG)		D	AMP Work	01/Jun/2024	17:00	01/Jun/2024	23:00		PLANNED	Requested	
225	RQ178228	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 765KV ICT	01/Jun/2024	14:00	07/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested	
226	RQ178223	OCC_219	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG)		D	Ladder logic commissioning with spare ICT logic scheme checking. Commissioning of RTCC	01/Jun/2024	14:00	07/Jun/2024	23:00		PLANNED	Requested	
227	RQ177629	OCC_219	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT RAMPUR_PRSTL (UP)		D	AMP Work	10/Jun/2024	10:00	10/Jun/2024	18:00		PLANNED	Requested	
228	RQ177609	OCC_219	slcds_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT PHAGI(RS)	UPPTCL	D	Quarterly maintenance work	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested	
229	RQ177603	OCC_219	slcds_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT PHAGI(RS)	RRVPNL	D	Quarterly maintenance work	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested	
230	RQ178156	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT-MANDOLA (PG) CKT-4		D	For A/R test after A/R relay retrofitment	30/Jun/2024	08:00	30/Jun/2024	18:00		PLANNED	Requested	
231	RQ178155	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT-MANDOLA (PG) CKT-3		D	For A/R test after A/R relay retrofitment	29/Jun/2024	08:00	29/Jun/2024	18:00		PLANNED	Requested	
232	RQ178078	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA-HISSAR (PG) CKT-2		D	For attending S/D nature defects	28/Jun/2024	08:00	28/Jun/2024	20:00	A/R of Moga-Hisar CKT-3 to be kept in non Auto mode	PLANNED	Requested	
233	RQ178084	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JAIPUR SOUTH-BASSI (PG) CKT-1		D	For attending S/D nature defects/ AMP OF LINE EQUIPMENTS	27/Jun/2024	09:00	28/Jun/2024	18:00		PLANNED	Requested	
234	RQ178111	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER_2 (PBTSL)-KHETRI (PKTSL) (PBTSL) CKT-4		D	For settings modification in relay and CSD fine tuning	27/Jun/2024	08:00	27/Jun/2024	18:00		PLANNED	Requested	
235	RQ178079	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA-HISSAR (PG) CKT-3		D	For attending S/D nature defects	27/Jun/2024	08:00	27/Jun/2024	20:00	A/R of Moga-Hisar CKT-2 to be kept in non Auto mode	PLANNED	Requested	

236	RQ178165	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT_PMSTL - SIMBHOLI_PMSTL (UP) CKT-2		C	SF6 Gas density monitor body replacement	27/Jun/2024	07:00	29/Jun/2024	18:00		PLANNED	Requested	
237	RQ178008	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-JAIPUR SOUTH (PG) CKT-2		D	To attend shutdown nature defects	26/Jun/2024	09:00	27/Jun/2024	18:00		PLANNED	Requested	
238	RQ178124	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_D(NP)-KOTA(PG) (PG) CKT-2		D	Additional glass disc insertion: LOA given	26/Jun/2024	08:00	27/Jun/2024	18:00	Non auto for 400 kv RAPPD-Jaipur South	PLANNED	Requested	
239	RQ177997	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAWANA CCGTB(DTL)-BAHADURGARH(PG) (PG) CKT-1		D	For S/D nature defect rectification	26/Jun/2024	08:00	26/Jun/2024	18:00	For S/D nature defect rectification	PLANNED	Requested	
240	RQ178110	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER_2 (PBTS)-KHETRI (PKTSL) (PBTS) CKT-3		D	For settings modification in relay and CSD fine tuning	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested	
241	RQ178160	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KHETRI (PKTSL)-BHIWADI(PG) (PBTS) CKT-1		D	Stringing of 765 kv D/C Khetri-Narela TL	26/Jun/2024	07:00	28/Jun/2024	19:00		PLANNED	Requested	
242	RQ178161	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KHETRI (PKTSL)-BHIWADI(PG) (PBTS) CKT-2		D	Stringing of 765 kv D/C Khetri-Narela TL	26/Jun/2024	07:00	28/Jun/2024	19:00		PLANNED	Requested	
243	RQ178109	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER_2 (PBTS)-KHETRI (PKTSL) (PBTS) CKT-2		D	For settings modification in relay and CSD fine tuning	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested	
244	RQ178150	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-MANDOLA(PG) (PG) CKT-1		D	For A/R test after A/R relay retrofit	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested	
245	RQ177999	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-1		D	stringing of 765 kv D/C Khetri Narela transmission line	25/Jun/2024	06:00	30/Jun/2024	21:00	stringing work	PLANNED	Requested	
246	RQ178000	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-2		D	stringing of 765 kv D/C Khetri Narela transmission line	25/Jun/2024	06:00	30/Jun/2024	21:00	stringing work	PLANNED	Requested	
247	RQ178007	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-BASSI (PG) CKT-1		D	To attend shutdown nature defects	24/Jun/2024	09:00	25/Jun/2024	18:00		PLANNED	Requested	
248	RQ178108	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER_2 (PBTS)-KHETRI (PKTSL) (PBTS) CKT-1		D	For settings modification in relay and CSD fine tuning	24/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested	
249	RQ178123	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_D(NP)-JAIPUR SOUTH(PG) (PG) CKT-1		D	Additional glass disc insertion: LOA given/ For attending S/D nature defects/ AMP OF LINE EQUIPMENTS	24/Jun/2024	08:00	25/Jun/2024	18:00	Non auto for 400 kv RAPPD-Kota	PLANNED	Requested	
250	RQ178151	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-MANDOLA(PG) (PG) CKT-2		D	For A/R test after A/R relay retrofit	24/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested	
251	RQ178164	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT_PMSTL - SIMBHOLI_PMSTL (UP) CKT-1		C	SF6 Gas density monitor body replacement	24/Jun/2024	07:00	26/Jun/2024	18:00		PLANNED	Requested	
252	RQ178154	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MANDOLA(PG)-MAHARANIBAGH(PG) (DTL) CKT-2		D	Relay retrofit	23/Jun/2024	08:00	23/Jun/2024	18:00		PLANNED	Requested	
253	RQ178153	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MANDOLA(PG)-MAHARANIBAGH(PG) (DTL) CKT-1		D	Relay retrofit	22/Jun/2024	08:00	22/Jun/2024	18:00		PLANNED	Requested	
254	RQ178099	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI-JIND (PG) CKT-2		D	LINE EQUIPMENT AMP WORK	21/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested	
255	RQ177998	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAWANA CCGTB(DTL)-BHIWANI(PG) (PG)		D	For S/D nature defect rectification	21/Jun/2024	08:00	21/Jun/2024	18:00	For S/D nature defect rectification	PLANNED	Requested	
256	RQ178098	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI-JIND (PG) CKT-1		D	LINE EQUIPMENT AMP WORK	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested	
257	RQ178152	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT)-BAWANA(DV) (PG) CKT-1		D	Modification of terminal connector for attending the repeated hotspot of line isolator	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested	
258	RQ178120	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA(RS)-KOTA(PG) (RS) CKT-1		D	AMP works of Line Bay equipments	19/Jun/2024	09:00	19/Jun/2024	18:00		PLANNED	Requested	
259	RQ178101	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JIND(PG)-KIRORI(HV) (HVPNL) CKT-2		D	LINE EQUIPMENT AMP WORK	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
260	RQ178107	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKROLI(PG)-JODHPUR(RS) (PG) CKT-1		D	For attending S/D nature defects	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
261	RQ178059	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH POOLING(FBTL) (FBTL) CKT-2		D	for AMP works	18/Jun/2024	14:00	20/Jun/2024	23:59		PLANNED	Requested	
262	RQ178106	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS)-KANKROLI(PG) (PG) CKT-1		D	For attending S/D nature defects	18/Jun/2024	08:00	18/Jun/2024	18:00	A/R of RAPP-Kankroli CKT to be kept in non Auto mode	PLANNED	Requested	
263	RQ178100	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JIND(PG)-KIRORI(HV) (HVPNL) CKT-1		D	LINE EQUIPMENT AMP WORK	17/Jun/2024	08:00	17/Jun/2024	18:00		PLANNED	Requested	
264	RQ177994	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAHADURGARH(PG)-KABULPUR(HV) (PG) CKT-1		D	For S/D nature defect rectification	17/Jun/2024	08:00	17/Jun/2024	18:00	For S/D nature defect rectification	PLANNED	Requested	
265	RQ178159	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI-HISSAR (PG) CKT-1		D	Stringing of 765 kv D/C Khetri-Narela TL	17/Jun/2024	07:00	19/Jun/2024	19:00		PLANNED	Requested	
266	RQ178085	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JAIPUR SOUTH-BASSI (PG) CKT-2		D	AMP OF LINE EQUIPMENTS	16/Jun/2024	09:00	16/Jun/2024	17:00		PLANNED	Requested	
267	RQ178179	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH POOLING(FBTL) (FBTL) CKT-2		D	Installation of Bird Diverter	16/Jun/2024	08:00	30/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested	

268	RQ178029	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTPUTLI-BHIWADI (PG) CKT-1		C	FOR NCRTC DIVERSION WORK	16/Jun/2024	08:00	25/Jun/2024	18:30		PLANNED	Requested	
269	RQ178026	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI-HISSAR (PG) CKT-1		C	FOR NCRTC DIVERSION WORK	16/Jun/2024	08:00	25/Jun/2024	18:30		PLANNED	Requested	
270	RQ178177	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)-BHADLA(PG) (PG) CKT-2		D	Installation of Bird Diverter	16/Jun/2024	08:00	30/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested	
271	RQ178175	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(PG)-BHADLA_2 (PG) (FBTL) CKT-2		D	Installation of Bird Diverter	16/Jun/2024	08:00	30/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested	
272	RQ178122	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_(NP)-KANKROLI(PG) (PG) CKT-1		D	Polymer insulator replacement work/ For attending S/D nature defects/ Rectification of CoE Audit point	16/Jun/2024	08:00	30/Jun/2024	18:00	Non auto for 400 kV RAPPCC-Chittorgarh/ & A/R of CHITTOR-KANKROLI(PG) to be kept in non Auto mode	PLANNED	Requested	
273	RQ178012	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-SIKAR (PG) CKT-2		D	Non-auto mode for tower tightening & missing tower member fixing above waist level	15/Jun/2024	09:00	30/Jun/2024	18:00		PLANNED	Requested	
274	RQ178010	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-SIKAR (PG) CKT-1		D	Non-auto mode for tower tightening & missing tower member fixing above waist level	15/Jun/2024	09:00	30/Jun/2024	18:00		PLANNED	Requested	
275	RQ177989	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SHREE CEMENT(SCL)-MERTA(RS) (PG) CKT-1		D	For S/D nature defect rectification	15/Jun/2024	08:00	15/Jun/2024	17:00	For S/D nature defect rectification	PLANNED	Requested	
276	RQ177988	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SHREE CEMENT(SCL)-KOTA(PG) (PG) CKT-1		D	For S/D nature defect rectification	14/Jun/2024	08:00	14/Jun/2024	17:00	For S/D nature defect rectification	PLANNED	Requested	
277	RQ178167	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-SIKAR (PG) CKT-2		D	Replacement Disc porcelain insulators by polymer insulators.	14/Jun/2024	08:00	17/Jun/2024	18:00	Replacement of Disc porcelain insulators by polymer insulators.	PLANNED	Requested	
278	RQ178002	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR-BALLABHGARH (PG) CKT-3		D	For attending S/D nature defects	13/Jun/2024	09:00	13/Jun/2024	18:00		PLANNED	Requested	
279	RQ177987	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTA(PG)-MERTA(RS) (PG) CKT-1		D	For S/D nature defect rectification	13/Jun/2024	08:00	13/Jun/2024	17:00	For S/D nature defect rectification	PLANNED	Requested	
280	RQ178105	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKROLI-ZERDA (PG) CKT-2		D	For attending S/D nature defects/Rectification of CoE Audit point	13/Jun/2024	08:00	15/Jun/2024	18:00	A/R of Kankrol-Zerda CKT 1 to be kept in non Auto mode	PLANNED	Requested	
281	RQ178086	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JAIPUR SOUTH-KOTA (PG) CKT-1		D	AMP OF LINE EQUIPMENTS	12/Jun/2024	09:00	12/Jun/2024	17:00		PLANNED	Requested	
282	RQ177986	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AJMER(RS)-AJMER(PG) (PG) CKT-2		D	For S/D nature defect rectification	12/Jun/2024	08:00	12/Jun/2024	17:00	For S/D nature defect rectification	PLANNED	Requested	
283	RQ178089	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAMBOLI(DV)-JHATIKARA(PG) (DTL) CKT-2		D	shutdownrelated defect rectification	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
284	RQ178128	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TEHRI(THDC)-KOTESHWAR(PG) (PG) CKT-3		D	For increasing height of Y & B phase LAs	11/Jun/2024	09:00	11/Jun/2024	18:00		PLANNED	Requested	
285	RQ177985	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AJMER(RS)-AJMER(PG) (PG) CKT-1		D	For S/D nature defect rectification	11/Jun/2024	08:00	11/Jun/2024	17:00	For S/D nature defect rectification	PLANNED	Requested	
286	RQ178040	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS)-CHITTORGARH(PG) (PG) CKT-2		D	AR relay Rtrofitment work	10/Jun/2024	09:00	10/Jun/2024	15:00		PLANNED	Requested	
287	RQ178001	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR-BALLABHGARH (PG) CKT-2		D	For attending S/D nature defects	10/Jun/2024	09:00	10/Jun/2024	18:00		PLANNED	Requested	
288	RQ178127	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TEHRI(THDC)-KOTESHWAR(PG) (PG) CKT-1		D	Replacement of CVT of B-phase.	10/Jun/2024	09:00	10/Jun/2024	18:00		PLANNED	Requested	
289	RQ178166	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-SIKAR (PG) CKT-1		D	Replacement of Disc porcelain insulators by polymer insulators.	10/Jun/2024	08:00	13/Jun/2024	18:00	Replacement of Disc porcelain insulators by polymer insulators.	PLANNED	Requested	
290	RQ178092	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA(PG)-MUNDKA(DV) (PG) CKT-2		D	shutdownrelated defect rectification	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	
291	RQ178077	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL-HISSAR (PG) CKT-2		C	For NHAI diversion work	10/Jun/2024	07:00	25/Jun/2024	20:00		PLANNED	Requested	
292	RQ178076	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL-HISSAR (PG) CKT-1		C	For NHAI diversion work	10/Jun/2024	07:00	25/Jun/2024	20:00		PLANNED	Requested	
293	RQ178158	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BABAI(RS)-BHIWANI(PG) (NRSS36) CKT-2		D	Stringing of 765 kv D/C Khetri-Narela TL	10/Jun/2024	07:00	12/Jun/2024	19:00		PLANNED	Requested	
294	RQ178157	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BABAI(RS)-BHIWANI(PG) (NRSS36) CKT-1		D	Stringing of 765 kv D/C Khetri-Narela TL	10/Jun/2024	07:00	12/Jun/2024	19:00		PLANNED	Requested	
295	RQ178058	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1		D	for AMP works	08/Jun/2024	14:00	11/Jun/2024	23:59		PLANNED	Requested	
296	RQ178169	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SIKAR(PG)-RATANGARH(RS) (PG) CKT-2		D	For S/D nature defect rectification	08/Jun/2024	08:00	08/Jun/2024	18:00	For S/D nature defect rectification	PLANNED	Requested	
297	RQ178093	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA-DWARKA (PG)		D	shutdownrelated defect rectification	08/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested	
298	RQ178061	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH_III(PG) (PRTL) CKT-2		D	For pending construction related works	07/Jun/2024	14:00	17/Jun/2024	23:59		PLANNED	Requested	
299	RQ178039	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS)-CHITTORGARH(PG) (PG) CKT-1		D	AR relay Rtrofitment work	07/Jun/2024	09:00	07/Jun/2024	15:00		PLANNED	Requested	

300	RQ178133	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV XJURKSHETRA-JIND (PG) CKT-2		C	For rectification of S6 leakage in S6 to Air bushing	07/Jun/2024	09:00	09/Jun/2024	17:00		PLANNED	Requested	
301	RQ178126	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTESWAR(TH)-KOTESHWAR(PG) (PG) CKT-2		D	For installation and testing of differential relay.	07/Jun/2024	09:00	07/Jun/2024	18:00		PLANNED	Requested	
302	RQ178022	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHINMAL(PG)-BARMER(RS) (RS) CKT-2		D	FOR LBB TESTING OF TIE BAY- under SS-95 PACKAGE PROJECT	07/Jun/2024	09:00	07/Jun/2024	18:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested	
303	RQ178168	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SIKAR(PG)-RATANGARH(RS) (PG) CKT-1		D	For S/D nature defect rectification	07/Jun/2024	08:00	07/Jun/2024	18:00	For S/D nature defect rectification	PLANNED	Requested	
304	RQ178173	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MANDOLA(PG)-MAHARANIBAGH(P G) (DTL) CKT-1		D	For OPGW replacement works from TN-14 to TN-16	07/Jun/2024	08:00	07/Jun/2024	18:00	Non-Auto for OPGW Replacement works	PLANNED	Requested	
305	RQ178171	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAWANA(DV)-MAHARANIBAGH(P G) (DTL) CKT-1		D	For OPGW replacement works from TN-14 to TN-16	07/Jun/2024	08:00	07/Jun/2024	18:00	Shutdown for OPGW Replacement works	PLANNED	Requested	
306	RQ178071	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH POOLING(FBTL) (FBTL) CKT-2		D	Rectification of Shutdown nature defects in transmission line.	06/Jun/2024	17:30	07/Jun/2024	23:30	S/D Type defect rectification work	PLANNED	Requested	
307	RQ178006	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI-BALLABHGARH (PG) CKT-2		D	For attending S/D nature defects	06/Jun/2024	09:00	06/Jun/2024	18:00		PLANNED	Requested	
308	RQ178125	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTESWAR(TH)-KOTESHWAR(PG) (PG) CKT-1		D	For installation and testing of differential relay.	06/Jun/2024	09:00	06/Jun/2024	18:00		PLANNED	Requested	
309	RQ178104	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKROLI-ZERDA (PG) CKT-1		D	For attending S/D nature defects	06/Jun/2024	08:00	08/Jun/2024	18:00	A/R of Kankrolli-Zerda CKT 2 to be kept in non Auto mode	PLANNED	Requested	
310	RQ178043	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-MANDOLA(PG) (PG) CKT-2		D	CC RING FITTING	06/Jun/2024	06:00	06/Jun/2024	18:00		PLANNED	Requested	
311	RQ178172	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR(UP)-MURADNAGAR_1(U P) (PG) CKT-1		D	For OPGW replacement works at Muradnagar Gantry	05/Jun/2024	11:00	05/Jun/2024	15:00	Shutdown for OPGW Replacement works	PLANNED	Requested	
312	RQ178042	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-MANDOLA(PG) (PG) CKT-1		D	CC RING FITTING	05/Jun/2024	06:00	05/Jun/2024	18:00		PLANNED	Requested	
313	RQ178025	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-BHIWADI (PG) CKT-2		D	For attending S/D nature defects	04/Jun/2024	12:00	04/Jun/2024	16:00		PLANNED	Requested	
314	RQ178005	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI-BALLABHGARH (PG) CKT-2		C	For shifting line bay equipments for reactor commissioning	04/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested	
315	RQ178041	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)-CHITTORGARH(RS) (PG) CKT-1		D	AR relay Rtrofitment work	03/Jun/2024	09:00	03/Jun/2024	15:00		PLANNED	Requested	
316	RQ178004	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI-BALLABHGARH (PG) CKT-1		D	For attending S/D nature defects	03/Jun/2024	09:00	03/Jun/2024	18:00		PLANNED	Requested	
317	RQ178072	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH_III(PG) (PRTL) CKT-1		C	Replacement of bend leg at Loc No 9/1 to avoid any mishappening	02/Jun/2024	07:00	02/Jun/2024	20:15		PLANNED	Requested	
318	RQ178073	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH_III(PG) (PRTL) CKT-2		C	Replacement of bend leg at Loc No 9/1 to avoid any mishappening	02/Jun/2024	07:00	02/Jun/2024	20:15		PLANNED	Requested	
319	RQ178060	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH_III(PG) (PRTL) CKT-1		D	For pending construction related works	01/Jun/2024	14:00	07/Jun/2024	23:59		PLANNED	Requested	
320	RQ178011	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-SIKAR (PG) CKT-2		C	NHAI DIVERSION WORK	01/Jun/2024	09:00	14/Jun/2024	18:00		PLANNED	Requested	
321	RQ178009	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-SIKAR (PG) CKT-1		C	NHAI DIVERSION WORK	01/Jun/2024	09:00	14/Jun/2024	18:00		PLANNED	Requested	
322	RQ178178	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1		D	Installation of Bird Diverter	01/Jun/2024	08:00	15/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested	
323	RQ178027	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI-HISSAR (PG) CKT-2		C	FOR NCRTC DIVERSION WORK	01/Jun/2024	08:00	10/Jun/2024	18:30		PLANNED	Requested	
324	RQ178028	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI-HISSAR (PG) CKT-3		C	FOR NCRTC DIVERSION WORK	01/Jun/2024	08:00	10/Jun/2024	18:30		PLANNED	Requested	
325	RQ178176	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)-BHADLA(PG) (PG) CKT-1		D	Installation of Bird Diverter	01/Jun/2024	08:00	15/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested	
326	RQ178174	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(PG)-BHADLA_2 (PG) (FBTL) CKT-1		D	Installation of Bird Diverter	01/Jun/2024	08:00	15/Jun/2024	18:00	A/R to be kept in Non auto mode of other charged ckt from both ends	PLANNED	Requested	
327	RQ177996	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAHADURGARH-SONIPAT (PG) CKT-2		C	Diversion at Loc84. NHAI Construction of Delhi-Amritsar-Katra Highway	01/Jun/2024	08:00	16/Jun/2024	18:00	Diversion	PLANNED	Requested	
328	RQ177995	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAHADURGARH-SONIPAT (PG) CKT-1		C	Diversion at Loc84. NHAI Construction of Delhi-Amritsar-Katra Highway	01/Jun/2024	08:00	16/Jun/2024	18:00	Diversion	PLANNED	Requested	
329	RQ178003	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI-BALLABHGARH (PG) CKT-1		C	For shifting line bay equipments for reactor commissioning	01/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested	
330	RQ178121	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)-CHITTORGARH(RS) (PG) CKT-1		D	Polymer insulator replacement work	01/Jun/2024	08:00	15/Jun/2024	18:00	Non auto for 400 kV RAPPCC-Kankrolli	PLANNED	Requested	
331	RQ178044	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR(UP)-MORADABAD(UP) (PG) CKT-1		C	DIVERSION WORK IN BETWEEN TOWER NO. 171-173	01/Jun/2024	06:00	15/Jun/2024	18:00	DIVERSION WORK	PLANNED	Requested	

332	RQ177711	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR_GIS-LUCKNOW_2 (PG) CKT-2	POWERGRID	D	AMP Work	29/Jun/2024	08:00	29/Jun/2024	18:00		PLANNED	Requested
333	RQ177895	OCC_219	slccs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SHREE CEMENT(SCL)-MERTA(RS) (PG) CKT-1	POWERGRID	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	29/Jun/2024	08:00	29/Jun/2024	18:00		PLANNED	Requested
334	RQ177710	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR_GIS-LUCKNOW_2 (PG) CKT-1	POWERGRID	D	AMP Work	28/Jun/2024	08:00	28/Jun/2024	18:00		PLANNED	Requested
335	RQ177897	OCC_219	slccs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTA(PG)-MERTA(RS) (PG) CKT-1	POWERGRID	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	28/Jun/2024	08:00	28/Jun/2024	18:00		PLANNED	Requested
336	RQ177466	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-SAMBA (PG) CKT-2	POWERGRID	D	"SD required for rectification of shutdown nature defects."	27/Jun/2024	08:00	27/Jun/2024	18:00	Kindly approve	PLANNED	Requested
337	RQ177699	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SARNATH(UP)-VARANASI(PG) (PG) CKT-2	POWERGRID	D	Rectification of S/D nature defects	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested
338	RQ177724	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR-BALLABHAGARH (PG) CKT-2	POWERGRID	D	AMP and Rectification of S/D nature defects	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested
339	RQ177630	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT)-BAWANA(DV) (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects in line.	26/Jun/2024	08:00	26/Jun/2024	18:00	kindly approve	PLANNED	Requested
340	RQ177465	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-SAMBA (PG) CKT-1	POWERGRID	D	"SD required for rectification of shutdown nature defects."	26/Jun/2024	08:00	26/Jun/2024	18:00	Kindly approve	PLANNED	Requested
341	RQ177698	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SARNATH(UP)-VARANASI(PG) (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested
342	RQ177723	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR-BALLABHAGARH (PG) CKT-1	POWERGRID	D	AMP and Rectification of S/D nature defects	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested
343	RQ177631	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)-BAWANA(DV) (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects in line.	25/Jun/2024	08:00	25/Jun/2024	18:00	kindly approve	PLANNED	Requested
344	RQ177756	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR(PG)-PANKI(UP) (PG) CKT-1	POWERGRID	D	LA retrofitment work under ADD-CAP	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested
345	RQ177440	OCC_219	singrauli_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-2	POWERGRID	C	bay equipment testing	24/Jun/2024	08:00	25/Jun/2024	18:00	SHUTDOWN REQUIRED	PLANNED	Requested
346	RQ177622	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-KATTHAL(PG) (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects in line.	21/Jun/2024	08:00	22/Jun/2024	18:00	kindly approve	PLANNED	Requested
347	RQ177760	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR-AGRA (PG) CKT-1	POWERGRID	C	Oil drainage,jumper opening & HV Bushing dismantling of non-switchable line reactor.Line reactor will be replaced under ADD-CAP	21/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested
348	RQ178441	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHANDI(NT)-ALLAHABAD(PG) (PG) CKT-1	POWERGRID	D	Line Bay AMP Work	21/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested
349	RQ177653	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA(PG)-NAKODAR(PG) (PG) CKT-1	POWERGRID	D	For line equipment's AMP work	20/Jun/2024	10:00	20/Jun/2024	16:00	kindly approve	PLANNED	Requested
350	RQ177896	OCC_219	slccs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKROLI(PG)-JODHPUR(RS) (PG) CKT-1	POWERGRID	D	Quarterly Preventive Maintenance and testing work.	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
351	RQ177841	OCC_219	slccs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI(PG)-PHAGI(RS) (PG) CKT-2	POWERGRID	D	Maintenance line bay Equipments i.e. CVT, WT & line Isolator.	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
352	RQ177755	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR(PG)-PANKI(UP) (PG) CKT-2	POWERGRID	C	405-89A Isolator retrofitment work under ADD-CAP	20/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested
353	RQ177790	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-SIKAR (PG) CKT-2	POWERGRID	D	Rectification of S/D nature defects	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested
354	RQ177782	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-2	POWERGRID	D	AMP Work	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested
355	RQ177628	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA-JIND (PG) CKT-2	POWERGRID	D	For rectification of shutdown nature defects in line.	19/Jun/2024	08:00	19/Jun/2024	18:00	kindly approve	PLANNED	Requested
356	RQ177627	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA-JIND (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects in line.	18/Jun/2024	08:00	18/Jun/2024	18:00	kindly approve	PLANNED	Requested
357	RQ177789	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-SIKAR (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	17/Jun/2024	08:00	17/Jun/2024	18:00		PLANNED	Requested
358	RQ177722	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2-JAULIJI (PG) CKT-2	POWERGRID	D	For Isolation of Gas Zone Tripping PRD Tripping Scheme Modification and Scheme Modification for NGR as per CC-AM Technical Circular	17/Jun/2024	08:00	17/Jun/2024	18:00		PLANNED	Requested
359	RQ177953	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-MOGA (PG) CKT-2	POWERGRID	D	For Jumper/Dropper Tightning and Strengthening work And FDS Test of Line Reactor.	14/Jun/2024	09:30	14/Jun/2024	17:00	Kindly approve	PLANNED	Requested
360	RQ177876	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)-KASHIPUR(UK) (PG) CKT-2	POWERGRID	D	Rectification of shutdown nature defects	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
361	RQ177721	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2-JAULIJI (PG) CKT-1	POWERGRID	D	For Isolation of Gas Zone Tripping PRD Tripping Scheme Modification and Scheme Modification for NGR as per CC-AM Technical Circular	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
362	RQ177875	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)-KASHIPUR(UK) (PG) CKT-1	POWERGRID	D	Rectification of shutdown nature defects	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested

363	RQ177625	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA-SONIPAT (PG) CKT-2	POWERGRID	D	For rectification of shutdown nature defects in line.	13/Jun/2024	08:00	14/Jun/2024	18:00	kindly approve	PLANNED	Requested
364	RQ177840	OCC_219	slidcup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI(PG)-PHAGI(RS) (PG) CKT-1	POWERGRID	D	Maintenance line bay Equipments i.e. CVT, WT & line Isolator.	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
365	RQ177967	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-NEWWANPOH (PG) CKT-1	POWERGRID	D	A/R required in Non auto mode for installation of Pilot Insulator in 400KV Baglihar-New Wanpoh-1 for safety purpose.	12/Jun/2024	09:00	13/Jun/2024	18:00	kindly approve	PLANNED	Requested
366	RQ177762	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-KANPUR_GIS (PG) CKT-2	POWERGRID	D	AMP Work	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested
367	RQ177940	OCC_219	slidcup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT(PG)-MUZAFFARNAGAR(UP) (PG) CKT-1	POWERGRID	C	Planned shutdown Maintenance of Pantagraph Isolator	11/Jun/2024	13:00	11/Jun/2024	17:00		PLANNED	Requested
368	RQ177420	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHABAD-HISSAR (PG) CKT-1	POWERGRID	D	"SD required for rectification of shutdown nature defects."	11/Jun/2024	09:00	11/Jun/2024	18:00	kindly approve.	PLANNED	Requested
369	RQ177775	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-FATEHPUR (PG) CKT-2	POWERGRID	D	AMP Work	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
370	RQ177624	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA-SONIPAT (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects in line.	11/Jun/2024	08:00	12/Jun/2024	18:00	kindly approve	PLANNED	Requested
371	RQ177726	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI-BALLABGHARH (PG) CKT-2	POWERGRID	C	For shifting of Line bay for Line reactor commissioning work	11/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
372	RQ177574	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-KISHENPUR(PG) (PG) CKT-1	POWERGRID	D	Replacement of broken insulator at Loc No. 271.	11/Jun/2024	08:00	12/Jun/2024	18:00	kindly approve	PLANNED	Requested
373	RQ177783	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-FATEHPUR (PG) CKT-3	POWERGRID	D	AMP Work	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
374	RQ177761	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-KANPUR_GIS (PG) CKT-1	POWERGRID	D	AMP Work	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
375	RQ177754	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR-BALLABGHARH (PG) CKT-3	POWERGRID	D	80 MVAR Line reactor protection scheme modification	09/Jun/2024	08:00	09/Jun/2024	18:00		PLANNED	Requested
376	RQ177419	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL-HISSAR (PG) CKT-2	POWERGRID	D	For line equipment's AMP work.	08/Jun/2024	09:30	08/Jun/2024	18:00	kindly approve.	PLANNED	Requested
377	RQ177961	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-NEWWANPOH (PG) CKT-1	POWERGRID	D	Shutdown Required for installation of Pilot Insulator	08/Jun/2024	09:00	10/Jun/2024	18:00	Kindly approve	PLANNED	Requested
378	RQ177418	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL-HISSAR (PG) CKT-1	POWERGRID	D	Replacement of conductor Jumper in Y phase.	07/Jun/2024	09:30	07/Jun/2024	18:00	kindly approve.	PLANNED	Requested
379	RQ177422	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA-HISSAR (PG) CKT-3	POWERGRID	D	"SD required for rectification of shutdown nature defects."	07/Jun/2024	09:00	07/Jun/2024	18:00	kindly approve.	PLANNED	Requested
380	RQ177791	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)-AGRA(PG) (PG) CKT-2	POWERGRID	D	Rectification of S/D nature defects	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested
381	RQ177621	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAGHPAT-KAITHAL (PG) CKT-2	POWERGRID	D	For rectification of shutdown nature defects in line.	07/Jun/2024	08:00	07/Jun/2024	18:00	kindly approve	PLANNED	Requested
382	RQ178440	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-1	POWERGRID	D	Line Bay AMP Work	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested
383	RQ177774	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-FATEHPUR (PG) CKT-1	POWERGRID	D	AMP Work	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
384	RQ177713	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_2-LUCKNOW_1 (PG) CKT-2	POWERGRID	D	AMP Work	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
385	RQ177738	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-RIHAND(NT) (PG) CKT-1	POWERGRID	D	AMP Work	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
386	RQ177421	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA-HISSAR (PG) CKT-1	POWERGRID	D	"SD required for rectification of shutdown nature defects."	05/Jun/2024	09:00	05/Jun/2024	18:00	kindly approve.	PLANNED	Requested
387	RQ177796	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR-MAINPURI (PG) CKT-2	POWERGRID	D	Rectification of S/D nature defects	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
388	RQ177753	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR(PG)-AURAIYA(NT) (PG) CKT-2	POWERGRID	D	AMP Work	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
389	RQ177620	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAGHPAT-KAITHAL (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects in line.	05/Jun/2024	08:00	05/Jun/2024	18:00	kindly approve	PLANNED	Requested
390	RQ177645	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PATIALA-PANCHKULA (PG) CKT-2	POWERGRID	D	S/D Required for installation of Pilot Insulator	04/Jun/2024	09:00	04/Jun/2024	18:00	kindly approve	PLANNED	Requested
391	RQ177644	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PATIALA-PANCHKULA (PG) CKT-1	POWERGRID	D	A/R Non Auto Required	04/Jun/2024	09:00	04/Jun/2024	18:00	kindly approve	PLANNED	Requested
392	RQ177752	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR(PG)-AURAIYA(NT) (PG) CKT-1	POWERGRID	D	AMP Work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested
393	RQ177737	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-FATEHPUR(PG) (PG) CKT-1	POWERGRID	D	AMP Work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested
394	RQ177784	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-VARANASI (PG) CKT-1	POWERGRID	D	AMP Work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested
395	RQ177708	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)-BASTI(UP) (PG) CKT-1	POWERGRID	D	AMP Work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested

396	RQ177973	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW(UP)-BAREILLY(PG) (PG) CKT-1	POWERGRID	D	for fixing of Insulation sleeve on conductors at crossing point of 220kV D/C Roza (Shahjahanpur)-Dohna (Bareilly) Line	03/Jun/2024	10:00	03/Jun/2024	17:00		PLANNED	Requested	
397	RQ177641	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PATIALA-PANCHKULA (PG) CKT-1	POWERGRID	D	S/O Required for installation of Pilot Insulator	03/Jun/2024	09:00	03/Jun/2024	18:00	kindly approve	PLANNED	Requested	
398	RQ177642	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PATIALA-PANCHKULA (PG) CKT-2	POWERGRID	D	A/R Non Auto Required	03/Jun/2024	09:00	03/Jun/2024	18:00	kindly approve	PLANNED	Requested	
399	RQ177747	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR_GIS-KANPUR (PG) CKT-2	POWERGRID	D	AMP Work	02/Jun/2024	08:00	02/Jun/2024	18:00		PLANNED	Requested	
400	RQ177746	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR_GIS-KANPUR (PG) CKT-1	POWERGRID	D	AMP Work	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested	
401	RQ177798	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR(PG)-PANKI(UP) (PG) CKT-1	POWERGRID	D	A/R into Non-Auto mode for PID testing	01/Jun/2024	08:00	10/Jun/2024	18:00	Actual non- auto of A/R required from 21.05.24 to 31.05.24	PLANNED	Requested	
402	RQ177799	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-FATEHPUR(PG) (PG) CKT-1	POWERGRID	D	A/R into Non-Auto mode for PID testing	01/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	
403	RQ177725	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI-BALLABHAGARH (PG) CKT-1	POWERGRID	C	For shifting of Line bay for Line reactor commissioning work	01/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	
404	RQ177411	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DULHASTI(NH)-KISHENPUR(PG) (PG) CKT-2	POWERGRID	C	AR non auto mode is required to carryout stringing on circuit 2.400KV Dulhasti Kishenpur -II is a Double circuit Line but stringing is done on one circuit only	01/Jun/2024	08:00	30/Jun/2024	18:00	Under construction head, Kindly approve	PLANNED	Requested	
405	RQ177410	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DULHASTI(NH)-KISHENPUR(PG) (PG) CKT-2	POWERGRID	C	"400KV Dulhasti Kishenpur -II is a Double circuit Line but stringing is done on one circuit only. Award has been placed for stringing on Circuit 2 under evacuation of Power from Pakaldul HEP in Chenab Valley HEPS. Shutdown is required to carryout stringing on circuit 2 "	01/Jun/2024	08:00	30/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
406	RQ177902	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER-MERTA (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS alongwith 50MVAR line Reactor at Merta	26/Jun/2024	08:00	27/Jun/2024	18:00		PLANNED	Requested	
407	RQ177833	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA-CHHABRA SCTPS (RS) CKT-2	RRVPNL	D	Installation, Configuration and Commissioning of New/Repaired line distance protection M-1 Relay (ABB REL 670) by Service Engineer in place of existing defective relay. And Half Yearly Maintenance work	25/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested	
408	RQ177837	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PHAGI-HEERAPURA (RS) CKT-2	RRVPNL	D	Maintenance line bay Equipments i.e. CVT, WT & line Isolator.	24/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested	
409	RQ177844	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA-CHHABRA SCTPS (RS) CKT-1	RRVPNL	D	Installation, Configuration and Commissioning of New/Repaired line distance protection M-1 Relay (ABB REL 670) by Service Engineer in place of existing defective relay. And Half Yearly Maintenance work	24/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested	
410	RQ177892	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA-KANKANI (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS at Merta and on 25.06.2024 Preventive maintenance & Testing of bay and equipments by Kankani end	24/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested	
411	RQ177832	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA-CHHABRA SCTPS (RS) CKT-1	RRVPNL	D	Installation, Configuration and Commissioning of New/Repaired line distance protection M-1 Relay (ABB REL 670) by Service Engineer in place of existing defective relay. And Half Yearly Maintenance work	22/Jun/2024	08:00	22/Jun/2024	18:00		PLANNED	Requested	
412	RQ177836	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PHAGI-HEERAPURA (RS) CKT-1	RRVPNL	D	Maintenance line bay Equipments i.e. CVT, WT & line Isolator.	21/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested	
413	RQ177891	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA-MERTA (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	20/Jun/2024	17:00	21/Jun/2024	23:00		PLANNED	Requested	
414	RQ177839	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA-KALISINDH (RS) CKT-2	RRVPNL	D	Installation, Configuration and Commissioning of New/Repaired line distance protection M-1 Relay (ABB REL 670) by Service Engineer in place of existing defective relay. And Half Yearly Maintenance work	20/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested	
415	RQ177824	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA(RS)-KAWAI SCTPS(APR) (RS) CKT-2	RRVPNL	D	Annual maintenance and testing of Line/Bay equipments.	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested	
416	RQ177904	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JODHPUR-KANKANI (RS) CKT-2	RRVPNL	D	Preventive maintenance & Testing of bay and equipments at both end alongwith line reactor at Jodhpur	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
417	RQ178517	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA(RS)-KOTA(PG) (RS) CKT-1	RRVPNL	D	AMP works of Line Bay equipments	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested	
418	RQ177860	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL-BARMER (RS) CKT-1	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	17/Jun/2024	08:00	17/Jun/2024	18:00		PLANNED	Requested	

419	RQ177901	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BARMER(RS)-RAJWEST(RW) (RS) CKT-1	RRVPNL	D	Planned maintenance at Rajwest end	15/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested
420	RQ177857	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHINMAL(PG)-BARMER(RS) (RS) CKT-2	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	15/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested
421	RQ177889	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJWEST(RW)-KANKANI (RS) CKT-1	RRVPNL	D	Preventive maintenance & Testing of bay and equipments at both end	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
422	RQ177823	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA(RS)-KAWAI SCTPS(APR) (RS) CKT-1	RRVPNL	D	Annual maintenance and testing of Line/Bay equipments.	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
423	RQ177856	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHINMAL(PG)-BARMER(RS) (RS) CKT-1	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
424	RQ177903	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JODHPUR-KANKANI (RS) CKT-1	RRVPNL	D	Preventive maintenance & Testing of bay and equipments at both end	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested
425	RQ177826	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHHABRA(RVUN)-KAWAI SCTPS(APR) (RS) CKT-1	RRVPNL	D	Annual maintenance and testing of Line/Bay equipments.	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
426	RQ177859	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JAISALMER-BARMER (RS) CKT-2	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
427	RQ177894	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJWEST(RW)-JODHPUR (RS) CKT-1	RRVPNL	D	Quarterly Preventive Maintenance and testing work at both end . alongwith line reactor at Jodhpur	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
428	RQ177887	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL-JAISALMER (RS) CKT-1	RRVPNL	D	To attend damaged spacer of Quad moose Akal- Kankani line at various locations for safety as D/C line	10/Jun/2024	16:00	15/Jun/2024	20:00		PLANNED	Requested
429	RQ177893	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL-KANKANI (RS) CKT-1	RRVPNL	D	Required by Akal end To attend damaged spacer of Quad moose Akal- Kankani line at various locations for safety as D/C line. (one day shutdown required by Kankani for Preventive maintenance & Testing of bay and equipments)	10/Jun/2024	16:00	15/Jun/2024	20:00		PLANNED	Requested
430	RQ177858	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JAISALMER-BARMER (RS) CKT-1	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
431	RQ177890	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA-JODHPUR (RS) CKT-1	RRVPNL	D	Quarterly Preventive Maintenance and testing work.	07/Jun/2024	17:00	07/Jun/2024	23:00		PLANNED	Requested
432	RQ177834	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA(RS)-KOTA(PG) (RS) CKT-1	RRVPNL	D	Half Yearly Maintenance work	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
433	RQ177900	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL-JODHPUR (RS) CKT-1	RRVPNL	D	Quarterly Preventive Maintenance and testing work. alongwith line reactor at Jodhpur	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
434	RQ177813	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER-BHADLA (RS) CKT-2	RRVPNL	D	For Tightening of jumper, Missing , Spacer,Loosening Nut Bolts at various Locations	05/Jun/2024	16:00	14/Jun/2024	22:00		PLANNED	Requested
435	RQ177825	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER-BHADLA (RS) CKT-1	RRVPNL	D	For Tightening of jumper, Missing , Spacer,Loosening Nut Bolts at various Locations	05/Jun/2024	16:00	14/Jun/2024	22:00		PLANNED	Requested
436	RQ177898	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA-HEERAPURA (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	05/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
437	RQ177888	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKANI-JAISALMER (RS) CKT-2	RRVPNL	D	Preventive maintenance & Testing of bay and equipments by Kankani end	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
438	RQ177835	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA-CHHABRA (RS) CKT-1	RRVPNL	D	Half Yearly Maintenance work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested
439	RQ177899	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA-RATANGARH (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	03/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested
440	RQ177560	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAGLIHAR(JK)-KISHENPUR(PG) (JKSPDCL) CKT-3	POWERGRID,J KSPDCL	D	SD required for attending shutdown nature defects	24/Jun/2024	09:00	24/Jun/2024	18:00	kindly approve	PLANNED	Requested
441	RQ177963	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEWWANPOH(PG)-BAGLIHAR(JK) (JKSPDCL) CKT-1	POWERGRID,J KSPDCL	D	Shutdown Required for installation of Pilot Insulator	12/Jun/2024	09:00	13/Jun/2024	18:00	kindly approve	PLANNED	Requested
442	RQ177965	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEWWANPOH(PG)-BAGLIHAR(JK) (JKSPDCL) CKT-1	POWERGRID,J KSPDCL	D	A/R required in Non auto mode for installation of Pilot Insulator in 400KV Kishenpur-New Wanpoh-1 for safety purpose.	08/Jun/2024	09:00	10/Jun/2024	18:00	kindly approve	PLANNED	Requested
443	RQ177966	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAGLIHAR(JK)-KISHENPUR(PG) (JKSPDCL) CKT-3	POWERGRID,J KSPDCL	D	A/R required in Non auto mode for installation of Pilot Insulator in 400KV Kishenpur-New Wanpoh-1 for safety purpose.	08/Jun/2024	09:00	10/Jun/2024	18:00	kindly approve	PLANNED	Requested
444	RQ177566	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)-SAINJ(HP) (PKTCL) CKT-1	PKTCL,POWER GRID	D	Replacement of Porcelaine insulator with CLR Polymer Insulator	21/Jun/2024	09:00	23/Jun/2024	18:00	kindly approve	PLANNED	Requested
445	RQ177567	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)-PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL,POWER GRID	D	A/R Non Auto Mode to facilitate the Shutdown work of 400KV Parbari - 3 - Sainj TL for safety purpose	21/Jun/2024	09:00	23/Jun/2024	18:00	kindly approve	PLANNED	Requested
446	RQ177565	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)-PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL,POWER GRID	D	Replacement of Porcelaine insulator with CLR Polymer Insulator	17/Jun/2024	09:00	20/Jun/2024	18:00	kindly approve	PLANNED	Requested
447	RQ177564	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)-SAINJ(HP) (PKTCL) CKT-1	PKTCL,POWER GRID	D	A/R Non Auto Mode to facilitate the Shutdown work of 400KV Banala - Parbari - 3 TL for safety purpose	17/Jun/2024	09:00	20/Jun/2024	18:00	kindly approve	PLANNED	Requested

448	RQ177561	OCC_219	cpc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NALAGARH(PG)-PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL,POWE RGRID	D	Replacement of Porcelain insulator with CLR Polymer Insulator	10/Jun/2024	09:00	11/Jun/2024	18:00	kindly approve	PLANNED	Requested	
449	RQ177562	OCC_219	cpc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_2(NH)-PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL,POWE RGRID	D	A/R. Non Auto Mode to facilitate the Shutdown work of 400kV Banala - Nalagarh TL for safety purpose	10/Jun/2024	09:00	11/Jun/2024	18:00	kindly approve	PLANNED	Requested	
450	RQ177568	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AZAMGARH-MAU (UP) CKT-1	UPPTCL	D	* Bushing tan delta testing of 50MVAR mau line reactor and CT,PT connection.	21/Jun/2024	08:00	22/Jun/2024	18:00		PLANNED	Requested	
451	RQ177563	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SARNATH-AZAMGARH (UP) CKT-1	UPPTCL	D	Bushing tan delta testing of 50MVAR sarnath line reactor and CT, PT connection.	19/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested	
452	RQ177578	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MURADNAGAR_2-MATHURA (UP) CKT-1	UPPTCL	D	* Suspension Insulator cleaning/Replacement, Tesion Tower Tightening,Bird Nest removal and Other work	18/Jun/2024	09:00	21/Jun/2024	20:00		PLANNED	Requested	
453	RQ177592	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TANDA(NT)-SULTANPUR(UP) (UP) CKT-1	UPPTCL	D	* Preventive Maintenance of Bay at 400KV S/S Sultanpur	13/Jun/2024	10:00	13/Jun/2024	16:00		PLANNED	Requested	
454	RQ177643	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV OBRA_B-SULTANPUR (UP) CKT-1	UPPTCL	D	* Preventive Maintenance of Bay at 400KV S/S Sultanpur	12/Jun/2024	10:00	12/Jun/2024	16:00		PLANNED	Requested	
455	RQ177368	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALAKNANDA GVK(UPC)-MUZAFFARNAGAR (UP) CKT-1	UPPTCL	C	Reason of Planned shutdown Re-locate of tower no 507 to 508 in same way of line corridor	11/Jun/2024	09:00	17/Jun/2024	18:00	Generation affected: Generation not affected because generations of both plant (Ip hydro & Alaknanda hydro) evacuated through Vishnu prayag- Muzaffarnagar and Vishnu prayag- Alaknanda Line.	PLANNED	Requested	
456	RQ177572	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUZAFFARNAGAR-ATAUR (UP) CKT-1	UPPTCL	D	* looping -chooping of trees, removing bird nests,conductor repairing and other work.	04/Jun/2024	09:00	05/Jun/2024	17:00		PLANNED	Requested	
457	RQ177367	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUZAFFARNAGAR(UP)-VISHNUPRAYAG(IP) (UP) CKT-1	UPPTCL	C	Reason of Planned shutdown Re-locate of tower no 507 to 508.in same way of line corridor	01/Jun/2024	09:00	10/Jun/2024	18:00		PLANNED	Requested	
458	RQ177920	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-UNNAO (UP) CKT-1	UPPTCL	C	* NHAI Diversion work replacement of damage earthwire other preventive maintenance work	01/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested	
459	RQ177735	OCC_219	cpc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JALANDHAR(PG)-SAMBA(PG) (NRSS XXIX) CKT-1	NRSS XXIX	D	AMP OF LINE EQUIPMENTS	19/Jun/2024	10:00	19/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
460	RQ177736	OCC_219	cpc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JALANDHAR(PG)-SAMBA(PG) (NRSS XXIX) CKT-2	NRSS XXIX	D	AMP OF LINE EQUIPMENTS	18/Jun/2024	10:00	18/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
461	RQ177500	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-2	HVPNL	D	To attend the drone survey observations	19/Jun/2024	10:00	19/Jun/2024	18:00		PLANNED	Requested	
462	RQ177499	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-1	HVPNL	D	To attend the drone survey observations and repairing of worn-out conductor.	18/Jun/2024	10:00	18/Jun/2024	18:00		PLANNED	Requested	
463	RQ177498	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-2	HVPNL	D	To attend the drone survey observations and repairing of worn-out conductor.	14/Jun/2024	10:00	14/Jun/2024	18:00		PLANNED	Requested	
464	RQ177942	OCC_219	jhajar_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHAJJAR(APCL)-DAULATABAD(HV) (HV) CKT-2	HVPNL	C	PM and testing of bay 16 & 17	12/Jun/2024	08:00	13/Jun/2024	18:00	Daultabad ckt-1 will be in charged conditions. Auto-reclosure of circuit-1 required in off condition	PLANNED	Requested	
465	RQ177497	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-1	HVPNL	D	To attend the drone survey observations and repairing of worn-out conductor.	11/Jun/2024	10:00	11/Jun/2024	18:00		PLANNED	Requested	
466	RQ177486	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHAJJAR(APCL)-DAULATABAD(HV) (HV) CKT-2	HVPNL	D	For attending red hot points observed in thermo vision scanning	10/Jun/2024	09:00	10/Jun/2024	17:00		PLANNED	Requested	
467	RQ177941	OCC_219	jhajar_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHAJJAR(APCL)-DAULATABAD(HV) (HV) CKT-1	HVPNL	C	PM & Testing of Bay 8 & 9	10/Jun/2024	08:00	11/Jun/2024	18:00	Tie Bay Mundka-II bay 08 will be under SD. Daultabad ckt-II will be in charged conditions.Auto-reclosure of Circuit-2 required in off condition	PLANNED	Requested	
468	RQ177485	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHAJJAR(APCL)-DAULATABAD(HV) (HV) CKT-1	HVPNL	D	For attending red hot points observed in thermo vision scanning	07/Jun/2024	09:00	07/Jun/2024	17:00		PLANNED	Requested	
469	RQ177494	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-1	HVPNL	D	To attend the drone survey observations.	05/Jun/2024	10:00	05/Jun/2024	18:00		PLANNED	Requested	
470	RQ177484	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GURGAON(PG)-DAULATABAD(HV) (HV) CKT-2	HVPNL	D	For attending red hot points observed in thermo vision scanning	05/Jun/2024	09:00	05/Jun/2024	17:00		PLANNED	Requested	
471	RQ177495	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-2	HVPNL	D	To attend the drone survey observations and OPGW tightening.	03/Jun/2024	10:00	03/Jun/2024	18:00		PLANNED	Requested	
472	RQ177483	OCC_219	slidchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GURGAON(PG)-DAULATABAD(HV) (HV) CKT-1	HVPNL	D	For attending red hot points observed in thermo vision scanning	03/Jun/2024	09:00	03/Jun/2024	17:00		PLANNED	Requested	
473	RQ177927	OCC_219	slidcuk_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ROORKEE(PG)-MUZAFFARNAGAR(UP) (PTCUL) CKT-1	PTCUL	D	Replacement of insulators work	19/Jun/2024	08:00	19/Jun/2024	17:00		PLANNED	Requested	

474	RQ177925	OCC_219	slidcuk_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RISHIKESH(UK)-NEHTAUR(UP) (UK) CKT-1	PTCUL	D	Preventive Maintenance & replacement of insulators work	18/Jun/2024	08:00	18/Jun/2024	17:00		PLANNED	Requested	
475	RQ177818	OCC_219	slidcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEEMRANA(PG)-BABAI(RS) (NRSS36) CKT-1	POWERGRID, NRSS36	D	Half Yearly Maintenance and Testing of bay equipments .	19/Jun/2024	06:00	19/Jun/2024	12:00		PLANNED	Requested	
476	RQ177816	OCC_219	slidcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SIKAR(PG)-BABAI(RS) (NRSS36) CKT-1	POWERGRID, NRSS36	D	Half Yearly Maintenance and Testing of bay equipments .	07/Jun/2024	06:00	07/Jun/2024	12:00		PLANNED	Requested	
477	RQ177651	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SULTANPUR(UP)-MOHANLALGANJ (PGYTJ) (PGYTJ) CKT-1	UPPTCL,PGYTL	D	* Preventive Maintenance of Bay at 400KV S/S Sultanpur	18/Jun/2024	10:00	18/Jun/2024	16:00		PLANNED	Requested	
478	RQ177926	OCC_219	slidcuk_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ROORKEE(PG)-RISHIKESH(UK) (PG) CKT-1	POWERGRID, PTCUL	D	Preventive Maintenance work	17/Jun/2024	08:00	17/Jun/2024	17:00		PLANNED	Requested	
479	RQ177581	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-GR.NOIDA(UPC) (PG) CKT-1	POWERGRID, UPPTCL	D	* Maintenance work will be done at Tower No. 1 of mentioned line.	16/Jun/2024	07:30	16/Jun/2024	16:00		PLANNED	Requested	
480	RQ177729	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV UNNAO(UP)-JEHTA_HARDDOI ROAD (UP) (PG) CKT-2	POWERGRID, UPPTCL	D	AMP Work	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	
481	RQ177728	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV UNNAO(UP)-JEHTA_HARDDOI ROAD (UP) (PG) CKT-1	POWERGRID, UPPTCL	D	AMP Work	08/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested	
482	RQ177709	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)-BASTI(UP) (PG) CKT-2	POWERGRID, UPPTCL	D	AMP Work	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested	
483	RQ177933	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GR.NOIDA(UPC)-NAWADA(HV) (PG) CKT-1	POWERGRID, UPPTCL	D	* Maintenance Work will be done at Wave trap clamp of mentioned line. 400 >X KV Nawada line shutdown will be required for menti	01/Jun/2024	07:30	01/Jun/2024	12:30		PLANNED	Requested	
484	RQ177812	OCC_219	slidcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BABAI(RS)-BHIWANI(PG) (NRSS36) CKT-2	NRSS36	D	Half Yearly Maintenance, Testing of bay equipments and To attend the SF6 GAS leakage in 552T C.B.	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested	
485	RQ177811	OCC_219	slidcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BABAI(RS)-BHIWANI(PG) (NRSS36) CKT-1	NRSS36	D	Half Yearly Maintenance, Testing of bay equipments	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
486	RQ177795	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-LUCKNOW_1(PG) (PG) CKT-1	POWERLINK	D	AMP Work	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
487	RQ177649	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI(BB)-RAIPURA(PS) (PG) CKT-1	POWERGRID, BBMB	D	S/D Required for installation of Pilot Insulator	06/Jun/2024	09:00	06/Jun/2024	18:00	kindly approve	PLANNED	Requested	
488	RQ177648	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHAR(BB)-RAIPURA(PS) (PG) CKT-1	POWERGRID, BBMB	D	A/R Non Auto Required	06/Jun/2024	09:00	06/Jun/2024	18:00	kindly approve	PLANNED	Requested	
489	RQ177646	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHAR(BB)-RAIPURA(PS) (PG) CKT-1	POWERGRID, BBMB	D	S/D Required for installation of Pilot Insulator	05/Jun/2024	09:00	05/Jun/2024	18:00	kindly approve	PLANNED	Requested	
490	RQ177647	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI(BB)-RAIPURA(PS) (PG) CKT-1	POWERGRID, BBMB	D	A/R Non Auto Required	05/Jun/2024	09:00	05/Jun/2024	18:00	kindly approve	PLANNED	Requested	
491	RQ177385	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-WAGOORA(PG) (NRSS XXIX) CKT-1	POWERGRID, NRSS XXIX	D	"Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021""	01/Jun/2024	09:00	01/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
492	RQ177405	OCC_219	cpcc_sd	BUS	400KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	29/Jun/2024	09:00	29/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
493	RQ177404	OCC_219	cpcc_sd	BUS	400KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	28/Jun/2024	09:00	28/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
494	RQ177403	OCC_219	cpcc_sd	BUS	400KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	27/Jun/2024	09:00	27/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
495	RQ177402	OCC_219	cpcc_sd	BUS	400KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	26/Jun/2024	09:00	26/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
496	RQ178320	OCC_219	cpcc_sd	BUS	400 KV FATEHGARH-II(PG) - BUS 1		D	For erection work of bay extension of 400KV/220KV ICT 11 Dia at Fatehgarh 2 RS INFRA	20/Jun/2024	14:00	28/Jun/2024	23:00	FOR BAY EXTENSION WORK OF ICT-3	PLANNED	Requested	
497	RQ177395	OCC_219	cpcc_sd	BUS	400KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	15/Jun/2024	09:00	15/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
498	RQ177394	OCC_219	cpcc_sd	BUS	400KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	14/Jun/2024	09:00	14/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
499	RQ177391	OCC_219	cpcc_sd	BUS	400KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	11/Jun/2024	09:00	11/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
500	RQ177390	OCC_219	cpcc_sd	BUS	400KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	10/Jun/2024	09:00	10/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
501	RQ178316	OCC_219	cpcc_sd	BUS	400 KV FATEHGARH-II(PG) - BUS 3		D	for AMP works	07/Jun/2024	14:00	07/Jun/2024	23:00		PLANNED	Requested	

502	RQ178315	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) - BUS 2		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:00		PLANNED	Requested
503	RQ178324	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) - BUS 4		D	For erection work of bay extension of 400 kv Jackson line bays	07/Jun/2024	14:00	12/Jun/2024	23:00		PLANNED	Requested
504	RQ178323	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) - BUS 3		D	For erection of LV side Jack bus of 765/400 kv ICT-5, Busbar, LBB Testing of ICT-5 under Phase 2 commissioning works	07/Jun/2024	14:00	12/Jun/2024	23:00		PLANNED	Requested
505	RQ177389	OCC_219	cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	06/Jun/2024	09:00	06/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested
506	RQ177388	OCC_219	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	05/Jun/2024	09:00	05/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested
507	RQ177387	OCC_219	cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	04/Jun/2024	09:00	04/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested
508	RQ177386	OCC_219	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	03/Jun/2024	09:00	03/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested
509	RQ178314	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-III(PG) - BUS 1		D	for AMP works	01/Jun/2024	14:00	06/Jun/2024	23:00		PLANNED	Requested
510	RQ178317	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-III(PG) - BUS 4		D	for AMP works	01/Jun/2024	14:00	06/Jun/2024	23:00		PLANNED	Requested
511	RQ178321	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-III(PG) - BUS 2		D	For erection work of bay extension of 400kv/220kv ICT 11 Dia at Fatehgarh 2 RS INFRA	01/Jun/2024	14:00	06/Jun/2024	23:00	FOR BAY EXTENSION WORK OF ICT-3	PLANNED	Requested
512	RQ178322	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-III(PG) - BUS 3		D	For erection work of bay extension of 400 kv Jackson line bays	01/Jun/2024	14:00	06/Jun/2024	23:00	FOR BAY EXTENSION WORK OF ICT-3	PLANNED	Requested
513	RQ177803	OCC_219	cpcc3_sd	BUS	400KV AGRA(PG) - BUS 6	POWERGRID	D	Jumper and isolator maintenance work at 400 KV Bus-2B	29/Jun/2024	08:00	29/Jun/2024	18:00		PLANNED	Requested
514	RQ177714	OCC_219	cpcc3_sd	BUS	400KV BUS 2 AT ALLAHABAD(PG)	POWERGRID	C	Relay Testing and AMP Work	27/Jun/2024	08:00	28/Jun/2024	18:00		PLANNED	Requested
515	RQ178357	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT BHINMAL(PG)	POWERGRID	D	For 412 89T Isolator jumper work - under Project SS-95 package	27/Jun/2024	08:00	27/Jun/2024	18:00		PLANNED	Requested
516	RQ177742	OCC_219	cpcc3_sd	BUS	400KV BUS 2 AT LUCKNOW_1(PG)	POWERGRID	D	For AMP work	25/Jun/2024	09:00	25/Jun/2024	18:00		PLANNED	Requested
517	RQ178353	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT BHINMAL(PG)	POWERGRID	D	For BUS BAR TESTING - under Project SS-95 package	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested
518	RQ177707	OCC_219	cpcc3_sd	BUS	400KV BUS 1 AT ALLAHABAD(PG)	POWERGRID	C	Bus Bar relay testing and AMP Work	25/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested
519	RQ178394	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (For Stability Test of 400 kv Bus-2)	25/Jun/2024	08:00	26/Jun/2024	20:00		PLANNED	Requested
520	RQ177741	OCC_219	cpcc3_sd	BUS	400KV BUS 1 AT LUCKNOW_1(PG)	POWERGRID	D	For AMP work	24/Jun/2024	09:00	24/Jun/2024	18:00		PLANNED	Requested
521	RQ178372	OCC_219	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 4	POWERGRID	D	Jumpering and testing works for Bay Extension	23/Jun/2024	17:00	24/Jun/2024	23:00		PLANNED	Requested
522	RQ178362	OCC_219	cpcc1_sd	BUS	400 KV BIKANER(PG) - BUS 2	POWERGRID	D	For jumpering, testing & commissioning works of 400/220kv ICT-3	23/Jun/2024	16:00	27/Jun/2024	23:00	Under Project SS-101 Package	PLANNED	Requested
523	RQ178393	OCC_219	cpcc1_sd	BUS	400KV BUS 1 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (For Stability Test of 400 kv Bus-1)	23/Jun/2024	08:00	24/Jun/2024	20:00		PLANNED	Requested
524	RQ178361	OCC_219	cpcc1_sd	BUS	400 KV BIKANER(PG) - BUS 1	POWERGRID	D	For jumpering, testing & commissioning works of 400/220kv ICT-3	18/Jun/2024	17:00	22/Jun/2024	22:00	Under Project SS-101 Package	PLANNED	Requested
525	RQ178371	OCC_219	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 3	POWERGRID	D	Jumpering and testing works for Bay Extension	17/Jun/2024	17:00	22/Jun/2024	23:00		PLANNED	Requested
526	RQ178335	OCC_219	cpcc1_sd	BUS	400KV BUS 4 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT WORK	17/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested
527	RQ177556	OCC_219	cpcc2_sd	BUS	400KV BUS 3 AT MOGA(PG)	POWERGRID	C	Attending SF6 Leakage in 400 kv GIS Bus-1	16/Jun/2024	08:00	30/Jun/2024	18:00	kindly approve	PLANNED	Requested
528	RQ178370	OCC_219	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 2	POWERGRID	D	Jumpering and testing works for Bay Extension	15/Jun/2024	17:00	16/Jun/2024	23:00		PLANNED	Requested
529	RQ178334	OCC_219	cpcc1_sd	BUS	400KV BUS 3 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT WORK	14/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested
530	RQ178369	OCC_219	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 1	POWERGRID	D	Jumpering and testing works for Bay Extension	13/Jun/2024	17:00	14/Jun/2024	23:00		PLANNED	Requested
531	RQ177424	OCC_219	cpcc2_sd	BUS	400KV BUS 2 AT NEWWANPOH(PG)	POWERGRID	D	For AMP work	12/Jun/2024	09:00	12/Jun/2024	18:00	kindly approve.	PLANNED	Requested
532	RQ178333	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT WORK	12/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
533	RQ178373	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT BAHADURGARH(PG)	POWERGRID	D	AMP Work	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
534	RQ177720	OCC_219	cpcc3_sd	BUS	400KV BUS 2 AT SOHAWAL(PG)	POWERGRID	D	AMP Work	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
535	RQ178374	OCC_219	cpcc1_sd	BUS	400KV BUS 4 AT BAHADURGARH(PG)	POWERGRID	D	AMP Work	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
536	RQ178378	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT BHIWADI(PG)	POWERGRID	C	For Bus Bar testing works	09/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
537	RQ178332	OCC_219	cpcc1_sd	BUS	400KV BUS 1 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT WORK	09/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
538	RQ178390	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (erection of equipment)	08/Jun/2024	08:00	10/Jun/2024	20:00		PLANNED	Requested
539	RQ177423	OCC_219	cpcc2_sd	BUS	400KV BUS 1 AT NEWWANPOH(PG)	POWERGRID	D	For AMP work	05/Jun/2024	09:00	05/Jun/2024	18:00	kindly approve.	PLANNED	Requested
540	RQ178344	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT HISSAR(PG)	POWERGRID	D	BUSBAR AMP WORK	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
541	RQ178341	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT NEEMRANA(PG)	POWERGRID	D	Bay Integration Work	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
542	RQ178379	OCC_219	cpcc1_sd	BUS	400KV BUS 2 AT JIND(PG)	POWERGRID	D	For const. activities of SS-104 package (Erection of IPS Tube and Clamps connectors in bay 412)	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
543	RQ178343	OCC_219	cpcc1_sd	BUS	400KV BUS 1 AT HISSAR(PG)	POWERGRID	D	BUSBAR AMP WORK	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested

544	RQ178389	OCC_219	cpcc1_sd	BUS	400KV BUS 1 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (erection of equipment)	04/Jun/2024	08:00	06/Jun/2024	20:00		PLANNED	Requested	
545	RQ177950	OCC_219	cpcc2_sd	BUS	400KV BUS 1 AT KISHENPUR(PG)	POWERGRID	D	For AMP and Jumper Strengthening work.	03/Jun/2024	09:00	03/Jun/2024	17:00	Kindly approve	PLANNED	Requested	
546	RQ178377	OCC_219	cpcc1_sd	BUS	400KV BUS 1 AT BHIWADI(PG)	POWERGRID	C	For Bus Bar testing works	03/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested	
547	RQ178340	OCC_219	cpcc1_sd	BUS	400KV BUS 1 AT NEEMRANA(PG)	POWERGRID	D	Bay Integration Work	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested	
548	RQ178388	OCC_219	cpcc1_sd	BUS	400KV BUS 1 AT BASSI(PG)	POWERGRID	D	400KV BUSBAR RETROFITMENT WORK	03/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested	
549	RQ178519	OCC_219	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) - BUS 2	POWERGRID	C	For Compliance of Vigilance department observation regarding strengthening of foundation (Civil) of 401 Bay bus isolator 401 89 A (B-phase) and earth switch 401 89 AE (B-phase).	01/Jun/2024	17:00	07/Jun/2024	22:00	along with bay Fatehgarh-3 413 bay	PLANNED	Requested	
550	RQ177557	OCC_219	cpcc2_sd	BUS	400KV BUS 4 AT MOGA(PG)	POWERGRID	C	Attending SF6 Leakage in 400 KV GIS Bus-2	01/Jun/2024	08:00	15/Jun/2024	18:00	kindly approve	PLANNED	Requested	
551	RQ177534	OCC_219	slcds_sd	BUS	400KV BUS 2 AT BARMER(RS)	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	28/Jun/2024	08:00	28/Jun/2024	18:00		PLANNED	Requested	
552	RQ177537	OCC_219	slcds_sd	BUS	400KV BUS 2KANKANI(RS)	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested	
553	RQ177533	OCC_219	slcds_sd	BUS	400KV BUS 1 AT BARMER(RS)	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested	
554	RQ177536	OCC_219	slcds_sd	BUS	400KV BUS 1KANKANI(RS)	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	24/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested	
555	RQ177530	OCC_219	slcds_sd	BUS	400KV BUS 2 AT MERTA(RS)	RRVPNL	D	Annual maintenance and testing of Bus-1 and bus connecting isolators.	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
556	RQ177535	OCC_219	slcds_sd	BUS	400KV BUS 1 AT BIKANER(RS)	RRVPNL	D	Routine Maintenance	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested	
557	RQ177526	OCC_219	slcds_sd	BUS	400KV BUS 1 AT JODHPUR(RS)	RRVPNL	D	Quarterly Preventive Maintenance and testing work.	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested	
558	RQ177529	OCC_219	slcds_sd	BUS	400KV BUS 1 AT MERTA(RS)	RRVPNL	D	Annual maintenance and testing of Bus-1 and bus connecting isolators.	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested	
559	RQ177527	OCC_219	slcds_sd	BUS	400KV BUS 2 AT JODHPUR(RS)	RRVPNL	D	Quarterly Preventive Maintenance and testing work.	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	
560	RQ177532	OCC_219	slcds_sd	BUS	400KV BUS 2 AT BABAII(RS)	RRVPNL	D	Half Yearly Maintenance, Testing of bay equipments	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested	
561	RQ177531	OCC_219	slcds_sd	BUS	400KV BUS 1 AT BABAII(RS)	RRVPNL	D	Half Yearly Maintenance, Testing of bay equipments and To attend the SF6 GAS leakage in 152 A.C.B.	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested	
562	RQ177528	OCC_219	slcds_sd	BUS	400KV BUS 1 AT KAWAI SCTPS(APR)	APRL	D	Annual maintenance and testing of Bus-1 and bus connecting isolators.	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested	
563	RQ177650	OCC_219	sttuup_sd	BUS	400KV BUS 2 AT SULTANPUR(UP)	UPPTCL	D	* Preventive Maintenance of Bus-B at 400KV S/S Sultanpur	14/Jun/2024	10:00	14/Jun/2024	16:00		PLANNED	Requested	
564	RQ177370	OCC_219	sttuup_sd	BUS	400KV BUS 2 AT MUZAFFARNAGAR(UP)	UPPTCL	C	MAINTINANCE OF PANTAGRAPH ISOLATOR	13/Jun/2024	09:00	15/Jun/2024	18:00	Generation affected: Generation not affected because SUPPLY evacuated through B- BUS & TBC Muzaffarnagar	PLANNED	Requested	
565	RQ177369	OCC_219	sttuup_sd	BUS	400KV BUS 1 AT MUZAFFARNAGAR(UP)	UPPTCL	C	MAINTINANCE OF PANTAGRAPH ISOLATOR	10/Jun/2024	09:00	12/Jun/2024	18:00	Generation affected: Generation not affected because SUPPLY evacuated through B- BUS & TBC Muzaffarnagar	PLANNED	Requested	
566	RQ177928	OCC_219	sttuup_sd	BUS	400 KV GR.NOIDA_2(LPC) - BUS 2	UPPTCL	D	* Maintenance work will be done of 400 KV Main Bus-2nd.	02/Jun/2024	08:00	02/Jun/2024	12:00		PLANNED	Requested	
567	RQ178511	OCC_219	cpcc1_sd	BUS	400 KV BIKANER_2 (PBTS) - BUS 2	PBTS	D	For Bay extension works	11/Jun/2024	15:00	17/Jun/2024	23:00		PLANNED	Requested	
568	RQ178510	OCC_219	cpcc1_sd	BUS	400 KV BIKANER_2 (PBTS) - BUS 1	PBTS	D	For Bay extension works	05/Jun/2024	17:00	10/Jun/2024	23:00		PLANNED	Requested	
569	RQ177439	OCC_219	singrauli_sd	BUS	400KV BUS 2 AT SINGRAULI(NT)	NTPC	C	BUS-02 OF ANPARA AND ALD-01 ISOLATOR REPLACEMENT	10/Jun/2024	08:00	15/Jun/2024	18:00	BUS-02 SHUTDOWN REQUIRED	PLANNED	Requested	
570	RQ177915	OCC_219	ntpcos_sd	BUS	400KV BUS 3 AT RIHAND(NT)	NTPC	D	For OH works on BUS & Bus side connected isolators OH works.	07/Jun/2024	08:00	07/Jun/2024	18:00	For OH works on BUS & Bus side connected isolators OH works.	PLANNED	Requested	
571	RQ177579	OCC_219	slcds_sd	BUS	400KV BUS 1 AT KASHIPUR(UK)	PTCUL	D	For dismantling of existing line side switchgear equipment of 400kV Srinagar Main Bay for upgradation work by M/s K.R.T.L. Limited	06/Jun/2024	09:00	06/Jun/2024	12:00	Bus I Shut Down will not cause any disturbance as all the 400kV feeders will feed through 400kV Main Bus II	PLANNED	Requested	
572	RQ177481	OCC_219	slcds_sd	BUS	400KV BUS 2 AT KABULPUR(HV)	HVPNL	D	AMP of BUS Equipment (Testing of line CVT, BUS Isolator Alignment)	06/Jun/2024	08:00	06/Jun/2024	20:00		PLANNED	Requested	
573	RQ177480	OCC_219	slcds_sd	BUS	400KV BUS 1 AT KABULPUR(HV)	HVPNL	D	AMP of BUS Equipment (Testing of line CVT, BUS Isolator Alignment)	05/Jun/2024	08:00	05/Jun/2024	20:00		PLANNED	Requested	
574	RQ177354	OCC_219	sttuup_sd	BUS	400 KV BADAUNE(UP) - BUS 1	OCBTL	C	For rectification of very minor Gas leakage observed in Y-ph Bus-1 PT	04/Jun/2024	10:00	07/Jun/2024	18:00		PLANNED	Requested	
575	RQ178515	OCC_219	cpcc1_sd	LINE REACTOR	80 MVAR SWITCHABLE LR ON 400 KV BIKANER_2 (PBTS)-KHETRI (PKTSL) (PBTS) CKT-1 @BIKANER_2 (PBTS)	PBTS	D	For Implementing the logic in Back-up Impedance relay as per latest IOM	25/Jun/2024	17:00	25/Jun/2024	23:00		PLANNED	Requested	
576	RQ178514	OCC_219	cpcc1_sd	LINE REACTOR	80 MVAR SWITCHABLE LR ON 400 KV BIKANER_2 (PBTS)-KHETRI (PKTSL) (PBTS) CKT-2 @BIKANER_2 (PBTS)	PBTS	D	For Implementing the logic in Back-up Impedance relay as per latest IOM	24/Jun/2024	17:00	24/Jun/2024	23:00		PLANNED	Requested	

577	RQ178513	OCC_219	cpcc1_sd	LINE REACTOR	80 MVAR SWITCHABLE LR ON 400 KV BIKANER_2 (PBTS)-KHETRI (PKTSL) (PBTS) CKT-3 @BIKANER_2 (PBTS)	PBTS	D	For attending the issue in PT100 Sensor	22/Jun/2024	17:00	22/Jun/2024	23:00		PLANNED	Requested
578	RQ178512	OCC_219	cpcc1_sd	LINE REACTOR	80 MVAR SWITCHABLE LR ON 400 KV BIKANER_2 (PBTS)-KHETRI (PKTSL) (PBTS) CKT-4 @BIKANER_2 (PBTS)	PBTS	D	For attending the issue in PT100 Sensor	21/Jun/2024	17:00	21/Jun/2024	22:00		PLANNED	Requested
579	RQ177654	OCC_219	cpcc2_sd	LINE REACTOR	50 MVAR NON-SWITCHABLE LR ON KURUKSHETRA(PG)-NAKODAR(PSG) (PG) CKT-1 @NAKODAR(PSG)	POWERGRID	D	For AMP work	20/Jun/2024	10:00	20/Jun/2024	16:00	kindly approve	PLANNED	Requested
580	RQ178444	OCC_219	cpcc1_sd	LINE REACTOR	50 MVAR NON-SWITCHABLE LR ON AGRA-JAIPUR SOUTH (PG) CKT-2 @JAIPUR SOUTH(PG)	POWERGRID	D	CSD Fine tuning of 50MVAR AGRA-2 Line Reactor (406 Main Bay, Minimum 5 open & close on load operations will be carried out during fine tuning of the CSD)	08/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested
581	RQ178451	OCC_219	cpcc1_sd	LINE REACTOR	50 MVAR SWITCHABLE LR ON 400 KV KANKROLI-ZERDA (PG) CKT-1 @KANKROLI(PG)	POWERGRID	D	Rectification of CoE Audit point	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested
582	RQ178443	OCC_219	cpcc1_sd	LINE REACTOR	50 MVAR NON-SWITCHABLE LR ON AGRA-JAIPUR SOUTH (PG) CKT-1 @JAIPUR SOUTH(PG)	POWERGRID	D	CSD Fine tuning of 50MVAR AGRA-1 Line Reactor (406 Main Bay, Minimum 5 open & close on load operations will be carried out during fine tuning of the CSD)	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested
583	RQ178442	OCC_219	cpcc1_sd	LINE REACTOR	50 MVAR NON-SWITCHABLE LR ON 400 KV RAPS_D(NP)-JAIPUR SOUTH(PG) (PG) CKT-1 @JAIPUR SOUTH(PG)	POWERGRID	D	CSD Fine tuning of 50MVAR RAPP-D Line Reactor (415 Main Bay, Minimum 5 open & close on load operations will be carried out during fine tuning of the CSD)	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
584	RQ178438	OCC_219	cpcc1_sd	LINE REACTOR	50 MVAR SWITCHABLE LR ON 400 KV BHINMAL-KANKROLI (PG) CKT-1 @BHINMAL(PG)	POWERGRID	D	CSD Fine tuning of 50MVAR 400KV Bhinmal-KankrolI Line Reactor-(404R Main Bay, Minimum 5 open & close on load operations will be carried out during fine tuning of the CSD)	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested
585	RQ177633	OCC_219	slcds_sd	LINE REACTOR	80 MVAR SWITCHABLE LR ON 400 KV BABAI(RS)-SURATGARH SCTPS(RVUN) (RS) CKT-1 @BABAI(RS)	RRVPNL	D	Half Yearly Maintenance and Testing of bay equipments .	06/Jun/2024	06:00	06/Jun/2024	12:00		PLANNED	Requested
586	RQ177632	OCC_219	slcds_sd	LINE REACTOR	80 MVAR SWITCHABLE LR ON 400 KV BABAI(RS)-SURATGARH SCTPS(RVUN) (RS) CKT-2 @BABAI(RS)	RRVPNL	D	Half Yearly Maintenance and Testing of bay equipments .	04/Jun/2024	06:00	04/Jun/2024	12:00		PLANNED	Requested
587	RQ177618	OCC_219	slcds_sd	BR/BSR/MS/M SR	80 MVAR BUS REACTOR NO 1 AT 400 KV KANKANI(RS)	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	28/Jun/2024	08:00	28/Jun/2024	18:00		PLANNED	Requested
588	RQ177617	OCC_219	slcds_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 1 AT 400KV PHAGI(RS)	RRVPNL	D	QUARTERLY MAINTENANCE WORK OF ASSOCIATED BAY EQUIPMENTS	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested
589	RQ177706	OCC_219	slcds_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 1 AT 400 KV AKAL(RS)	RRVPNL	D	Quarterly maintenance work	19/Jun/2024	16:00	20/Jun/2024	20:00		PLANNED	Requested
590	RQ177705	OCC_219	slcds_sd	BR/BSR/MS/M SR	50 MVAR BUS REACTOR NO 1 AT 400KV AKAL(RS)	RRVPNL	D	Quarterly maintenance work	17/Jun/2024	16:00	18/Jun/2024	20:00		PLANNED	Requested
591	RQ177616	OCC_219	slcds_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 1 AT 400KV MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested
592	RQ177619	OCC_219	slcds_sd	BR/BSR/MS/M SR	80 MVAR BUS REACTOR NO 1 AT 400 KV BABAI(RS)	RRVPNL	D	Half Yearly Maintenance and Testing of bay equipments .	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
593	RQ177615	OCC_219	slcds_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 1 AT 400KV BARMER(RS)	RRVPNL	D	Quarterly / Half yearly Maintenance along with testing of Bay equipments	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested
594	RQ178433	OCC_219	cpcc1_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 1 AT 400 KV FATEHGARH_JI(PG)		D	for AMP works	22/Jun/2024	14:00	24/Jun/2024	22:00		PLANNED	Requested
595	RQ178424	OCC_219	cpcc1_sd	BR/BSR/MS/M SR	50 MVAR BUS REACTOR NO 2 AT 400KV KOTA(PG)	POWERGRID	D	CSD Fine tuning Work	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
596	RQ178420	OCC_219	cpcc1_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 1 AT 400KV KURUKSHETRA(PG)	POWERGRID	D	Rectification of SIR Audit point AND CSD FINE TUNING	20/Jun/2024	08:00	20/Jun/2024	18:00	(Minimum 5 open & close on load operations of Bus Reactor will be carried out during fine tuning of the CSD relay)	PLANNED	Requested
597	RQ178406	OCC_219	cpcc1_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 2 AT 400KV JAIPUR SOUTH(PG)	POWERGRID	D	Rectification of CoE Audit point	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
598	RQ178422	OCC_219	cpcc1_sd	BR/BSR/MS/M SR	125 MVAR BUS REACTOR NO 1 AT 400KV KOTESWAR(TH)	POWERGRID	D	AMP WORK	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested

599	RQ178405	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	125 MVAR BUS REACTOR NO 1 AT 400KV JAIPUR SOUTH(PG)	POWERGRID	D	Rectification of CoE Audit point	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested	
600	RQ178399	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	225 MVAR BUS SERIES REACTOR NO 1 AT 400 KV MANDOLA(PG)	POWERGRID	D	BUS BAR RETROFITMENT WORK	13/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested	
601	RQ178400	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	50 MVAR BUS REACTOR NO 1 AT 400KV MANDOLA(PG)	POWERGRID	D	BUS BAR RETROFITMENT WORK	10/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
602	RQ178403	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	125 MVAR BUS REACTOR NO 1 AT 400KV JAIPUR SOUTH(PG)	POWERGRID	D	CSD Fine tuning of 125MVAR Bus Reactor-1 (410 Main Bay, Minimum 5 open & close on load operations will be carried out during fine tuning of the CSD)	06/Jun/2024	09:00	06/Jun/2024	17:00	(Minimum 5 open & close on load operations of Bus Reactor will be carried out during fine tuning of the CSD relay)	PLANNED	Requested	
603	RQ178410	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	80 MVAR BUS REACTOR NO 1 AT 400KV SIKAR(PG)	POWERGRID	D	AMP WORK	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested	
604	RQ178416	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	125 MVAR BUS REACTOR NO 2 AT 400KV KANKROLI(PG)	POWERGRID	D	Rectification of CoE Audit point	06/Jun/2024	08:00	06/Jun/2024	15:00		PLANNED	Requested	
605	RQ178401	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	125 MVAR BUS REACTOR NO 2 AT 400 KV MANDOLA(PG)	POWERGRID	D	BUS BAR RETROFITMENT WORK	06/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested	
606	RQ178409	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	50 MVAR BUS REACTOR NO 2 AT 400KV SAHARANPUR(PG)	POWERGRID	D	For AMP work	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested	
607	RQ178415	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	50 MVAR BUS REACTOR NO 1 AT 400KV KANKROLI(PG)	POWERGRID	D	Rectification of CoE Audit point	05/Jun/2024	08:00	05/Jun/2024	15:00		PLANNED	Requested	
608	RQ178404	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	125 MVAR BUS REACTOR NO 2 AT 400KV JAIPUR SOUTH(PG)	POWERGRID	D	CSD Fine tuning of 125MVAR Bus Reactor-2 (413 Main Bay & 414 Tie Bay, Minimum 5 open & close on load operations will be carried out during fine tuning of the CSD)	04/Jun/2024	09:00	04/Jun/2024	17:00	(Minimum 5 open & close on load operations of Bus Reactor will be carried out during fine tuning of the CSD relay)	PLANNED	Requested	
609	RQ178425	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	225 MVAR BUS SERIES REACTOR NO 1 AT 400 KV MANDOLA(PG)	POWERGRID	D	For AMP work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested	
610	RQ178408	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	50 MVAR BUS REACTOR NO 1 AT 400KV SAHARANPUR(PG)	POWERGRID	D	For AMP work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested	
611	RQ178407	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	80 MVAR BUS REACTOR NO 1 AT 400KV BHINMAL(PG)	POWERGRID	D	CSD Fine tuning of 80MVAR Bus Reactor (409 Main Bay & 408 Tie Bay, Minimum 5 open & close on load operations will be carried out during fine tuning of the CSD)	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested	
612	RQ177542	OCC_219	stuup_sd	BR/BSR/MSC/M/SR	125 MVAR BUS REACTOR NO 1 AT 400 KV BASTI(UP)	UPPTCL	D	* Shutdown of 125MVAR Bus Reactor is required for annual testing and maintenance purpose.	17/Jun/2024	10:00	17/Jun/2024	16:00		PLANNED	Requested	
613	RQ178411	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	80 MVAR BUS REACTOR NO 1 AT 400 KV MEERUT_PMSTL (UP)	UPPTCL	C	SF6 Gas density monitor body replacement	12/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested	
614	RQ177929	OCC_219	stuup_sd	BR/BSR/MSC/M/SR	63 MVAR BUS REACTOR NO 1 AT 400KV ANPARA(UP)	UPPTCL	D	For testing of Bus reactor and Transfer bus bay element.Attending oil leakage from bus reactor	03/Jun/2024	09:00	06/Jun/2024	17:00	Bus reactor will be in charged condition from Transfer bus BTPS	PLANNED	Requested	
615	RQ178414	OCC_219	cpcc1_sd	BR/BSR/MSC/M/SR	125 MVAR BUS REACTOR NO 1 AT 400 KV KHETRI (PKTSL)	PKTSL	C	For CSD fine tuning	01/Jun/2024	08:00	02/Jun/2024	18:00	(Minimum 5 open & close on load operations of Bus Reactor will be carried out during fine tuning of the CSD relay)	PLANNED	Requested	
616	RQ177544	OCC_219	rampur_sd	BR/BSR/MSC/M/SR	80 MVAR BUS REACTOR NO 1 AT 400KV RAMPUR HEP(SJ)	SJVNL	C	The peaking season is about to start as per the past observation and during this period the voltage level of the transmission line become under 400KV. So we have to disconnect the bus reactor to optimize the voltage level.	01/Jun/2024	08:00	28/Sep/2024	18:00		PLANNED	Requested	
617	RQ177639	OCC_219	jhakri_sd	BR/BSR/MSC/M/SR	80 MVAR BUS REACTOR NO 1 AT 400KV NATHPA JHAKRI(SJ)	SJVNL	C	The peaking season is about to start as per the past observation and during this period the voltage level of the transmission lines become about 400 KV. So, we have to disconnect the Bus Reactor to optimize the voltage level. The shutdown for Bus Reactor is required w.e.f. 20.05.2024 to 15.09.2024. You are requested to approve for the same.	01/Jun/2024	08:00	15/Sep/2024	18:00		PLANNED	Requested	
618	RQ177595	OCC_219	cpcc3_sd	BAY	408 TIE BAY - 400 KV SAMBHAL_PRSTL - RAMPUR_PRSTL (UP) CKT-1 (UPPTCL) AND 400/220 KV 500 MVA ICT 2 AT SAMBHAL_PRSTL (UP) AT 400 KV SAMBHAL_PRSTL (UP) (UPPTCL)	UPPTCL	C	CB Interrupter maintenance work	27/Jun/2024	10:00	06/Jul/2024	18:00		PLANNED	Requested	

619	RQ178502	OCC_219	cpcc1_sd	BAY	408 TIE BAY - 765/400 KV 1500 MVA ICT 1 AT MEERUT_PMSTL (UP) (UPPTCL) AND FUTURE AT 400 KV MEERUT_PMSTL (UP) (UPPTCL)	UPPTCL	C	SF6 Gas density monitor body replacement	20/Jun/2024	08:00	22/Jun/2024	18:00			PLANNED	Requested
620	RQ178501	OCC_219	cpcc1_sd	BAY	409 MAIN BAY - 400 KV MEERUT_PMSTL (UP) - BUS 2 (UPPTCL) AT 400 KV MEERUT_PMSTL (UP)	UPPTCL	C	SF6 Gas density monitor body replacement	20/Jun/2024	08:00	22/Jun/2024	18:00			PLANNED	Requested
621	RQ177922	OCC_219	stuup_sd	BAY	407 MAIN BAY - 400 KV REWA ROAD-PANKI (UP) CKT-1 (UPPTCL) AT 400 KV PANKI(UP)	UPPTCL	D	* SHUTDOWN OF 400KV PANKI-FATEHPUR CKT-I FOR BAY MAINTENANCE	18/Jun/2024	08:00	18/Jun/2024	17:00			PLANNED	Requested
622	RQ177591	OCC_219	cpcc3_sd	BAY	407 MAIN BAY - 400/220 KV 500 MVA ICT 2 AT SAMBHAL_PRSTL (UP) (UPPTCL) AT 400 KV SAMBHAL_PRSTL (UP)	UPPTCL	C	CB Interrupter maintenance work	17/Jun/2024	10:00	26/Jun/2024	18:00			PLANNED	Requested
623	RQ178499	OCC_219	cpcc1_sd	BAY	414 MAIN BAY - 400 KV MEERUT_PMSTL (UP) - BUS 2 (UPPTCL) AT 400 KV MEERUT_PMSTL (UP)	UPPTCL	C	SF6 Gas density monitor body replacement	17/Jun/2024	08:00	19/Jun/2024	18:00			PLANNED	Requested
624	RQ178500	OCC_219	cpcc1_sd	BAY	413 TIE BAY - 400/220 KV 500 MVA ICT 1 AT MEERUT_PMSTL (UP) (UPPTCL) AND FUTURE AT 400 KV MEERUT_PMSTL (UP) (UPPTCL)	UPPTCL	C	SF6 Gas density monitor body replacement	17/Jun/2024	08:00	19/Jun/2024	18:00			PLANNED	Requested
625	RQ177923	OCC_219	stuup_sd	BAY	401 MAIN BAY - 400 KV UNNAO(UP)-JEHTA_HARDOI ROAD (UP) (PG) CKT-1 (UPPTCL)	UPPTCL	D	* Shutdown of 400 kv Unnao Ckt-1 for BCU rectification work	11/Jun/2024	10:00	12/Jun/2024	17:00			PLANNED	Requested
626	RQ177590	OCC_219	cpcc3_sd	BAY	406 MAIN BAY - 400 KV SAMBHAL_PRSTL - BADAJUNE (UP) CKT-2 (UPPTCL) AT 400 KV SAMBHAL_PRSTL (UP)	UPPTCL	C	CB Interrupter maintenance work	07/Jun/2024	08:00	16/Jun/2024	18:00			PLANNED	Requested
627	RQ177351	OCC_219	stuup_sd	BAY	411 MAIN BAY - 400KV BAREILLY-UNNAO (UP) CKT-2 AT BAREILLY(UP)	UPPTCL	D	* 19.03.2024 12:37:58 INDIA (11007707) Phone 9412738883 >X* for testing of line and preventive maintenance	04/Jun/2024	06:00	04/Jun/2024	18:00			PLANNED	Requested
628	RQ177543	OCC_219	stuup_sd	BAY	406 MAIN BAY - 400 KV LUCKNOW_1(PG)-BASTI(UP) (PG) CKT-2 (UPPTCL)	UPPTCL	D	* Shutdown of 400kv Basti-Lko.(PG) II is required to check and testing of >X Bus Bar protection scheme. During shutdown, inter-	03/Jun/2024	11:00	03/Jun/2024	16:00			PLANNED	Requested
629	RQ177545	OCC_219	stuup_sd	BAY	404 MAIN BAY - 400 KV GORAKHPUR(PG)-BASTI(UP) (PG) CKT-2 (UPPTCL)	UPPTCL	D	* Shutdown of 400kv Basti-Gkp.(PG) II is required to check and testing of >X Bus Bar protection scheme. During shutdown, inter-	03/Jun/2024	11:00	03/Jun/2024	16:00			PLANNED	Requested
630	RQ177924	OCC_219	stuup_sd	BAY	409 BUS COUPLER BAY - 400 KV BASTI(UP) - BUS 1 (UPPTCL) AND 400 KV BASTI(UP) - BUS 2 AT 400 KV BASTI(UP) (UPPTCL)	UPPTCL	D	* Shutdown of 400kv Bus Coupler is required for annual testing and >X maintenance purpose.	03/Jun/2024	11:00	03/Jun/2024	16:00			PLANNED	Requested
631	RQ177350	OCC_219	stuup_sd	BAY	410 MAIN BAY - 400KV BAREILLY-UNNAO (UP) CKT-1 AT BAREILLY(UP)	UPPTCL	D	* 19.03.2024 12:40:57 INDIA (11007707) Phone 9412738883 >X* for testing of line and preventive maintenance	03/Jun/2024	06:00	03/Jun/2024	18:00			PLANNED	Requested
632	RQ177688	OCC_219	cpcc3_sd	BAY	W10Q2 TIE BAY - 400 KV AGRA(PG)-FILTER BANK-1 (POWERGRID) AND FUTURE AT 400 KV AGRA(PG) (POWERGRID)	POWERGRID	D	For AMP work	26/Jun/2024	09:00	26/Jun/2024	18:00			PLANNED	Requested
633	RQ177744	OCC_219	cpcc3_sd	BAY	409 MAIN BAY - 400 KV MAU(UP)-RASRA (UP) (PG) CKT-1 (POWERGRID)	POWERGRID	C	FOR CB Retrofitment Work	26/Jun/2024	08:00	30/Jun/2024	18:00			PLANNED	Requested
634	RQ177686	OCC_219	cpcc3_sd	BAY	W10Q1 MAIN BAY - 400 KV AGRA(PG)-FILTER BANK-1 (POWERGRID)	POWERGRID	D	For AMP work	25/Jun/2024	09:00	25/Jun/2024	18:00			PLANNED	Requested
635	RQ177692	OCC_219	cpcc3_sd	BAY	W1 W3.Q1 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT AGRA(PG) (POWERGRID) AT 400 KV AGRA(PG)	POWERGRID	D	For AMP work	24/Jun/2024	09:00	24/Jun/2024	18:00			PLANNED	Requested
636	RQ177743	OCC_219	cpcc3_sd	BAY	408 MAIN BAY - 400 KV MAU(UP)-BALIA(PG) (PG) CKT-1 (POWERGRID)	POWERGRID	C	FOR CB Retrofitment Work	22/Jun/2024	08:00	28/Jun/2024	18:00			PLANNED	Requested

637	RQ178471	OCC_219	cpcc1_sd	BAY	424 TIE BAY - 400KV KURUKSHETRA-SONIPAT (PG) CKT-1 AND 400KV KURUKSHETRA-SONIPAT (PG) CKT-2 AT KURUKSHETRA(PG)	POWERGRID	C	FOR CB RECTIFICATION WORKS	21/Jun/2024	08:00	28/Jun/2024	18:00			PLANNED	Requested
638	RQ177680	OCC_219	cpcc3_sd	BAY	415 MAIN BAY - 80 MVAR BUS REACTOR NO 1 AT 400KV ALLAHABAD(PG) (POWERGRID) AT 400 KV ALLAHABAD(PG)	POWERGRID	C	CB Drive mechnaism overhauling	20/Jun/2024	10:00	23/Jun/2024	18:00			PLANNED	Requested
639	RQ177434	OCC_219	cpcc3_sd	BAY	409 MAIN BAY - 400KV NALLAGARH-PATIALA (PG) CKT-1 AT NALLAGARH(PG)	POWERGRID	C	Drive Overhauling of Circuit Breaker	20/Jun/2024	09:00	22/Jun/2024	18:00	kindly approve.		PLANNED	Requested
640	RQ177678	OCC_219	cpcc3_sd	BAY	403 MAIN BAY - 400/220 KV 315 MVA ICT 3 AT ALLAHABAD(PG) (POWERGRID) AT 400 KV ALLAHABAD(PG)	POWERGRID	C	CB Drive mechanism overhauling	17/Jun/2024	10:00	19/Jun/2024	18:00			PLANNED	Requested
641	RQ177684	OCC_219	cpcc3_sd	BAY	W12.Q1 MAIN BAY - 400 KV AGRA(PG)-FILTER BANK-3 (POWERGRID)	POWERGRID	D	For AMP work	17/Jun/2024	09:00	17/Jun/2024	18:00			PLANNED	Requested
642	RQ177435	OCC_219	cpcc3_sd	BAY	406 MAIN BAY - 400KV NALLAGARH-PATIALA (PG) CKT-2 AT NALLAGARH(PG)	POWERGRID	C	Drive Overhauling of Circuit Breaker	17/Jun/2024	09:00	19/Jun/2024	18:00	kindly approve.		PLANNED	Requested
643	RQ177693	OCC_219	cpcc3_sd	BAY	414 TIE BAY - 400KV BUS 1 AT SOHAWAL(PG) (POWERGRID) AND 63 MVAR BUS REACTOR NO 2 AT 400 KV SOHAWAL(PG) AT 400 KV SOHAWAL(PG) (POWERGRID)	POWERGRID	C	CB mechanism overhauling	15/Jun/2024	09:00	20/Jun/2024	18:00			PLANNED	Requested
644	RQ177788	OCC_219	cpcc3_sd	BAY	413 MAIN BAY - 400 KV BALIA(PG)-NAUBATPUR (BS) (PG) CKT-2 (POWERGRID) AND 400KV BUS 1 AT BALIA(PG) AT 400 KV BALIA(PG) (POWERGRID)	POWERGRID	C	FOR CB Retrofitment Work	15/Jun/2024	08:00	21/Jun/2024	18:00			PLANNED	Requested
645	RQ177852	OCC_219	slcds_sd	BAY	423 TIE BAY - 400 KV AJMER(RS)-AJMER(PG) (PG) CKT-1 AND FUTURE AT 400 KV AJMER(RS)	POWERGRID	D	Quarterly maintenance work of associated equipments of Bay.	14/Jun/2024	08:00	14/Jun/2024	18:00			PLANNED	Requested
646	RQ178470	OCC_219	cpcc1_sd	BAY	427 TIE BAY - 125 MVAR BUS REACTOR NO 1 AT 400KV KURUKSHETRA(PG) AND 400KV ABDULLAPUR-KURUKSHETRA (PG) CKT-2	POWERGRID	C	FOR CB RECTIFICATION WORKS	14/Jun/2024	08:00	21/Jun/2024	18:00			PLANNED	Requested
647	RQ177432	OCC_219	cpcc3_sd	BAY	407 MAIN BAY - 400KV BUS 1 AT NALLAGARH(PG) (POWERGRID) AND FUTURE AT 400 KV NALLAGARH(PG) (POWERGRID)	POWERGRID	C	Drive Overhauling of Circuit Breaker	13/Jun/2024	09:00	15/Jun/2024	18:00	kindly approve.		PLANNED	Requested
648	RQ177853	OCC_219	slcds_sd	BAY	422 MAIN BAY - 400 KV AJMER(RS)-AJMER(PG) (PG) CKT-1 AT AJMER(RS)	POWERGRID	D	Quarterly maintenance work of associated equipments of Bay.	13/Jun/2024	08:00	13/Jun/2024	18:00			PLANNED	Requested
649	RQ177850	OCC_219	slcds_sd	BAY	420 TIE BAY - 400 KV AJMER(RS)-AJMER(PG) (PG) CKT-2 AND FUTURE AT 400 KV AJMER(RS)	POWERGRID	D	Quarterly maintenance work of associated equipments of Bay.	12/Jun/2024	08:00	12/Jun/2024	18:00			PLANNED	Requested
650	RQ178473	OCC_219	cpcc1_sd	BAY	439 MAIN BAY - 400KV KURUKSHETRA-JIND (PG) CKT-1 AT KURUKSHETRA(PG)	POWERGRID	C	FOR CB RECTIFICATION WORKS	12/Jun/2024	08:00	20/Jun/2024	18:00			PLANNED	Requested
651	RQ177473	OCC_219	cpcc3_sd	BAY	411 TIE BAY - 400/220KV 315 MVA ICT 1 AT JALANDHAR(PG) AND 400KV CHAMBA-JALANDHAR (PG) CKT-2	POWERGRID	C	CB DRIVE OVERHAULING WORK	11/Jun/2024	10:00	13/Jun/2024	18:00	Kindly approve		PLANNED	Requested
652	RQ177851	OCC_219	slcds_sd	BAY	419 MAIN BAY - 400 KV AJMER(RS)-AJMER(PG) (PG) CKT-2 AT AJMER(RS)	POWERGRID	D	Quarterly maintenance work of associated equipments of Bay.	11/Jun/2024	08:00	11/Jun/2024	18:00			PLANNED	Requested
653	RQ177683	OCC_219	cpcc3_sd	BAY	W22Q1 MAIN BAY - 400 KV AGRA(PG)-FILTER BANK-5 (POWERGRID)	POWERGRID	D	AMP Work	10/Jun/2024	09:00	10/Jun/2024	18:00			PLANNED	Requested

654	RQ177677	OCC_219	cpcc3_sd	BAY	409 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT ALLAHABAD(PG) (POWERGRID)	POWERGRID	C	CB retrofitment work	09/Jun/2024	10:00	16/Jun/2024	18:00			PLANNED	Requested
655	RQ177696	OCC_219	cpcc3_sd	BAY	412 MAIN BAY - 400/220KV 315 MVA ICT 1 AT SOHAWAL(PG)	POWERGRID	C	CB mechanism overhauling	09/Jun/2024	09:00	14/Jun/2024	18:00			PLANNED	Requested
656	RQ177457	OCC_219	cpcc2_sd	BAY	417 TIE BAY - 400KV MOGA-JALANDHAR (PG) CKT-1 AND 400KV MOGA-JALANDHAR (PG) CKT-2 AT MOGA(PG)	POWERGRID	D	For Testing After retrofiting of Busbar / LBB relay.	09/Jun/2024	08:00	10/Jun/2024	18:00	Kindly approve		PLANNED	Requested
657	RQ177472	OCC_219	cpcc2_sd	BAY	410 MAIN BAY - 400KV CHAMBA-JALANDHAR (PG) CKT-2 AT JALANDHAR(PG)	POWERGRID	C	CB DRIVE OVERHAULING WORK	08/Jun/2024	10:00	10/Jun/2024	18:00	Kindly approve		PLANNED	Requested
658	RQ177797	OCC_219	cpcc3_sd	BAY	415 MAIN BAY - 400KV BALIA(PG)-BIHARSHARIFF(PG) (UNDEF) CKT-1 AT BALIA(PG)	POWERGRID	C	FOR CB Retrofitment Work	08/Jun/2024	08:00	14/Jun/2024	18:00			PLANNED	Requested
659	RQ178469	OCC_219	cpcc1_sd	BAY	417 TIE BAY - 400KV KURUKSHETRA-MALERKOTLA (PG) CKT-1 AND 400KV AMRITSAR-MALERKOTLA (PG) CKT-2 AT MALERKOTLA(PG)	POWERGRID	C	FOR CB RECTIFICATION WORKS	07/Jun/2024	08:00	14/Jun/2024	18:00			PLANNED	Requested
660	RQ177456	OCC_219	cpcc2_sd	BAY	411 TIE BAY - 400 KV TALWANDI SABOO(PG)-MOGA(PG) (PS) CKT-1 (POWERGRID) AND 125 MVAR BUS REACTOR NO 2 AT 400 KV MOGA(PG) AT 400 KV MOGA(PG) (POWERGRID)	POWERGRID	D	For Testing After retrofiting of Busbar / LBB relay.	07/Jun/2024	08:00	08/Jun/2024	18:00	Kindly approve		PLANNED	Requested
661	RQ177662	OCC_219	cpcc3_sd	BAY	424 MAIN BAY - SVC NO 2(-140/+140MVAR) AT 400 KV KANPUR(PG)	POWERGRID	C	Isolator replacement work under Addcap	06/Jun/2024	10:00	10/Jun/2024	18:00			PLANNED	Requested
662	RQ177433	OCC_219	cpcc2_sd	BAY	408 TIE BAY - 400KV NALLAGARH-PATIALA (PG) CKT-1 AND FUTURE AT NALLAGARH(PG)	POWERGRID	C	Drive Overhauling of Circuit Breaker	06/Jun/2024	09:00	08/Jun/2024	18:00	kindly approve.		PLANNED	Requested
663	RQ177801	OCC_219	cpcc3_sd	BAY	W1.WCA.Q2 BAY BUS-1 8amp; 1A BUS SECTIONALISER BUS SECTIONALIZER BAY - 400KV AGRA(PG) - BUS 1 (POWERGRID) AND FUTURE AT 400 KV AGRA(PG) (POWERGRID)	POWERGRID	D	AMP Work	06/Jun/2024	08:00	06/Jun/2024	18:00			PLANNED	Requested
664	RQ177455	OCC_219	cpcc2_sd	BAY	408 TIE BAY - 400KV MOGA-HISSAR (PG) CKT-1 AND 400/220KV 315 MVA ICT 4 AT MOGA(PG)	POWERGRID	D	For Testing After retrofiting of Busbar / LBB relay.	05/Jun/2024	08:00	06/Jun/2024	18:00	Kindly approve		PLANNED	Requested
665	RQ177471	OCC_219	cpcc2_sd	BAY	407 MAIN BAY - 400KV CHAMERA_1(NH)-JALANDHAR(PG) (PG) CKT-2 AT JALANDHAR(PG)	POWERGRID	C	CB DRIVE OVERHAULING WORK	04/Jun/2024	10:00	06/Jun/2024	18:00	Kindly approve		PLANNED	Requested
666	RQ177802	OCC_219	cpcc3_sd	BAY	W1.WCA.Q1 BAY BUS-2 8amp; 2A SECTIONALIZER BUS SECTIONALIZER BAY - 400KV AGRA(PG) - BUS 2 (POWERGRID) AND FUTURE AT 400 KV AGRA(PG) (POWERGRID)	POWERGRID	D	AMP Work	03/Jun/2024	08:00	03/Jun/2024	18:00			PLANNED	Requested
667	RQ178472	OCC_219	cpcc1_sd	BAY	440 MAIN BAY - 400KV KURUKSHETRA-JIND (PG) CKT-2 AT KURUKSHETRA(PG)	POWERGRID	C	FOR CB RECTIFICATION WORKS	03/Jun/2024	08:00	10/Jun/2024	18:00			PLANNED	Requested
668	RQ177454	OCC_219	cpcc2_sd	BAY	405 TIE BAY - 400 KV MOGA-FATEHABAD (PG) CKT-1 (POWERGRID) AND 400/220 KV 500 MVA ICT 3 AT MOGA(PG) AT 400 KV MOGA(PG) (POWERGRID)	POWERGRID	D	For Testing After retrofiting of Busbar / LBB relay.	03/Jun/2024	08:00	04/Jun/2024	18:00	Kindly approve		PLANNED	Requested
669	RQ177470	OCC_219	cpcc2_sd	BAY	406 MAIN BAY - 400KV AMRITSAR-JALANDHAR (PG) CKT-1 AT JALANDHAR(PG)	POWERGRID	C	CB DRIVE OVERHAULING WORK	01/Jun/2024	10:00	03/Jun/2024	18:00	Kindly approve		PLANNED	Requested
670	RQ177674	OCC_219	cpcc3_sd	BAY	406 MAIN BAY - 400/220 KV 315 MVA ICT 2 AT ALLAHABAD(PG) (POWERGRID) AT 400 KV ALLAHABAD(PG)	POWERGRID	C	Circuit breaker retrofitment work	01/Jun/2024	10:00	08/Jun/2024	18:00			PLANNED	Requested

671	RQ177664	OCC_219	cpcc3_sd	BAY	425 TIE BAY - SVC NO 2(-140/+140MVAR) AT 400 KV KANPUR(PG) (POWERGRID) AND 400/220 KV 315 MVA ICT 1 AT KANPUR(PG) AT 400 KV KANPUR(PG) (POWERGRID)	POWERGRID	C	isolator replacement under addcap	01/Jun/2024	10:00	10/Jun/2024	18:00			PLANNED	Requested
672	RQ177785	OCC_219	cpcc3_sd	BAY	407 MAIN BAY - 400 KV BALIA-PATNA (PG) CKT-2 AND 400KV BUS 1 AT BALIA(PG)	POWERGRID	C	FOR CB Retrofitment Work	01/Jun/2024	08:00	07/Jun/2024	18:00			PLANNED	Requested
673	RQ178466	OCC_219	cpcc3_sd	BAY	411 TIE BAY - 400KV BHINMAL-KANKROLI (PG) CKT-1 AND 400/220KV 315 MVA ICT 2 AT KANKROLI(PG)	POWERGRID	C	For 400KV CB erection work, 412 89A erection work, 400KV yard IPS tube erection work, 412 89B (towards Tie Bay) jumper removing work and related testing & commissioning work	01/Jun/2024	08:00	15/Jun/2024	18:00			PLANNED	Requested
674	RQ177453	OCC_219	cpcc3_sd	BAY	402 TIE BAY - 400/220KV 250 MVA ICT 2 AT MOGA(PG) AND 400/220KV 500 MVA ICT 1 AT MOGA(PG)	POWERGRID	D	For Testing After retrofitting of Busbar / LBB relay.	01/Jun/2024	08:00	02/Jun/2024	18:00	Kindly approve		PLANNED	Requested
675	RQ177863	OCC_219	slcds_sd	BAY	423 MAIN BAY - 400KV BIKANER(RS)-SIKAR(PG) (RS) CKT-1 AT BIKANER(RS)	RRVPNL	D	Routine Maintenance & Testing work	20/Jun/2024	08:00	20/Jun/2024	18:00			PLANNED	Requested
676	RQ177861	OCC_219	slcds_sd	BAY	421 TIE BAY - 400KV BIKANER(RS)-SIKAR(PG) (RS) CKT-2 AND FUTURE AT BIKANER(RS)	RRVPNL	D	Routine Maintenance & Testing work	19/Jun/2024	08:00	19/Jun/2024	18:00			PLANNED	Requested
677	RQ177849	OCC_219	slcds_sd	BAY	409-52D MAIN BAY - 400 KV ANTA(RS)-KAWAI SCTPS(APR) (RS) CKT-2 (RRVPNL)	RRVPNL	D	Half Yearly Maintenance work	14/Jun/2024	08:00	14/Jun/2024	18:00			PLANNED	Requested
678	RQ177848	OCC_219	slcds_sd	BAY	408-52D MAIN BAY - 400 KV ANTA(RS)-KAWAI SCTPS(APR) (RS) CKT-1 (RRVPNL)	RRVPNL	D	Half Yearly Maintenance work	13/Jun/2024	08:00	13/Jun/2024	18:00			PLANNED	Requested
679	RQ177864	OCC_219	slcds_sd	BAY	420 MAIN BAY - 400KV BIKANER(RS)-SIKAR(PG) (RS) CKT-2 AT BIKANER(RS)	RRVPNL	D	Routine Maintenance & Testing work	13/Jun/2024	08:00	13/Jun/2024	18:00			PLANNED	Requested
680	RQ177866	OCC_219	slcds_sd	BAY	404 MAIN BAY - 400KV BIKANER(RS)-SSCTPSSURATGARH (RS) (UNDEF) CKT-2 AT BIKANER(RS)	RRVPNL	D	Routine Maintenance & Testing work	12/Jun/2024	08:00	12/Jun/2024	18:00			PLANNED	Requested
681	RQ177846	OCC_219	slcds_sd	BAY	404-52T TIE BAY - 400 KV ANTA-KALISINDH (RS) CKT-1 (RRVPNL) AND FUTURE AT 400 KV ANTA(RS) (RRVPNL)	RRVPNL	D	Half Yearly Maintenance work	11/Jun/2024	08:00	11/Jun/2024	18:00			PLANNED	Requested
682	RQ177847	OCC_219	slcds_sd	BAY	404-52D MAIN BAY - 400 KV ANTA-KALISINDH (RS) CKT-1 (RRVPNL)	RRVPNL	D	Half Yearly Maintenance work	10/Jun/2024	08:00	10/Jun/2024	18:00			PLANNED	Requested
683	RQ177854	OCC_219	slcds_sd	BAY	411 TIE BAY - 400KV PHAGI-AJMER (RS) CKT-2 AND FUTURE AT AJMER(RS)	RRVPNL	D	Quarterly maintenance work of associated equipments of Bay.	10/Jun/2024	08:00	10/Jun/2024	18:00			PLANNED	Requested
684	RQ177855	OCC_219	slcds_sd	BAY	410 MAIN BAY - 400KV PHAGI-AJMER (RS) CKT-2 AND SELECT AT AJMER(RS)	RRVPNL	D	Quarterly maintenance work of associated equipments of Bay.	07/Jun/2024	08:00	07/Jun/2024	18:00			PLANNED	Requested
685	RQ177862	OCC_219	slcds_sd	BAY	408 TIE BAY - 400KV BIKANER(RS)-SSCTPSSURATGARH (RS) (UNDEF) CKT-1 AND FUTURE AT BIKANER(RS)	RRVPNL	D	Routine Maintenance & Testing work	06/Jun/2024	08:00	06/Jun/2024	18:00			PLANNED	Requested
686	RQ177865	OCC_219	slcds_sd	BAY	407 MAIN BAY - 400KV BIKANER(RS)-SSCTPSSURATGARH (RS) (UNDEF) CKT-1 AT BIKANER(RS)	RRVPNL	D	Routine Maintenance & Testing work	05/Jun/2024	08:00	05/Jun/2024	18:00			PLANNED	Requested
687	RQ177477	OCC_219	slcds_sd	BAY	400-2T TIE BAY - 400 KV DEEPALPUR(JHKT)-KABULPUR(HV) (HVPNL) CKT-1 (HVPNL) AND 400KV BUS 1 AT DEEPALPUR(JHKT) AT 400 KV DEEPALPUR(JHKT) (HVPNL)	HVPNL	D	AMP for Bay equipment only, the system availability will not affect. line will be charged through main bay.	18/Jun/2024	08:00	18/Jun/2024	16:00			PLANNED	Requested
688	RQ177478	OCC_219	slcds_sd	BAY	402 MAIN BAY - 400KV DEEPALPUR(JHKT)-KABULPUR(HV) (JHKT) CKT-1 AT DEEPALPUR(JHKT)	HVPNL	D	AMP for Bay equipment only, the system availability will not affect. line will be charged through Tie bay	17/Jun/2024	08:00	17/Jun/2024	16:00			PLANNED	Requested

689	RQ177479	OCC_219	sidchr_sd	BAY	401 MAIN BAY - 400KV DEEPALPUR(JHKT)-KABULPUR(HV) (JHKT) CKT-2 AT DEEPALPUR(JHKT)	HVPNL	D	AMP for Bay equipment only, the system availability will not affect. line will be charged through Tie bay	15/Jun/2024	08:00	15/Jun/2024	16:00		PLANNED	Requested	
690	RQ177919	OCC_219	stuup_sd	BAY	405 TIE BAY - 400 KV TANDA(NT)-SULTANPUR(UP) (UP) CKT-1 AND FUTURE AT TANDA(NT)	NTPC	D	* Preventive Maintenance of Bay at 400KV S/S Sultanpur	13/Jun/2024	10:00	13/Jun/2024	16:00		PLANNED	Requested	
691	RQ177438	OCC_219	singrauli_sd	BAY	409 MAIN BAY - 400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-1 AT SINGRAULI(NT)	NTPC	C	BUS-02 ISOLATOR REPLACEMENT	13/Jun/2024	08:00	15/Jun/2024	18:00	BAY WILL BE CHARGED THROUGH TRANSFER BUS	PLANNED	Requested	
692	RQ177437	OCC_219	singrauli_sd	BAY	407 MAIN BAY - 400 KV SINGRAULI(NT)-ANPARA(UP) (PG) CKT-1 AT SINGRAULI(NT)	NTPC	C	BUS-02 ISOLATOR REPLACEMENT	10/Jun/2024	08:00	12/Jun/2024	18:00	BAY WILL BE CHARGED THROUGH TRANSFER BUS	PLANNED	Requested	
693	RQ178503	OCC_219	cpcc1_sd	BAY	417 TIE BAY - 400/220 KV 500 MVA ICT 2 AT BIKANER_2 (PBTSLS) (PBTSLS) AND FUTURE AT 400 KV BIKANER_2 (PBTSLS) (PBTSLS)	PBTSLS	C	For Bay extension works	12/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested	
694	RQ177883	OCC_219	cpcc3_sd	BAY	407 MAIN BAY - 400/220 KV 500 MVA ICT 2 AT FIROZABAD(PJFTL) (PJFTL)	PJFTL	D	Annual Maintenance Work.	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested	
695	RQ178522	OCC_219	bbmb_sd	BAY	X10 MAIN BAY - 50 MVAR LR ON BHIWANI(BB)-RAJPURA(PG) (BB) CKT-1 @BHIWANI(BB) AT BHIWANI(BB)	BBMB	D	Bay equipment's Half yearly mtc	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested	
696	RQ178521	OCC_219	cpcc1_sd	BAY	413 MAIN BAY - 125 MVAR BUS REACTOR NO 2 AT 400 KV FATEHGARH_III(PG) (PRTL) AT 400 KV FATEHGARH_III(PG)	PRTL	C	For Compliance of Vigilance department observation regarding strengthening of foundation (Civil) of 413 Bay Circuit breaker R-phase.	01/Jun/2024	08:00	08/Jun/2024	18:00		PLANNED	Requested	
697	RQ178468	OCC_219	cpcc1_sd	BAY	408 TIE BAY - 400 KV KURUKSHETRA(PG)-DHANANSU(PG) (PG) CKT-1 (PSTCL) AND FUTURE AT 400 KV DHANANSU(PG) (PSTCL)	PSTCL	C	FOR CB RECTIFICATION WORKS	01/Jun/2024	08:00	07/Jun/2024	18:00	at KURUKSHETRA(PG)	PLANNED	Requested	
698	RQ177769	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT ALLAHABAD(PG)	POWERGRID	D	AMP Work	30/Jun/2024	09:00	30/Jun/2024	18:00		PLANNED	Requested	
699	RQ177554	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT NEWWANPOH(PG)	POWERGRID	D	For AMP work	27/Jun/2024	10:00	27/Jun/2024	18:00	kindly approve	PLANNED	Requested	
700	RQ177768	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT ALLAHABAD(PG)	POWERGRID	D	AMP Work	24/Jun/2024	09:00	24/Jun/2024	18:00		PLANNED	Requested	
701	RQ177655	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT PATIALA(PG)	POWERGRID	C	S/D required for rectification of work for attending water logging on roof top of ICT and AMP activities.	21/Jun/2024	09:00	24/Jun/2024	18:00	kindly approve	PLANNED	Requested	
702	RQ177553	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT NEWWANPOH(PG)	POWERGRID	D	For AMP work	20/Jun/2024	10:00	20/Jun/2024	18:00	kindly approve	PLANNED	Requested	
703	RQ177969	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 4 AT WAGOOORA(PG)	POWERGRID	D	"Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"" For safety purpose.	19/Jun/2024	09:00	19/Jun/2024	12:00	Under construction head. kindly approve.	PLANNED	Requested	
704	RQ177766	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT FATEHPUR(PG)	POWERGRID	D	AMP Work	18/Jun/2024	09:00	18/Jun/2024	18:00		PLANNED	Requested	
705	RQ177409	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT WAGOOORA(PG)	POWERGRID	D	"Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021""	18/Jun/2024	09:00	18/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
706	RQ177733	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT LUCKNOW_1(PG)	POWERGRID	D	For AMP Work & for taking oil sample	15/Jun/2024	10:00	15/Jun/2024	17:30		PLANNED	Requested	
707	RQ177408	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT WAGOOORA(PG)	POWERGRID	D	"Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021""	12/Jun/2024	09:00	12/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
708	RQ177548	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT AMRITSAR(PG)	POWERGRID	C	To attend Oil leakages and Filtration work	11/Jun/2024	10:00	16/Jun/2024	18:00	kindly approve	PLANNED	Requested	
709	RQ177952	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KISHENPUR(PG)	POWERGRID	D	For Spare ICT charging and Jumper Strengthening work.	10/Jun/2024	10:00	10/Jun/2024	15:00	Kindly approve	PLANNED	Requested	
710	RQ178437	OCC_219	cpcc3_sd	TRANSFORMER	400/38 KV 519 MVA ICT 1 AT LUCKNOW_2(PG)	POWERGRID	D	AMP Work	10/Jun/2024	08:00	10/Jun/2024	18:00		PLANNED	Requested	
711	RQ177407	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT WAGOOORA(PG)	POWERGRID	D	"Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021""	08/Jun/2024	09:00	08/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	

712	RQ177406	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT WAGOORA(PG)	POWERGRID	D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021****	07/Jun/2024	09:00	07/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested
713	RQ177759	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KANPUR(PG)	POWERGRID	D	AMP Work	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested
714	RQ177886	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KANPUR(PG)	POWERGRID	D	Jumper Closing of 425-89B isolator after isolator retrofitment under ADDCAP	05/Jun/2024	12:00	05/Jun/2024	16:00		PLANNED	Requested
715	RQ177951	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KISHENPUR(PG)	POWERGRID	D	For AMP of Equipment and Jumper Strengthening work.	05/Jun/2024	09:00	05/Jun/2024	18:00	Kindly approve	PLANNED	Requested
716	RQ177730	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT JAULIWI (PG)	POWERGRID	D	AMP Work & application of insulation sleeve on jumpers	05/Jun/2024	09:00	05/Jun/2024	18:00		PLANNED	Requested
717	RQ178496	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SIKAR(PG)	POWERGRID	D	AMP WORK	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested
718	RQ177416	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KAITHAL(PG)	POWERGRID	D	For AMP work	04/Jun/2024	09:30	04/Jun/2024	18:00	kindly approve.	PLANNED	Requested
719	RQ177555	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT NALLAGARH(PG)	POWERGRID	D	For AMP work	04/Jun/2024	09:00	04/Jun/2024	18:00	kindly approve	PLANNED	Requested
720	RQ177614	OCC_219	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT SAMBA(PG)	POWERGRID	D	For AMP work	03/Jun/2024	09:00	03/Jun/2024	18:00	kindly approve	PLANNED	Requested
721	RQ177727	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT JAULIWI (PG)	POWERGRID	D	AMP Work and application of insulation sleeve on Jumpers	03/Jun/2024	09:00	03/Jun/2024	18:00		PLANNED	Requested
722	RQ178435	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT JAIPUR SOUTH(PG)	POWERGRID	D	Rectification of CoE Audit point	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested
723	RQ177771	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT SOHAWAL(PG)	POWERGRID	D	AMP Work	02/Jun/2024	09:00	02/Jun/2024	18:00		PLANNED	Requested
724	RQ177763	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KANPUR(PG)	POWERGRID	D	protection scheme modification and winding tan delta	02/Jun/2024	08:00	02/Jun/2024	18:00		PLANNED	Requested
725	RQ178436	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT JAIPUR SOUTH(PG)	POWERGRID	D	Rectification of CoE Audit point	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested
726	RQ177757	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KANPUR(PG)	POWERGRID	D	Jumper opening of 425-89B isolator for isolator retrofitment under ADDCAP	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested
727	RQ177551	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MATHURA(UP)	UPPTCL	C	for OLTC Oil replacement work	26/Jun/2024	09:00	28/Jun/2024	20:00		PLANNED	Requested
728	RQ177513	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT SULTANPUR(UP)	UPPTCL	D	For Preventive maintenance of ICT	22/Jun/2024	10:00	22/Jun/2024	17:00		PLANNED	Requested
729	RQ177514	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SULTANPUR(UP)	UPPTCL	D	For Preventive maintenance of ICT	20/Jun/2024	10:00	20/Jun/2024	17:00		PLANNED	Requested
730	RQ177593	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT SAMBHAL_PRSTL (UP)	UPPTCL	D	AMP Work	18/Jun/2024	10:00	18/Jun/2024	18:00		PLANNED	Requested
731	RQ177547	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT GR.NOIDA(UPC)	UPPTCL	D	* Maintenance work will be done of mentioned ICT.	15/Jun/2024	07:00	15/Jun/2024	11:30		PLANNED	Requested
732	RQ177541	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BASTI(UP)	UPPTCL	D	* Shutdown of 500MVA ICT-2 is required for annual maintenance and testing >X purpose. Power shall continue to be fed through 50	13/Jun/2024	09:00	13/Jun/2024	18:00		PLANNED	Requested
733	RQ177656	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT PANKI(UP)	UPPTCL	D	* SHUTDOWN OF 315MVA ICT-II FOR BAY MAINTENANCE	12/Jun/2024	08:00	13/Jun/2024	17:00		PLANNED	Requested
734	RQ177515	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 4 AT SULTANPUR(UP)	UPPTCL	D	For Preventive maintenance of ICT	11/Jun/2024	10:00	11/Jun/2024	17:00		PLANNED	Requested
735	RQ177540	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BASTI(UP)	UPPTCL	D	* Shutdown of 500MVA ICT-1 is required for annual testing and maintenance. >X Power shall continue to be fed through 500MVA ICT	10/Jun/2024	09:00	10/Jun/2024	18:00		PLANNED	Requested
736	RQ177546	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT GR.NOIDA(UPC)	UPPTCL	D	* Maintenance work will be done of mentioned ICT.	09/Jun/2024	07:00	09/Jun/2024	11:30		PLANNED	Requested
737	RQ177930	OCC_219	stuup_sd	TRANSFORMER	400/132 KV 100 MVA ICT 2 AT ANPARA(UP)	UPPTCL	C	For replacement of breaker of 400 kv ICT-II Main breaker	07/Jun/2024	09:00	15/Jul/2024	17:00		PLANNED	Requested
738	RQ177931	OCC_219	stuup_sd	TRANSFORMER	400/132 KV 100 MVA ICT 2 AT ANPARA(UP)	UPPTCL	D	For ,attending oil leakage,testing of transfer and bay equipments.	07/Jun/2024	09:00	07/Jun/2024	17:00		PLANNED	Requested
739	RQ177510	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BAREILLY(UP)	UPPTCL	D	preventive maintenance	07/Jun/2024	06:00	07/Jun/2024	18:00		PLANNED	Requested
740	RQ177512	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 240 MVA ICT 2 AT SULTANPUR(UP)	UPPTCL	D	For Preventive maintenance of ICT	06/Jun/2024	10:00	06/Jun/2024	17:00		PLANNED	Requested
741	RQ177511	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BAREILLY(UP)	UPPTCL	D	preventive maintenance	06/Jun/2024	06:00	06/Jun/2024	18:00		PLANNED	Requested
742	RQ177569	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT SAMBHAL_PRSTL (UP)	UPPTCL	D	AMP Work	05/Jun/2024	10:00	05/Jun/2024	18:00		PLANNED	Requested
743	RQ177508	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT BAREILLY(UP)	UPPTCL	D	preventive maintenance and testing	05/Jun/2024	06:00	05/Jun/2024	18:00		PLANNED	Requested
744	RQ177658	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT ORAI(UP)	UPPTCL	D	for attending hot points in LV side bus isolator found during thermovision scanning of substation.	05/Jun/2024	06:00	05/Jun/2024	15:00		PLANNED	Requested
745	RQ177882	OCC_219	cpcc3_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT FIROZABAD(PJFTL)	UPPTCL	D	Annual Maintenance Work.	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested
746	RQ177509	OCC_219	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT UNNAO(UP)	UPPTCL	D	The shutdown is required for maintenance work and 220KV side jack bus >X stringing work of section, which cross over 220kV Ma	01/Jun/2024	07:00	04/Jun/2024	16:00		PLANNED	Requested

747	RQ178210	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	25/Jun/2024	14:00	28/Jun/2024	23:00		PLANNED	Requested
748	RQ178208	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	23/Jun/2024	14:00	25/Jun/2024	23:00		PLANNED	Requested
749	RQ178213	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 8 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	23/Jun/2024	14:00	25/Jun/2024	23:00		PLANNED	Requested
750	RQ178218	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 9 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 400kV ICT	21/Jun/2024	14:00	29/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested
751	RQ178212	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	21/Jun/2024	14:00	23/Jun/2024	23:00		PLANNED	Requested
752	RQ178207	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	21/Jun/2024	14:00	23/Jun/2024	23:00		PLANNED	Requested
753	RQ178238	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 9 AT FATEHGARH_II(PG)		D	Testing with TBC bay in 220kV & pending construction related works	21/Jun/2024	14:00	26/Jun/2024	23:00		PLANNED	Requested
754	RQ178206	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	19/Jun/2024	14:00	21/Jun/2024	23:00		PLANNED	Requested
755	RQ178211	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	19/Jun/2024	14:00	21/Jun/2024	23:00		PLANNED	Requested
756	RQ178237	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 8 AT FATEHGARH_II(PG)		D	Testing with TBC bay in 220kV & pending construction related works	15/Jun/2024	14:00	20/Jun/2024	23:00		PLANNED	Requested
757	RQ178288	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT KURUKSHETRA(PG)		C	FOR ROOFTOP TREATMENT	15/Jun/2024	09:00	17/Jun/2024	17:00		PLANNED	Requested
758	RQ178216	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 400kV ICT	14/Jun/2024	14:00	20/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested
759	RQ178266	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BHINMAL(PG)		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchohore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
760	RQ178265	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BHINMAL(PG)		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchohore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
761	RQ178287	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT KURUKSHETRA(PG)		D	FOR RECTIFICATION OF SIR AUDIT POINT	13/Jun/2024	09:00	13/Jun/2024	17:00		PLANNED	Requested
762	RQ178272	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT JIND(PG)		D	for AMP works	11/Jun/2024	09:00	11/Jun/2024	18:00		PLANNED	Requested
763	RQ178286	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT KURUKSHETRA(PG)		D	FOR RECTIFICATION OF SIR AUDIT POINT	11/Jun/2024	09:00	11/Jun/2024	17:00		PLANNED	Requested
764	RQ178243	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 9 AT FATEHGARH_II(PG)		D	FOR CSD FINE TUNING OF ICT	10/Jun/2024	17:00	13/Jun/2024	23:59	DURING FINE TUNING OF ICT, 04-05 NO LOAD OPERATIONS OF ICT SHALL BE PERFORMED	PLANNED	Requested
765	RQ178236	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(PG)		D	Testing with TBC bay in 220kV & pending construction related works	09/Jun/2024	14:00	14/Jun/2024	23:00		PLANNED	Requested
766	RQ178242	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 8 AT FATEHGARH_II(PG)		D	FOR CSD FINE TUNING OF ICT	07/Jun/2024	17:00	10/Jun/2024	23:59	DURING FINE TUNING OF ICT, 04-05 NO LOAD OPERATIONS OF ICT SHALL BE PERFORMED	PLANNED	Requested
767	RQ178209	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	07/Jun/2024	14:00	17/Jun/2024	23:00		PLANNED	Requested
768	RQ178214	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 9 AT FATEHGARH_II(PG)		D	Commissioning of RTCC for ICT. For AMP works	07/Jun/2024	14:00	17/Jun/2024	23:00		PLANNED	Requested

769	RQ178292	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT MANDOLA(PG)		D	For 220 KV BUS BAR retrofitment work	07/Jun/2024	09:00	07/Jun/2024	18:00	FOR BUS BAR RETROFITMENT WORK	PLANNED	Requested
770	RQ178293	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT MANDOLA(PG)		D	For 220 KV BUS BAR retrofitment work	07/Jun/2024	09:00	07/Jun/2024	18:00	FOR BUS BAR RETROFITMENT WORK	PLANNED	Requested
771	RQ178271	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT JIND(PG)		D	for AMP works	06/Jun/2024	09:00	06/Jun/2024	18:00		PLANNED	Requested
772	RQ178291	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MANDOLA(PG)		D	For 220 KV BUS BAR retrofitment work	06/Jun/2024	09:00	06/Jun/2024	18:00	FOR BUS BAR RETROFITMENT WORK	PLANNED	Requested
773	RQ178215	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 400kv ICT	05/Jun/2024	14:00	09/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested
774	RQ178217	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 8 AT FATEHGARH_II(PG)		D	For final testing/fine tuning of CSD Relay of 400kv ICT	05/Jun/2024	14:00	12/Jun/2024	23:00	Kindly note that, during fine tuning of CSD, 4 to 5 on load operations of ICT will be done from each bay	PLANNED	Requested
775	RQ178274	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT MEERUT_PMSTL (UP)		C	SF6 Gas density monitor body replacement	05/Jun/2024	07:00	06/Jun/2024	18:00		PLANNED	Requested
776	RQ178280	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT BHADLA_2 (PG)		D	AMP Work	04/Jun/2024	17:00	04/Jun/2024	23:00		PLANNED	Requested
777	RQ178241	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(PG)		D	FOR CSD FINE TUNING OF ICT	04/Jun/2024	17:00	06/Jun/2024	23:59	DURING FINE TUNING OF ICT, 04-05 NO LOAD OPERATIONS OF ICT SHALL BE PERFORMED	PLANNED	Requested
778	RQ178281	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT KANKROLI(PG)		D	AMP Work	04/Jun/2024	09:00	04/Jun/2024	17:00		PLANNED	Requested
779	RQ178290	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT MANDOLA(PG)		D	For 220 KV BUS BAR retrofitment work	04/Jun/2024	09:00	04/Jun/2024	18:00	FOR BUS BAR RETROFITMENT WORK	PLANNED	Requested
780	RQ178282	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KANKROLI(PG)		D	Rectification of CoE Audit point	04/Jun/2024	09:00	04/Jun/2024	17:00		PLANNED	Requested
781	RQ178283	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KANKROLI(PG)		D	Rectification of CoE Audit point	04/Jun/2024	09:00	04/Jun/2024	17:00		PLANNED	Requested
782	RQ178279	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BHADLA_2 (PG)		D	AMP Work	03/Jun/2024	17:00	03/Jun/2024	23:00		PLANNED	Requested
783	RQ178235	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT FATEHGARH_II(PG)		D	Testing with TBC bay in 220kv & pending construction related works	03/Jun/2024	14:00	08/Jun/2024	23:00		PLANNED	Requested
784	RQ178269	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SONIPAT(PG)		D	for AMP works	03/Jun/2024	09:00	03/Jun/2024	18:00		PLANNED	Requested
785	RQ178270	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SAHARANPUR(PG)		D	for AMP works	03/Jun/2024	09:00	03/Jun/2024	18:00		PLANNED	Requested
786	RQ178273	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT MEERUT_PMSTL (UP)		C	SF6 Gas density monitor body replacement	03/Jun/2024	07:00	04/Jun/2024	18:00		PLANNED	Requested
787	RQ178240	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT FATEHGARH_II(PG)		D	FOR CSD FINE TUNING OF ICT	01/Jun/2024	17:00	03/Jun/2024	23:59	DURING FINE TUNING OF ICT, 04-05 NO LOAD OPERATIONS OF ICT SHALL BE PERFORMED	PLANNED	Requested
788	RQ178289	OCC_219	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT MANDOLA(PG)		D	For 220 KV BUS BAR retrofitment work	01/Jun/2024	09:00	01/Jun/2024	18:00	FOR BUS BAR RETROFITMENT WORK	PLANNED	Requested
789	RQ177606	OCC_219	slcds_sd	TRANSFORMER	400/11 KV 80 MVA ST 2 AT KAWAI SCTPS(APR)	RRVPNL	D	Annual maintenance and testing of Bay equipments	24/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested
790	RQ177605	OCC_219	slcds_sd	TRANSFORMER	400/11 KV 80 MVA ST 1 AT KAWAI SCTPS(APR)	RRVPNL	D	Annual maintenance and testing of Bay equipments	22/Jun/2024	08:00	22/Jun/2024	18:00		PLANNED	Requested
791	RQ177607	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KANKANI(RS)	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested
792	RQ177608	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT KANKANI(RS)	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested
793	RQ177597	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BABAI(RS)	RRVPNL	D	Half Yearly Maintenance, Testing of bay equipments and To attend the oil leakage	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
794	RQ177602	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT JODHPUR(RS)	RRVPNL	D	Quarterly Preventive Maintenance and testing work.	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
795	RQ177596	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	13/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested
796	RQ177601	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT RATANGARH(RS)	RRVPNL	D	Maintenance work of bay equipments , isolators and testing.	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
797	RQ177600	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT JODHPUR(RS)	RRVPNL	D	Quarterly Preventive Maintenance and testing work.	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested
798	RQ177604	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK & TESTING OF BAY EQUIPMENTS	11/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested
799	RQ177599	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT RATANGARH(RS)	RRVPNL	D	Maintenance work of bay equipments , isolators and testing.	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested
800	RQ177697	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT AJMER(RS)	RRVPNL	D	Quarterly maintenance work of associated equipments of Bay.	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
801	RQ177598	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT RATANGARH(RS)	RRVPNL	D	Maintenance work of bay equipments , isolators and testing.	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested
802	RQ177501	OCC_219	slcds_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT DHANODA(HV)	HVPNL	D	To carry out the Mtc of OLTC	21/Jun/2024	10:00	21/Jun/2024	14:00		PLANNED	Requested

803	RQ177918	OCC_219	htpcos_sd	TRANSFORMER	400/132 KV 200 MVA ICT 3 AT RIHAND(NT)	NTPC	C	For Annual maintenance works on IBT-3, 400 KV bay equipments & 132 KV bay equipments.	10/Jun/2024	08:00	17/Jun/2024	18:00	For Annual maintenance works on IBT-3, 400 KV bay equipments & 132 KV bay equipments. IBT-3 is for internal supply only and no outgoing line connected with IBT-3. Other two IBTs 1 & 2 will be inservice. Inview of above mentioned activities shutdown is required on continuous basis.	PLANNED	Requested	
804	RQ177436	OCC_219	singrauli_sd	TRANSFORMER	400/132 KV 100 MVA ICT 2 AT SINGRAULI(NT)	NTPC	C	LINE ISOLATOR REPLACEMENT	03/Jun/2024	08:00	06/Jun/2024	18:00	ICT WILL BE UNDERSHUTDOWN	PLANNED	Requested	
805	RQ177577	OCC_219	slidcuk_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KASHIPUR(UK)	PTCUL	D	For Seepage Arresting, Tightening, Replacement of Jaw, Blades of 207-89C and 209-89C Isolator and other T&C related work	05/Jun/2024	10:00	05/Jun/2024	15:00		PLANNED	Requested	
806	RQ177576	OCC_219	slidcuk_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KASHIPUR(UK)	PTCUL	D	For Seepage Arresting, Tightening, Replacement of Jaw, Blades of 207-89C and 209-89C Isolator and other T&C related work	04/Jun/2024	10:00	04/Jun/2024	15:00		PLANNED	Requested	
807	RQ177770	OCC_219	cpcc_sd	TRANSFORMER	220/132 KV 100 MVA ICT 1 AT SITARGANJ(PG)	POWERGRID	D	AMP Work	04/Jun/2024	09:00	04/Jun/2024	17:00		PLANNED	Requested	
808	RQ177937	OCC_219	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV UNCHAHAR(NT)-RAEBAREILLY(PG) (PG) CKT-1	POWERGRID, UPPTCL	C	bay equipment testing	22/Jul/2024	08:00	23/Jul/2024	18:00		PLANNED	Requested	
809	RQ177734	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAEBAREILLY(PG)-BACHRAVAN(UP) (PG) CKT-1	POWERGRID, UPPTCL	D	AMP Work	30/Jun/2024	08:00	30/Jun/2024	18:00		PLANNED	Requested	
810	RQ177745	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)-KIDWAI NAGAR KANPUR (UP) (PG) CKT-1	POWERGRID, UPPTCL	D	AMP Work	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested	
811	RQ177921	OCC_219	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AURAIYA(NT)-SAIFAI (UP) (PG) CKT-1	POWERGRID, UPPTCL	D	* S/D of 220 KV Saifai-Auraiya(NTPC) for Testing and Commissioning of Bus Bar protection relayother maintenance wor	01/Jun/2024	10:00	01/Jun/2024	15:00		PLANNED	Requested	
812	RQ177467	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SARNA(PS)-UDHAMPUR(PDD) (PDD) CKT-1	PDD JK	D	SD required for Peak replacement work at Loc -23 of 220KV D/C Kishnepur- Sama Line crossing from above.	29/Jun/2024	08:00	29/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
813	RQ177464	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)-SARNA(PS) (PG) CKT-2	POWERGRID	D	SD required for Peak replacement work at Loc -23	29/Jun/2024	08:00	29/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
814	RQ177463	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)-SARNA(PS) (PG) CKT-1	POWERGRID	D	SD required for Peak replacement work at Loc -23	29/Jun/2024	08:00	29/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
815	RQ177939	OCC_219	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-3	POWERGRID	C	bay equipment testing	28/Jun/2024	08:00	29/Jun/2024	18:00		PLANNED	Requested	
816	RQ177938	OCC_219	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-1	POWERGRID	C	bay equipment testing	26/Jun/2024	08:00	27/Jun/2024	18:00		PLANNED	Requested	
817	RQ177583	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)-NEHRIAN(HP) (PG) CKT-2	POWERGRID	D	Line equipment's AMP work and testing work.	20/Jun/2024	09:00	20/Jun/2024	18:00	kindly approve	PLANNED	Requested	
818	RQ177582	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)-NEHRIAN(HP) (PG) CKT-1	POWERGRID	D	Line equipment's AMP work and testing work.	18/Jun/2024	09:00	18/Jun/2024	18:00	kindly approve	PLANNED	Requested	
819	RQ177690	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PITHORAGARH-JAULIJI (PG) CKT-2	POWERGRID	D	AMP Work	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested	
820	RQ177689	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PITHORAGARH-JAULIJI (PG) CKT-1	POWERGRID	D	AMP Work	15/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested	
821	RQ177954	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)-UDHAMPUR(PDD) (PG) CKT-1	POWERGRID	D	For AMP of Line Equipment and Jumper Strengthening work.	12/Jun/2024	09:00	12/Jun/2024	17:00	Kindly approve	PLANNED	Requested	
822	RQ177786	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SITARGANJ(PG)-CBGANJ(UP) (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
823	RQ177750	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-3	POWERGRID	D	Modification in Mutual compensation scheme & Line bay equipment AMP at Kanpur	12/Jun/2024	08:00	12/Jun/2024	18:00	Simultaneous S/D of 220 KV Kanpur-Unchahar -3 & 4 required	PLANNED	Requested	
824	RQ177751	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-4	POWERGRID	D	Modification in Mutual compensation scheme & Line bay equipment AMP at Kanpur	12/Jun/2024	08:00	12/Jun/2024	18:00	Simultaneous S/D of 220 KV Kanpur-Unchahar -1 & 2 required	PLANNED	Requested	
825	RQ177787	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV TANAKPUR(NH)-CBGANJ(UP) (PG) CKT-1	POWERGRID	D	Rectification of S/D nature defects	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested	
826	RQ177748	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-1	POWERGRID	D	Modification in Mutual compensation scheme & Line bay equipment AMP at Kanpur	11/Jun/2024	08:00	11/Jun/2024	18:00	Simultaneous S/D of 220 KV Kanpur-Unchahar -1 & 2 required	PLANNED	Requested	
827	RQ177749	OCC_219	cpcc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-2	POWERGRID	D	Modification in Mutual compensation scheme & Line bay equipment AMP at Kanpur	11/Jun/2024	08:00	11/Jun/2024	18:00	Simultaneous S/D of 220 KV Kanpur-Unchahar -1 & 2 required	PLANNED	Requested	

828	RQ177490	OCC_219	slidck_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SALAL(NH)-JAMMU(PDD) (PG) CKT-2	POWERGRID	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc.	09/Jun/2024	07:00	09/Jun/2024	12:00	30-50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grids. Rest 200 MW load shall be affected.	PLANNED	Requested	
829	RQ177489	OCC_219	slidck_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SALAL(NH)-JAMMU(PDD) (PG) CKT-1	POWERGRID	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc.	09/Jun/2024	07:00	09/Jun/2024	12:00	30-50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grids. Rest 200 MW load shall be affected.	PLANNED	Requested	
830	RQ177815	OCC_219	slidcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAWAIMADHOPUR(RS)-DAUSA(RS) (PG) CKT-1	POWERGRID	D	For Half yearly Maintenance at 220KV GSS SWM	07/Jun/2024	09:00	07/Jun/2024	15:00		PLANNED	Requested	
831	RQ177585	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)-HAMIRPUR(HP) (PG) CKT-2	POWERGRID	D	Line equipment's AMP work	07/Jun/2024	09:00	07/Jun/2024	18:00	kindly approve	PLANNED	Requested	
832	RQ177570	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JESSORE(HP)-PONG(BB) (PG) CKT-1	POWERGRID	D	Replacement of Control & Relay Panel under Add Cap_Petition No. 712/TT/2020 at Pong end. (TO COMPLETE BALANCE PUNCH POINTS OF ADD CAP WORK)	06/Jun/2024	10:00	08/Jun/2024	18:00	Under construction activity, kindly approve.	PLANNED	Requested	
833	RQ177819	OCC_219	slidcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)-SAWAIMADHOPUR(RS) (PG) CKT-1	POWERGRID	D	For Half yearly Maintenance at 220kv GSS SWM	06/Jun/2024	09:00	06/Jun/2024	15:00		PLANNED	Requested	
834	RQ177781	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ALLAHABAD(PG)-ALLAHABADREWAROAD(UP) (PG) CKT-1	POWERGRID	D	AMP Work	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested	
835	RQ177584	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)-HAMIRPUR(HP) (PG) CKT-1	POWERGRID	D	Line equipment's AMP work	05/Jun/2024	09:00	05/Jun/2024	18:00	kindly approve	PLANNED	Requested	
836	RQ177773	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHPUR(PG)-KANPURSOUTH(UP) (PG) CKT-1	POWERGRID	D	AMP Work	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested	
837	RQ177573	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAIKASUL(NH)-JESSORE(HP) (PG) CKT-1	POWERGRID	D	Rectification of broken strand of OPGW between span 78-79.	04/Jun/2024	08:00	04/Jun/2024	18:00	kindly approve	PLANNED	Requested	
838	RQ177571	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAIKASUL(NH)-PONG(BB) (PG) CKT-1	POWERGRID	D	Replacement of Control & Relay Panel under Add Cap_Petition No. 712/TT/2020 at Pong end. (TO COMPLETE BALANCE PUNCH POINTS OF ADD CAP WORK)	01/Jun/2024	10:00	03/Jun/2024	18:00	Under construction activity, kindly approve.	PLANNED	Requested	
839	RQ177413	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ABDULLAPUR(PG)-RAILWAYHR(RLY) (HVPNL) CKT-2	HVPNL	D	For AMP work	27/Jun/2024	08:00	27/Jun/2024	18:00	kindly approve.	PLANNED	Requested	
840	RQ177412	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ABDULLAPUR(PG)-RAMPUR(HV) (HVPNL) CKT-1	HVPNL	D	For AMP work	20/Jun/2024	08:00	20/Jun/2024	18:00	kindly approve.	PLANNED	Requested	
841	RQ177793	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AGRA(PG)-SHAMSHABAD(UP) (UP) CKT-1	UPPTCL	D	AMP Work	27/Jun/2024	08:00	27/Jun/2024	18:00		PLANNED	Requested	
842	RQ177792	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AGRA(PG)-TUNDLA (UP) (UP) CKT-1	UPPTCL	D	AMP Work	26/Jun/2024	08:00	26/Jun/2024	18:00		PLANNED	Requested	
843	RQ177800	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SOHAWAL(PG)-SOHAWAL(UP) (UP) CKT-1	UPPTCL	D	AMP Work	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested	
844	RQ177936	OCC_219	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV UNCHAHAR(NT)-FATEHPUR(UP) (UP) CKT-1	UPPTCL	C	bay equipment testing	06/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested	
845	RQ177652	OCC_219	stupu_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANTNAGAR(UK)-BAREILLY(UP) (UP) CKT-1	UPPTCL	D	* Preventive maintenance and replacement of Jumpers	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested	
846	RQ178103	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)-BHILWARA(RS) (PG) CKT-2		D	For attending S/D nature defects	25/Jun/2024	08:00	25/Jun/2024	18:00	A/R of Kankroli-Zerda CKT to be kept in non Auto mode	PLANNED	Requested	
847	RQ178102	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)-BHILWARA(RS) (PG) CKT-1		D	For attending S/D nature defects	24/Jun/2024	08:00	24/Jun/2024	18:00	A/R of Anta-Bhilwara CK2 to be kept in non Auto mode	PLANNED	Requested	
848	RQ178149	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-4		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
849	RQ178118	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DUNI(RS)-KOTA(PG) (RS) CKT-1		D	AMP works of Line Bay equipments	18/Jun/2024	09:00	18/Jun/2024	18:00		PLANNED	Requested	
850	RQ178148	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-4		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	18/Jun/2024	08:00	18/Jun/2024	18:00		PLANNED	Requested	
851	RQ178147	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-3		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	17/Jun/2024	08:00	17/Jun/2024	18:00		PLANNED	Requested	
852	RQ178037	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)-CHITTORGARH(RS) (PG) CKT-2		D	Repairing of PLC system and Relay testing	15/Jun/2024	09:00	15/Jun/2024	15:00		PLANNED	Requested	
853	RQ178097	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JIND(PG)-NARWANA (HV) (HVPNL) CKT-2		D	LINE EQUIPMENT AMP WORK	15/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested	

854	RQ178146	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-3		D	For Busbar Bay unit retrofit and hardware rectification in switchyard	15/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested
855	RQ178036	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)-CHITTORGARH(RS) (PG) CKT-1		D	Repairing of PLCC system and Relay testing	14/Jun/2024	09:00	14/Jun/2024	15:00		PLANNED	Requested
856	RQ178018	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHINMAL(PG)-SANCHORE(RS) (RS) CKT-1		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
857	RQ178017	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHINMAL(PG)-BHINMAL(RS) (RS) CKT-2		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
858	RQ178021	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHINMAL(PG)-SIROHI(RS) (RS) CKT-1		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
859	RQ178016	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHINMAL(PG)-BHINMAL(RS) (RS) CKT-1		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
860	RQ178019	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHINMAL(PG)-SAYLA(RS) (RS) CKT-1		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
861	RQ178020	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHINMAL(PG)-SAYLA(RS) (RS) CKT-2		D	For 220kV side IPS tube erection work from 220kV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220kV Bus 1 & 220kV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220kV Bhinmal - Sirohi Line, 220kV Bhinmal - Bhinmal Line-I, 220kV Bhinmal - Bhinmal Line-II, 220kV Bhinmal - Sanchore Line, 220kV Bhinmal - Sayala Line-I, 220kV Bhinmal - Bhinmal Line-II AND 400/220kV ICT-I, 400/220kV ICT-II)	14/Jun/2024	08:00	14/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested
862	RQ178145	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-2		D	For Busbar Bay unit retrofit and hardware rectification in switchyard	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested

863	RQ178144	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-2		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	13/Jun/2024	08:00	13/Jun/2024	18:00			PLANNED	Requested
864	RQ178038	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)-DEBARI(RS) (PG) CKT-1		D	Repairing of PLCC system and Relay testing	12/Jun/2024	09:00	12/Jun/2024	15:00			PLANNED	Requested
865	RQ178143	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-1		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	12/Jun/2024	08:00	12/Jun/2024	18:00			PLANNED	Requested
866	RQ178142	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-SOUTH WAZIRABAD(DV) (DTL) CKT-1		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	11/Jun/2024	08:00	11/Jun/2024	18:00			PLANNED	Requested
867	RQ178081	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DUNI(RS)-JAIPUR SOUTH(PG) (RS) CKT-1		D	AMP OF LINE EQUIPMENTS	10/Jun/2024	09:00	10/Jun/2024	17:00			PLANNED	Requested
868	RQ178141	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-NARELA(DV) (DTL) CKT-2		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	10/Jun/2024	08:00	10/Jun/2024	18:00			PLANNED	Requested
869	RQ178082	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAIPUR SOUTH(PG)-SEZJAIPUR(RS) (RS) CKT-1		D	AMP OF LINE EQUIPMENTS	09/Jun/2024	09:00	09/Jun/2024	17:00			PLANNED	Requested
870	RQ178095	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JIND(PG)-MUND (HV) (HVPNL) CKT-2		D	LINE EQUIPMENT AMP WORK	08/Jun/2024	08:00	08/Jun/2024	18:00			PLANNED	Requested
871	RQ178140	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-NARELA(DV) (DTL) CKT-2		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	08/Jun/2024	08:00	08/Jun/2024	18:00			PLANNED	Requested
872	RQ178057	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RENEW SUNBRIGHT SL_FGARH_PG (RSBPL)-FATEHGARH_III(PG) (RENEW SUN BRIGHT (RSBPL) CKT-1		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:59			PLANNED	Requested
873	RQ178051	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_III(PG)-ASER2PL_SL_FTHG2_PG (ADANI SOLAR ENRGY RJ TWO PRIVATE LIMITED) CKT-1		D	for AMP works	07/Jun/2024	14:00	11/Jun/2024	23:59			PLANNED	Requested
874	RQ178048	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_III(PG)-AHEJOL PSS HB_FGRAH_PG (AHEJOL) (AHEJOL) CKT-2		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:59			PLANNED	Requested
875	RQ178045	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_III(PG)-AHEJ2L PSS HB_FGRAH_PG (AHEJ2L) (AHEJ2L) CKT-1		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:59			PLANNED	Requested
876	RQ178047	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_III(PG)-AHEJOL PSS HB_FGRAH_PG (AHEJOL) (AHEJOL) CKT-1		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:59			PLANNED	Requested
877	RQ178046	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_III(PG)-AHEJ3L PSS HB_FGRAH_PG (AHEJ3L) (AHEJ3L) CKT-1		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:59			PLANNED	Requested
878	RQ178094	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JIND(PG)-MUND (HV) (HVPNL) CKT-1		D	LINE EQUIPMENT AMP WORK	07/Jun/2024	08:00	07/Jun/2024	18:00			PLANNED	Requested
879	RQ178139	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-NARELA(DV) (DTL) CKT-1		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	07/Jun/2024	08:00	07/Jun/2024	18:00			PLANNED	Requested
880	RQ178138	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-NARELA(DV) (DTL) CKT-1		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	06/Jun/2024	08:00	06/Jun/2024	18:00			PLANNED	Requested
881	RQ178132	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KJURUKSHETRA(PG)-SALEMPUR(HV) (HVPNL) CKT-2		D	For attending SIR audit point	05/Jun/2024	09:00	05/Jun/2024	17:00			PLANNED	Requested
882	RQ178137	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-GOPALPUR(DTL) (DTL) CKT-2		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	05/Jun/2024	08:00	05/Jun/2024	18:00			PLANNED	Requested
883	RQ178170	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MOHANA(HV)-SONIPAT(PG) (HVPNL) CKT-2		D	AMP OF LINE EQUIPMENTS	04/Jun/2024	09:00	04/Jun/2024	18:00			PLANNED	Requested
884	RQ178096	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JIND(PG)-NARWANA (HV) (HVPNL) CKT-1		D	LINE EQUIPMENT AMP WORK	04/Jun/2024	08:00	04/Jun/2024	18:00			PLANNED	Requested
885	RQ178136	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-GOPALPUR(DTL) (DTL) CKT-2		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	04/Jun/2024	08:00	04/Jun/2024	18:00			PLANNED	Requested
886	RQ178135	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-GOPALPUR(DTL) (DTL) CKT-1		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	03/Jun/2024	08:00	03/Jun/2024	18:00			PLANNED	Requested
887	RQ178024	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWADI(PG)-BHIWADI(RS) (RS) CKT-2		D	Distance Protectino Relay testing works at Bhiwadi end	02/Jun/2024	08:00	02/Jun/2024	18:00			PLANNED	Requested
888	RQ178052	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_III(PG)-DEVIKOT SL_FTHG2 (NTPC_DEVIKOT) (NTPC_DEVIKOT) CKT-1		D	for AMP works	01/Jun/2024	14:00	07/Jun/2024	23:59			PLANNED	Requested

889	RQ178055	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)-RENEW_JHARKHAND 3 SL_FGARH_PG (RSEJ3PL) (RSEJ3PL) CKT-1		D	for AMP works	01/Jun/2024	14:00	07/Jun/2024	23:59		PLANNED	Requested	
890	RQ178049	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)-ASEJOL_HB FTGH2 (ASEJOL) (ASEJOL) CKT-1		D	for AMP works	01/Jun/2024	14:00	07/Jun/2024	23:59		PLANNED	Requested	
891	RQ178054	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)-RENEW SUNWAVE SL_FGRAH_PG (RSWPL) (RENEW SUN WAVE (RSWPL)) CKT-1		D	for AMP works	01/Jun/2024	14:00	07/Jun/2024	23:59		PLANNED	Requested	
892	RQ178056	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RENEW SOLARURIA SL_FGARH_PG (RSUPL)-FATEHGARH_II(PG) (RENEW SOLARURIA (RSUPL)) CKT-1		D	for AMP works	01/Jun/2024	14:00	07/Jun/2024	23:59		PLANNED	Requested	
893	RQ178050	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)-ASEJOL_HB FTGH2 (ASEJOL) (ASEJOL) CKT-2		D	for AMP works	01/Jun/2024	14:00	07/Jun/2024	23:59		PLANNED	Requested	
894	RQ178053	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)-EDEN SL_FGRAH_PG (ERCP) (EDEN (ERCP)) CKT-1		D	for AMP works	01/Jun/2024	14:00	07/Jun/2024	23:59		PLANNED	Requested	
895	RQ178119	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_C(NP)-ANTA(NT) (PG) CKT-1		C	NHAI DIVERSION WORK	01/Jun/2024	08:00	10/Jun/2024	18:00	Timely requirement of S/D	PLANNED	Requested	
896	RQ178117	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)-BHILWARA(RS) (PG) CKT-2		C	NHAI DIVERSION WORK	01/Jun/2024	08:00	10/Jun/2024	18:00	Timely requirement of S/D	PLANNED	Requested	
897	RQ178116	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)-BHILWARA(RS) (PG) CKT-1		C	NHAI DIVERSION WORK	01/Jun/2024	08:00	10/Jun/2024	18:00	Timely requirement of S/D	PLANNED	Requested	
898	RQ178023	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWADI(PG)-BHIWADI(RS) (RS) CKT-1		D	Distance Protectino Relay testing works at Bhiwadi end	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested	
899	RQ178134	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MANDOLA(PG)-GOPALPUR(DTL) (DTL) CKT-1		D	For Busbar Bay unit retrofitment and hardware rectification in switchyard	01/Jun/2024	08:00	01/Jun/2024	18:00		PLANNED	Requested	
900	RQ177808	OCC_219	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR-JAMALPUR (BB) CKT-2	BBMB	D	Maintenance of Sub-Station Equipments	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested	
901	RQ177822	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI(BB)-KHETRI(RS) (BB) CKT-2	BBMB	D	For Tree trimming & bay maintenance work	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested	
902	RQ177806	OCC_219	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_R-GANGUWAL (BB) CKT-1	BBMB	D	Half yearly mtc	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
903	RQ177821	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI(BB)-KHETRI(RS) (BB) CKT-1	BBMB	D	For Tree trimming & bay maintenance work	11/Jun/2024	08:00	11/Jun/2024	18:00		PLANNED	Requested	
904	RQ177817	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(BB)-CHIRAWA(RS) (BB) CKT-1	BBMB	D	For Half yearly maintenance work	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested	
905	RQ177805	OCC_219	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL-DHULKOTE (BB) CKT-2	BBMB	D	Half yearly mtc at Ganguwal end & General mtc at Dhulkote end.	06/Jun/2024	08:00	06/Jun/2024	18:00		PLANNED	Requested	
906	RQ177804	OCC_219	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL-DHULKOTE (BB) CKT-1	BBMB	D	Half yearly mtc at Ganguwal end & General mtc at Dhulkote end.	04/Jun/2024	08:00	04/Jun/2024	18:00		PLANNED	Requested	
907	RQ177820	OCC_219	slcds_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BASSI(PG)-BAGRU(RS) (PG) CKT-1	POWERGRID, RRVNPL	D	For quarterly maintenance work of whole grid sub-station	13/Jun/2024	08:00	13/Jun/2024	18:00		PLANNED	Requested	
908	RQ177611	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAMBA(PG)-SAMBA (JK) (PDD JK) CKT-2	POWERGRID, PDD JK	D	For line equipment's AMP work	12/Jun/2024	09:00	12/Jun/2024	18:00	kindly approve	PLANNED	Requested	
909	RQ177610	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAMBA(PG)-SAMBA (JK) (PDD JK) CKT-1	POWERGRID, PDD JK	D	For line equipment's AMP work	10/Jun/2024	09:00	10/Jun/2024	18:00	kindly approve	PLANNED	Requested	
910	RQ177491	OCC_219	slcdjk_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHOWADHI (JK)-GLADNI(PDD) (PDD JK) CKT-1	POWERGRID, PDD JK	D	Preve ntive ma inten- a nce works ncluding, replace- ment of worn out jumpers / droppers and allied clamps etc.	09/Jun/2024	07:00	09/Jun/2024	12:00	30-50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grids. Rest 200 MW load shall be affected.	PLANNED	Requested	
911	RQ177462	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MOGA(PG)-MOGAN(PS) (PSTCL) CKT-3	PSTCL	D	For Bus Bar Relay testing of 220 kv bus-2 after modification on 12.06.2024	12/Jun/2024	08:00	12/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
912	RQ177461	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MOGA(PG)-MOGAN(PS) (PSTCL) CKT-1	PSTCL	D	For Bus Bar Relay testing of 220 kv Bus-1 after modification on 11.06.2024	11/Jun/2024	08:00	11/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
913	RQ177807	OCC_219	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DEHAR(BB)-KANGOO(HP) (HP) CKT-1	HPPTCL	D	Half yearly mtc	05/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested	
914	RQ177549	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ABDULLAPUR(PG)-NEW JAGADHARI TSS(DFCCL) (RAILWAYS) CKT-2	RAILWAYS	D	FOR CT OIL SAMPLING FOR DGA TESTING	04/Jun/2024	14:00	04/Jun/2024	17:00	kindly approve	PLANNED	Requested	

915	RQ177550	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ABDULLAPUR(PG)-NEW JAGADHARI TSS(DFCCIL) (RAILWAYS) CKT-1	RAILWAYS	D	FOR CT OIL SAMPLING FOR DGA TESTING	04/Jun/2024	10:00	04/Jun/2024	13:00	kindly approve	PLANNED	Requested	
916	RQ178518	OCC_219	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DUNI(RS)-KOTA(PG) (RS) CKT-1	RRVPLN	D	AMP works of Line Bay equipments	01/Jun/2024	08:00	30/Jun/2024	18:00		PLANNED	Requested	
917	RQ177716	OCC_219	cpcc3_sd	BUS	220KV BUS 1 AT ALLAHABAD(PG)	POWERGRID	C	Relay Testing and AMP Work	29/Jun/2024	08:00	30/Jun/2024	18:00		PLANNED	Requested	
918	RQ178339	OCC_219	cpcc1_sd	BUS	220KV BUS 4 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT AND HARDWARE RECTIFICATION WORK	28/Jun/2024	08:00	29/Jun/2024	18:00		PLANNED	Requested	
919	RQ178366	OCC_219	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 2	POWERGRID	D	Jumper Tightning	27/Jun/2024	17:00	28/Jun/2024	23:00		PLANNED	Requested	
920	RQ178359	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT BHINMAL(PG)	POWERGRID	D	For BUS BAR TESTING - under Project SS-95 package	27/Jun/2024	08:00	27/Jun/2024	18:00		PLANNED	Requested	
921	RQ178338	OCC_219	cpcc1_sd	BUS	220KV BUS 3 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT AND HARDWARE RECTIFICATION WORK	26/Jun/2024	08:00	27/Jun/2024	18:00		PLANNED	Requested	
922	RQ178365	OCC_219	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 1	POWERGRID	D	Jumper Tightning	25/Jun/2024	17:00	26/Jun/2024	23:00		PLANNED	Requested	
923	RQ178358	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT BHINMAL(PG)	POWERGRID	D	For BUS BAR TESTING - under Project SS-95 package	25/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested	
924	RQ178337	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT AND HARDWARE RECTIFICATION WORK	24/Jun/2024	08:00	25/Jun/2024	18:00		PLANNED	Requested	
925	RQ177718	OCC_219	cpcc3_sd	BUS	220KV BUS 2 AT ALLAHABAD(PG)	POWERGRID	C	Relay Testing and AMP Work	23/Jun/2024	08:00	24/Jun/2024	18:00		PLANNED	Requested	
926	RQ177948	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT KISHENPUR(PG)	POWERGRID	D	For Jumper/Dropper Tightning and Strengthening work.	21/Jun/2024	09:00	21/Jun/2024	17:00	Kindly approve	PLANNED	Requested	
927	RQ178356	OCC_219	cpcc1_sd	BUS	220KV BUS 3 AT BHINMAL(PG)	POWERGRID	D	For 220KV side transfer bus 1 side 89A isolator jumper work - under SS-95 package	21/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested	
928	RQ178355	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT BHINMAL(PG)	POWERGRID	D	For 220KV side Main Bus-2 side 89A isolator jumper work - under SS-95 package	19/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
929	RQ178336	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT MANDOLA(PG)	POWERGRID	D	BUSBAR RETROFITMENT AND HARDWARE RECTIFICATION WORK	19/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested	
930	RQ177949	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT KISHENPUR(PG)	POWERGRID	D	For Jumper/Dropper Tightning and Strengthening work.	18/Jun/2024	09:00	18/Jun/2024	17:00	Kindly approve	PLANNED	Requested	
931	RQ177638	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWERGRID	D	****Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021****	17/Jun/2024	09:00	17/Jun/2024	12:00	Under construction head. kindly approve.	PLANNED	Requested	
932	RQ178354	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT BHINMAL(PG)	POWERGRID	D	For 220KV side Main Bus-1 side 89A isolator jumper work - under SS-95 package	17/Jun/2024	08:00	17/Jun/2024	18:00		PLANNED	Requested	
933	RQ178381	OCC_219	cpcc1_sd	BUS	220 KV JIND(PG) - BUS 2	POWERGRID	D	For const. activities of SS-104 package (Jumpering of 220 kv Bus-2 on bay 202)	14/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested	
934	RQ177637	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWERGRID	D	****Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021****	13/Jun/2024	09:00	13/Jun/2024	12:00	Under construction head. kindly approve.	PLANNED	Requested	
935	RQ178376	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT SONIPAT(PG)	POWERGRID	D	For const. activities of SS-104 package (Erection and comm. works of 220 KV Bays)	13/Jun/2024	08:00	15/Jun/2024	18:00		PLANNED	Requested	
936	RQ178349	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT BHINMAL(PG)	POWERGRID	D	"For 220kv side IPS tube erection work from 220KV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220KV Bus 1 & 220KV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220KV Bhinmal - Sirohi Line, 220KV Bhinmal - Bhinmal Line-I, 220KV Bhinmal - Bhinmal Line-II, 220KV Bhinmal - Sanchore Line, 220KV Bhinmal - Sayala Line-I, 220KV Bhinmal - Bhinmal Line-II AND 400/220KV ICT-I, 400/220KV ICT-II)"	12/Jun/2024	08:00	12/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested	
937	RQ178350	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT BHINMAL(PG)	POWERGRID	D	"For 220kv side IPS tube erection work from 220KV Bus-1 (89A isolator) to Circuit breaker (212 52) -under SS-95 package - 220KV Bus 1 & 220KV Bus 2 shutdown together (Along with all 220kV Lines-i.e. 220KV Bhinmal - Sirohi Line, 220KV Bhinmal - Bhinmal Line-I, 220KV Bhinmal - Bhinmal Line-II, 220KV Bhinmal - Sanchore Line, 220KV Bhinmal - Sayala Line-I, 220KV Bhinmal - Bhinmal Line-II AND 400/220kv ICT-I, 400/220kv ICT-II)"	12/Jun/2024	08:00	12/Jun/2024	20:00	under SS-95 PACKAGE PROJECT	PLANNED	Requested	
938	RQ177452	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT MOGA(PG)	POWERGRID	D	Bus Bar relay retrofiting work	12/Jun/2024	08:00	12/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
939	RQ178380	OCC_219	cpcc1_sd	BUS	220 KV JIND(PG) - BUS 1	POWERGRID	D	For const. activities of SS-104 package (Jumpering of 220 kv Bus-1 on bay 202)	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
940	RQ177552	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT KAITHAL(PG)	POWERGRID	D	Shutdown required for installation of BPI to provide additional support for Bus	11/Jun/2024	09:00	15/Jun/2024	18:00	kindly approve	PLANNED	Requested	
941	RQ177451	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT MOGA(PG)	POWERGRID	D	Bus Bar relay retrofiting work	11/Jun/2024	08:00	11/Jun/2024	18:00	Kindly approve	PLANNED	Requested	
942	RQ178396	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (erection of equipment)	11/Jun/2024	08:00	12/Jun/2024	20:00	Shutdown of 220 kv Bus-1,BUS-2 and BUS 3 required simultaneously for stringing of Jack Bus in R&Y phase.	PLANNED	Requested	

943	RQ178395	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (erection of equipment)	11/Jun/2024	08:00	12/Jun/2024	20:00	Shutdown of 220 kv Bus-1,BUS-2 and BUS 3 required simultaneously for stringing of Jack Bus in R&Y phase.	PLANNED	Requested	
944	RQ178397	OCC_219	cpcc1_sd	BUS	220KV BUS 3 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (erection of equipment)	11/Jun/2024	08:00	12/Jun/2024	20:00	Shutdown of 220 kv Bus-1,BUS-2 and BUS 3 required simultaneously for stringing of Jack Bus in R&Y phase.	PLANNED	Requested	
945	RQ178375	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT SONIPAT(PG)	POWERGRID	D	For const. activities of SS-104 package (Erection and comm. works of 220 KV Bays)	10/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
946	RQ178348	OCC_219	cpcc1_sd	BUS	220KV BUS 3 AT BHINMAL(PG)	POWERGRID	D	For 220KV side Transfer Bus 89C tandem isolator erection work -under SS-95 package	10/Jun/2024	08:00	10/Jun/2024	16:00		PLANNED	Requested	
947	RQ177580	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT PANCHKULA(PG)	POWERGRID	D	For AMP work	06/Jun/2024	09:00	06/Jun/2024	18:00	kindly approve	PLANNED	Requested	
948	RQ177427	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT PATIALA(PG)	POWERGRID	D	For replacement of Bus Coupler Dropper of R Phase from Bus to Isolator	05/Jun/2024	09:00	05/Jun/2024	17:00	kindly approve.	PLANNED	Requested	
949	RQ178347	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT BHINMAL(PG)	POWERGRID	D	For 220KV side Main Bus-2 side 89B tandem isolator erection work -under SS-95 package	05/Jun/2024	08:00	05/Jun/2024	16:00		PLANNED	Requested	
950	RQ177417	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT KAITHAL(PG)	POWERGRID	D	Replacement of jumper during ICT-2 shutdown period.	04/Jun/2024	09:30	04/Jun/2024	18:00	kindly approve.	PLANNED	Requested	
951	RQ178387	OCC_219	cpcc1_sd	BUS	220 KV BHADLA(PG) - BUS 6	POWERGRID	D	For AMP work	03/Jun/2024	19:00	03/Jun/2024	23:00		PLANNED	Requested	
952	RQ178368	OCC_219	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 4	POWERGRID	D	Jumper Tightning	03/Jun/2024	17:00	04/Jun/2024	23:00		PLANNED	Requested	
953	RQ178386	OCC_219	cpcc1_sd	BUS	220 KV BHADLA(PG) - BUS 5	POWERGRID	D	For AMP work	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested	
954	RQ178346	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT BHINMAL(PG)	POWERGRID	D	For ICT jack bus Stringing work-Jack bus jumper work, 220kv side Main Bus-1 side 89A isolator erection work-under SS-95 package	03/Jun/2024	08:00	03/Jun/2024	18:00		PLANNED	Requested	
955	RQ178392	OCC_219	cpcc1_sd	BUS	220KV BUS 2 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (erection of equipment)	02/Jun/2024	08:00	02/Jun/2024	20:00		PLANNED	Requested	
956	RQ178367	OCC_219	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 3	POWERGRID	D	Jumper Tightning	01/Jun/2024	17:00	02/Jun/2024	23:00		PLANNED	Requested	
957	RQ178391	OCC_219	cpcc1_sd	BUS	220KV BUS 1 AT KOTPUTLI(PG)	POWERGRID	D	For Construction Activities of SS-104 Package (erection of equipment)	01/Jun/2024	08:00	01/Jun/2024	20:00		PLANNED	Requested	
958	RQ177401	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	25/Jun/2024	09:00	25/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
959	RQ177400	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	22/Jun/2024	09:00	22/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
960	RQ177399	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	21/Jun/2024	09:00	21/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
961	RQ177398	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	20/Jun/2024	09:00	20/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
962	RQ178326	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) - BUS 6		D	For Bay extension and bus bar testing of 06 Nos. line Bay (Jumpering and bay extension work of new bays of Phase II)	18/Jun/2024	14:00	28/Jun/2024	23:00		PLANNED	Requested	
963	RQ177384	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT AMRITSAR(PG)		D	For Construction Works and Stability of Upcoming 220kV LINE Bay (213).	18/Jun/2024	10:00	21/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
964	RQ177397	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	17/Jun/2024	13:00	17/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
965	RQ177393	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)		D	Retrofitting of equipments under ADD CAP works approved under CERC petition No.470/TT/2020 dated 14.10.2021"	13/Jun/2024	13:00	13/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
966	RQ177383	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT AMRITSAR(PG)		D	For Construction Works and Stability of Upcoming 220kV LINE Bay (213).	13/Jun/2024	10:00	16/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
967	RQ178311	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) - BUS 6		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:00		PLANNED	Requested	
968	RQ178310	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) - BUS 5		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:00		PLANNED	Requested	
969	RQ178312	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) - BUS 7		D	for AMP works	07/Jun/2024	14:00	17/Jun/2024	23:00		PLANNED	Requested	
970	RQ177382	OCC_219	cpcc2_sd	BUS	220KV BUS 2 AT AMRITSAR(PG)		D	For Construction Works and Stability of Upcoming 220kV LINE Bay (213).	07/Jun/2024	10:00	10/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
971	RQ178308	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH (PG) - BUS 3		D	for AMP works	02/Jun/2024	14:00	07/Jun/2024	23:00		PLANNED	Requested	
972	RQ178309	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH (PG) - BUS 4		D	for AMP works	02/Jun/2024	14:00	07/Jun/2024	23:00		PLANNED	Requested	
973	RQ178325	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) - BUS 5		D	For Bay extension and bus bar testing of 06 Nos. line Bay (Jumpering and bay extension work of new bays of Phase II)	02/Jun/2024	14:00	13/Jun/2024	23:00		PLANNED	Requested	

974	RQ178306	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH (PG) - BUS 1		D	for AMP works	01/Jun/2024	14:00	06/Jun/2024	23:00		PLANNED	Requested	
975	RQ178313	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) - BUS 8		D	for AMP works	01/Jun/2024	14:00	06/Jun/2024	23:00		PLANNED	Requested	
976	RQ178307	OCC_219	cpcc1_sd	BUS	220 KV FATEHGARH (PG) - BUS 2		D	for AMP works	01/Jun/2024	14:00	06/Jun/2024	23:00		PLANNED	Requested	
977	RQ177381	OCC_219	cpcc2_sd	BUS	220KV BUS 1 AT AMRITSAR(PG)		D	For Construction Works and Stability of Upcoming 220KV LINE Bay (213).	01/Jun/2024	10:00	04/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
978	RQ178508	OCC_219	cpcc1_sd	BUS	220 KV BIKANER_2 (PBTSL) - BUS 1	PBTSL	D	For Bay extension works	21/Jun/2024	17:00	30/Jun/2024	23:00		PLANNED	Requested	
979	RQ178509	OCC_219	cpcc1_sd	BUS	220 KV BIKANER_2 (PBTSL) - BUS 2	PBTSL	D	For Bay extension works	11/Jun/2024	17:00	20/Jun/2024	23:00		PLANNED	Requested	
980	RQ177810	OCC_219	bbmb_sd	BUS	220KV BUS 2 AT DELHI RR(BB)	BBMB	D	Half Yearly Mtc..	20/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested	
981	RQ178520	OCC_219	bbmb_sd	BUS	220KV BUS 1 AT GANGUWALI(BB)	BBMB	D	Half Yearly Mtc..	18/Jun/2024	08:00	19/Jun/2024	18:00		PLANNED	Requested	
982	RQ177809	OCC_219	bbmb_sd	BUS	220KV BUS 1 AT DELHI RR(BB)	BBMB	D	Half yearly mtc	07/Jun/2024	08:00	07/Jun/2024	18:00		PLANNED	Requested	
983	RQ177935	OCC_219	ntpcos_sd	BUS	220KV BUS 2 AT UNCHAHAR(NT)	NTPC	C	Maint of Bus#2 side isolator of diff bays.	17/Jun/2024	08:00	21/Jun/2024	18:00		PLANNED	Requested	
984	RQ177934	OCC_219	ntpcos_sd	BUS	220KV BUS 1 AT UNCHAHAR(NT)	NTPC	C	Maint of Bus#1 side isolator of diff bays.	10/Jun/2024	08:00	14/Jun/2024	18:00		PLANNED	Requested	
985	RQ177415	OCC_219	cpcc2_sd	BUS	220 KV KALA AMB(PKTL) - BUS 2	PKATL	C	For Bus bar differential and LBB protection testing during commissioning of 220KV Line 3 and Line 4.	10/Jun/2024	09:00	14/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
986	RQ177414	OCC_219	cpcc2_sd	BUS	220 KV KALA AMB(PKTL) - BUS 1	PKATL	C	For Bus bar differential and LBB protection testing during commissioning of 220KV Line 3 and Line 4.	03/Jun/2024	09:00	07/Jun/2024	18:00	SD required for construction activity. Kindly approve	PLANNED	Requested	
987	RQ177492	OCC_219	slidck_sd	BUS	220KV BUS 1 AT GLADNI(PDD)	PDD JK	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc.	09/Jun/2024	07:00	09/Jun/2024	12:00	30-50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grids. Rest 200 MW load shall be affected.	PLANNED	Requested	
988	RQ177493	OCC_219	slidck_sd	BUS	220KV BUS 2 AT GLADNI(PDD)	PDD JK	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc.	09/Jun/2024	07:00	09/Jun/2024	12:00	30-50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grids. Rest 200 MW load shall be affected.	PLANNED	Requested	
989	RQ177613	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HIRANAGAR(PDD)-SEWA_2(NH) (PG) CKT-2	POWERGRID	D	For line equipment's AMP work	17/Jun/2024	09:00	17/Jun/2024	18:00	kindly approve	PLANNED	Requested	
990	RQ177612	OCC_219	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HIRANAGAR(PDD)-SEWA_2(NH) (PG) CKT-1	POWERGRID	D	For line equipment's AMP work	14/Jun/2024	09:00	14/Jun/2024	18:00	kindly approve	PLANNED	Requested	
991	RQ177874	OCC_219	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	132 KV BALIA(PG)-BANSDIH(UP) (UP) CKT-1	UPPTCL	D	AMP Work	12/Jun/2024	08:00	12/Jun/2024	18:00		PLANNED	Requested	
992	RQ177814	OCC_219	sliders_sd	AC TRANSMISSION LINE CIRCUIT	132 KV SHEOPUR(MP)-KHANDAR(RS) (MPSEB) CKT-1	MPSEB,RRVP NL	D	For Half yearly Maintenance at 132KV GSS khandar	07/Jun/2024	09:00	07/Jun/2024	13:00		PLANNED	Requested	
993	RQ178402	OCC_219	cpcc1_sd	BR/BSR/MSC/M SR	25 MVAR BUS REACTOR NO.1 AT 220 KV MANDOLA(PG)	POWERGRID	D	BUS BAR RETROFITMENT WORK	03/Jun/2024	08:00	05/Jun/2024	18:00		PLANNED	Requested	
994	RQ177672	OCC_219	cpcc3_sd	BAY	208 MAIN BAY - 220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-3 (POWERGRID) AT 220 KV KANPUR(PG)	POWERGRID	C	CB Drive mechanism overhauling	27/Jun/2024	10:00	30/Jun/2024	18:00	line will remain in service through TBC Bay	PLANNED	Requested	
995	RQ177671	OCC_219	cpcc3_sd	BAY	207 MAIN BAY - 220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-2 (POWERGRID) AT 220 KV KANPUR(PG)	POWERGRID	C	CB Drive mechanism overhauling	23/Jun/2024	10:00	26/Jun/2024	18:00	line will remain in service through TBC Bay	PLANNED	Requested	
996	RQ177670	OCC_219	cpcc3_sd	BAY	206 MAIN BAY - 220 KV KANPUR(PG)-UNCHAHAR(NT) (PG) CKT-1 (POWERGRID) AT 220 KV KANPUR(PG)	POWERGRID	C	CB Drive mechanism overhauling	19/Jun/2024	10:00	22/Jun/2024	18:00	line will remain in service through TBC Bay	PLANNED	Requested	
997	RQ178467	OCC_219	cpcc1_sd	BAY	209 MAIN BAY - 220 KV BHIWADI(PG)-REWARI(HV) (HVPNL) CKT-2 (POWERGRID) AT 220 KV BHIWADI(PG)	POWERGRID	C	Overhauling works	15/Jun/2024	08:00	20/Jun/2024	18:00		PLANNED	Requested	
998	RQ177665	OCC_219	cpcc3_sd	BAY	201 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT KANPUR(PG) (POWERGRID) AT 220 KV KANPUR(PG)	POWERGRID	C	CB Drive mechanism overhauling	11/Jun/2024	10:00	14/Jun/2024	18:00		PLANNED	Requested	

