



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
उत्तर क्षेत्रीय विद्युत समिति
Northern Regional Power Committee

दिनांक: 07.10.2024

सेवा में : संरक्षण उप-समिति के सदस्य (सूची के अनुसार) ।

To: Members of Protection Sub-Committee (As per mail list)

विषय: संरक्षण उप-समिति की 52 वीं बैठक की कार्यवृत्त ।

Subject: Minutes for 52nd Protection Sub-Committee Meeting.

संरक्षण उप-समिति की 52 वीं बैठक, दिनांक 20.09.2024 को 10:30 बजे से एनआरपीसी सचिवालय, कटवारिया सराय, नई दिल्ली-110016 में आयोजित की गयी थी । उक्त बैठक की कार्यवृत्त संलग्न है । यह उत्तर क्षेत्रीय विद्युत् समिति की वेबसाइट (<http://164.100.60.165/>) पर भी उपलब्ध है ।

The 52nd meeting of Protection Sub-Committee was held on 20.09.2024 at 10:30 Hrs at NRPC Secretariat, Katwaria Sarai, New Delhi-110016. The minutes of the meeting is attached herewith. The same is also available on NRPC website (<http://164.100.60.165/>).

Signed by Dharmendra

Kumar Meena

Date: 07-10-2024 18:01:28

(डी.के. मीना)

(D.K. Meena)

अधीक्षण अभियंता (संरक्षण)

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

Contents

A.1.	Confirmation of minutes of 51 st meeting of Protection Sub-Committee.....	3
A.2.	Submission of protection performance indices along with reason and corrective action taken for indices less than unity to NRPC Secretariat on monthly basis (agenda by NRPC Secretariat).....	3
A.3.	Annual protection audit plan for FY 2024-25 and third-party protection audit plan (agenda by NRPC Secretariat).....	6
A.4.	Observations and Compliance of recommendations of protection audit (agenda by NRPC Secretariat).....	7
A.5.	Violation of protection standard in case of tripping of the Inter-Regional lines of voltage class 220 kV and above (agenda by NRPC Secretariat).....	9
A.6.	Review of Overvoltage protection stage -1 settings across Northern Region (agenda by NLDC).....	10
A.7.	Sensitive Earth Fault relay (to be kept on Alarm Mode only) of 440/220KV 315MVA ICT at 2X600MW Kalisindh Thermal Power Station, Jhalawar (agenda by RVPN).....	12
A.8.	Excessive SPS tripping of 2x315 MVA, 400/220kV ICTs at STPS Suratgarh (agenda by RVPN).....	14
A.9.	Status of remedial actions recommended during 51st PSC meeting (agenda by NRLDC)	16
A.10.	Status of Bus bar protection (agenda by NRLDC).....	19
A.11.	Replacement of electromechanical relays with numerical relays (agenda by NRLDC)	20
A.12.	Availability and Standardization of recording instrument (Disturbance recorder and Station Event Logger) (agenda by NRLDC).....	22
A.13.	Analysis of the tripping events occurred during July-2024 to August-2024 and status of remedial action taken (agenda by NRLDC).....	23
A.14.	Corrective action for healthiness of 500kV Mundra-Mahindergarh SPS (agenda by NRLDC)	49
A.15.	Implementation and updation of Protection setting Database (agenda by NRPC Secretariat).....	50
A.16.	Review and uniformity of df/dt (ROCOF) protection philosophy in Northern Region (agenda by NLDC).....	51
A.17.	Provisional protection clearance during FTC in July-August-September 2024 (agenda by NRLDC).....	53
A.18.	Recommendations of the committee to analyse the grid event happened at 13:53 hrs on 17th June 2024 due to tripping of HVDC Champa-Kurukshetra (agenda by NRPC Secretariat).....	53
A.19.	Issues with 400KV JPL-Kabulpur Ckt-1&2 PLCC Spare management & Maintenance (agenda by Apraava Energy Private Limited).....	58
A.20.	Approval of protection settings in compliance of IEGC 2023 (agenda by Adani Green Energy Limited).....	60

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

**Minutes of
52nd Meeting of Protection Sub-Committee (PSC) of
Northern Regional Power Committee**

Date and time of meeting : 20.09.2024 10.30 Hrs.

Venue : NRPC Secretariat, Katwaria Sarai, New
Delhi-110016

MS, NRPC welcomed the participants. List of participants is attached as **Annexure-P**.

A.1. Confirmation of minutes of 51st meeting of Protection Sub-Committee

A.1.1 AEE (P), NRPC apprised that the 51st PSC meeting was held on 23.07.2024. Minutes of the meeting were issued vide letter dtd. 17.08.2024. No comment has been received till the date.

Decision taken by Forum:

Forum approved the minutes of 51st PSC meeting as issued.

A.2. Submission of protection performance indices along with reason and corrective action taken for indices less than unity to NRPC Secretariat on monthly basis (agenda by NRPC Secretariat)

A.2.1 AEE (P), NRPC apprised that as per clause 15 (6) of IEGC 2023;

- *Users shall submit the following protection performance indices of previous month to their respective RPC and RLDC on monthly basis for 220 kV and above (132 kV and above in NER) system, which shall be reviewed by the RPC:*

a) The **Dependability Index** defined as $D = N_c / N_c + N_f$

b) The **Security Index** defined as $S = N_c / N_c + N_u$

c) The **Reliability Index** defined as $R = N_c / N_c + N_i$

where,

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

Nc is the number of correct operations at internal power system faults,

Nf is the number of failures to operate at internal power system faults,

Nu is the number of unwanted operations,

Ni is the number of incorrect operations and is the sum of Nf and Nu

Further, as per clause 15 (7) of IEGC 2023;

- *Each user shall also submit the reasons for performance indices less than unity of individual element wise protection system to the respective RPC and action plan for corrective measures. The action plan will be followed up regularly in the respective RPC.*

- A.2.2 In earlier PSC meetings, it was decided that each utility shall submit the Performance indices of previous month by 7th day of next month.
- A.2.3 Accordingly, the status of the indices reported for the months from June-2024 to August-2024 were presented and utilities have not started submission the performance indices were asked to submit the same at the earliest.
- A.2.4 SE (O), NRPC stressed that many utilities have not started submission the performance indices even after sensitization in each PSC meeting. These concerned may look into this and send the indices timely.
- A.2.5 Forum highlighted that reporting of performance indices has not been started by HP-GCL, HPSEBL, HPPCL, MEIL Anpara Energy Ltd, MEJA Urja Nigam Ltd., UT of J&K, Ladakh, and Chandigarh. There was no representative in the meeting from the above-mentioned power utilities.
- A.2.6 MS, NRPC emphasized that protection is utmost requirement for our power system to operate smoothly and uninterruptedly. All power utilities should participate in the PSC meeting.
- A.2.7 Further, he highlighted that all the concerned power utilities need to stream line the submission of performance indices in pursuance to the IEGC 2023 for every month. He commented that this agenda may be placed in OCC meeting also.
- A.2.8 PSPCL representative conveyed to submit the performance indices data timely in future. UPSLDC representative mentioned that they have been coordinating with UP-RVUNL for protection related data. UPSLDC has been taking up the matter with IPPs of its control area also. NTPC were directed to share the performance indices of all plants regularly.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- A.2.9 The current status of the performance indices reported for the months from June-2024 to August-2024 is attached as **Annexure-I**.
- A.2.10 Further, the summary of events, reported prior to this meeting which caused indices less than unity was discussed. The concerned utilities were supposed to submit the reason for the same and corrective action taken to resolve the related issue. Accordingly, concerned utilities were asked about the reason and remedial action taken for unwanted, incorrect operation and failure of operation.
- A.2.11 AEE (P), NRPC mentioned that ICT trippings have been reported in many of the cases due to water/moisture ingress in Bucholz, PRV, OSR. POWERGRID representative suggested that a plastic canopy may be placed to cover these mechanical relays of ICT. APCPL representative added that silicon sealant may be placed to avoid moisture/water ingress.
- A.2.12 RVPNL representative informed that entrance of cable in the relay is now being done from the bottom side so that water may not rise due to capillary action.
- A.2.13 Forum suggested PSTCL, RVPNL, UPPTCL to implement the above-mentioned practices at its substations to avoid water/moisture ingress so that unwanted tripping of ICTs may be prevented. Others may also adopt these practices and take control measures to avoid tripping of elements.
- A.2.14 Further, AEE (P), NRPC mentioned that utilities have reported many trippings because of control cable damage/cut and DC problem. Forum recommended concerned utilities to increase the inspection frequency of cable and must avoid water logging in trenches.
- A.2.15 Regarding un-healthiness of carrier on most of the lines, PSTCL representative informed that matter is being taken up to resolve. He was also informed that it involves a huge procurement. Forum advised PSTCL to expedite the process.
- A.2.16 Based on the detailed discussion and submission of information by utilities, the reason and corrective action taken for Performance Indices less than Unity related to events of June, 2024 to August, 2024 are attached as **Annexure- II**.
- A.2.17 CGM, NRLDC stated utilities to take the matter seriously and need to increase efforts for sending the performance indices. This helps in monitoring the system performance and utilities may also increase best practices after analysing events causing indices less than unity.
- A.2.18 MS, NRPC emphasized that repetitive tripping due to same causes may be avoided and review of protection settings may be done timely. He stressed that Bus Bar relay should be operational as per applicability, numerical relay should be available. He

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

directed that relay settings coordination may be implemented properly. Inspection frequency of cable may be increased as required.

A.2.19 Subsequently, MS, NRPC highlighted that utilities may submit the performance indices of previous month by 7th day of next month. Utilities may submit the element wise performance indices along with the reason for indices less than unity and corrective action taken. He directed all concerned utilities to send their reasons within a week via email along with corrective action taken for indices less than unity. SLDCs may send the compiled data of all utilities (GENCOs, & TRANSCO) under their jurisdiction.

Decision taken by Forum:

Concerned utilities were requested to submit the Protection performance indices of previous month by 7th day of next month element wise along with corrective action taken for indices less than unity. It was also decided that letters may be sent to concerned utilities from where indices are not being reported for sensitizing higher management of the utilities. Moreover, agenda shall be discussed in upcoming OCC meeting also.

A.3. Annual Protection Audit Plan for FY 2024-25 and Third Party Protection Audit Plan (agenda by NRPC Secretariat)

Annual Internal Audit Plan:

- A.3.1 AEE (P), NRPC apprised that under as per clause 15 of IEGC 2023;
- *Annual audit plan for the next financial year shall be submitted by the users to their respective RPC by 31st October. The users shall adhere to the annual audit plan and report compliance of the same to their respective RPC.*
- A.3.2 In the 48th, 49th, 50th and 51st PSC meetings, all utilities were requested to submit the annual protection audit plan.
- A.3.3 In view of above, some utilities have submitted their annual audit plans and others were requested to submit annual audit plan for FY 2024-25 at the earliest.

Third Party Protection Audit Plan:

- A.3.4 As per clause 15 of IEGC 2023:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

All users shall also conduct third party protection audit of each sub-station at 220 kV and above (132 kV and above in NER) once in five years or earlier as advised by the respective RPC.

- A.3.5 In view of above, some utilities have submitted their third-party protection audit plans and other remaining were requested submit the same at the earliest.
- A.3.6 SE (O), NRPC observed that those who have not been submitting protection performance indices, have also not sent the Protection audit plan.
- A.3.7 CGM, NRLDC stated to take this agenda in the OCC meeting, highlighting the concerned from Protection audit plan has not been received. MS, NRPC was also of the same view.
- A.3.8 POWERGRID representative informed that third party protection audit plan will be submitted within 2 to 3 days.
- A.3.9 UPPTCL representative intimated that third party protection audit plan finalization is under process at higher authorities which is going to be decided combinedly for all the zones.
- A.3.10 UPSLDC representative informed that tender of third-party protection audit for UPRVUNL plants will be finalized within 1-2 months. Further, he asked for any designated authority that will do 3rd party protection audit.
- A.3.11 EE (P), NRPC replied that in IEGC 2023, there is no mandate given regarding designated authority. Therefore, it is at disposal of utilities to find audit parties as per rules of their organization.
- A.3.12 RVUN stated that there must be some criteria for selection of parties for audit such as minimum experience of protection domain.
- A.3.13 MS, NRPC directed that concerned SLDCs shall send the internal annual audit plan for FY 2024-25 and third protection audit plan of all utilities in its control area. The status of audit as per submitted schedule, audit report and compliance of observations shall also to be updated by SLDCs of all utilities (Genco, Transco) in its control area.
- A.3.14 MS, NRPC also directed that Utilities may send the 3rd party protection audit plan. Subsequently, the audit reports along with compliance status may be submitted to NRPC Secretariat regularly.
- A.3.15 Subsequently, MS, NRPC stated to send a letter for the concerned utilities whose audit plan has not been received.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

A.3.16 Status of Internal Protection Audit plan for FY 2024-25 and third-party protection audit plan is attached as **Annexure-III & Annexure-IV**.

Decision taken by Forum:

Utilities were requested to submit the Annual Internal Protection Audit plan for FY 2024-25 and third-party protection audit plan at the earliest and comply the same timely. Audit report along with action plan for deficiency detected, if any may be submitted. It was also decided that letters may be sent to concerned utilities from where audit plan are not being reported for sensitizing higher management of the utilities. Moreover, agenda shall be discussed in upcoming OCC meeting also.

A.4. Observations and Compliance of recommendations of protection audit (agenda by NRPC Secretariat)

A.4.1 AEE (P), NRPC apprised that as per clause 15 of IEGC 2023;

- *All users shall conduct internal audit of their protection systems annually, and any shortcomings identified shall be rectified and informed to their respective RPC. The audit report along with action plan for rectification of deficiencies detected, if any, shall be shared with respective RPC for users connected at 220 kV and above (132 kV and above in NER).*

A.4.2 Utilities have submitted the internal audit report based on the audit done at their substations. The submitted reports after the 51st Protection sub-committee are attached as **Annexure-V**. However, observations and compliance of audit recommendations have not been reported to NRPC Secretariat.

A.4.3 The reports were presented and discussed. All members of PSC and concerned utilities were asked to share their findings and observations based on audit report.

A.4.4 POWERGRID NR-2 was requested to submit the compliance report.

A.4.5 EE (P), NRPC conveyed that as per IEGC 2023, **compliance report of action taken against any deficiency is to be submitted within one month after the audit.**

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- A.4.6 SE (O), NRPC conveyed that no observations have been mentioned in many audit reports even after the report has visible deviations as per the NRPC protection philosophy.
- A.4.7 Further, AEE (P), NRPC highlighted that as per audit report submitted by RVPN, variances have been observed in the adopted settings with respect to finalized NRPC Protection philosophy viz. PD relay setting, Zone-4 time setting, Overcurrent adopted in the 220kV lines, SOTF disabled and Time Synchronization problems.
- A.4.8 However, no such observations have been mentioned in the audit report submitted by audit team. Forum noticed the same.
- A.4.9 In view of above, Forum directed RVPN to look into the matter and do compliance after finding out such observations. The same may be taken care by RVPN in the future also.
- A.4.10 RVPN representative conveyed that overcurrent setting has been kept on 220kV lines at higher side based on limit of CTs for safety purpose of equipment. Forum decided to review the overcurrent protection enabling in the protection philosophy.

Decision taken by Forum:

Utilities were requested to submit action taken or compliance of observations/recommendations of audit. Forum directed all utilities to ensure that audit reports (internal and external) should be in proper sequence along with annexures, if any, while sharing with NRPC.

A.5. Violation of protection standard in case of tripping of the Inter-Regional lines of voltage class 220 kV and above (agenda by NRPC Secretariat)

- A.5.1 AEE (P), NRPC apprised that NLDC vide letter dated 21.8.2024 has informed the violation of protection standard in case of tripping of Inter Regional Lines of voltage class 220 kV and above.
- A.5.2 As per section 3.e of Grid Standards Regulation of CEA, 2010, fault is to be cleared within the following time:

Sl. No.	Nominal System Voltage	Maximum time of fault clearing

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

	in kV rms	in msec
1	400	100
2	220	160

- A.5.3 NLDC has prepared the list of tripping of Inter Regional Lines of voltage class 220 kV and above, during the month of July 2024 in which violations have been observed. The same is attached as **Annexure-VI**.
- A.5.4 It has been observed that fault had not cleared within specified time during these incidents (Annexure-VI).
- A.5.5 UP representative informed that there was fault in GIS compartment of 400kV Sahupuri-Varanasi ckt-2 at Sahupuri(UP) end. Multiple incidents occurred on 10th July 2024 was due to this fault only.
- A.5.6 Regarding reason of delayed clearance of fault, it was informed that bus bar protection was not in service during the time of incident. Currently Station is being operated by GE and UPPTCL was also not informed about unavailability of bus bar protection. Therefore, time delay setting of Z-4 distance protection was also not reduced to 160msec. Now, bus bar protection has been taken into service. However, rectification of fault in GIS compartment is under process.
- A.5.7 NRLDC representative raised concern over reliability of inter-regional link. Due to non-availability of 400kV Sahupuri-Varanasi ckt-2, Varanasi & Biharsharif (ER) are connected with single circuit only which affects the reliability and security of the system. UP was requested to rectify the fault and restore the line at the earliest. Being an inter-regional link, more vigilant operation and maintenance of protection system also need to be ensured.
- A.5.8 CGM, NRLDC also requested concerned to take appropriate actions/remedial measures to get fault cleared within specified time abovementioned.
- A.5.9 Further, all the utilities were also requested to ensure the fault clearance of the 220kV and above Inter-Regional lines within specified time to avoid any violation of protection standards.

Decision taken by Forum:

Forum directed all utilities to ensure the fault clearance of the 220kV and above Inter-

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

Regional lines within specified time as per Grid Standard Regulation of CEA, 2010.

A.6. Review of Overvoltage protection stage -1 settings across Northern Region (agenda by NLDC)

- A.6.1 AEE (P), NRPC apprised that in the 75th NRPC meeting (held on 28.08.2024), the grid event happened at 13:53 hrs on 17th June 2024 due to tripping of HVDC Champa-Kurukshetra was briefed and recommendation of committee constituted by MoP to analyse the above event, were discussed.
- A.6.2 Further, it was directed that overvoltage protection settings of 765kV and 400kV line of Northern Region may be reviewed and proper grading may be done by the utilities.
- A.6.3 The Committee, constituted by MoP has recommended the followings for implementing overvoltage Stage-I protection settings:
- a) Pick up voltage & time delay setting of Antitheft lines to be kept low with sufficient time gap from other lines at S/s
 - b) Parallel lines grading to be done such that one line should trip early by setting at low voltage and other line should trip last by keeping setting at high voltage.
 - c) Highly loaded lines should be given last priority in tripping.
 - d) Net MVAR relief (based on line charging MVAR & MVAR compensation in line) based on the simulation to be considered for arriving at the priority of line tripping. Lines providing high net MVAR relief to be tripped early.
 - e) Grading to be done in such a manner that one major incoming and outgoing line shall remain connected after tripping of lines at any node.
 - f) Protection setting of remote end station of a line need to be coordinated so as to avoid tripping of line from other end.
 - g) Drop-off to pick-up ratio of Relays implemented for overvoltage protection shall be more than 99.5%.
- A.6.4 Further, NLDC & NRLDC representative highlighted that during analysis of 17th Grid event of load loss of 16.5 GW in Northern Region, multiple 765kV line in Aligarh, Agra complex tripped. Overvoltage protection setting of Aligarh s/s was reviewed and revised settings were recommended.
- A.6.5 NRLDC representative informed that details of overvoltage protection setting of

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

765kV & 400kV lines have been received from POWERGRID(NR-2), ADANI (Mahendergarh) and Rajasthan only. Other constituents are requested to share the overvoltage setting in lines of their respective control area at the earliest.

- A.6.6 MS, NRPC also emphasized that grading of the overvoltage setting is utmost requirement from the protection point of view.
- A.6.7 He conveyed that a Committee under the chairmanship of SE (Protection), NRPC may be formed having members from Grid-India (NRLDC & NLDC), PowerGrid, STUs, SLDCs, NTPC, RRVUNL. Committee shall review the existing overvoltage protection setting and propose the revised settings.
- A.6.8 He also conveyed that simulation study (PSSe) is required to be done for all states having 400kV and 765kV transmission lines. A member from SLDC and an expert from protection wing may be included from State TRANSCOs.
- A.6.9 After the constitution of Committee, report may be submitted within 2 months and recommended setting will be implemented within next one month after approval of Protection Sub-Committee (PSC) Forum.
- A.6.10 In view of above, nominations may be asked from Grid-India (NRLDC & NLDC), PowerGrid, STUs, SLDCs, NTPC, RRVUNL.

Decision taken by Forum:

Forum agreed for constitution of Committee under the chairmanship of SE (Protection), NRPC having members from Grid-India (NRLDC & NLDC), PowerGrid, STUs, SLDCs, NTPC, RRVUNL to review Overvoltage protection settings of transmission lines across Northern Region.

A.7. Sensitive Earth Fault relay (to be kept on Alarm Mode only) of 440/220KV 315MVA ICT at 2X600MW Kalisindh Thermal Power Station, Jhalawar (agenda by RVPN)

- A.7.1 RVPN representative apprised that RVPN vide letter (**Annexure-VII**) dated 12.8.2024 intimated that Sensitive Earth Fault protection (SEF) is used on 400/220kV, 315 MVA ICT at Kalisindh with tripping mode, and recently few tripping occurred on 400/220 kV, 315 MVA ICT due to SEF Protection (details attached in the annexure-VII)

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

causing a large area disturbance i.e. Jhalawar, Bhawanimandi & Aklera.

- A.7.2 RVPN has mentioned that 220kV GSS Jhalawar, Bhawanimandi and Aklera supply is presently fed radially through (400/220kV,315MVA ICT) Kalisindh Generating Station (KSTPS).
- A.7.3 SEF (Sensitive Earth Fault) protection is used in 440/220kV 315MVA ICT with tripping mode having time 1.5Sec. (DT).
- A.7.4 Recently few trippings occurred on 440/220kV,315MVA ICT on SEF (Sensitive Earth Fault) because of jumper snapping (Broken Conductor) in 220 KV lines. Due to this, supply of large area having 03 Nos. above 220kV GSS& connected 132kV GSS disturbed.
- A.7.5 RVPN has submitted that SEF Protection may operate because of unbalance current due to broken conductor of 220 kV line. The RVPN has enabled broken conductor protection in 220 & 132 KV lines on alarm mode. In case any alarm observed, the line shall be manually tripped after checking current in all phases.
- A.7.6 SEF relay is connected on neutral CT having CT ratio 500/1 and current plug setting is 0.1 A (i.e. 45.4 Amp only), TMS- 1.5 Sec. DT mode.
- A.7.7 At Kalisindh Thermal Power Station, Jhalawar the backup protection is also available on ICT which may take care of unbalance current in case of jumper snapping or actual phase to earth fault.
- A.7.8 Such protection with tripping mode is nowhere used in RVPN Transmission system, this protection (SEF) is also not included in the recent Protection Philosophy.
- A.7.9 In view of above, RVPN requested to disable tripping through SEF relay or increase the setting from existing value & keep it on alarm mode only for 440/220kV,315MVA ICT at Kalisindh Thermal Power Station, Jhalawar.
- A.7.10 RVUNL representative highlighted that in case of broken conductor there is no zero-sequence current. Hence, without involvement of earth, there cannot be sensitive earth fault relay operation technically. However, he also agreed that there has been 2 times operation of sensitive earth fault relay observed in case of broken conductor of

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

lines. This thing is under investigation because shutdown availability of ICT is quite difficult.

- A.7.11 He conveyed that after the availability of shutdown of ICT, this malfunctioning of SEF relay will be checked. Till then remedial measures are being taken up by RVUNL.
- A.7.12 RVPN representative requested RVUN to keep the SEF relay operation on alarm mode or pick up setting may be increased to 10% of LV side current rating (~80amp). By this immediate solution will be possible. Further, based on shutdown availability, RVUN may test the relay and take appropriate action. RVUN representative agreed with this proposal of RVPN.
- A.7.13 MS, NRPC guided that all utilities should try to resolve issues mutually at the first stage.

Decision taken by Forum:

In line with mutual agreement of RVPN and RVUNL, Forum directed RVUNL to keep either SEF relay operation on alarm mode or may increase its pick up current setting to 10% of LV side current rating (~80amp).

A.8. Excessive SPS tripping of 2x315 MVA, 400/220kV ICTs at STPS Suratgarh (agenda by RVPN)

- A.8.1 RVPN representative apprised that RVPN vide letter (**Annexure-VIII**) dated 20.8.2024 submitted there was excessive trippings on SPS at 400/220kV 2X315MVA ICTs at STPS, Suratgarh causing a large area disturbance.
- A.8.2 SPS of 400/220kV 2x315 MVA ICTs at STPS Suratgarh was approved in the 49th PSC meeting held on 25.1.2024 and has been commissioned on dated 06.05.2024 to meet out the N-I contingency.
- A.8.3 Further, RVPN submitted that excessive interruptions (i.e. 39 Nos w.e.f. 18/5/24 to 22/7/24) has been observed due to operation of newly commissioned SPS at STPS Suratgarh since commissioning and a large load approx. 150 MW was affected due to same.
- A.8.4 After analysis of trippings, it is observed that these trippings were due to operation of

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

Over Current element of relay either by gradual overloading, poor power factor, poor voltage profile, Traction load etc. or some other reasons instead of "N-I contingency".

A.8.5 RVPN mentioned that after analyzing fault records /DR & discussion with RVUN officials, it is found that the present settings of Over current protection element of numerical relay used for SPS initiation is "Anyone Phase" on full Load current.

A.8.6 In view of above, RVPN recommended the followings to update in the existing approved SPS scheme of STPS Suratgarh to avoid the power supply disturbance caused by gradual overloading instead of "N-I Contingency".

a) To update the settings of over current element used for SPS start on "ALL Phase" instead of "Any Phase". As in most of the trippings, there is very much unbalance between the phases and the same may cause undesired initiation of SPS.

b) To update the Current Setting (I_>) from full load to 125 % of load on each ICT as per thermal capability of each ICT's.

c) To incorporate C.B. status in the tripping circuit of SPS on each 220 KV lines at both ends to avoid unnecessary trippings.

d) To Split the first stage of time delay of 1.0 sec (approx load relief of 150MW) at 220 KV GSS Bhadra by providing timer with 0.85 Sec (with load relief of 20 MW) and with 1.0 Sec (with load relief of rest 140 MW).

A.8.7 Further, RVUNL vide mail dated 06.09.2024 shared the comments on the proposal of RVPN. The same is attached as **Annexure-IX**.

A.8.8 RVPN representative stated that overcurrent means rise in current in all three phase, then an SPS should operate. If there is rise in current on one phase, then it may be taken care by earth fault and other protective relays. Hence RVPN requested RVUNL to change the current setting of SPS operation from one phase to three phase.

A.8.9 RVUNL representative replied that all windings of ICT are of same capacity. Therefore, increase of current of any of the winding should not be ignored from the point of load shedding or SPS operation. He disagreed with the proposed changes of RVPN regarding single phase to three phase overcurrent SPS operation.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- A.8.10 Further, RVPN representative stated the 2nd proposal for updating the Current Setting (I_>) from full load to 125 % of load on each ICT as per thermal capability of each ICT's. NRLDC representative conveyed that from the RVUNL comments, it seems that they have misunderstood this proposal of RVPN. RVUNL representative stated that overcurrent protection is going to operate in case of phase fault. Therefore, overcurrent and overload are two different phenomena.
- A.8.11 Further, 3rd and 4th proposals of RVPN were discussed. RVPN and RVUNL agreed mutually with respect to comments mentioned at S. No. 3rd and 4th of Annexure-IX. RVPN agreed to take action as suggested by RVUNL at S.No. 3rd and 4th point.

Decision taken by Forum:

In line with mutual agreement of RVUNL and RVPN, Forum accorded consent on S. No. 3rd and 4th mentioned at the Annexure-IX and directed RVPN to install underpower relay at the GSS and implement bifurcation of load relief at each stage. The overcurrent protection settings of transformer will be discussed in the meeting of 'Power Transformer and Reactor protection philosophy finalization' scheduled on 27.09.2024.

A.9. Status of remedial actions recommended during 51st PSC meeting (agenda by NRLDC)

- A.9.1 NRLDC representative apprised that as per the discussion in 51st PSC meeting, necessary remedial actions were recommended based on the analysis and discussion of the grid events. Constituents were requested to share the details of actions taken and present status via mail to NRLDC and NRPC. However, details not received on mail. During the meeting constituents were requested to apprise the status of the same. Constituents informed following during the meeting:

a) Frequent multiple elements tripping at 220kV Kunihar, Baddi, Upperla Nangal complex and load loss event in HP control area

51 PSC recommendations:

PSC Forum requested HP to complete the protection audit as per mentioned timelines (protection audit of 220kV Kunihar has been awarded and it would be completed within next 15-20 days. In next phase, by 15th September, protection

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

audit of substations in downstream and upstream of 220kV Kunihar S/s would be completed.) and resolve the protection related issues. HP was also requested to share the reports of protection audit to NRPC & NRLDC after completion of audits.

HPSEBL representative informed that protection audit of 220kV Kunihar has been awarded to POWERGRID on 09th July 2024 and it would be completed by October 2024. In next phase, protection audit of substations in downstream and upstream of 220kV Kunihar S/s would be completed, tender process of rest of the stations is in process.

NRLDC representative requested POWERGRID to expedite the protection audit of 220kV Kunihar S/s and HPSEBL was requested to expedite the process at their end and submit the report of protection audit after its completion.

Forum requested POWERGRID to complete the protection audit of Kunihar S/s at the earliest and requested HPSEBL to expedite the process of other upstream end. HP was also requested to share the reports of protection audit to NRPC & NRLDC after completion of audits.

**b) Multiple elements tripping at 220kV Hissar(BBMB) 07th May 2024, 11:16 hrs:
51 PSC recommendations:**

Expedite the implementation of differential protection in short lines to avoid undesired operation of distance protection.

HVPNL representative informed that clearance related to OPGW received from POWERGRID. Matter was forwarded to design team and is pending at that stage.

NRLDC representative requested HVPNL to expedite the process as it is long pending issue which leads to undesired tripping of multiple transmission lines due to overreach of distance protection.

HVPNL agreed to expedite the process of implementation of differential protection in short lines in coordination with POWERGRID & BBMB.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

c) Multiple elements tripping at 400/220kV Akal(RS) on 02nd Jan 2024, 07:28 hrs:

51 PSC recommendations:

- i. Bus bar protection at 220kV bus at 400/220kV Akal shall be made operational by June 2024.
- ii. Time synchronization of recording instruments (DR/EL) need to be ensured.

Rajasthan representative stated that three faulty PU were replaced from the future bay and one PU is still unhealthy which is in warranty period. Process is getting delayed due to lack of response from the OEM. Process will be expedited and will try to resolve the bus bar protection issue on priority.

NRLDC representative requested Rajasthan to expedite the process as Akal S/s is in RE complex and important S/s for evacuation of RE generation. Rajasthan agreed to resolve the issues on priority.

d) Multiple elements tripping at 400kV Sainj (HP), 400kV Parbati2 & Parbati3 (NHPC) Stations on 07th May 2024, 16:17 hrs:

51 PSC recommendations:

- i. NHPC shall follow up with the relay engineer and taken necessary remedial actions to ensure proper operation of A/R scheme at Parbati2 end.
- ii. NHPC and HPPTCL shall review the healthiness of PLCC at Parbati3 and Sainj end and take necessary actions to ensure their proper operation.
- iii. Expedite the implementation of differential protection in 400kV Parbati2-Sainj line.
- iv. Standardisation of recording instruments (DR/EL) need to be ensured.

NHPC representative informed following during the meeting:

- i. Material for differential protection has been purchased.
- ii. A/R scheme at Parabati2 is healthy as per preliminary test, further test needs to be done by taking shutdown.
- iii. Shutdown has been planned in 1st week of November 2024, testing of A/R scheme and implementation of differential protection will be done during that period.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- iv. Issue of time sync of recording instruments (GPS synchronisation) at Par-bati2(NHPC) has been resolved.
- v. PLCC card at Parabti3 end will be replaced by the end of September 2024. For dual test of PLCC operation, PLCC at Sianj end also need to be healthy.

Sainj HEP representative was not present in the meeting. HPPTCL was requested to intimate concerned person of HPPCL to taken necessary corrective actions and ensure healthiness of PLCC at Sainj end.

e) Multiple elements tripping at 400kV Khedar(RGTPS) Station at 10th May 2024, 19:35 hrs

51 PSC recommendations:

Revised corrected protection settings of Main-2 Micom P442 distance protection relay and A/R scheme at Khedar(RGTPS) end need to implemented at the earliest.

HVPNL representative informed that Khedar(RGTPS) have conducted 3rd party protection audit. Status of corrective action taken yet to be confirmed.

NRLDC representative requested HVPNL to confirm whether necessary changes required in protection setting has been done or not. Necessary actions need to be expedited.

f) Multiple elements tripping at 220kV Sarna (PS) on 04th May 2024, 07:10 hrs

51 PSC recommendations:

- i. Punjab shall expedite the commissioning of new bus scheme.
- ii. POWERGRID shall revise the Z-4 time delay setting of Kishenpur lines at Sarna (PS) end as 160msec till bus bar get operational.

Punjab representative informed that tender of bus bar protection has been processed, bus bar protection at 220kV Sarna will be commissioned within 4-5 months tentatively.

POWERGID(NR-2) representative informed that Z-4 time delay setting of lines of their control area has been revised.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

g) Multiple elements tripping at 400/132kV Masoli(UP) on 29th May 2024, 15:57 hrs

51 PSC recommendations:

UP shall implement the bus bar protection at 132kv level at 400/132kV Masoli S/s.

UP representative informed that this case has been communicated to design team. In response, they have asked the list of all such stations in UP control area. Further follow up actions is expected in due time course.

A.10. Status of Bus bar protection (agenda by NRLDC)

A.10.1 NRLDC representative apprised that Clause - 4 in schedule - V of Central Electricity Authority (Technical Standards for Construction of Electrical Plants and Electric Lines) Regulations, 2022 reads as

"Bus bar protection and local breaker backup protection shall be provided in 220kV and higher voltage interconnecting sub- stations as well as in all generating station switchyards".

A.10.2 During analysis of many grid incidents/disturbances, it has been found that the Busbar protection at the affected substation was not present or non-operational which resulted in considerably increasing both the number of affected elements and fault clearance time. Accordingly, it becomes critical to monitor and keep Busbar protection at all the 220 kV and above voltage level substations healthy and operational.

A.10.3 Continuous follow-ups have been done at OCC & PSC forum to expedite the commissioning of bus bar protection at 220kV & above stations and to ensure their healthiness. On the basis of details received till date, it is observed that the status of bus bar protection has been improved however, further improvement is desired.

A.10.4 Constituent wise status of bus bar protection where bus bar protection is either not installed or installed but not operational along with present status as per detail received from constituents is attached as **Annexure-X**.

A.10.5 Constituents were requested to share the present status of remedial action taken/to

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

be taken regarding commissioning and healthiness of bus bar protection at 220kV & above substations and also expedite the implementation of bus bar protection.

- A.10.6 Members were requested to appraise the status of bus bar protection in their respective control areas.
- A.10.7 UP, Haryana, Punjab and Rajasthan shared the updated status of bus bar protection in their control area. State wise summary of updated status of bus bar protection is attached as **Annexure-XI**.
- A.10.8 HP and Uttarakhand were requested to share the updated status of their control area.

Decision taken by Forum

Forum requested all the constituents to update the status of bus bar protection at S/s of their control area and expedite the commissioning and implementation work of bus bar protection system. Members agreed for the same.

A.11. Replacement of electromechanical relays with numerical relays (agenda by NRLDC)

- A.11.1 NRLDC representative apprised that Clause-37.2(c) of IEGC, clause-15(4) of CEA Grid standards and clause-48(4) of CEA Construction Standards 2022 mandates that "each line or transformer or reactor or any other bay shall be provided with facility for disturbance recording, event logging and time synchronizing equipment".
- A.11.2 During analysis of grid incidents/disturbances, it has been found that there are few stations where electromechanical relays are still in use and thus disturbance recorder are not available there which accounts for violation of Clause-37.2(c) of IEGC, clause-15(4) of CEA Grid Standards and clause 48(4) CEA Construction Standards 2022.
- A.11.3 In addition, clause-3 in part III (Grid Connectivity Standards applicable to Transmission Line and Sub-Station) of Standards for Connectivity to the Grid, 2007 reads as
- "Two main numerical Distance Protection Schemes shall be provided on all the transmission lines of 220 kV and above for all new sub-stations. For existing sub-stations, this shall be implemented in a reasonable time frame"

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- A.11.4 It is known that Disturbance recorder (DR) is essential for analysis of grid incidents/disturbances. Its non-availability eventually affects the proper analysis of grid incidents/disturbances and monitoring of protection system.
- A.11.5 Continuous follow-ups have been done at OCC & PSC forum. During the meeting, all the constituents/SLDC/STU were requested to review the same in their control area and take expedite actions to replace electromechanical relays with numerical relays.
- A.11.6 Constituent wise details of static/electromechanical type protection relays at their respective substations along with its present status per detail received from constituents is attached as **Annexure-XII**.
- A.11.7 Constituents were requested to share the status of remedial action taken/to be taken regarding replacement of static/electromechanical relay with numerical relays at 220kV & above substations and also expedite the process of replacement of static/electromechanical relay with numerical relays.
- A.11.8 Rajasthan representative informed that procurement process of 350 numbers of numerical relays is in pipeline and it is expected to be completed by December 2024. Thereafter, all the Main protection relays up to 132kV which are of electromechanical / static type will be replaced by numerical relays.
- A.11.9 Haryana representative informed that except few lines, all the line protection relays have been retrofit with numerical relays. Except few of the transformers, differential protection relay in all the transformers have been replaced with numerical relay. Mainly back up protection relays are of electromechanical type. Necessary actions and follow ups are being done to replace them also with the numerical relays.
- A.11.10 UP representative informed that in this regard Director Operation UPPTCL has also asked complete list of electromechanical relays in UP control area to initiate further follow up actions.
- A.11.11 Haryana, UP and Rajasthan shared the updated status. Based on details received from states, the updated status of relay type is attached as **Annexure-XIII**.
- A.11.12 Other states were also requested to share the updated status of their control area.

Decision taken by Forum

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

PSC forum requested all the constituents to update the status of type of protection relays at S/s of their control area and expedite the replacement work of static/electromechanical type protection relays with numerical relays. Members agreed for the same.

A.12. Availability and Standardization of recording instrument (Disturbance recorder and Station Event Logger) (agenda by NRLDC)

A.12.1 NRLDC representative apprised that as per IEGC clause 17

- 1) All users shall keep the recording instruments (disturbance recorder and event logger) in proper working condition.
- 2) The disturbance recorders shall have time synchronization and a standard format for recording analogue and digital signals.

A.12.2 IEGC clause 37.2 (c) also mandates the submission of Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) within 24 hrs of the event.

A.12.3 NRLDC representative highlighted that during FTC process, cases of non-availability of station event logger and non-standardisation of recording instruments have been observed.

A.12.4 Data of recording instruments (DR/EL) are very helpful in grid event analysis and is being used in availability verification of transmission lines. Complete and conclusive analysis of any grid event is not possible without these recording instruments and thus their standardisation is very important.

A.12.5 Therefore, availability of disturbance recorder with standardisation, time sync and correct nomenclature and station event logger need to be ensured by users at the station of their respective control area.

A.12.6 Deliberation on this subject was done during 50th & 51st PSC meeting. Details were received from UP & Haryana only.

A.12.7 In view of above, all the constituents were requested share the updated details w.r.t. availability and standardisation of disturbance recorder and event logger at the station of their respective control area in format attached as **Annexure-XIV**.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

Decision taken by Forum

PSC forum requested all the members to share the status of availability and standardisation of disturbance recorder and event logger at the station of their control area and ensure the standardisation of recording instruments at all the stations of their control area.

A.13. Analysis of the tripping events occurred during July-2024 to August-2024 and status of remedial action taken (agenda by NRLDC)

A.13.1 Followings were discussed as below:

a) Frequent forced outages of transmission elements in the month of August'24:

The following transmission elements were frequently tripping during the month of **August'24:**

S. No.	Element Name	No. of forced outages	Utility/SLDC
1	220 KV Anta(NT)-Sakatpura(RS) (RS) Ckt-1	4	NTPC/Rajasthan
2	220 KV DandhariKalanl(PS)-Ludhiana(PG) (PSTCL) Ckt-2	3	PG/Punjab
3	220 KV NAPP(NP)-Khurja(UP) (UP) Ckt-1	6	NAPP/UP
4	220 KV Saharanpur(PG)-Shamli(UP) (UP) Ckt-1	4	PG/UP
5	400 KV Agra-Unnao (UP) Ckt-1	4	UP
6	400 KV Bhadla-Merta (RS) Ckt-1	5	Rajasthan
7	400 KV Dadri(NT)-Panipat(BB) (PG) Ckt-1	3	NTPC/PG

The complete details are attached at **Annexure-XV**.

Discussion during the meeting:

- i. 220 KV Anta(NT)-Sakatpura(RS) (RS) Ckt-1:** NRLDC representative raised concern over frequent incidents of faults and non-operation of A/R at Sakatpura end.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

Rajasthan representative informed that two of the fault incidents occurred due to flashover of disc insulators and regarding non-operation of A/R, it was informed that relay penal is old, same is planned to be replaced with new within one month.

- ii. **220 KV DandhariKalan(PS)-Ludhiana(PG) (PSTCL) Ckt-2:** NRLDC representative raised concern over non-operation of A/R at Dandharikalan(PS) end. Punjab representative informed that in Main-2 relay, A/R lockout was coming. Issue in PSL (feedback of CB through auxiliary contacts) was found and same has been rectified.
- iii. **220 KV NAPP(NP)-Khurja(UP) (UP) Ckt-1:** NRLDC representative raised concern over frequent trippings of transmission lines connected at 220kV NAPP in the recent past. As per details available at NRLDC, 220kV NAPP(NP)-Khurja(UP) line tripped 16 (sixteen) times during the year 2024, A/R operation was also not observed at Khurja end during most of the incidents . Being a Nuclear Power Station, evacuating transmission lines are important and critical for safe evacuation of power. Such frequent tripping of evacuating transmission lines may lead to challenges in safe evacuation of generation at NAPP, which is a must run generating station. It is desirable that the transmission system remains intact and in healthy condition.
- iv. **220 KV Saharanpur(PG)-Shamli(UP) (UP) Ckt-1:** NRLDC representative raised concern over frequent incidents of faults and non-operation of A/R in line. UP representative informed that most of the faults occurred due to flashover of disc insulators, damaged insulators have been replaced. Regarding non-operation of A/R, it was informed that A/R is healthy and operational at Shamli(UP) end and it was successful during some of the transient fault cases. However, A/R is off at Saharanpur(PG) end. NRLDC requested POWERGRID to share the status of A/R operation at their end and ensure proper operation of A/R during single phase to earth fault. POWERGRID(NR-1) representative informed that there is no direction to OFF the A/R in line. However, they will review the status of A/R operation at Baghapat(PG) and shall ensure its proper operation in future.
- v. **400 KV Agra-Unnao (UP) Ckt-1:** NRLDC representative raised concern over frequent incidents of faults and non-operation of A/R during some incidents. UP representative informed that tripping on 3rd August was due to pole discrepancy and

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

on 28th A/R didn't operate at Unnao end. Fault was in Z-2 from Unnao end. During investigation, PLCC channel-1 was found unhealthy, and channel-2 was in OFF condition during the event. Channel-2 has been taken into service and status of healthiness of channel-1 will be confirmed.

vi. 400 KV Bhadla-Merta (RS) Ckt-1: NRLDC representative raised concern over frequent incidents of faults. Rajasthan representative informed that there was incident of tower collapse of this line during which ERS was installed. There was some design related defect in ERS due to which ph-ph faults were occurring. During 1st week of September, ERS has been removed and healthy tower has been installed. Further incidents was such fault not occurring now.

vii. 400 KV Dadri(NT)-Panipat(BB) (PG) Ckt-1: NRLDC representative raised concern over frequent incidents of faults and non-operation of A/R at Dadri(NTPC) end. Non submission of DR/EL from Dadri end was also highlighted. NTPC representative stated that they will look into the issue and share the updated on the same.

A.13.2 NRLDC representative emphasized that A/R (auto re-closer) issue was found in many of these tripping. He sensitized all the utilities to ensure healthiness/in service of A/R in 220 kV and above transmission lines in compliance to CEA Grid Standards. He further informed that most of the tripping are transient in nature but due to non-operation of A/R, it resulted into tripping of the transmission element thus reducing the reliability of the grid. All the utilities shall endeavour to keep auto re-closer in service and healthy condition of 220 kV and above voltage level transmission line. The issue of time syncing of DR/EL at many of the stations was highlighted, constituents were requested to ensure the time syncing of DR/EL. In addition, necessary actions also need to be taken to ensure the Right of Way and other operation & maintenance issues to minimize the frequent faults in the line. All utilities agreed for the same.

PSC forum reiterated that frequent outages of such elements affect the reliability and security of the grid. Members were requested to investigate such frequent outages and share the suitable remedial measures taken/being taken in this respect.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

b) Protection related issues in multiple elements tripping and status of remedial measures:

In some of the tripping incidents occurred during July-August 2024, there was some issues related to protection system. List of the such tripping incidents is attached as **Annexure-XVI**. Concerned utilities were requested to apprise the status of remedial actions to forum.

Discussion during the meeting:

i. Frequent tripping of 220 KV Khara(UP)-Saharanpur(PG) (UP) Ckt-1 during July24:

NRLDC representative stated that during 222nd OCC meeting UP intimated that static/electromechanical relays at Khara(UP) will be replaced by numerical relay. UP was requested to apprise forum about present status.

UP representative informed that new relay is available at site. Relay will be replaced during lean season as per the shutdown opportunity.

ii. Frequent tripping of 400 KV Bikaner-Bhadla (RS) Ckt-1 during July24:

NRLDC representative stated that during 222 OCC meeting Rajasthan intimated that a) issue in BCU at Bikaner end due to which command is not reaching to breaker. b) dead time setting in A/R, it seems that it is kept as 600msec which need to be ~1sec

Rajasthan representative informed that protection system is not healthy at both the stations and dead time is also as per standard (1sec).

iii. Multiple elements tripping event at Baghpat(PG) & Baghpat(UP):

NRLDC representative stated that A/R operation was not observed in 220 KV Baghpat(PG)-Baghpat(UP) (UP) Ckt-1 on B-N fault.

POWERGRID(NR-1) representative informed that there is no direction to OFF the A/R in line. However, they will review the status of A/R operation at Baghpat(PG) and shall ensure its proper operation in future.

iv. Multiple elements tripping event at Ziankote(J&K) & Amargarh(INDIGRID):

NRLDC representative asked J&K to apprise the forum about status of carrier communication and A/R scheme implementation at Ziankote end.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

J&K representative was not present in the meeting.

INDIGRID representative informed that PLCC is not installed at Ziankote end therefore, line is charged without carrier aided tripping since commissioning and Z-2 time delay is kept as instantaneous (0 sec).

MS NRPC instructed to prepare a dedicate agenda for discussion with J&K and conduct a separate meeting with J&K to discuss the issues and status of follow up action at J&K end.

v. Multiple elements tripping event at Patiala(PG): NRLDC representative asked POWERGRID(NR-2) to apprise the forum about status of replacement of bus bar relay.

POWERGRID(NR-2) representative informed that LOA was placed last year, material yet not received due to delay in supply. Continuous follow ups are being done for expeditious delivery of material. Thereafter, new bus bar protection will be implemented.

vi. Multiple elements tripping event at Mandaula(PG), Bawana(DTL) & Maharani Bagh(PG): NRLDC representative asked POWERGRID(NR-1) about the reason of tripping of 400 KV Mandala(PG)-Maharani Bagh(PG) (DTL) Ckt-1 from Mandaula end during the event without any fault on the line.

POWERGRID(NR-1) representative informed that issue was found in tripping initiation logic in Main-1 relay at Mandaula end which led to undesired tripping of line from Mandaula end. Same has been rectified.

vii. Multiple elements tripping event at Nara(UP): NRLDC representative asked UP to share the status of work related to relay communication cables replacement of Muzaffarnagar & Jansath Ckt bay at Nara(UP) S/s.

UP representative informed that earlier assumed reason was wrong. Actual issue identified is that new distance protection relays were installed in Roorkee, Jansath & Muzaffarnagar line. During this work, tripping of these bays through bus bar was not completely configured (96 relay). Due to this, on LBB operation of Matore bay, bus bar protection initiated tripping command however aforementioned three lines didn't trip and later tripped on remote end Z-2/Z-3 protection operation. Now, this

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

issue has been resolved and recent operation of bus bar protection at Nara(UP) on 10th September was correct.

viii. Multiple elements tripping event at Vishnuparyag HEP: NRLDC representative asked UP to share the status of remedial action taken w.r.t. O/C protection applied on bus coupler at Vishnuprayag.

UP representative informed that Vishnuprayag HEP kept O/C protection setting due to safety concern. However, now they have increased the O/C protection setting at bus coupler from 2*In to 6*In.

ix. Multiple elements tripping event at Bawana(DV), Mundka (DV) & Maharani-bagh(PG): NRLDC representative asked DTL about the status of remedial action taken for issue of overreaching of distance relays at Mundka(DTL) end.

DTL representative informed that there was issue in blinder setting of Z-2 in Main-2 relay (D60) at Mundka end. Necessary changes in PSL of relay has been done.

c) Analysis of the tripping events occurred during July-2024 to August-2024 and status of remedial action taken:

The list of major tripping events occurred during July-2024 to August-2024 is attached as **Annexure-XVII**. Concerned constituents/utilities were requested to share the detailed analysis of the tripping elements along with status of remedial action taken/to be taken.

A.13.3 As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event and as per IEGC clause 37.2 (e), the user shall submit a detailed report in the case of grid disturbance or grid incidence within one (1) week of the occurrence of event to RLDC and RPC

Tripping Events

A. Multiple elements tripping at 400/220kV Akal(RS) 06th July 2024, 05:26 hrs

1. Discussion during the meeting:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM**a. Brief of the event shared by NRLDC representative based on detail available is as follows:**

- 400/220kV Akal(RS) has one and half breaker scheme at 400kV level and double main and transfer bus scheme at 220kV level.
- During antecedent condition, incoming power at Akal(RS) S/s through 220 KV Akal-Akal(Suzlon) (RS) D/C and 220 KV Akal-Mulana (RS) Ckt were approx. 235 MW and 125 MW respectively.
- As reported, at 05:26 hrs, R-phase conductor of 220 KV Akal-Akal(Suzlon) (RS) ckt-2 broke at a distance of approx. 160m from Akal(RS) S/s which caused R-N phase to earth fault and subsequently 220 KV
- Akal-Akal(Suzlon) (RS) ckt-2 tripped on zone-1 distance protection from Akal(RS) end.
- As per PMU at ASP1(IP), R-Y phase to phase fault followed by R-N phase to earth fault with fault clearance time of 80msec and 80msec respectively are observed.
- At the same time, 220 KV Akal-Akal(Suzlon) (RS) Ckt-1 and 220 KV Akal-Mulana (RS) Ckt also tripped from Akal(RS) end (Reason of tripping yet to be received).
- During this event, dip in Rajasthan wind generation of approx. 1800 MW is observed out of which approx. 1150 MW recovered within 10 minutes. (As per SCADA).
- As per SCADA, no change in demand is observed in Rajasthan control area.
- As per SCADA, change in Rajasthan wind generation of approx. 168MW is observed.
- Major observations:
 - Reason for tripping of 220 KV Akal-Akal(Suzlon) (RS) Ckt-1 and 220 KV Akal-Mulana (RS) Ckt need to be shared.
 - SCADA data was freeze during the event. Availability and healthiness of SCADA data need to be ensured.
 - DR/EL (.dat/.cfg file) of all tripped elements along with detailed tripping report and remedial action taken report need to be shared.
 - Trippings at Akal(RS) S/s are not recorded in SCADA SOE. Availability of SCADA SOE data needs to be ensured.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

b. Rajasthan representative and others informed the following:

- 220kV Akal-Suzlon D/C are on same tower (D/C tower). B-ph conductor of Suzlon ckt-2 snapped at distance approx. 400meter from Akal end, this fault converted into Y-B fault. Further after ~200msec, snapped conductor of Suzlon ckt-2 touched Suzlon ckt-1 also.
- Both 220kV Akal-Suzlon ckt-1&2 tripped from Akal end on distance protection operation in Z-1.
- 220kV Akal-Mulana ckt tripped on undervoltage protection from Mulana end.

NRLDC representative raised concern over non submission of DR/EL files due to which complete analysis of the event couldn't done. During the event, significant quantum of RE generation was affected therefore, complete analysis, findings of shortcomings and subsequent remedial actions are important to avoid such event in future. Issue of phase sequence was also highlighted (reported fault signature is not matching with PMU fault signature).

Forum's Recommendations:

- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*
- *Detailed analysis along with remedial action taken report need to be shared.*
- *Issue of mismatch in phase sequence need to be resolved.*

B. Multiple elements tripping at 400/220kV Bhadla(RS) on 30th July 2024, 11:38 hrs

1. Discussion during the meeting:

a. Brief of the event shared by NRLDC representative based on details available is as follows:

- 400/220kV Bhadla(RS) has double main and transfer bus arrangement at 220kV side.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- During antecedent condition, 220 kV Bhadla(RS)-Saurya Urja-2 and 220kV Bhadla(RS)-RSDCL I Ckt-2 were carrying approx. 242 MW & 128 MW respectively (reported data).
- As reported, at 11:38hrs, B-ph jumper of 220kV Bhadla(RS)-Saurya Urja Ckt-2 snapped from Main Bus at Bhadla(RS) which led to tripping of 220kV Bhadla(RS)-Saurya Urja Ckt-2.
- During the same time, 220 kV Bus sectionalizer-I (Bay no. 09) and 220 kV Bus Coupler-I (Bay no. 13) at Bhadla(RS) also tripped due to B-N phase to ground fault (As per PMU, Y-N fault; phase sequence issue is observed).
- Further as reported, 220kV Bhadla(RS)-RSDCL I Ckt-2 also tripped from RSDCL I end only due to LBB operation at the same time (exact reason of LBB operation yet to be shared).
- As per PMU at Bhadla(PG), Y-N phase to ground fault is observed with delayed fault clearing time of 160 ms.
- As per SCADA, change in solar generation of approx. 905MW is observed in Rajasthan control area.
- As reported by SLDC Rajasthan, approx. 370 MW of solar generation loss occurred in Rajasthan control area and there is total approx. 730 MW reduction in solar generation by RE plants connected at Bhadla(RS).
- Major observations:
 - Exact reason of LBB operation at RSDCL need to be shared.
 - Phase sequence issue need to be resolved at the earliest.
 - Tripping is not recorded in SCADA SOE. Availability of SCADA SOE data needs to be ensured.
 - DR/EL (.dat/.cfg file) along with tripping report need to be shared for each element from both the ends.
 - Remedial action taken report to be shared.

b. Rajasthan representative and others informed the following:

- Fault occurred due to snapping of bus post jumper of 220kV Bhadla-Saurya Urja ckt-2 at Bhadla end leading to bus fault on 220kV Bus B.
- Bus bar protection is not in service at 220kV Bhadla(RS). Commissioning work of the same is in process and it is getting delayed due to non-

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

availability of shutdown of bus sectionalizer. However, it will be expedited.

- As bus bar protection is not available, time graded overcurrent protection has been implemented on bus sectionalizer to isolate the faulty bus section and to avoid complete blackout of station.
- However, during this event, both bus sectionalise-1&2 opened due to delayed opening of bus sectionliser-1.
- To avoid such incident in future, plug setting of bus sectionalise-2 has been increased from 20% to 30%.
- Regarding reason of LBB operation at RSDCL, it was informed that analysis in this regard is yet to be done. DR files are not received yet from site.

NRLDC representative requested Rajasthan to identify the root cause of LBB operation at RSDCL. Incidents of LBB operation at RSDCL were reported in past also. Therefore, root cause behind this maloperation need to be identified and any shortcomings in protection system may be rectified. Issue of phase sequence was also highlighted (reported fault signature is not matching with PMU fault signature).

Forum's Recommendations:

- *Commissioning of Bus bar protection at 220kV bus at 400/220kV Bhadla(RS) need to be expedited.*
- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*
- *Detailed analysis along with remedial action taken report need to be shared.*
- *Issue of mismatch in phase sequence need to be resolved.*

C. Multiple elements tripping at 220kV Chinhat(UP) on 01st July 2024, 00:15 hrs

1. Discussion during the meeting:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM**a. Brief of the event shared by NRLDC representative based on detail available is as follows:**

- 220kV Chinhat(UP) has main and transfer bus scheme at 220kV level.
- During antecedent condition, incoming power at Chinhat(UP) was through 220kV Satrikh ckt (~100MW), Kursi Road ckt (~30MW) and Lucknow(PG) ckt (~80MW) and outgoing power was through 220kV Gomatinagar ckt (~30MW) and load at Chinhat(UP) S/s (~90MW). All 220kV lines and ICTs connected to 220kV main bus at Chinhat(UP) S/s. 220kV Chinhat-LMRC D/C is radial line from Chinhat(UP) S/s.
- As reported, at 00:15 hrs, LA of 220 KV Chinhat-Satrikh Road (UP) Ckt bay burst at Chinhat(UP) S/s which caused R-N phase to earth fault.
- On this fault 220kV lines from Chinhat(UP) to Satrikh Road (UP), Gomtinagar (UP), Kursi Road (UP) & Lucknow_1(PG) tripped (Reason of tripping and type of protection operated for all elements yet to receive).
- Due to these trippings at Chinhat(UP) S/s, 220kV Chinhat-LMRC D/C, 220/132kV ICT-1 & 2 became dead and blackout occurred at 220kV Chinhat(UP) S/s.
- As per PMU at Lucknow(PG), R-N phase to earth fault with delayed fault clearance of 440msec is observed (reason for delayed fault clearance yet to receive).
- As per SCADA, change in demand of approx. 195 MW in UP control area.
- Major observations:
 - Reason for delayed fault clearance need to be shared.
 - Type of protection operated in tripping of all elements need to be shared.
 - DR/EL (.dat/.cfg file) of all the tripped elements along with detailed tripping report need to be shared.
 - Remedial action taken report to be shared.

b. UP representative and others informed the following:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- Fault occurred on 220kV Chinhat-Satrikh Road line due to damage of R-ph LA at Chinhat end. Distance protection relay of the line got blocked due to initiation of Power Swing Blocking (PSB).
- Thereafter, fault cleared with the tripping of adjacent lines from remote end in Z-2.
- Distance relay of Satrikh Road line was found OKAY during testing. Double earthing also found in PT of this line at Chinhat end however this wouldn't have led to initiation of PSB. Issue related to earthing has been rectified.
- 220kV Bus coupler at Satrikh Road also tripped during this event due to sensitive overcurrent protection on bus coupler. This issue also has been rectified.
- In Gomati Nagar line, back up E/F protection operated at Chinhat end due to non-configuration of direction feature. Same has been incorporated.

NRLDC representative raised concern over non submission of DR/EL files and requested UP to share the DR/EL files w.r.t. this event.

Forum's Recommendations:

- *Proper operation of protection system needs to be ensured.*
- *Any issue in protection settings may be revised and corrected.*
- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*

D. Multiple elements tripping at 400/132kV Mau(UP) at 07th July 2024, 11:44 hrs

1. Discussion during the meeting:

a. Brief of the event shared by NRLDC representative based on detail available is as follows:

- 400/132kV Mau(UP) has double main and transfer bus scheme at 400kV level.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- During antecedent condition, 400 KV Azamgarh-Mau (UP) Ckt, 400 KV Mau(UP)-Baliala(PG) (PG) Ckt & 400/132 kV 200 MVA ICT-3 connected to 400kV bus-1 and 400kV Mau-Rasra (UP) ckt, 400/132/33kV 200MVA ICT-1 & 2 connected to 400kV bus-2. 400 KV Anpara_B(UPUN)-Mau(UP) (UP) Ckt was not in service during the event.
- As reported, at 11:44 hrs, B-phase CT of 400 KV Azamgarh-Mau (UP) Ckt burst which caused bus fault on 400kV bus-1 which led to bus bar protection operation on 400kV bus-1 at Mau(UP) S/s.
- As per PMU at Azamgarh(UP), B-N phase to earth fault converted into Y-B phase to phase fault with delayed fault clearance time of 560ms is observed
- Due to bus bar protection operation, all elements connected to 400kV bus-1 (400kV Azamgarh(UP) ckt, Baliala(PG) ckt and 400/132 kV 200 MVA ICT-3) tripped at 400kV Mau(UP) S/s.
- As per SCADA, change in demand of approx. 60 MW in UP control area.
- Major observations:
 - Nature of fault and reason for delayed fault clearance need to be shared.
 - Reason for delayed operation of bus bar protection and protection settings at Mau(UP) S/s need to be shared.
 - DR/EL (.dat/.cfg file) of all the tripped elements along with detailed tripping report need to be shared.
 - Remedial action taken report to be shared.

b. UP representative and others informed the following:

- Fault occurred on 400kV Mau-Azamgarh line (connected at 400kV Bus-1) due to damage of B-ph CT at Mau end.
- Distance protection at Mau end sensed fault in Z-1 with ~25kA and initiated tripping. However, B-ph pole got stuck and CB failed to open.
- LBB should have operated instantaneously however due to lack of sufficient current it didn't operate.
- Further after ~280msec, fault converted into Y-B phase to phase fault. With the inclusion of Y-ph, sufficient current received in LBB CT core

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

and after further ~200msec, LBB initiated tripping to all the elements connected at 400kV bus-1.

NRLDC representative raised concern over no submission of DR/EL files and requested UP to share the DR/EL files w.r.t. this event.

Forum's Recommendations:

- *Proper operation of protection system needs to be ensured.*
- *Routine maintenance of circuit breakers and their associated equipment's need to be done to avoid frequent incidents of breaker failure.*
- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*

E. Multiple elements tripping at 400/220kV Lucknow(UP) on 14th July 2024, 15:53 hrs

1. Discussion during the meeting:

a. Brief of the event shared by NRLDC representative based on detail available is as follows:

- 400/220kV Lucknow(UP) has double main and transfer bus scheme at 220kV level.
- During antecedent condition, 400/220kV 500 MVA ICT-1 & 2, 220/132kV 200 MVA ICT-1 & 2, 220kV Lucknow-Hardoi Road (UP) ckt & 220kV Lucknow-Unnao (UP) ckt were connected to 220kV bus-1 and
- 220kV lines from Lucknow(UP) to Bachrawan, Gomatinagar, Kanpur Road & 220/132kV 200MVA ICT-1 & 2 connected to 220kV bus-2 at 220kV Lucknow(UP) S/s. 220kV Lucknow-Kanpur Road (UP) ckt was not in service during the event.
- As reported, at 15:53 hrs, R-N phase to earth fault occurred on 220kV bus-1 which led to tripping of all elements connected to 220kV bus-1 at 220kV Lucknow(UP). Bus bar protection failed to operate and 400/220

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

kV 500 MVA ICT-1 & 2 tripped on LBB protection (Type of protection operated in tripping of other elements is yet to receive)

- As per PMU at Lucknow(PG), R-N phase to earth fault with delayed fault clearance time of 880ms is observed (Reason for delayed fault clearance is yet to receive).
- As per SCADA, change in demand of approx. 280 MW in UP control area. However, approx. 250 MW load loss in UP control area as per SLDC-UP.
- Major observations:
 - Reason of fault and reason for delayed fault clearance at 220kV Lucknow(UP) S/s need to be shared.
 - Reason for failed operation of bus bar protection at 220kV Lucknow(UP) S/s need to be shared.
 - Relay flag details and type of protection operated for all tripped elements need to be shared.
 - DR/EL (.dat/.cfg file) of all the tripped elements along with detailed tripping report need to be shared.
 - Remedial action taken report to be shared.

b. UP representative and others informed the following:

- 220kV Bus A & B were running in split mode. Fault on 220kV Bus-A occurred due to conductor drop by bird on Bus-A.
- Bus bar protection didn't operate as it was in blocked condition due to CT supervision alarm which was already persisting due to already existing fault in CT circuit.
- During inspection it was found that CT ratio configuration in bus bar relay of 02 number of bays were incorrect. Actual CT ration was 800:1 and in bus bar relay it was configured as 1000:1. This issue has been rectified now.
- Reason of tripping of 400/220kV ICT on LBB protection is not identified yet.
- As a remedial measure, process of replacing bus bar relay with numerical bus bar has been started.

Forum's Recommendations:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- *Healthiness of protection system need to be ensured. Proper operation of protection system needs to be ensured.*
- *Replacement of bus bar relay with numerical bus bar relay need to be expedited.*
- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*

F. Multiple elements tripping at 400/220kV Muzaffarnagar(UP) on 21st August 2024, 09:02 hrs

1. Discussion during the meeting:

a. Brief of the event shared by NRLDC representative based on detail available is as follows:

- During antecedent condition, 400/220kV 315 MVA ICT-1, 400/220kV 500 MVA ICT-4, 220kV Muzaffarnagar-Shamli (UP) Ckt, 220kV Muzaffarnagar-Khatauli (UP) Ckt, 220kV Muzaffarnagar-Badhni kalan (UP) Ckt & 220/132kV 160MVA ICT-4 were connected to 220kV bus-1 and 400/220 kV 315 MVA ICT-2, 400/220 kV 315 MVA ICT-3, 220kV Muzaffarnagar-Charla (UP) Ckt, 220kV Muzaffarnagar-Jansath (UP) Ckt & 220/132kV 160MVA ICT-5 were connected to 220kV bus-2 at Muzaffarnagar(UP) S/s. Bus coupler of 220kV bus-1 and 220kV bus-2 was in ON condition and 220kV Muzaffarnagar-Nara (UP) Ckt was not in service (under shutdown) during the tripping event.
- As reported, at 09:02 hrs, R-N phase to earth fault occurred on 220kV Muzaffarnagar-Badhni kalan (UP) Ckt with fault distance of 3.8km from Muzaffarnagar(UP) end and 20.4km from Badhni kalan(UP) end. Fault was sensed in zone-1 from both ends.
- On this fault 220kV Muzaffarnagar-Badhni kalan (UP) Ckt tripped from Badhni kalan end on zone-1 distance protection on R-N fault. During fault clearing process at Muzaffarnagar(UP) end, R-phase CB interrupting chamber got damaged which resulted into continuation of sparking between R phase male contact and R phase dropper wire of

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

breaker. The circuit breaker operated mechanically (auxiliary contacts operated properly) and thus breaker status reflected as OPEN.

- As breaker didn't open completely (sparking between R phase male contact and R phase dropper wire of breaker was still there), fault was not cleared yet. Due to continuous fault feeding 400/220kV 315MVA ICT-1 & 2 and 400/220kV 500 MVA ICT-4 tripped on directional earth fault protection and 400/220kV 315 MVA ICT-3 tripped on back up impedance protection. 220 kV Charla line, 220 kV Jansath line and 220 kV shamli line tripped from remote ends on zone-3 distance protection (it is confirmed from respective DRs also).
- Ideally, this fault would have been cleared by LBB protection of Badhni kalan bay, but as CB status changed from ON to OFF due to proper operation of breaker auxiliary contacts, LBB initiation got reset.
- Further, as reported, bus bar protection of 220kV bus-1 at Muzaffarnagar(UP) also operated after 1 second of fault starting time due to persisting differential current.
- As per DR of bus bar protection at Muzaffarnagar(UP), busbar protection operated on 220kV bus-1 after 1.05 second of fault starting time. On this, all remaining elements also tripped which were connected to 220kV bus-1 i.e. 220kV Muzaffarnagar-Khatauli (UP) Ckt, 220/132kV 160MVA ICT-4 and bus coupler of 220kV bus-1 and bus-2.
- As per PMU at Meerut(PG), R-N phase to earth fault with delayed fault clearing time of 1080 msec is observed.
- As per SCADA, load loss of approx. 290 MW in UP control area. However, SLDC-UP reported load loss of 127 MW in UP control area.
- Major observations:
 - Logic of identification of breaker ON & OFF status may be reviewed if needed.
 - Reason for bus bar protection operation need to be shared.
 - Remedial action taken report to be shared.

b. UP representative and others informed the following:

- R-N Fault occurred on 220kV Badhai kalan line due to snapping of OPGW.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- On this fault, distance protection of this line at Muzaffarnagar end initiated tripping command. Auxiliary contact of the R-ph pole of CB opened but mechanically it didn't open completely, and sparking was persisting.
- In bus bar protection (SEL make relay) logic for bay assignment is based on the AND logic on 52A (braker auxiliary contact status) & 89A (isolator status).
- During this event, auxiliary contact of the R-ph pole of CB opened leading to isolation of Badhai Kalan bay from Bus-1 in bus bar logic. Due to this, LBB protection also not operated.
- Now, in actual, fault was of through fault nature but due to isolation of this bay from bus bar logic, differential current reading of ~8kA was coming in bus bar relay.
- However, operation of bus bar protection got delayed by 1sec. As fault was of through fault nature and there is logic to increase the slope (I diff pick up) for 1sec to avoid undesired tripping due to CT saturation during through fault cases. In this case it increased from 60% to 80%.
- After 1sec, when slope again reduced back to 60%, on the already existing reading of bus bar differential of ~8kA, bus bar protection initiated tripping command, and all the elements connected to 220kV Bus-1 tripped.
- To avoid such event in future, it is proposed to exclude the status of 52A (braker auxiliary contact status) in bay assignment logic. Isolator status may also serve the purpose of proper operation of bus bar protection.

Forum's Recommendations:

- *Healthiness and proper operation of protection system need to be ensured.*
- *Necessary changes in logic of bay assignment may be done to ensure reliable operation of LBB and bus bar protection.*

G. Multiple elements tripping at 220kV Palli(HR) on 16th July 2024, 22:10 hrs

1. Discussion during the meeting:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM**a. Brief of the event shared by NRLDC representative based on detail available is as follows:**

- During antecedent condition, 220 kV Palli S/S importing load from 220 KV Samaypur (BB)-Palli (HV) (HVPNL) Ckt-1 & Ckt-2, 220 KV Badshahpur (HV)-Palli (HV) (HVPNL) Ckt-1 & ckt-2 and 220 KV Sector-56 (Gurgaon) -Palli (HV) (HVPNL) Ckt-1 & Ckt-2 and feeding that load to 220 KV Palla (HV) (Sec-46) & 220 KV Palli (2*100MVA+1*160MVA) S/S.
- As reported, to manage the line loading on sector-72 Gurgaon ckt, 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-1 was opened at 22:10 hrs on the instruction of SLDC-Haryana. This led to sparking on the 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-2 at Palli S/S end.
- At the same time, busbar protection operated at 220kV Palli(HV) due to which all the elements connected to 220kV Bus-1 and 2 at Palli(HV) tripped and complete blackout occurred at Palli(HV) S/s.
- As per PMU, R-Y phase to phase fault with delayed fault clearing time of 880 ms was observed.
- As per SCADA, change in demand of approx. 600 MW and 980 MW in Delhi and Haryana control area respectively were observed. However, as reported, approx. 400 MW load loss occurred at Palli & Sec-46 (Faridabad). Rest of the change in demand is suspected due to stalling of induction motor.
- Major observations:
 - Exact reason, location and nature of fault need to be shared.
 - Reason of delayed clearance of fault need to be shared.
 - Reason of tripping of multiple elements.
 - Feeder-wise load loss details need to be shared.
 - SCADA data issue was observed at 220/66kV Palli(HV) during the event. Availability and healthiness of SCADA data need to be ensured.
 - DR/EL (.dat/.cfg file) of all tripped elements need to be shared.
 - Remedial action taken report need to be shared.

b. Haryana representatives and others informed the following:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- Ph-Ph fault occurred due to snapping of R-ph jumper of 220kV Palli-Gurgaon Sec 56 ckt-2 which fall on Y-ph.
- On this fault, CB of Gurgaon Sec 56 end opened however, breaker of Palli end failed to open. LBB protection also didn't operate, and fault persisted.
- After few msec, conductor fall on jack bus and created bus fault. On this, bus bar protection operated and due to bus tied condition (incorrect isolator status) elements connected to both the 220kV bus at Palli tripped.
- Overhauling of CB and routing maintenance has been recommended to the site.
- On query of sequence of event, it was informed that time is not synced in DR & EL therefore sequence of event couldn't be ascertained.
- On non availability of SCADA data, it was informed that SCADA system at Palli S/s is not healthy.

NRLDC representative requested to resolve following issues:

- Healthiness of SCADA system and availability of SCADA data during grid event.
- Time sync issue of recording instrument.
- Correct isolator status needs to be ensured.

Forum's Recommendations:

- *Healthiness and proper operation of protection system need to be ensured.*
- *Time sync and standardisation of recording instrument (DR/EL) need to be ensured.*
- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*

H. Multiple elements tripping at 220kV Khodri(Utt) on 19th July 2024 at 21:31hrs:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM**1. Discussion during the meeting:****c. Brief of the event shared by NRLDC representative based on detail available is as follows:**

- During antecedent condition, all the four 30MW units of Khodri and 60 MW units of Chhibro were running and total active power generation of Khodri and Chhibro was approx. 89 MW and 196 MW (as per SCADA). Total generation of Chhibro was evacuating through 220 KV Khodri-Chhibro (UK) Ckt-1 & 2.
- As reported, at 21:31 hrs, while taking out 30MW Khodri Unit-2, B-phase pole of CB of Unit-2 did not open. This led to LBB protection operation which further resulted in tripping of all the elements connected to both the buses at 220kV Khodri(UK) and complete blackout occurred at 220kV Khodri(UK) S/s.
- Due to tripping of 220 KV Khodri-Chhibro (UK) Ckt-1 & 2, 60 MW Chhibro Unit-1, 2, 3 & 4 also tripped due to loss of evacuation path and complete blackout occurred at 220kV Chhibro(UK) S/s.
- As per PMU, no fault was observed in the system.
- As per SCADA, change in demand and generation of approx. 30 MW and 300 MW respectively in Uttarakhand control area were observed.
- As remedial action taken, over hauling & testing of generator CB has been performed and found satisfactory.
- Major observations:
 - Due to LBB operation, only the elements connected to the same bus as Unit-2 should have tripped. Exact reason of ripping of the elements connected to the other bus at Khodri need to be shared.
 - Wrong status of CB at Khodri and Chhibro was observed during the event. Availability and healthiness of SCADA data need to be ensured.
 - DR/EL (.dat/.cfg file) of all tripped elements need to be shared.

d. Uttarakhand representatives and others informed the following:

- During shutdown of Unit-2 at Khodri HEP, CB of Unit-2 (connected at 220kV Bus-1) failed to open which led to LBB operation.
- During pole stuck situation, reverse power fed to Unit-3 (connected at another 220kV bus-2) at Khodri HEP. Due to this unbalance current,

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

standby earth fault (SEF) protection operated in Unit-3 and initiated tripping. However, CB of Unit-3 also failed to open and LBB of Unit-3 bay also operated.

- Operation of bus bar protection of both the bus led to blackout of the Khodri S/s.
- NRLDC representative asked the reason of SEF protection without any earth fault in system and the delay of LBB protection.
- On this query, it was informed that reason of SEF relay will be reviewed and delay of LBB was 150msec which now revised to 200msec.
- Regarding unavailability of SCADA data if CB status, it was informed that there are issues related to CMR relay. Old breakers will also be replaced, their RMU is in pipeline

NRLDC representative raised concern over incorrect SCADA data and improper operation of protection system. Being an generating station which operate in tandem with Chibro HEP, Uttarakhand was requested to review the protection system to ensure the reliable operation of power station.

Forum's Recommendations:

- *Review of protection system need to be done to avoid such undesired operation and proper operation of protection system need to be ensured.*
- *Proper maintenance and healthiness of CB also need to be ensured.*
- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*

I. Multiple elements tripping at 220kV Shahbad(HR) and 220kV Rajokheri(HR) on 26th August 2024, 22:58 hrs

1. Discussion during the meeting:

- a. **Brief of the event shared by NRLDC representative based on detail available is as follows:**

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- 220kV Rajokheri(HV) & 220kV Shahbad(HV) S/s have double main bus arrangement at 220kV side.
- During antecedent condition, incoming power at Rajokheri(HV) S/s through 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) D/C was approx. 115 MW and outgoing power from Rajokheri(HV) through 220 KV Shahbad-Rajokheri(HV)(HVPNL) D/C was approx. 90 MW. Loading of 220 KV Shahbad-Joria(HV)(HVPNL) D/C and 220 KV Shahbad-Durla(HV)(HVPNL) D/C were approx. 100 MW and 75 MW feeding to Shahbad(HV) and Durla(HV) respectively.
- As reported, at 22:58 hrs, due to inclement weather conditions, Y-B phase to phase occurred on 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1 & 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-1.
- As reported, 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) D/C tripped only from Abdullapur(PG) end not from Rajokheri(HV) end. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1 tripped on zone-1 distance protection on Y-B-G double phase to ground fault with fault distance of 29km and fault current of $I_y \sim 5.79\text{kA}$ & $I_b \sim 5.39\text{kA}$ from Rajokheri(HV) end. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-2 & 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-2 tripped on direction earth fault from Rajokheri(HV) end. 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-1 tripped on zone-3 distance protection on Y-B phase to phase fault from Rajokheri(HV) end (details regarding trippings at Shahbad(HV) S/s is yet to be received).
- As per PMU at Abdullapur(PG), Y-B phase to phase fault converted into R-Y-B three phase fault with delayed fault clearing time of 2040msec is observed.
- Due to tripping of all 220kV lines at Rajokheri(HV) & Shahbad(HV), both sub-stations lost their connectivity from Grid which led to blackout of 220kV Rajokheri(HV) S/s & 220kV Shahbad(HV) S/s.
- As per SCADA, change in demand of approx. 350 MW in Haryana control area.
- Major observations:
 - Exact location of fault seen by distance protection relay at Rajokheri end at 22:58:19:800 hrs ?

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- Protection operation at 22:58:19:800 hrs at Rajokheri end on Y-B fault? Delayed clearance of fault is observed.
- DR/EL of all the tripped lines at Rajokheri end not received. Same need to be submitted.
- As reported, Bus bar differential relay maloperated at 220kV Shahbad(HR) due to issue in isolator status. Exact details of issues need to be shared.
- DR of bus bar relay need to be shared.
- Remedial action taken report to be shared.

b. Haryana representative and others informed the following:

- Haryana representative informed that fault occurred on 220kV Shahbad-Rajokheri ckt. CB opened at Rajokheri end but failed to open at Shahbad end which cleared with the LBB operation.
- NRLDC representative stated that based on PMU plot of fault signature (phase voltage), delayed fault clearance of ~2sec is observed and no recovery of voltage is observed at time delay of LBB. Hence, LBB operation can't be verified.
- POWERGRID (NR-2) representative informed that Abdullapur end distance protection of 220kV Abdullapur-Rajokheri ckt-1 sensed Y-B fault in Z-1 (1.3km) with ~28kA fault current. CB at Abdullapur end opened however there was no operation at Rajokheri end.
- Further, 220kV Abdullapur-Rajokheri ckt-2 tripped from Abdullapur end in Z-2. During patrolling also, burnt tree signature was observed at fault location.

NRLDC requested Haryana representative to analyse the event in detail and submit revised detailed tripping report along with details of action taken to avoid such event in future.

Haryana representative agreed to share the revised details analysis of the event.

Forum's Recommendations:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- *Review of protection system need to be done to avoid such undesired operation and proper operation of protection system need to be ensured.*
- *Proper maintenance and healthiness of CB also need to be ensured.*
- *Timely submission of disturbance recorder (DR) and event logger (EL) files need to be ensured. As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event.*

J. Multiple elements tripping at 220kV Barn(J&K) on 02th August 2024, 15:03 hrs

1. Discussion during the meeting:

a. Brief of the event shared by NRLDC representative based on detail available is as follows:

- As reported, at 15:03hrs, 220/132kV 160MVA ICT-1, 132kV Barn-Canal (JK) D/C tripped at Barn(JK) S/s on Y-B phase to phase fault which occurred on 132kV Barn-Canal (JK) D/C.
- As reported, due to tripping of ICT-1, the complete load shifted on 220/132kV 160MVA ICT-2 & 3 which led to tripping of 220/132kV 160MVA ICT-2 & 3 on overloading at Barn(JK) S/s.
- As per PMU at Kishenpur(PG), Y-B phase to phase fault with fault clearing time of 120ms is observed.
- As per SCADA, load loss of approx. 345MW occurred in J&K control area.
- Major observations:
 - Exact reason and location of fault need to be shared.
 - Details of protection operated during the tripping event need to be shared.
 - Loading of all three ICTs just before the tripping event need to be shared.
 - Overloading protection settings of all three ICTs at Barn(JK) need to be shared.
 - DR/EL (.dat/.cfg file) of all the tripped elements along with tripping report of the event need to be shared.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- SLD of 220/132kV Barn(JK) S/s need to be shared.
- Remedial action taken report to be shared.

J&K representatives were not present in the meeting due to which event couldn't be discussed.

Forum's Recommendations:

- *A separate meeting with J&K shall be conducted to discuss the issues and status of follow up action at J&K end. A dedicated agenda for discussion with J&K may be prepared in this regard.*

A.13.4 Tripping analysis details of all the tripping discussed during 52 PSC meeting is attached as **Annexure-XVIII**.

d) Frequent operation of breaker failure protection and necessary remedial actions

NRLDC representative highlighted that in many of the events, LBB operations was reported due to failure of breaker opening on protection operation. It shows that there are issues related circuit breaker healthiness. Following multiple elements tripping occurred due to non-opening of breaker and LBB operation:

- i) Multiple elements tripping at 400/220kV Lucknow(UP) on 14th July
- ii) Multiple elements tripping at 220kV Khodri(Utt) on 19th July
- iii) Multiple elements tripping at 400/220kV Patiala(PG) on 19th July
- iv) Multiple elements tripping at 220kV Nara(UP) on 11th August
- v) Multiple elements tripping at 400/220kV Muzaffarnagar(UP) on 21st August
- vi) Multiple elements tripping at 220kV Laltokalan(PS) on 22nd August
- vii) Multiple elements tripping at 400/220kV Unnao(UP) on 17th September

In view of above, constituents were requested to ensure proper maintenance of circuit breakers and their associated equipment's.

UP representative stated that timely instructions are being given at sites for routine maintenance of circuit breakers and their associated equipment's. However, in view of increase in such incidents we will again instruct sites to be vigilant in this regard.

Decision taken by Forum:

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

Forum requested all the members to ensure timely maintenance of circuit breakers and their associated equipment's so that such incidents of breaker failure during switching may be minimised and undesired events of multiple elements tripping may be avoided.

A.14. Corrective action for healthiness of 500kV Mundra-Mahindergarh SPS (agenda by NRLDC)

- A.14.1 NRLDC representative apprised that on 17th May 2024 on outage of both pole (carrying total ~1500MW), SPS of 500kV HVDC Mundra-Mahindergarh inter regional link didn't operate. This issue was discussed during 51st PSC meeting and ADANI was requested to share the details w.r.t. SPS operation during the meeting.
- A.14.2 Further, NRLDC in coordination with NLDC conducted an online discussion meeting with concerned stakeholders (SLDCs, ADANI, POWERGRID) on 12th August 2024, for further remedial actions required to make this SPS healthy.
- A.14.3 Following actions were decided during the meeting:
- i. POWERGRID, ADANI and concerned states were requested to identify the issue in communication links and take expeditious actions to make the all the communication link healthy. POWERGRID & ADANI shall review the healthiness of SPS system at different load centres and communication path between them in coordination with the SLDCs.
 - ii. States were requested to go through the details of load feeders mentioned in SPS document and share the changes / modifications as per present scenario and share the inputs w.r.t. unavailability in identified load feeders and load shedding. SLDCs shall share the revised updated feeder details (radial) along with expected average/peak load relief through respective feeders.
 - iii. SLDCs in coordination with their transmission and protection team shall share the status and healthiness of existing SPS system along with details of availability of communication path for incorporation of proposed revised/additional feeders.
- A.14.4 Load end details received from UP, Haryana, Rajasthan & Delhi. Details are attached as **Annexure-XIX**. Details yet to be received from Punjab.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- A.14.5 Regarding communication network and hardware system, ADANI has submitted the status of their healthiness. As per details submitted, counter status was found OFF at Alwar, Ratangarh, Gobindgarh, Malerkotla, Bamnuali, Shamli and Dhanonda.
- A.14.6 NRLDC representative requested Punjab to share their input with respect load details at the earliest. Further POWERGRID and ADANI were requested to share the status of remedial action taken / planned to be taken. Desired remedial actions need to be expedited.
- A.14.7 Delhi representative informed that SPS system at Bamnuali(DTL) is in OFF condition.
- A.14.8 ADANI representative informed that SPS & communication link is healthy at Mahindergarh and Bhiwani (PG) S/s. Healthiness at further linked stations need to be ensured for complete healthiness of SPS system.
- A.14.9 NRLDC representative requested ADANI to confirm the healthiness of SPS and communication system of their control area / ownership. Further, ADANI shall coordinate with POWERGRID and other stations to check issues at load stations. ADANI agreed for the same.

Decision taken by Forum:

Forum requested ADANI and concerned constituents to take necessary remedial actions and make the SPS link healthy and operational.

A.15. Implementation and updation of Protection setting Database (agenda by NRPC Secretariat)

- A.15.1 AEE (P), NRPC apprised that as per clause 14(3) of IEGC, 2023

RPCs shall:

(a) maintain a centralized database and update the same on periodic basis in respect of their respective region containing details of relay settings for grid elements connected to 220 kV and above (132 kV and above in NER). RLDCs shall also maintain such database

(b)

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

(c) provide the database access to CTU and NLDC and to all users, RLDC, SLDCs, and STUs of the respective regions. The database shall have different access rights for different users.

A.15.2 Further as per clause 14(4) of IEGC, 2023:

(4) The changes in the network and protection settings of grid elements connected to 220kV and above (132 kV and above in NER) shall be informed to RPCs by CTU and STUs, as the case may be.

A.15.3 In view of above, all the utilities have to submit the protection settings of their elements connected to 220kV and above. Further, the revisions in the settings need to update in the database.

A.15.4 However, reporting of protection settings is not regularised by utilities. In view of above, it was requested that all utilities may submit the protection settings of their elements connected to 220kV and above. Revision of settings may also be intimated in order to update the protection setting database.

A.15.5 MS, NRPC commented that NERPC, ERPC and SRPC have already got implemented the protection setting related database portal. NRPC and WRPC will also implement the same in pursuance of the IEGC 2023. Due to lack of PSDF fund, this could not be implemented as of now.

A.15.6 He stated that utilities may send the settings in excel format till the portal gets implemented.

A.15.7 EE (P), NRPC highlighted that after the implementation of the setting database, this process of setting submission will be smoothening and streamlined

Decision taken by Forum:

Forum directed all utilities to report the protection settings of their elements connected to 220kV and above along with revision of the settings if any.

A.16. Review and uniformity of df/dt (ROCOF) protection philosophy in Northern Region (agenda by NLDC)

A.16.1 NRLDC representative apprised that multiple incidents of load shedding on df/dt (ROCOF) protection operation have been reported during recent past. Major

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

operations were reported from Punjab control area. Delhi, Rajasthan & UP have also reported load shedding on df/dt operation during some of the incidents. Incidents during which df/dt operation have reported is attached as **Annexure-XX**.

A.16.2 In view of frequent incidents of tripping of distribution feeders on df/dt operation, analysis and review of df/dt operation is necessary. Communication has already been sent to SLDCs via mail to provide details of stage wise quantum of load relief on df/dt operation and protection setting adopted (average cycle, time delay etc.).

Name of State	df/dt settings (average cycles considered, time delay etc)	Maximum quantum of relief (MW)		
		Stage-1	Stage-2	Stage-3

A.16.3 NRLDC representative also highlighted that df/dt protection is not uniformly implemented at all India level. As intimated df/dt protection is not implemented in Eastern region and setting is different in Southern Region. Therefore, review of ROCOF protection need to be done to ensure its uniformity and its proper operation. In this regard members were requested to share their inputs so that further follow up discussion can be done to ensure the uniform df/dt protection setting in Northern Region.

A.16.4 SLDCs were requested to share the adopted philosophy of df/dt protection and confirm whether uniform philosophy has been adopted throughout the state or not.

A.16.5 Details have been received from Haryana, UP & Rajasthan and partial detail received from Delhi & Punjab. All the constituents were requested to share the setting details along with quantum of load mapped in respective df/dt protection stage.

A.16.6 UP representative informed that most of df/dt relays in their control area is Siemens make 7SJ relay in which this df/dt setting is implemented in extra functions and value of average cycle, validation etc. can't be ascertained. UP was requested to consult with the Siemens in this regard.

A.16.7 Rajasthan representative asked whether mapped feeder can be revised as some of the mapped feeders have become essential (industrial/essential load). NRLDC representative stated that it can be done with the intimation to the NRPC & NRLDC.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- A.16.8 NRLDC representative stated that further review of df/dt protection setting also need to be done to ensure its uniformity and to avoid undesired operation and load loss.
- A.16.9 NRLDC requested all the members to ensure the DR triggering in case of tripping of feeders on df/dt. It would be helpful in analysis of the event.

Decision taken by Forum:

Forum requested all the states to share the details related to df/dt protection in their control area. Based on those details, further discussion would be done in next PSC meeting to review the ROCOF (df/dt) protection and ensure its uniformity.

A.17. Provisional protection clearance during FTC in July-August-September 2024 (agenda by NRLDC)

- A.17.1 NRLDC representative apprised that Provisional protection clearance during FTC in July-August-September 2024 allowed by NRLDC is attached as **Annexure-XXI**. As per the approved protection setting procedure, concerned utilities need to send the agenda for Protection Sub-Committee meeting to get the final approval of its protection settings provisionally approved in FTC or any revision done in the settings.
- A.17.2 MS, NRPC highlighted that all concerned utilities may ensure the final approval of protection settings of their elements and send the agenda in the upcoming Protection Sub-Committee after obtaining provisional approval from NRLDC/SLDC as the case applicable.

Decision taken by Forum:

Forum requested all the concerned utilities to send the agenda items for final approval of the Protection settings of their elements.

A.18. Recommendations of the committee to analyse the grid event happened at 13:53 hrs on 17th June 2024 due to tripping of HVDC Champa-Kurukshetra (agenda by NRPC Secretariat)

- A.18.1 AEE (P), NRPC apprised that on 17th June 2024, a grid event occurred at 13:53 hours in the Northern Region, leading to a substantial load reduction of approximately

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

16.5 GW. This event started with the tripping of both bipoles of the +/-800 kV HVDC Champa (WR) – Kurukshetra (NR) link, which was transferring 4500 MW of power from the Western Region (WR) to the Northern Region (NR). The tripping of this HVDC link triggered a series of events. There was a sudden voltage drop across the stations in the Northern region which resulted in a significant load drop of around 16.5 GW in the Northern region. There was simultaneous reduction of around 2800 MW of RE-based generation in the Rajasthan RE complex. There was also trippings of conventional generating units leading to a generation loss of 3909 MW at the all-India level. The significantly higher load loss resulted in the rise in frequency of the Indian power system from 50.03 Hz to 50.68 Hz. The load drop resulted in a rise in the voltages of stations in the Northern region. This high voltage resulted in the tripping of 18 nos. of EHVAC lines in the Northern Region on over-voltage protection. The power system was normalised after the revival of all the poles of HVDC Champa-Kurukshetra by 15:51 Hrs.

A.18.2 Further, he added that Ministry of Power vide its order no. 6/3/2024-Trans dated 25.06.2024 constituted a Committee under the Chairmanship of Member (GO&D), CEA to analyse the above-mentioned issues during which about 16.5 GW of consumer load in Northern Region got interrupted for a brief period. The composition of the Committee is given as under:

- (i) Member (GO&D), CEA Chairman
- (ii) Director (SO), GRID-INDIA Member
- (iii) Deputy Chief Operating Officer, CTUIL Member
- (iv) Executive Director, NTAMC (POWERGRID) Member
- (v) Professor, Electrical Engineering, IIT Delhi Member
- (vi) Member Secretary, NRPC Member Convener

A.18.3 Accordingly, the Committee conducted five meetings and detailed analysis of the grid event was carried out by teams of CEA, IIT-Delhi, NRPC, NLDC, NRLDC, POWERGRID, SLDC Delhi & DISCOMs of Northern Region States and the Report was finalized and submitted its report to MoP on 24.7.2024.

A.18.4 The committee has found some major observations, the brief of which are as below-

- (i) **Outage of all four poles of HVDC Champa - Kurukshetra link (N-4 scenario)**- There was tripping of +/-800 kV HVDC Champa-Kurukshetra link (4500 MW) triggered load loss event. Localized storm caused jumper swing and flashover. It Redundancy in DMR has also been observed. Over 30 trippings of

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

HVDC link from Jan-Jun 2024. Detailed fault analysis and remediation needed to enhance reliability.

- (ii) **Cause of Voltage dip and high Reactive Power Drawl by loads:** - There was significant voltage drops across Northern Region and Reactive power absorption increased, exacerbating voltage issues.
- (iii) **Analysis of behavior of Load during the event:** Voltage reduction caused stalling of induction motors: total 16.5 GW load Reduced in NR. Stalling of motors at comparatively higher voltages (~0.85 - 0.9 p.u. voltage).
- (iv) **Impact on Conventional and Renewable Energy Generation:** Approximately 2800 MW of RE generation was reduced with around 1500 MW recovering within 4 minutes. 16 Conventional Generating Units tripped.
- (v) **Reactive Power Support from Generating Units in NR:** Heavy reactive power drawl by loads were observed. Many RE plants have opposite response.
- (vi) **High Voltage Scenario:** Total 18 (no.) of transmission lines (765kV and 400kV) tripped on OV, causing a partial blackout at the 765/400kV Aligarh (PG) S/s.
- (vii) **Frequency Response by Generating Units:** More than 50% capacity of the inter-state generators and more than 85% capacity of the intrastate generators exhibited inadequate governor response during the event.
- (viii) **Reactive Power Management:** The event highlighted the need for effective reactive power management. Heavy reactive power drawl was observed, leading to further voltage reductions.
- (ix) **Information sharing and Co-ordination:** Timely report submissions and communication are essential.

A.18.5 The committee recommended the following remedial measures for avoiding the recurrence of such grid event:

- (i) **Reactive Power Management (Dynamic/Static) by STU and DISCOMs:** In order to maintain voltage stability, reactive power support is desired from all grid connected utilities without leaning over each other so as to ensure minimum reactive exchange at different voltage levels.
- (ii) **Planning for dynamic reactive power sources near load centers based on load composition:** Adequate static/dynamic reactive devices may be planned at the distribution level near loads so that there is minimum drawl from reactive sources at the transmission (STU) level. The dynamic reactive power sources shall be commissioned near load centre stations based on the composition and quantum of individual load type.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- (iii) **Enhance reliability of HVDC Link:** Committee recommended POWERGRID to the followings-
- a. Review of protection schemes to avoid frequent outages.
 - b. Review of transmission line design including cross arms, jumpers, etc.
 - c. Design of filter switching logic to support system voltage.
- (iv) **Implementation of Overvoltage protection setting:** followings were recommended for implementing overvoltage Stage-I protection settings:
- a. Pick up voltage & time delay setting of Antitheft lines to be kept low with sufficient time gap from other lines at S/s
 - b. Parallel lines grading to be done such that one line should trip early by setting at low voltage and other line should trip last by keeping setting at high voltage.
 - c. Highly loaded lines should be given last priority in tripping.
 - d. Net MVAR relief (based on line charging MVAR & MVAR compensation in line) based on the simulation to be considered for arriving at the priority of line tripping. Lines providing high net MVAR relief to be tripped early.
 - e. Grading to be done in such a manner that one major incoming and outgoing line shall remain connected after tripping of lines at any node.
 - f. Protection setting of remote end station of a line need to be coordinated so as to avoid tripping of line from other end.
 - g. Drop-off to pick-up ratio of Relays implemented for overvoltage protection shall be more than 99.5%.
- (v) **Frequency Response by Generating Units as per IEGC 2023:** It was recommended that the performance of generating units where inadequate primary response was observed shall be discussed at RPC level.
- (vi) **Compliance of CEA Standards by Renewable Generating Plants:** RE generators must comply the CEA Standards. Committee recommended the followings-
- a. Protection settings of inverters/WTG shall be coordinated in such a way that it accounts for the voltage rise/drop between inverter/WTG terminal & Point of interconnection (POI). Overvoltage /undervoltage trip settings should be configured accordingly.
 - b. The reactive power controller settings (droop, deadband, power factor, operating modes) in inverters/WTGs should be configurable and shall be set in consultation with the respective load dispatch centre.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

- c. The protection settings of elements in collector system viz. transformers, cables etc. shall such that it allows RE plants to ensure the compliance of CEA standards at POI.
- d. RE plants shall ensure that the event records shall be shared with SLDC/ RLDC within the stipulated time for event analysis. All such data shall be retained in a retrievable format in a suitable archival system.

(vii) Retain of Conventional generators near load centers for providing grid support during such events: The presence of thermal generators near the load centres may significantly improve the voltage profile and can provide dynamic reactive power support in case of contingencies improving the stability.

(viii) Compliance of Standards by Load Serving Machines: The stalling of motors at high voltage (0.85-0.9 pu) is to be investigated and the motors serving load need to be compliant with IS/IEC.

(ix) Amendments in Existing Regulations: For ensuring reliable operation, provisions related to different emerging types of loads (Electrolysers etc.) may be added in the existing CEA standards.

A.18.6 NRLDC representative highlighted following points during the meeting:

- i) Poor primary frequency response of state controlled generating stations. States were requested to follow up with the intrastate generating station for testing and tuning of their governor system and organise workshop with generating stations for familiarization with Grid Code requirement w.r.t. governor response.
- ii) Poor power factor and high MVAR drawl from the grid. Majority of the states were drawing significant quantum of MVAR from the grid leading to poor voltage profile. States were requested to install additional capacitor banks at load levels in sync with the rise in demand and ensure good power factor at load level.

A.18.7 Regarding corrective actions at HVDC Champa-Kurukshetra link, NRLDC representative requested POWERGRID to apprise the forum about details of corrective measure taken / planned to be taken during ongoing shutdown of HVDC Champa-Kurukshetra link.

A.18.8 POWERGRID representative informed that shutdown of both the bipole was taken for 04 days each during which issues related to DCCT was attended and rectified. During upcoming 03 days shutdown of both the bipole together, software upgradation work will be done. After aforementioned modifications, major issues related to maloperation and undesired tripping will get rectified.

A.18.9 Rajasthan SLDC representative informed that Rajasthan has planned three

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

STATCOM as of now. (one at 400kV level in Bhadla and 2 nos. at 220kV level).

A.18.10 MS, NRPC highlighted that every stakeholder has its importance to operate the power system smoothly and should function collaborative manner.

Decision taken by Forum:

Forum acknowledged the sensitivity of event and directed the concerned to take appropriate actions based on the recommendations of Committee.

A.19. Issues with 400KV JPL-Kabulpur Ckt-1&2 PLCC Spare management & Maintenance (agenda by Apraava Energy Private Limited)

A.19.1 Apraava Energy Private Limited representative apprised the followings:-

Overview of Incident:

- On 7th August 2024, a scheduled shutdown of the 400KV MGTPS-Kabulpur Ckt-1 was initiated from the MGTPS side for meter replacement work.
- The breaker on the MGTPS side was manually opened; however, the Kabulpur end breaker failed to open on Direct Transfer Trip (DTT).
- Upon investigation, multiple cards of the FOTE PLCC Panel at the Kabulpur substation were found to have failed. Unfortunately, the Kabulpur team did not have spare cards available.
- The line was re-energized without the PLCC operational, with the Zone-2 timer setting temporarily adjusted to zero seconds.
- On the next day, during shutdown of the 400KV MGTPS-Kabulpur Ckt-2, it was again observed that the Kabulpur end breaker did not open on DTT.
- The Kabulpur team confirmed that multiple cards in the PLCC had failed.
- The line was re-energized without the PLCC operational, with the Zone-2 timer setting temporarily adjusted to zero seconds.
- However, after 2-3 days, Kabulpur team has replaced the PLCC cards and operationalised the PLCC.

Operational Concerns:

- This transmission line is managed by M/s Indigrd Pvt. Ltd., who have not maintained the necessary spare parts for PLCC (critical equipment).
- Additionally, it has been observed that regular maintenance of the PLCC equipment at the MGTPS Substation end is not being conducted by M/s Indigrd

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

team.

- A.19.2 In view of above, Apraava Energy Private Limited representative requested Forum to direct the relevant HVPN authorities to instruct the Indigrid team to resolve the PLCC issues at both ends, ensure effective spare management and regular maintenance to prevent any future operational disruptions. Because any prolonged shutdown of 400KV line may significantly affect power evacuation from our generating station.
- A.19.3 IndiGrid representative stated that on August 7 and 9, 2024, a shutdown was initiated by JPL (Apraava) for the 400kV Jharli-Kabulpur Ckt-1 to replace meters. During the shutdown, a failure in the FOTE panel at Kabulpur was detected, which impacted the receipt of the Direct Trip (DT) command at JPL. To address this, IndiGrid recommended temporary protection settings, which were approved by NRLDC on August 8 and 9, 2024. IndiGrid promptly restored the DTPC system on August 9, 2024, and submitted a detailed support test report (loop testing/software testing) to JPL, Haryana SLDC, and NRLDC.
- A.19.4 Despite the DTPC being in a healthy state as of August 9, 2024, JPL did not give consent for the normalization of the Zone 2 settings without further testing, insisting on a DT signal test involving physical line opening. Due to the lack of consent from JPL, both lines tripped on August 11, 2024. Further, he added that if JPL had provided consent earlier, this tripping could have been avoided. This tripping was attributable to IndiGrid.
- A.19.5 IndiGrid representative submitted that as part of prudent utility practices, line shutdowns can be avoided when simulations are feasible. He confirmed that IndiGrid will maintain spare card and also plan to conduct maintenance on the FOTE at JPL's end during the scheduled line maintenance.
- A.19.6 LPGCL representative stated that one end being generation plant, it is accurate to do physical testing of breaker for DT testing. But the outage of line may be avoided by taking out the trip signal wiring from breaker. IndiGrid representative replied that DTPC healthiness may be ensured by carrier communication in live condition.
- A.19.7 RVUNL representative mentioned that generally agencies maintaining PLCC equipment and relay breaker system, are different. Therefore, both can take care of its part.

52nd Protection Sub-Committee Meeting (20th September, 2024)-MoM

A.19.8 MS, NRPC highlighted that utilities should try to avoid the shutdown if possible by simulation testing, as it is being done in case of SPS mock testing.

Decision taken by Forum:

Forum guided Apraava Energy Private Limited and IndiGrid to co-operate each other for proper operation of the transmission assets and try to avoid unnecessary system shutdown by adopting simulation testing if possible. Forum also directed IndiGrid to resolve the PLCC issues at both ends, ensure effective spare management and regular maintenance to prevent any future operational disruptions. HVPN may ensure the same in future also.

A.20. Approval of protection settings in compliance of IEGC 2023 (agenda by Adani Green Energy Limited)

A.20.1 AGEL representative apprised that Adani Green Energy Twenty-Five Limited (AGE25L) has commissioned the 400kV Solar PSS on 07-09-2024 for 500 MWSolar Power Project at Badisid, Phalodi, Rajasthan.

A.20.2 Further, he mentioned that NRLDC has given the consent to the protection settings of 400kV Solar PSS. These settings are attached as **Annexure-XXII**.

A.20.3 NRLDC representative conveyed that these settings were found in order and may be considered for final approval.

A.20.4 MS, NRPC emphasized that all utilities may send the protection settings approval agenda timely.

Decision taken by Forum:

Forum accorded final approval to the protection settings (attached as Annexure-XXII) of newly commissioned 400 kV Solar PSS for 500 MW Solar Power Project at Badisid, Phalodi, Rajasthan.

Members of Protection Sub-Committee (FY 24-25)

S. No.	NRPC Member Organization	Designation	Email-ID
1	Member (GO&D), CEA	Director, NPC Division	skdotancea@nic.in
2	Member (PS), CEA	Chief Engineer, PSPA-I Division	i.sharan@nic.in
3	CTUIL	Sr.GM	schakraborty@powergrid.in
4	PGCIL	GM	gunian.agrawal@powergrid.in
5	NLDC*	Executive Director	scsaxena@grid-india.in
6	NRLDC*	Executive Director	nroy@grid-india.in
7	NTPC	GM(OS-NR)	dmandal@ntpc.co.in
8	BBMB	Director (P&C)	dirpc@bbmb.nic.in
9	THDC*	Chief General Manager (EM-Design)	rrsemwal@thdc.co.in
10	SJVN	General Manager	prakash_chand@sjvn.nic.in
11	NHPC	General Manager (O&M)	hod-om-co@nhpc.nic.in
12	NPCIL*	Director (Finance), SO/F, TSU(E&I)	df@npcil.co.in rajeshsharma@npcil.co.in
13	Delhi SLDC	General Manager	gmsldc@delhisldc.org
14	Haryana SLDC	Chief Engineer (SO&C)	cesocomm1@hvpn.org.in
15	Rajasthan SLDC	Chief Engineer (LD)	ce.ld@rvpn.co.in
16	Uttar Pradesh SLDC	Superintending Engineer (R&A)	sera@upslcd.org
17	Uttarakhand SLDC	Chief Engineer	anupam_singh@ptcul.org
18	Punjab SLDC	Chief Engineer	ce-sldc@punjabslcd.org
19	Himachal Pradesh SLDC	Chief Engineer	cehpsldc@gmail.com
20	DTL	AGM-Protection	bharatquijardtl@gmail.com
21	HVPNL	Chief Engineer (TS)	cetspk1@hvpn.org.in
22	RRVNL	CE (M&P)	ce.mps@rvpn.co.in
23	UPPTCL*	Managing Director	md@upptcl.org
24	PTCUL	SE(T&C)	setandchld@gmail.com
25	PSTCL	Chief Engineer (P&M)	ce-pm@pstcl.org
26	HPPTCL*	Managing Director	md.tcl@hpmail.in
27	IPGCL	DGM (Protection)	arif.ipgcl@gmail.com
28	HPGCL	SE/M&T RGTPP	semt.rgtp@hpgcl.org.in
29	RRVUNL*	CMD	cmd@rrvun.com
30	UPRVUNL	Chief Engineer, (L-2)	ce_ppmm@uprvunl.org
31	UJVNL*	Managing Director	mdujvnl@ujvnl.com
32	HPPCL*	Managing Director	md@hppcl.in
33	PSPCL	Chief Engineer/GHTP	ce-ghtp@pspcl.in
34	UHBVN	Managing Director	md@uhbvn.org.in
35	Jodhpur Vidyut Vitran Nigam Ltd.	Managing Director	MD.JDVVNL@RAJASTHAN.GOV.IN
36	Paschimanchal Vidyut Vitaran Nigam Ltd.	Managing Director	md@pvvnl.org
37	UPCL*	Managing Director	md@upcl.org
38	HPSEB*	Managing Director	md@hpseb.in
39	Prayagraj Power Generation Co. Ltd.*	Head (Commercial & Regulatory), DGM - Elect	sanjay.bhargava@tatapower.com , dhananjay.singh@ppqcl.co.in
40	Aravali Power Company Pvt. Ltd*	CEO	brahmajig@ntpc.co.in
41	Apraava Energy Private Limited*	GM-Electrical	navin.chaturvedi@apraava.com
42	Talwandi Sabo Power Ltd. *	COO	Vibhav.Agarwal@vedanta.co.in
43	Nabha Power Limited*	CEO	sk.narang@larsentoubro.com
44	MEIL Anpara Energy Ltd*	COO, ED	anandkumar.singh@meilanparapower.com , arun.tholia@meilanparapower.com
45	Rosa Power Supply Company Ltd	GM-ELECTRICAL	kesarinandan.pandey@relianceada.com
46	Lalitpur Power Generation Company Ltd	Head of Maintenance, GM Electrical	alokkumar.ltp@lpgcl.com , aupadhyay.ltp@lpgcl.com
47	MEJA Urja Nigam Ltd.	AGM-EMD	SPSPUNDIR@NTPC.CO.IN
48	Adani Power Rajasthan Limited*	COO, Thermal, O&M	iayadeb.nanda@adani.com
49	JSW Energy Ltd. (KWHEP)*	Head Regulatory & Power Sales	iyotiprakash.panda@jsw.in
50	TATA POWER RENEWABLE*	Zonal Head, NR	dhmahabale@tatapower.com
51	UT of J&K*	Chief Engineer, JKPCCL	cejkpcl2@gmail.com
52	UT of Ladakh*	Chief Engineer, LPDD	cepdladakh@gmail.com
53	UT of Chandigarh	Executive Engineer	elop2-chd@nic.in
54	Noida Power Company Limited	Head – Power Purchase	ssrivastava@noidapower.com
55	Fatehgarh Bhadla Transmission Limited	AGM- Protection and Metering	ashish.baviskar@adani.com
56	NTPC Vidyut Vyapar Nigam Ltd.	CEO	ceonvvn@ntpc.co.in

* Organizations from where nominations are not received for PSC, members of NRPC have been mentioned. Nomination for PSC forum may be sent at the earliest.

Attendance of 52nd Protection Sub-Committee Meeting held on 20.09.2024				
S. No.	Name	Designation	Organization	E-mail
1	V.K. Singh	Member Secretary	NRPC	ms-nrpc@nic.in
2	D. K. Meena	Suprintending Engineer (O&P)	NRPC	dharmendra.cea@gov.in
3	Reeturaj Pandey	Executive Engineer (Protection)	NRPC	pandeyr.cea@gov.in
4	Lokesh Agrawal	Assistant Executive Engineer (Protection)	NRPC	lokesh.cea.gov.in
5	D. K. Jain	Suprintending Engineer (Protection)	RVPN	se.prot.engg@rvpn.co.in
6	Vijay Pal	Executive Engineer (MP TES)	RVPN	xen.prot.alwar@rvpn.co.in
7	Abhay Singh	Executive Engineer (PPL & PTD)	RVUN	montg.rvun@gmail.com
8	Faraz	Deputy Director	CEA on deputy to GCIL	faraz@nic.in
9	Ashwini Kumar	Executive Engineer	PTCUL	ee_tanda_ddun@ptcul.org
10	Sunil Raval	General Manager	ADANI	sunil.raval@adani.com
11	Narendra Ojha	Manager	ADANI	narendran.ojha@adani.com
12	Anuj Kumar	Assistant Engineer	UPSLDC	eera@upslcd.org
13	Maaz	Assistant Engineer	UPPTCL	setncmrt@upptcl.org
14	P. K. Mishra	Suprintending Engineer (T & C)	UPPTCL	setncmrt@upptcl.org
15	Ramneet Chanana	Deputy Manager	DTL	chanana.ramneet15@gmail.com
16	Paritosh Joshi	Senior Manager (T)	DTL	paritoshjoshi2013@gmail.com
17	Vaibhav Vivek	Deputy General Manager (E)	SJVN	vaibhav.vivek@sjvn.nic.in
18	Arif Rahman	Deputy General Manager (T)	PPCL	arif.ipgcl@gmail.com
19	Vivek Karthikeyan	Assistant General Manager	INDIGRID	vivek.karthikeyan1@indigrid.com
20	Rakesh Kumar Gupta	Chief Manager	POWERGRID NR-II	rakeshgupta@powergrid.in
21	B. R. Meena	Deputy General Manager	NRLDC	brmeena@grid-india.in
22	Manjesh Kumar	Senior MGR	APCPL	manjeshkumar@ntpc.co.in
23	Mahavir Prasad Singh	Senior Deputy General Manager	NRLDC	mahavir@grid-india.in
24	Somara Lakara	Chief General Manager	NRLDC	somara.lakra@grid-india.in
25	Abhimanyu Upadhay	General Manager	LPGCL	aupadhay.ltp@lpgcl.com
26	Deepak Kumar	Deputy Manager	NRLDC	deepak.kr@grid-india.in
27	Manas R. Chand	Deputy General Manager	NLDC	manas@grid-india.in
28	Himanshu Kumar	Assistant Manager	NLDC	hkumar@grid-india.in
29	Jaganath Puri	Senior Manager	NHPC	jaganathpuri@nhpc.nic.in
30	Rajbir Singh	ASE	PSTCL	rajbir_walia74@yahoo.com
31	Raman Jain	Executive Engineer	RVUNL	raman.49599@rvun.in
32	Hitesh Rastogi	Deputy General Manager (US)	NTPC	hitesh_rastogi2001@yahoo.com
33	Er. Lalit Kumar	Assistant Engineer	HPPTCL	er.lalit.tcl@hppmail.in
34	Er. Mukesh Singh	Suprintending Executive Engineer	HPSEBL	mukeshsingh6322@gmail.com
35	Er. Dharmendra Kumar	Assistant Engineer	HPSLDC	sehpslde@gmail.com &
36	Uma Shankar	Executive Engineer	UJVNL	
37	Kedar Singh Rana	Executive Engineer	UJVNL	rana.ujvnl@gmail.com
38	B. K. Raghava	Suprintending Engineer	HVPN	semppcdelhi@hvpn.gov.in
39	Amit Maan	Executive Engineer	HVPN	xenmpccggn@nvpn.org.in
40	Vishal Mohan Dahiya	Deputy Director	BBMB	ddpntpnp@bbmb.nic.in
41	Manish	Assistant Director	BBMB	ddpntbwn1@gmail.com
42	Arvind Bahuguna	Assistant Engineer	UJVNL	arvind.anvi222@gmail.com
43	Er. Karan Bansal	Suprintending Executive Engineer	PSTCL	karan.bansal.00@gmail.com
44	Er. Amandeep Singh	Assistant Engineer	PSTCL	ase-slldcop@pstcl.org
45	Amit Sharma	ET	NRLDC	amsharma@grid-india.in
46	M. P. Sharma	Executive Engineer	SLDC, RAJASTHAN	se.sold@rvpn.co.in
47	Shashi Saini	Senior Manager	APRAAVA ENERGY	sashi.saini@apraava.com
48	Manish	Assistant Director	BBMB	ddpntbwn1@gmail.com
49	Sujata Bhattacharya	Deputy Manager	NRLDC	sujata@grid-india.in
50	Sunil Aharwal	General Manager	NRLDC	skaharwal@grid-india.in

Status of performance indices report of June 2024		
S. No.	Utility	Status of Protection Performance Indices
1	PGCIL	Received (NR-1,2,3)
2	NTPC	Received (Unchahar, Tanda, Dadri, Koldam)
3	BBMB	Received (Transmission)
4	THDC	Received (Tehri, Koteshwar HEP)
5	SJVN	Received
6	NHPC	Received
7	NPCIL	Received (RAP- 1-2, 5-6), NAP (1-2)
8	DTL	Received
9	HVPNL	Received
10	RRVPNL	Received
11	UPPTCL	Received
12	PTCUL	Received
13	PSTCL	Received
14	HPPTCL	Received
15	IPGCL	Received (PPCL)
16	HPGCL	Not Received
17	RRVUNL	Received
18	UPRVUNL	Not Received
19	UJVNL	Received (Dharashu, Utrakashi, Khodri, chibro, vyasi)
20	HPPCL	Not Received
21	PSPCL	Not Received
22	HPSEBL	Not Received
23	Prayagraj Power Generation Co. Ltd.	Received
24	Aravali Power Company Pvt. Ltd	Received
25	Apraava Energy Private Limited	Received
26	Talwandi Sabo Power Ltd.	Not Received
27	Nabha Power Limited	Received
28	MEIL Anpara Energy Ltd	Not Received
29	Rosa Power Supply Company Ltd	Received
30	Lalitpur Power Generation Company Ltd	Received
31	MEJA Urja Nigam Ltd.	Not Received
32	Adani Power Rajasthan Limited	Received (Kawai)
33	JSW Energy Ltd. (KWHEP)	Not Received
34	AESL	Received (ATIL, MTSCL, GTL)
35	Tata Power Renewable Energy Ltd.	Received
36	UT of J&K	Not Received
37	UT of Ladakh	Not Received
38	UT of Chandigarh	Not Received
39	ATIL, BKTL, FBTL	Received
40	INDIGRID	Received
41	POWERLINK	Not Received
42	ADHPL	Received
43	Sekura Energy Limited	Not Received
44	WUPPTCL	Received
45	SEUPPTCL	Not Received
46	Vishnuprayag Hydro Electric Plant (J.P.)	Not Received
47	Alaknanda Hydro Electric Plant (GVK)	Not Received

Status of performance indices report of July 2024

S. No.	Utility	Status of Protection Performance indices
1	PGCIL	Received (NR-1, 2)
2	NTPC	Received (Dadri, Koldam)
3	BBMB	Received (Transmission)
4	THDC	Received (Tehri, Koteshwar HEP)
5	SJVN	Received
6	NHPC	Received
7	NPCIL	Received (RAP- 1-6)
8	DTL	Received
9	HVPNL	Received
10	RRVNL	Received
11	UPPTCL	Received
12	PTCUL	Received
13	PSTCL	Received
14	HPPTCL	Received
15	IPGCL	Received (PPCL)
16	HPGCL	Not Received
17	RRVUNL	Received
18	UPRVUNL	Received (DTPS-Anpara)
19	UJVNL	Received (Dharashu, Utrakashi)
20	HPPCL	Not Received
21	PSPCL	Not Received
22	HPSEBL	Not Received
23	Prayagraj Power Generation Co. Ltd.	Received
24	Aravali Power Company Pvt. Ltd	Received
25	Apraava Energy Private Limited	Received
26	Talwandi Sabo Power Ltd.	Received
27	Nabha Power Limited	Received
28	MEIL Anpara Energy Ltd	Not Received
29	Rosa Power Supply Company Ltd	Received
30	Lalitpur Power Generation Company Ltd	Received
31	MEJA Ujja Nigam Ltd.	Not Received
32	Adani Power Rajasthan Limited	Received (Kawai)
33	JSW Energy Ltd. (KWHEP)	Not Received
34	AESL	Received (ATIL, OCBTL)
35	Tata Power Renewable Energy Ltd.	Received (Sourya, TPGEI, TPREL)
36	UT of J&K	Not Received
37	UT of Ladakh	Not Received
38	UT of Chandigarh	Not Received
39	ATIL, BKTL, FBTL	Received
40	INDIGRID	Received
41	POWERLINK	Not Received
42	ADHPL	Received
43	Sekura Energy Limited	Not Received
44	WUPPTCL	Received
45	SEUPPTCL	Not Received
46	Vishnuprayag Hydro Electric Plant (J.P.)	Not Received
47	Alaknanda Hydro Electric Plant (GVK)	Not Received

Status of performance indices report of August 2024

S. No.	Utility	Status of Protection Performance Indices
1	PGCIL	Received (NR-1,2)
2	NTPC	Received (Dadri, Unchahar, Tanda, Anta)
3	BBMB	Not Received
4	THDC	Received
5	SJVN	Received
6	NHPC	Received
7	NPCIL	Received (RAP- 1-6), NAP-(1-2)
8	DTL	Received
9	HVPNL	Received
10	RRVPNL	Received
11	UPPTCL	Received
12	PTCUL	Received
13	PSTCL	Not Received
14	HPPTCL	Received
15	IPGCL	Received (PPCL)
16	HPGCL	Not Received
17	RRVUNL	Received
18	UPRVUNL	Received (DTPS-Anpara)
19	UJVNL	Received (Dharashu, Utrakashi)
20	HPPCL	Not Received
21	PSPCL	Received (GGSSTPS, 220kV GATPL, 220kV GHTP)
22	HPSEBL	Not Received
23	Prayagraj Power Generation Co. Ltd.	Received
24	Aravali Power Company Pvt. Ltd	Received
25	Apraava Energy Private Limited	Received
26	Talwandi Sabo Power Ltd.	Received
27	Nabha Power Limited	Received
28	MEIL Anpara Energy Ltd	Not Received
29	Rosa Power Supply Company Ltd	Received
30	Lalitpur Power Generation Company Ltd	Received
31	MEJA Urja Nigam Ltd.	Not Received
32	Adani Power Rajasthan Limited	Received (Kawai)
33	JSW Energy Ltd. (KWHEP)	Not Received
34	AESL	Received(ATSCL, MTSCL, OCBL, HPTSLS)
35	Tata Power Renewable Energy Ltd.	Received (Sourya, TPGE, TPREL)
36	UT of J&K	Not Received
37	UT of Ladakh	Not Received
38	UT of Chandigarh	Not Received
39	ATIL, BKTL, FBTL	Received (ATIL, BKTL, FBTL)
40	INDIGRID	Received
41	POWERLINK	Not Received
42	ADHPL	Received
43	Sekura Energy Limited	Not Received
44	WUPPTCL	Received
45	SEUPPTCL	Not Received
46	Vishnuprayag Hydro Electric Plant (J.P.)	Not Received
47	Alaknanda Hydro Electric Plant (GVK)	Not Received

Reasons for Performance Indices less than Unity- June 2024**ATIL****Case-1 500kV Mundra - Mohindergarh HVDC Pole-2 tripped on 14.6.2024**

No. of unwanted operation -1

No. of correct operation -1

Reason for indices less than unity - Malfunction of Pole-2 Current converter to C&P measuring system at Mahendragarh end

Corrective action taken- Current converter replaced.

NTPC (Unchahar)**Case-1 Tripping of line**

No. of unwanted operation -1

No. of correct operation -6

No. of failures to operate-0

Reason for indices less than unity - Auto reclose block issued.

Corrective action taken- Distance protection relay shall be tested in next shutdown for the actual cause

Case-2 Tripping of GT

No. of unwanted operation -1

No. of correct operation -5

No. of failures to operate-0

Reason for indices less than unity - Rain water ingress inside GCB panel leading to pre synch earth fault protection.

Corrective action taken- Root cause was found and eliminated by Civil and EMD.

POWERGRID (NR-2)

Case-1 Tripping of SAMBA 315MVA ICT-III on 8.6.2024

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity - Due to maloperation of Sukrut make PRV caused by failure of microswitch make Jai Balaji

Corrective action taken- Defective microswitch replaced with spare.

Case-2 Tripping of LUDHIANA -400/+600 MVAR SVC

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity – Tripping due to flashover in TSC branch caused by entry of CAT

Corrective action taken- Proper sealing of SVC yard done.

Case-3 Tripping of LUDHIANA -400/+600 MVAR SVC

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity – SVC tripped on operation of TSC (Thyristor Switched Capacitor) current supervision protection caused by cable insulation failure at gland point.

Corrective action taken- IR measurement for all and other cables done. Proper glanding of cable done.

PPGCL

Case-1 Tripping of 765kV 1500MVA ICT-1 at BARA

No. of unwanted operation -1

No. of correct operation -1

No. of failures to operate-0

Reason for indices less than unity- Tripped due to mall operation of master relay. New future FGD bay work is going on. At fault time, some interruption came in dc circuit.

Corrective action taken- Isolated the FGD dc circuit from running 765kV and 400kV switchyard.

RVPN

Case-1 400/220 Kv 500 MVA ICT-II AT 400 KV GSS KANKANI on 16.06.2024

No. of Unwanted operation – 1

Reason for indices less than unity – DC fault due to control wiring damaged, wiring replaced with DC change over relay

Corrective Action taken – Control wiring replaced. Damaged DC change over relay also replaced.

Case-2 220 KV Sakatpura- Dahara Line on 21.06.2024

No. of Unwanted operation – 1

Reason for indices less than unity - Due to VT selection relay problem

Corrective Action taken – VT selection relay problem rectified.

Case-3 220 KV JHALAWAR-AKLERA Line on 24.06.2024

No. of Unwanted operation – 1

Reason for indices less than unity – CB tripped without any relay signal.

Corrective Action taken – CB problem rectified.

Case-4 220 KV Saurya Urja Line-I at 400KV GSS Bhadla on 30.06.2024

No. of Unwanted operation – 1

Reason for indices less than unity – Relay panel caught fire following relay are burnt Dist Prot. M1, 195 A, 295 A, 86 A. No reason of fire eruption established.

Corrective Action taken – New panel arranged and will soon be commissioning.

Case-5 220/132 KV, 100 MVA TRF BHEL MAKE at 220 KV GSS BHAWAD on 02.06.2024 and 24.06.2024

No. of Unwanted operation – 2

Reason for indices less than unity – LBB relay automatically went to default setting values.

Corrective Action taken – Relay settings revised on dated 24.06.2024.

Case-6 220 /132 KV, 160MVA BHEL Make, 220 KV GSS HINDAUN on 06.06.2024 and 220/132 KV 100MVA, Tr. No. 1 at 220KV GSS SAWA on dated 07.06.2024

No. of Unwanted operation – 2

Reason for indices less than unity – Water logging in relay terminal box during heavy rain.

Corrective Action taken – Reay terminal box cleaned, dried and sealed.

Case-7 220/132 kV, 100 MVA transformer-II at 220 KV GSS RVPNL Lalsot on 10.06.2024

No. of Unwanted operation – 1

Reason for indices less than unity – High impedance differential protection relay defective

Corrective Action taken – High Impedance differential protection relay replaced.

SJVN

Case-1 Tripping of Generating unit-2 at Rampur HPS on 30.6.2024

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Temperature measuring instrument mal-operated.

Corrective Action taken- The temperature measuring instrument replaced with the new one.

TATA POWER SOURYA LIMITED, BANDERWALA

Case-1 Tripping of 220/33KV 125MVA ICT-3 AT BTPSL_SL_BIK2_PG

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Tripped due to inadvertent setting of Definite time earth fault remain at lower side.

Corrective Action taken- Not received from utility.

NHPC

Case-1 Tripping of Chamera-I-Chamera-II Line

No. of unwanted operation -1

No. of correct operation -1

No. of failures to operate-0

Reason for indices less than unity- Over Current Protection Operated.

Corrective Action taken- Over current was disabled as it was mistakenly present in the relay at the time of relay checking.

DTL

Case-1 Tripping of 400kV Mundka-Bawana-1,2

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Tripped due to Main-2 relay seen the fault of other line in its zone-1.

Corrective Action taken- The issue was communicated to GE and the corrective action taken as per the recommendation of OEM. PSL has also been rectified.

UPPTCL

Case-1 Tripping of 315MVA ICT-2,3 at 400kV S/s Bareilly, 220kV feeders from Bareilly to Dohana-I, Pilibhit-2, C B Ganj-I and 220kV Bus coupler (Lucknow Zone)

No. of unwanted operation -0

No. of incorrect operation -1 for each element

No. of failures to operate-0

Reason for indices less than unity- Tripping due to mal operation of LBB protection of Pilibhit-2 feeder.

Corrective Action taken- Fault has been corrected.

Case-2 Tripping of 220kV Khurja-Dadri line on 19.06.2024 (Meerut Zone)

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Line was mistakenly tripped at Khurja end by firm engineer during checking of main -2 relay.

Corrective action taken- More sincerity will be taken to avoid such event in future.

Case-3 Tripping of 220kV Khurja NAP line on 14.06.2024 (Meerut Zone)

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Line tripped at Khurja end due to erratic force 3 phase trip generated on distance protection (due to wrong PSL).

Corrective action taken- Problem in the PSL has been rectified.

Case-4 Tripping pf 160MVA 220/132kV ICT-III at 220kV Baraut Substation (Meerut Zone)

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Erratic tripping due to settings of REF relay was wrongly programmed as 2 winding Transformer instead of Auto Transformer.

Corrective action taken- Settings have been corrected as Auto transformer on 14.06.2024.

Case-5 Tripping of 500MVA ICT-II at 400kV Substation Motiram Adda (Gorakhpur Zone)

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Tripping due to cable fault and polarity issue in NCT.

Corrective action taken- Fault removed.

Case-6 Tripping of 160MVA ICT- I at 220kV Substation Maharajganj (Gorakhpur Zone)

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Tripping due to wiring problem in relay panel.

Corrective action taken- Fault rectified.

Case-7 Tripping of 220kV Kirawali-Sikandra line (Agra Zone)

No. of unwanted operation -1

No. of correct operation -1

No. of failures to operate-0

Reason for indices less than unity- Tripping due to malfunctioning of PLCC panel.

Corrective action taken- Fault rectified.

Case-8 Tripping of 220kV Kirawali-PGCIL line (Agra Zone)

No. of unwanted operation -2

No. of correct operation -3

No. of failures to operate-0

Reason for indices less than unity- Tripping due to malfunctioning of PLCC panel.

Corrective action taken- Fault rectified.

Case-9 Several trippings at 400kV Sarnath Substation -400/220 KV 315 MVA ICT-III, 220 KV Beerapatti TSS Feeder, 220/132 KV 160 MVA TF-I, 220/132 KV 200 MVA TF-I, 220/132 KV 160 MVA TF-III (Prayagraj Zone)

No. of unwanted operation -1 for each element

No. of correct operation -0 for each element

No. of failures to operate-0 for each element

Reason for indices less than unity- Due to wrong operation of PRV of 500 MVA ICT-II because of cable damage Protection

Corrective action taken- Fault rectified.

PSTCL

Case-1 Tripping of 220 kV Bassi Pathana-G-1 ckt

No. of unwanted operation -2

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Maloperation of relay.

Corrective action taken- Direction set right on standalone E/F relay at Bassi Pathana and also settings revised at Gobindgarh end.

Case-2 Tripping of 220 kV Sandhwan-Muktsar(220) ckt.

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Maloperation of relay (tripped at Sandhawan end on zone-4 while no tripping at Muktsar end).

Corrective action taken- Relay will be tested after paddy season.

Case-3 Tripping of 100 MVA, 220/66 kV Power Transformer-6 at 220kV /s Badal

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Due to storm & wind- Rain water ingress in CT Marshalling box.

Corrective action taken- It has been covered now.

Case-4 Tripping of 220 kV Dhandari-Jamalpur ckt.I at Dhandari end only

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- DT received from Jamalpur BBMB end. Mal-operation.

Corrective action taken- To be investigated by Communication wing.

Case-5 Tripping of 220 kV Pakhowal-PGCIL ckt

No. of unwanted operation -0

No. of correct operation -0

No. of failures to operate-0

No. of incorrect operation-1

Reason for indices less than unity- Carrier not healthy at PGCIL end.

Corrective action taken- Carrier equipment are owned by PSTCL. End to end testing will be done based on shutdown.

Case-6 Tripping of 315 MVA, 400/220 kV ICT-2 at 400kV S/s Makhu

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Due to cut on Control cable entering the Buchholz relay- maloperation.

Corrective action taken- Defective part of control cable removed.

Case-7 Tripping of 220 kV Dasuya-Alawalpur ckt in zone -1 at Alawalpur and zone-2 at Dasuya

No. of unwanted operation -0

No. of correct operation -2

No. of failures to operate-0

O. of incorrect operation-1

Reason for indices less than unity- In spite of CR relay issued Z-2 trip.

Corrective action taken- Issue of relay configuration has been set right.

Case-8 Tripping of 100 MVA, 220/66 kV Power Transformer-3 at 220kV S/s Nabha

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- WTI tripping. Maloperation- no reason found.

Case-9 Tripping of 160 MVA, 220/66 kV Power Transformer-4 at 220kV S/s Nabha

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Mal-operation, Due to ingress of moisture in OLTC Buchholz.

Corrective action taken- Relay has been covered.

Case-10 Tripping of 100 MVA, 220/66 kV Power Transformer-3 at 220kV S/s Udhoke

No. of unwanted operation -3

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Control cable damaged and NCT connections found loose.

Corrective action taken- Control cable changed and NCT connections tightened.

Case-11 Tripping of 220/66 kV, 160 MVA Power Transformer-4 at 220kV S/s Chogawan

No. of unwanted operation -1

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- CTs were replaced and accordingly differential protection settings were not updated.

Corrective action taken- Settings have been changed.

Case-12 Tripping of 220 kV Butari-Railway ckt, 220 kV Butari-Verpal ckt, 220 kV Butari-BBMB ckt, 100 MVA,220/66 kV P.T/F T-1, 100 MVA,220/132 kV P.T/F T-5, 100 MVA,220/66 kV P.T/F T-4

No. of unwanted operation -1 for each element

No. of correct operation -0

No. of failures to operate-0

Reason for indices less than unity- Mal-operation of BBPS Relay.

Corrective action taken- Due to breaker contact issue. The issue will be resolved after 30.09.2024.

Case-13 Incorrect operations due to unhealthiness of carrier

Lines subjected- 220 kV Ferozepur Road - Ladhowal ckt, 220 kV Patti-Verpal ckt, 220 kV Numehal-Nakodar ckt, 220 kV Mahilpur-Bhakra ckt.II, 220 kV G-1-RTP ckt.II, 220 kV Sahnewal-PGCIL ckt, 220 kV Ablowal-Passiana ckt, 220 kV Malerkotla-Sandaur ckt.II, 220 kV Dhuri-Dhuri(400) ckt, 220 kV Doraha-PGCIL ckt, 220 kV Ghulal-Sahnewal ckt, 220 kV Badhni-PGCIL ckt

Due to unhealthiness of carrier, the concerned ends have been getting tripped in zone-2 leading to delayed clearance.

Corrective action taken- Matter is being taken up to resolve. It involves a huge procurement.

Reasons for Performance Indices less than Unity- July 2024

RVPN

Case-1 220 KV Dausa - Mandawar Line AT 220 KV GSS DAUSA on 03.07.2024

No. of unwanted operation -1

Reason for indices less than unity - VT supply failed due to problem in VT selection relay.

Corrective action taken- VT selection relay repaired and problem rectified.

Case-2 220 KV KUCHAMAN-MAKRANA LINE at 220 KV GSS Kuchaman on 06.07.2024

No. of unwanted operation -1

Reason for indices less than unity – Tripping due to DC problem at 220 KV GSS Kuchaman.

Corrective action taken- DC problem rectified.

Case-3 Multiple trippings of 220 KV lines at Ratangarh on 08.07.2024

220kV Sri Dungargarh-Ratangarh Line - No. of unwanted operation -2

220 KV RATANGARH- KHETRI-I- No. of unwanted operation -2

220 KV RATANGARH- KHETRI-II- No. of unwanted operation -2

Reason for indices less than unity – Tripping due to DC problem due to heavy rain at 400/220 KV GSS Ratangarh.

Corrective action taken- DC problem rectified.

Case-4 220KV Dausa - PGCIL Bassi Ckt-I Line at 220KV GSS Dausa on 24.07.2024

No. of unwanted operation -1

Reason for indices less than unity – CB tripped at Dausa end due to heavy air leakage from Pneumatic Drive of Y-Ph CB pole

Corrective action taken- CB repaired.

Case-5 220Kv Bikaner-Gajner-I line at 400 KV GSS Bikaner on 26.07.2024

No. of unwanted operation -1

Reason for indices less than unity – May be a DC fault, exact reason could not be identified.

Corrective action taken- Under observation.

Case-6 400 kV Bikaner-Merta Line at 400 KV GSS Bikaner on 22.07.2024

No. of unwanted operation -1

Reason for indices less than unity – May be a DC fault, exact reason could not be identified.

Corrective action taken- Under observation.

Case-7 220/132 KV 160 MVA Transformer-I at 220 KV GSS Bhiwadi on 04.07.2024

No. of unwanted operation -1

Reason for indices less than unity – Water logging in relay terminal box during heavy rain.

Corrective action taken- Reay terminal box cleaned, dried and sealed.

Case-8 220/132 KV, 160 MVA Transformer at 220 KV GSS RAWATSAR on 14.07.2024

No. of unwanted operation -1

Reason for indices less than unity – Water logging in relay terminal box during heavy rain.

Corrective action taken- Reay terminal box cleaned, dried and sealed.

Case-9 220/132KV 100 MVA ICT-I AT 220 KV GSS IG NAGAR on dated 25.07.2024

No. of unwanted operation -1

Reason for indices less than unity – Water logging in relay terminal box during heavy rain.

Corrective action taken- Reay terminal box cleaned, dried and sealed.

Case-10 220/132 KV, 100 MVA Transformer-I at 220KV GSS DECHU on 02.07.2024

No. of unwanted operation -1

Reason for indices less than unity – High impedance differential protection relay defective.

Corrective action taken- High Impedance differential protection relay replaced.

Case-11 220/132KV, 100 MVA Transformer-II AREVA at 220kV GSS GULABPURA on 16.07.2024

No. of unwanted operation -1

Reason for indices less than unity – High impedance differential protection relay defective.

Corrective action taken- High Impedance differential protection relay shall be replaced soon.

Case-12 220kV 160MVA Transformer-II at 220KV GSS GAJNER on 26.07.2024

No. of unwanted operation -1

Reason for indices less than unity – DC Fault due to heavy rain.

Corrective action taken- DC fault rectified.

RRVUNL

Case-1 Tripping of GT-1 at 220kV KSTPS kota on 19.7.2024

No. of unwanted operation -1

No. of correct operation-3

No. of failure to operate-0

Reason for indices less than unity – tripped due to malfunctioning of UAT Protection Relay RET650.

Corrective action taken- The faulty Relay has been taken out of circuit and is being sent to the OEM, M/s. HIEL (Formerly M/s. ABB India Ltd.) for analysis of the same.

SJVN

Case-1 Tripping of 68.67 MW generating unit no. 6 of Rampur HPS on 07.07.2024.

Number of unwanted operations = 1

Reason for indices less than unity – High TGB vibration above permissible limit. High TGB vibration occurred due to labyrinth seal damaged at runner.

Corrective action taken– The same was replaced.

UPPTCL

Case-1 Tripping of 220kV Kanduni-PG 2 line on 25.7.2024 (Lucknow zone)

No. of unwanted operation -1

No. of correct operation-1

No. of failure to operate-0

Reason for indices less than unity – DT received at Kanduni end.

Corrective action taken–Fault at 400kV Substation Khuri road (POWERGRID) removed.

Case-2 Tripping of 400/220kV 500MVA ICT-1 at 400kV Substation Azamgarh (Gorakhpur Zone)

No. of unwanted operation -1

No. of correct operation-1

No. of failure to operate-0

Reason for indices less than unity- Tripped on PRV due to DC cable fault.

Corrective action taken- Rectified on 14.7.2024.

Case-3 Tripping of 220kV Khurja NAPP line (Meerut Zone)

No. of unwanted operation -2

No. of correct operation-1

No. of failure to operate-0

Reason for indices less than unity- At Khurja Substation Damaged cable carrying signals to trip circuit and has operated due to water logging in trenches during severe rain.

Corrective action taken- Control cables of both trip circuits were replaced on 31.7.2024.

Case-4 Tripping of 220kV Debai NAPP line (Meerut Zone)

No. of unwanted operation -2

No. of correct operation-1

No. of failure to operate-0

Reason for indices less than unity- Line tripped at Debai end due to SOTF/TOR when distance protection picked in Zone-3.

Corrective action taken- Protection settings have been checked and revised.

PSTCL

Case-1 Tripping of 500 MVA, 400/220 kV ICT-1 at 400 kV S/S Dhanansu

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Ingress of moisture due to Rain.

Corrective action taken- Officials have been asked to cover it properly.

Case-2 Tripping of 100 MVA, 220/132 kV Power Transformer-2 at 220 kV S/S Science City

No. of unwanted operation -2

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Control cable of NCT damaged.

Corrective action taken- Replaced.

Case-3 Tripping of 500 MVA, 400/220 kV ICT-1 at 400 kV S/S Dhuri

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Due to ingress of moisture in PRD & OSR.

Corrective action taken- Officials have been asked to cover it properly.

Case-4 Tripping of 100 MVA, 220/66 kV Power Transformer-4 at 220kV S/s Patran

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Due to rain & bird's dropping resulting in flashover at LA jumper HV side.

Case-5 Tripping of 220 kV Muktsar-Ghubaya ckt

No. of unwanted operation -1

No. of correct operation-1

No. of failure to operate-0

Reason for indices less than unity- Mal-operation of PDR of CB.

Corrective action taken- Connections tightened in CB marshalling box.

Case-6 Tripping of 220 kV Muktsar-Sandhwan ckt, 220 kV Muktsar-Sadiq ckt, 220 kV Muktsar-Katorewala ckt, 220 kV Muktsar-Bathinda ckt.I, 220 kV Muktsar-Bathinda ckt.II

No. of unwanted operation -0

No. of correct operation-0

No. of failure to operate-0

No. of incorrect operation- 1 on each element

Reason for indices less than unity- Bus fault developed subsequent to tripping of 220 kV Muktsar-Ghubaya circuit. BBPS failed to operate.

Corrective action taken- Due to issue in bus bar operation all feeders were tripped in zone-4 and Bus bar was out due to patch cord issue. The matter will be resolved after installation of new patch cord.

Case-7 Tripping of 220 kV Butari-BBMB Jalandhar ckt in Zone-1 from BBMB end and E/F at Butari end

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Protection coordination issues of E/F relay.

Corrective action taken- Issue is being resolved.

Case-8 Tripping of 100 MVA, 220/66 kV Power Transformer-3 at 220kV S/s Rehana Jattan

No. of unwanted operation -2

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Bucchholz Trip Stage-II, Master operated, due to DC leakage.

Corrective action taken- Partially attended.

Case-9 Tripping of 100 MVA, 220/66 kV, P.T/F T-3 at 220kV S/s Dera Bassi

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Bucchholz Trip Stage-II, Master operated, due to Control cable punctured.

Corrective action taken- Control cable replaced.

Case-10 Tripping of 220kV Bhateri-Faggan Majra ckt. I

No. of unwanted operation -0

No. of correct operation-0

No. of failure to operate-0

No. of incorrect operation- 1

Reason for indices less than unity- Operation of O/C on adjacent circuit due to snapping of conductor.

Corrective action taken- Relays are old. Over current casing may be placed out.

Case-11 Tripping of 220 kV Passiana-Ablowal ckt and 220 kV Passiana-Rajla ckt from Passiana end only

No. of unwanted operation -1 for each element.

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- DC leakage.

Corrective action taken- Partially attended.

Case-12 Tripping of 100 MVA, 220/66 kV Power Transformer-2 at 220kV S/s Sarna

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Control cable damaged by reptiles.

Corrective action taken- Control cable replaced.

Case-13 Tripping of 220 kV Verpal-Udhoke ckt and 220 kV Verpal-Wadala Granthian ckt

No. of unwanted operation -1 for each element.

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Maloperation of DPRs due to damaging of bush of ICT at Wadala granthian.

Corrective action taken- PSL and settings of distance protection relay have been revised.

Case-14 Tripping of 160 MVA, 220/66kV Power Transformer-2 at 220kV S/s Malerkotla

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity- Earth stick comes in induction during attending hot point at 66 kV Naudhrani.

Corrective action taken- Directed concerned officials to take care in future.

Case-15 Tripping of 220 kV Bhawanigarh-Nabha ckt at Bhawanigarh end only

No. of unwanted operation -0

No. of correct operation-0

No. of failure to operate-1

Reason for indices less than unity- failed to trip from Nabha end.

Corrective action taken- Will be taken up.

Case-16 Incorrect operations due to unhealthiness of carrier

Lines subjected- 220 kV Kotla Janga-Kartarpur ckt.II, 220 kV Bathinda-GHTP ckt.I

Due to unhealthiness of carrier, the concerned ends have been getting tripped in zone-2 leading to delayed clearance.

Corrective action taken- Matter is being taken up to resolve. It involves a huge procurement.

POWERGRID – NR-2

Case-1 Tripping of PATIALA 315MVA ICT-I & 500MVA ICT- III

No. of unwanted operation -1 for each element

Reason for indices less than unity- ICTs tripped on operation of 220KV Bus-1 Protection caused by operation of LBB protection of 220KV Nabha-1 due to problem in B-pole CB Patiala (PG).

Case-2 Tripping of DEHAR 315 MVA ICT-I at 220kV side only

No. of unwanted operation -1

Reason for indices less than unity- Tripped due to maloperation of Micom P743 Breaker failure relay owned by BBMB Dehar.

Corrective action taken- BBMB will email settings to POWERGRID for review.

Reasons for Performance Indices less than Unity- August 2024

POWERGRID- NR-2

Case-1 Tripping of 220KV SALAL-JAMMU-II at Jammu end on 07.08.2024

No. of unwanted operation -1

Reason for indices less than unity - Line tripped from Jammu end only due to maloperation of Trip supervision contactor. Dead earth fault was persisting at that time (JKPTCL Station)

Corrective action taken- earth fault at the substation could not be figured out at Jammu.

Case-2 Tripping of 220KV SARNA-DASUYA-I on 16.08.2024

No. of incorrect operation -1

Reason for indices less than unity – Line successfully Auto Reclosed on B-N fault from Dasuya (PSTCL) but tripped from Sarna (PSTCL) due to maloperation of A/R scheme at Sarna (PSTCL). DTPC cable issue.

Corrective action taken- DTPC issue resolved.

Case-3 Tripping of 400KV BHIWANI (BBMB) - RAJPURA (PSTCL) LILO PORTION on 31.08.2024

No. of unwanted operation -1

Reason for indices less than unity – Line tripped from Rajpura (PS) end only due to DT received at Rajpura (PS) PSTCL end caused by maloperation of PLCC at BBMB Bhiwani. PLCC maloperation. PLCC and bay at Bhiwani are owned by BBMB.

Corrective action taken- Wrong PSL in distance protection of the line has been rectified by BBMB at Bhiwani end.

Case-4 Tripping of PATIALA 315MVA ICT-II & 500MVA ICT-IV on 24.07.2024

No. of unwanted operation -1 for each element.

Reason for indices less than unity – ICT-4 TBCB bay wiring issue. During shifting of ICT-4 (214) bay to TBC, +ive voltage extended to trip bus of 220kV Bus-2, resulting in operation of 220KV Bus-2.

Corrective action taken- Rectified.

CCGT Bawana, IPGCL

Case-1 Tripping of Generator Transformer GT – 4 on 18.8.2024 & 25.8.2024

No. of unwanted operation -2

No. of correct operation-2

No. of failure to operate-0

Reason for indices less than unity – On differential tripped due to CT Secondary wire of R – Phase Yard CT (Core 4 & Core 5) from CT Junction Box to CT MK found grounded.

Corrective action taken- New cable laid from R – Phase CT Junction Box to CT MK for Core 4 as well as Core 5

PSPCL (GGSSTPS)

Case-1 the following feeders tripped in Zone-2

1. 220 kV feeder Jadla-1 on 24.08.2024
2. 220 kV feeder Jadla-2 on 24.08.2024
3. 220 kV feeder Gobindgarh-2 on 27.08.2024

Reason for indices less than unity –Due to the unhealthiness of Carrier Communication.

Corrective action taken- In earlier testing, there was no discrepancy found. However, PSTCL will do testing again after taking planned shutdown.

RVPNL

Case-1 Tripping of 400 KV Merta - Bikaner Bay at 400 KV GSS MERTA on 09.08.2024

No. of Unwanted operation – 1

Reason of unwanted operation – DC cable problem initiated the breaker tripping.

Corrective Action taken – DC cable replace and problem rectified.

Case-2 Tripping of 400/220KV 315 MVA ILT-2ND AT 400 KV GSS RATANGARH on 02.08.2024

No. of Unwanted operation – 1

Reason of unwanted operation – Due to DC mixing of source 1 and source 2 at 400KV GSS Ratangarh in 400/220KV 315MVA ILT-2 panel.

Corrective Action taken – DC problem rectified.

Case-3 Tripping of 220 KV Manoharpur - Kukas line at Manoharpur on 01.08.2024

No. of Unwanted operation – 1

Reason of unwanted operation – DC problem due to damage of DC cable at 220 KV GSS Manoharpur.

Corrective Action taken – DC problem rectified.

Case-4 Tripping of 220kV Sri Dungargarh - Ratangarh line at 220KV GSS Ratangarh on 06.08.2024

No. of Unwanted operation – 1

Reason of unwanted operation – CB tripped at Ratangarh end without any indication due to DC problem.

Corrective Action taken – DC problem rectified.

Case-5 Tripping of 220kV Bhilwara Kankroli (PG) line at Bhilwara end on 08.08.2024

No. of Unwanted operation – 1

Reason of unwanted operation – PSL of relay was found wrong, the relay tripped with Carrier healthy signal.

Corrective Action taken – PSL corrected.

Case-6 Tripping of 220 kV Kankroli- Bamantukda Line at 220 KV GSS Bamantukda on 11.08.2024

No. of Unwanted operation – 1

Reason of unwanted operation – LBB relay setting found incorrect.

Corrective Action taken – LBB relay setting corrected.

Case-7 Tripping of 220KV Khetri- Ratangarh Ckt-II line at 220 KV GSS Khetri on dated 21.08.2024

No. of Unwanted operation – 1

Reason of unwanted operation – VT selection relay operation defective, VT output became near to zero.

Corrective Action taken – Problem of VT selection relay rectified.

Case-8 Tripping of 220/132 KV 160 MVA Transformer at 220 KV GSS VATIKA on 30.08.2024

No. of Unwanted operation – 2

Reason of unwanted operation – Main 2 differential relay was installed at the panel with incomplete CT wiring and was put out of ckt by removing DC supply. Workmen unknowingly put on the DC supply fuses.

Corrective Action taken – Main 2 differential relay again put out of circuit.

DTL

Case-1 400kV Mundaka- Bawana Ckt-1 and Ckt-2

No. of unwanted operation -2

No. of correct operation-0

No. of failure to operate-0

Reason of unwanted operation – Fault was in 400kV Bawana-Maharani Bagh Ckt.-1. Main-1 relay (P442) has correctly seen the fault in Zone-2. However, Main 2 Relay (GE make D-60) has seen the fault in Zone-1 and tripped accordingly. Main-2 Relay again saw the fault in Zone-1 even after revision of settings as per OEM recommendation in the month of June-2024.

Corrective Action taken- The issue was again raised with OEM and after further analysis by OEM they have recommended for change in Flex logic of GE make relay. Necessary recommendations were implemented and kept under observations.

PTCUL

Case-1 Tripping of 315 MVA ICT -II (400/220 KV) at 400 KV S/S Kashipur

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason of unwanted operation – transformer tripped without flags due to DC Earth fault.

Corrective Action taken- will look into issue after taking the shutdown.

UPPTCL

Case-1 220kV Parichha to Moth line (Jhansi Zone)

No. of unwanted operation -0

No. of correct operation-1

No. of failure to operate-1

Reason for indices less than unity – At 220kV S/s Moth Bus coupler breaker trip on E/F high set, while line CB did not trip.

Corrective Action taken- Fault got rectified.

Case-2 220kV Debai to Khurja line (Meerut Zone)

No. of unwanted operation -0

No. of correct operation-0

No. of failure to operate-1

Reason for indices less than unity – CB at 220kV Debai end failed to trip as trip signal was transferred to TBC breaker due to mal functioning of BCU.

Corrective Action taken- Trip transfer scheme is permanently shifted to main CB till the time BCU trouble is rectified.

Case-3 Tripping of 500MVA ICT-1 at 400kV Substation Azamgarh (Gorakhpur Zone)

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity –ICT tripped on PRV due to mal functioning of PRV contact due to accumulation of water vapour.

Corrective Action taken- Gasket placed and proper sealing of PRV micro switch has been done.

Case-4 Tripping of 160MVA ICT (220/132kV) -1 at 400kV Substation Agra (Agra Zone)

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity – Due to control cable fault.

Corrective Action taken- Fault rectified.

Case-5 Tripping of 400kV Aligarh Panki line (Agra Zone)

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity – Due to DC Earth fault.

Corrective Action taken- Rectified after finding out cable fault.

Case-6 Tripping of 500MVA ICT-1 (LV side) at 400kV Substation Panki (Agra Zone)

No. of unwanted operation -3

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity – Due to DC Earth fault.

Corrective Action taken- Rectified after finding out cable fault.

Case-7 Tripping of 500MVA ICT-I (HV side) at 400kV Substation Panki (Agra Zone)

No. of unwanted operation -1

No. of correct operation-0

No. of failure to operate-0

Reason for indices less than unity – Due to DC Earth fault.

Corrective Action taken- Rectified after finding out cable fault.

Status of Internal Protection Audit Plan for FY 2024 -25

S. No.	NRPC Member	Category	Status
1	PGCIL	Central Government owned Transmission Company	Received
2	NTPC	Central Generating Company	Received
3	BBMB		Received
4	THDC		Received
5	SJVN		Received (Rampur)
6	NHPC		Received
7	NPCIL		
8	DTL		State Transmission Utility
9	HVPNL	Received	
10	RRVNL	Received	
11	UPPTCL	Received for Jhansi, Lucknow, Meerut, Gorakhpur, Prayagraj, Agra zone)	
12	PTCUL	Received	
13	PSTCL	Received	
14	HPPTCL	Received	
15	IPGCL	State Generating Company	Received (PPCL)
16	HPGCL		
17	RRVUNL		Received
18	UPRVUNL		Received (obra -B, Anpara-B switch yard, Harduganj-C,D,E))
19	UJVNL		Received (Khodri, Chibro, Vyasi)
20	HPPCL		
21	PSPCL	State Generating Company & State owned Distribution Company	
22	HPSEBL	Distribution company having Transmission connectivity ownership	
23	Prayagraj Power Generation Co. Ltd.	IPP having more than 1000 MW installed capacity	Received
24	Aravali Power Company Pvt. Ltd		Received
25	Apraava Energy Private Limited		Received
26	Talwandi Sabo Power Ltd.		
27	Nabha Power Limited		
28	MEIL Anpara Energy Ltd		
29	Rosa Power Supply Company Ltd		Received
30	Lalitpur Power Generation Company Ltd		Received
31	MEJA Urja Nigam Ltd.		
32	Adani Power Rajasthan Limited		Received
33	JSW Energy Ltd. (KWHEP)	Received	
34	AESL	Other transmission licensee	Received (ATIL -400kV Mohindergarh S/s, OBTL, FBTL, MTSCL, ATSCL, HPTSL, BKTL, GTL)
35	Tata Power Renewable Energy Ltd.		Received (TPGEL, BTPSL)
36	UT of J&K	UT of Northern Region	
37	UT of Ladakh		
38	UT of Chandigarh		
39	INDIGRID		Received
40	POWERLINK		
41	ADHPL		Received
42	Sekura Energy Limited		
43	WUPPTCI	Other transmission licensee in UP	
44	SEUPPTCL	Other transmission licensee in UP	
45	Vishnuprayag Hydro Electric Plant (J.P.)	Other Generating Units in UP	Received
46	Alaknanda Hydro Electric Plant (GVK)	Other Generating Units in UP	

Status of 3rd Party Protection Audit Plan

S. No.	NRPC Member	Category	Status	Schedule submitted as per utility	Present Status Completed (yes/no)
1	PGCIL	Central Government owned Transmission Company			
2	NTPC	Central Generating Company	Received (Tanda)	By 17.07.2025	
3	BBMB				
4	THDC		Received (Tehri)	March 2026	
5	SJVN		Received	FY-2025-26 for RHPS, Nov 24- March 25 for NJHPS	
6	NHPC		Received	FY-2025-26	
7	NPCIL				
8	DTL	State Transmission Utility			
9	HVPNL				
10	RRVPNL				
11	UPPTCL				
12	PTCUL				
13	PSTCL				
14	HPPTCL				
15	IPGCL				
16	HPGCL	State Generating Company			
17	RRVUNL		Received (DTPS-Anpara)	01.05.2024	Revised schedule will be submitted
18	UPRVUNL				
19	UJVNL				
20	HPPCL				
21	PSPCL	State Generating Company & State owned Distribution Company			
22	HPSEBL	Distribution company having Transmission connectivity ownership			
23	Prayagraj Power Generation Co. Ltd.	IPP having more than 1000 MW installed capacity	Received	Dec-24	
24	Aravali Power Company Pvt. Ltd				
25	Apraava Energy Private Limited		Received	By May, 2025	
26	Talwandi Sabo Power Ltd.				
27	Nabha Power Limited				
28	MEIL Anpara Energy Ltd				
29	Rosa Power Supply Company Ltd		Received	By 30.09.2024	
30	Lalitpur Power Generation Company Ltd		Conducted	26.03.2024	
31	MEJA Urja Nigam Ltd.				
32	Adani Power Rajasthan Limited		Received (Kawai)	September, 2024	
33	JSW Energy Ltd. (KWHEP)	Received	December 2024 to March 2025		
34	AESL	Other Transmission Licensee	Received (ATIL -400kV Mohindergarh S/s.)	400kV Mohindergarh SS- Q2 , FY 2025-26	
			Received (OBTL)	OBTL-Q1 , FY 2025-26	
			Received (FBTL)	FBTL-Q3 , FY 2025-26	
			Received (MTSCL)	MTSCL-Q4 , FY 2025-26	
			Received (ATSCL)	ATSCL-Q1 , FY 2026-27	
			Received (HPTSL)	HPTSL- Q2 , FY 2026-27	
			Received (BKTL)	BKTL-Q3 , FY 2026-27	
			Received (GTL)	GTL- Q3 & Q4, FY 2026-27	
35	Tata Power Renewable Energy Ltd.	IPP having less than 1000 MW installed capacity (alphabetical rotaional basis)			
36	UT of J&K	UT of Northern Region			
37	UT of Ladakh				
38	UT of Chandigarh				
39	INDIGRID				
40	POWERLINK				
41	ADHPL		Received	30.09.2024	
42	Sekura Energy Limited				
43	WUPPTCI	Other transmission licensee in UP	Received	*2024-25	
44	SEUPPTCL	Other transmission licensee in UP			
45	Vishnuprayag Hydro Electric Plant (J.P.)	Other Generating Units in UP			
46	Alaknanda Hydro Electric Plant (GVK)	Other Generating Units in UP			

* Revised Schedule

POWERGRID NR-2 400/220kV GIS Chamba

Protection Audit report – 400/220 KV GIS Chamba Substation**Observations during Protection Audit carried out on 28th June -29th June 2024**

1. Settings for protection relays to be implemented as per Latest Template & COE observations. All the protection templates need to be upgraded with the latest version and new fault current level. PSL/ Application configuration/CFC also needs to be modified as per the new templates wherever applicable.
2. Preventive maintenance record of protection system for not available with site except 400kV Bus Reactor-2, 400kV Chamba-Lahal ckt-1&2 & 207 bay (Majra line).
3. Tap position of ICT-1 R-phase is showing erroneous value i.e. -28 in SAS and same needs to be rectified.
4. ICT-2 WTI HV Y-Phase & WTI LV R-Phase are showing erroneous value in SAS. WTI HV Y-Phase: 76° & WTI LV R-Phase: -8.21°. same needs to be rectified.
5. BR-1 WTI is reporting erroneous value i.e 70° in SAS whereas 32° in WTI, same needs to be rectified.
6. In BR-1, Group-B Protection DC fail alarm persisting in DIFF relay but not showing SAS, on fail of actual DC-2, no change in alarm, same needs to be rectified.
7. In BR-1, on switch off Power supply of REF, Diff & BUI relay, no event/alarm of relays unhealthy in SAS, needs to be rectified.
8. ABB make CSD of BR-1 is not reporting to SAS.
9. Mutual Compensation wiring of Main-1 Relay (REL670) of 400kV Chamba-Lahal Ckt-1&2 not connected properly, same needs to be corrected.
10. Goose IED absent alarm is persisting in Main-2(P444) of 220kV Chamba-Karian, 220kV Chamba- Majra Line but not reporting to SAS, needs to be rectified.
11. Goose receives fail alarm persisting in Main-1 relay of 400kV Chamba-Lahal Ckt-2, same needs to be rectified.



12. CN-1 Carrier fail alarm persisting in 220 KV Chamba-Karian line (Bay 206).
13. 220KV Chamba- Majra Line PLCC counters are not reporting in SAS.
14. Most of Indication lamps for CB/Isolators status are not working.
15. LT system (Tertiary & HPPCL supply) Voltage is not reporting in SAS-1 but reporting in SAS-2, needs to be rectified.
16. DG is working in Manual Mode. However, ACDB B/C is not working in Auto Mode, therefore DG unable to operate on Auto Mode. Same needs to be rectified.
17. Battery Room Temp is not reporting in SAS.
18. 50V Battery Charger-1 & 2 current and voltage are not reporting correctly needs to be rectified. SAS Value: Charger-1: -18V & 600A, & Charger-2: -18V & -4.5A.
19. 220V Battery Charger-1 & 2 current is not reporting correctly needs to be rectified. SAS Value: Charger-1: -0A, & Charger-2: -0A.
20. In 220V Battery Charger-1, Ammeter found defective, same needs to be replaced.
21. Firefighting pressure showing Zero in SAS, needs to be rectified.
22. Fire diesel engine is not functional in auto mode, same needs to be made functional in auto mode.
23. Out of 8 cameras, 7 are working and 1 (Camera No.-08) is not functional, same needs to be made functional.
24. DC voltage measured during audit, no DC earth fault present. Setting for E/F relay kept as 0.3 mA.
 - a. 220V Source 1: +123.4V, -123.2V 48V Source 1: +0.5V, -51.5V
 - b. 220V Source 2: +122.6V, -124.2V 48V Source 2: +0.7V, -52.0V
25. DC earth fault is simulated in 220 V DC Source-2. No Voltage deflection detected in DC source-1:- No mixing found.







26. Logic for PRD trip with NO/NC & OTI/WTI trip with time delay 20ms and Buch Alarm/Trip with time delay 200ms is implemented in ICT-1,2 & BR-1,2.

27. 02 nos. Carrier switch out signals simulated. Found ok and reported to SAS.

28. Smoke detectors simulated from 3 no. zones (Zone-2, Zone-3 & Zone-5). Found ok and reported to SAS.

Rectification during Audit-

1. ICT-1 RY phase voltage is showing 93kV in SAS, rectified during audit.
2. In BR-2, REF relay found out of time sync, rectified during audit.
3. In BR-2, REF Stabilizing Resister found defective, replaced and value set as per Template i.e. 219 Ω during audit.

AUDITEE	AUDITOR
 VIKENDER SINGH, DM	 NARESH KUMAR, AM
ABHISHEK KUMAR, JE	

Protection Check-List

Name:- 400/220KV GIS CHAMBA Month and Year of Commissioning:- December 2011 Date of audit:- 28 TH to 29 th JUNE-2024		Status (OK/ Not Ok)	Remarks
Element	Description		
Main-I/Main-II	Check the settings Parameters with respect to the template updated with latest in-feed values	OK	To be updated as per Latest template and COE observation
	Check the Signal Matrix/PSL/Application Configuration/Masking with respect to the Input and Output assignment as per scheme	OK	
	Check the Logic for DT send	OK	
	Check the Logic for 86A and 86B trip	OK	
	Check the Logic for single phase tripping	OK	
	Check the Logic for LBB Initiations	OK	
	Check the Logic for A/R starts	OK	
	Check the Logic of STUB protection & Line Isolator open status (to be enable for one & Half CB scheme having no Line side CT and to be disable for DMT scheme & having Line side CT)	NA	
	Check that the wiring of Line Isolator open is connected at correct input for Stub Protection	NA	
	Check the Logic for SOTF protection	OK	
	Check that OV protection is analog (Voltage) as well as time graded for Double Ckt/Parallel lines	OK	
	Check that the VT fail shall block the tripping	OK	
	Check the current, voltage and angle in the relay	OK	
	Check for mutual compensation wiring (if applicable) and Check setting and configuration according to wiring.	OK	400kV Lahal-1&2 Main-1, wiring found not ok.
	Whether all relays are accessible from remote dedicated PC for setting & DR extraction in control room	OK	
	Whether Main-I & Main-II protections of all line are time synchronised with GPS based time synchronised equipment.	OK	
PLCC	Check the healthiness of PLCC protection panels	OK	Ch-1 fail of 220 KV Karian line (Bay-206)
	Check alarm during OUT position of Carrier IN/OUT Switch in Control room as well as in RTAMC/NTAMC	OK	
Auto Reclosure	Check the logic and configuration of the AR Start and Block	OK	
	Check the dead time and reclaim time settings	OK	
	Check the Logic and Configuration of the AR Lockout	OK	
	Check the logic & wiring for Priority Ckt in one & Half CB scheme.	NA	
	Whether priority scheme is working properly (check previous A/R DR)	NA	

[Handwritten Signature]

[Handwritten Signature]

Protection Check-List

LBB relay/PU relay	Check the relay settings (particularly, pick-up, retrip time and back-trip time)		OK	TEMPLATE NOT AVAILABLE.
	Check that single phase initiation is wired and configured correctly for lines		OK	
	Check the logic that re-trip trips the same breaker		NA	
	Check the Signal Matrix/PSL/Application Configuration with respect to the Input and Output assignment as per scheme		OK	
	Check the logic that back-trip trips the associated bus-bar(for Main-CB LBB) OR both the Main-CB (for Tie CB LBB)		OK	
	In case of half dia, check that the Tie Bay LBB instantaneously trips the Bus connected to future bay(also check the wiring)		NA	
	For bays commissioned in the extension projects have Tie-LBB wiring changed from "Tripping the bus" to "Tripping the Main CB"		NA	
	Dead Zone/ End zone Protection is disabled; Topology is independent of switch status in One and Half CB scheme		NA	
	Check/measure phase wise current in LBB/PU relay		OK	
Reactor/Transformer Differential	Check the differential current and bias current in the relay		OK	
	Check the relay settings as per the template		OK	TO BE UPDATED AS PER COE OBSERVATIONS & LATEST TEMPLATE
	Check the relay configuration for proper input and output contact assignment.		OK	
	Check the tripping logic wrt the scheme.		OK	
	In case of single phase transformer with spare, check the correct implementation of spare selection in trip logic		NA	
REF protection	Check the current in the relay		OK	
	Check the relay settings as per the template		OK	TO BE UPDATED AS PER COE OBSERVATIONS & LATEST TEMPLATE
	Check the relay configuration for proper input and output contact assignment.		OK	
	Check the tripping logic wrt the scheme.		OK	
	In case of single phase transformer with spare, check the correct implementation of spare selection in trip logic		NA	
	Check for the CT selection scheme and logic		NA	
Back-up	Check the current and voltage in the relay		OK	

As per relay

21/08/20

Protection Check-List



impedance				
	Check the VT selection logic in BCU/relay panel		OK	
	Check that at a time only one bus VT is selected		OK	
	Check the relay settings as per the template		OK	TO BE UPDATED AS PER COE OBSERVATIONS & LATEST TEMPLATE
	Check the relay configuration for proper input and output contact assignment.		OK	
	Check the tripping logic wrt the scheme.		OK	
	Check that VT fail blocks the tripping		OK	
	Check for implementation of NGR protection scheme		NA	
CSD	Check whether CSD installed with ICT/Reactor is working properly as per its requirement. (Check recent graph/DR)		OK	BR-1 CSD IS NOT Reporting to SAS.
	Check provision of bypassing of CSD is provided		OK	
	Check DR triggering of other relay on Manual operation of CB in case CSD is not having the provision of extraction of DR/graph.		OK	
General	Check that the two trippings of PRD, Buchholz etc are wired to two separate relays		OK	
	Check that the relays powered by DC-1 are supervised by relays powered by DC-2 and Vice-versa		OK	
	Check Relay Failure and Relay disconnected alarms for all the relays.		OK	
	Check for time-sync status of the relay		OK	
	Check the DR channel standardisation		OK	TO BE UPDATED AS PER LATEST CIRCULAR.
	Check pre-commissioning test reports (whether print-outs of DR and EL enclosed)		OK	
	Check the logic of Bus earth switch interlock		OK	
	Check the auto download of DR		NOT OK	TO BE IMPLEMENTED.
	Check for implementation of relevant CC-AM circulars		OK	
	Check the single point earthing of CT secondary core on sample basis.		OK	
	Check the earthing interconnecting link/strip connected in inter panel/adjacent panel		OK	
	Back up of important data of sub-station		OK	
Bus Bar Protection	Whether duplicate bus bar protection provided in 400 & 765 kV Bus bar		OK	

Handwritten signature

Handwritten signature

Protection Check-List

	Check the topology of both the CUs		NA	
	Check the Diff current and restrain current		OK	
	Check /Measure the Spill current in bus-bar relay		OK	
	Check that CB status is permanently shorted in one and half CB scheme		NA	
	Check the operation of the selector switch and correct alarms in SCADA		OK	
	Check the settings and Configuration of the CU		NA	
	Simulate PU disconnected and check for Bus Bar Block		NA	
	Check the setting of CT supervision/CT fail/CT circuitry fault alarm		OK	
	Check logic for LBB initiation on bus bar trip		OK	
	Check the logic for BUS Bar Tripping on SF6 Gas compartment zone trip in case of GIS Station.		NA	
	Check that the Bus-Bar bay selection is independent of the topology status in One and Half CB schemes		NA	
SAS	As per Annexure-I (SAS Checklist)		OK	
Alarms	Simulate the alarms as per Annex-II for at least 20% bays, Minimum 6 bays.		OK	
DC System	Check DC voltage at the farthest point in the switchyard (+ to Earth, - to earth)		OK	
AC system	Check auto operation of DG set		OK	
FFPH	Check auto operation of HVW and Diesel driven pump		OK	Diesel Engine Not working on Auto Mode.
Smoke detection system	Simulate smoke detection in any kiosk and check for alarm		OK	

AUDITEE	AUDITOR
 VIKENDER SINGH, DM	 NARESH KUMAR, AM
ABHISHEK KUMAR, JE	

Rajasthan Rajya Vidhyut Prasaran Nigam
Report of the Protection Audit-M/O-MAY 2024

1 Date of Audit - 23.5.2024

A. General Information
(a) Name of Utility:- 220 KV GSS HAMIRGARH
(aa) Date of Commissioning:- 20.03.1996
(c) Name and Organization of Audit Team:- AEN (AP/T&S) RVP/NL, BHILWARA

(b) Name of Voltage Level of Sub Stations:- 220/132 KV
(ba) Type of Bus Switching Scheme:- Two Main Bus and Aux. Bus
(cb) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVP/NL, HAMIRGARH

B. Check List for Protection Audit

S No	Check	Functional/Non-functional/Failed/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
(1)	Transformer Protection Panel: Name of Transformer (Rating/Capacity) Tripping by Buschholz relay (Alarm)	220/132, 160MVA Transformer-1 (ALSTOM Make)	Conventional		
	Differential Protection	Functional	Conventional		
	2nd Harmonic Block (Setting)	Yes Enabled	Numerical	pick-up- 0.2 pu slope 1 - 0.3, slope 2-0.7	
	Event logger Operation	No (No Event logger Installed)		15%	
	Restricted Earth Fault Protection (11V Side)	Yes Functional	Numerical	20%	
	Event logger Operation	No (No Event logger Installed)		20%	
	Restricted Earth Fault Protection (LV Side)	Yes Functional	Numerical	20%	
	Event logger Operation	No (No Event logger Installed)		54%, CTR-800/1	
	Backup Over Current	Yes Functional	Numerical	30%	
	Event logger Operation	No (No Event logger Installed)			
	Earth Fault Protection	Yes Functional	Numerical		
	Event logger Operation	No (No Event logger Installed)			
	Over Flux Protection	Yes Enabled	Numerical	alarm -110%, 5 sec , Trip- As per inverse curve characteristics	
	Event logger Operation	No (No Event logger Installed)			
	Local Breaker Back Trip	YES Feature enabled in Bus bar scheme, no separate LBB Relay	Numerical		
	Current and Time Setting	yes		100 msec	
	Separate Single and three Phase Initiation	no		120% Inernal, 100 msec	
	Earth Fault	no		three phase initiation	
	Event logger Operation	no			

Udeep shukla
ASSISTANT ENGINEER (P&T&S)
RRV/PN, BHILWARA

Dr. of Audit - 22.05.2024.

Sl. No.	Name of Transformer (Rating/Capacity) Topology by Buchholz relay (Alarm)	220/132, 100MVA Transformer-1 (BHFL Make)	Conventional	
	Differential Protection	Yes	Functional	Conventional
	3rd Harmonic Block (Setting)	Yes	Functional	pick-up: 0.2 pu, slope: 1 - 0.2, slope: 2.0-7
	Event logger Operation	No	(No Event logger installed)	15% (Inbuilt)
	Restricted Earth Fault Protection (11V Side)	No	(No Event logger installed)	20%
	Event logger Operation	No	(No Event logger installed)	20%
	Restricted Earth Fault Protection (LV Side)	No	(No Event logger installed)	
	Event logger Operation	No	(No Event logger installed)	
	Backup Over Current	Yes	Functional	57% CTR-100, 1A
	Event logger Operation	No	(No Event logger installed)	
	Earth Fault Protection	Yes	Functional	20%
	Event logger Operation	No	(No Event logger installed)	
	Over Flux Protection	Yes	Enabled	alarm - 110%, 5 sec Trip- As per inverse curve characteristics
	Event logger Operation	No	(No Event logger installed)	
	Local Breaker Back Up	YES	Feature enabled in Bus bar scheme, no separate LBB Relay	Numerical
	Recip	No	Enabled	100 msec
	Current and Time Setting	No		120% Innormal, 100 msec
	Separate Single and three Phase Initiation	No		three phase initiation
	Earth Fault	No	DISABLED	
	Event logger Operation	No	(No Event logger installed)	

Subodh Kumar
ASSISTANT ENGINEER (MPT&S)
 RRVP/NL, BHILWARA

Date of Audit - 23.05.2024.

Rajasthan Rajya Vidhyut Prasaran Nigam
Report of the Protection Audit

- A General Information
 (i) Name of Units - 220 KV GSS HAMIRGARH
 (ii) Name of Commissioning - 30.03.1996
 (iii) Name and Organization of Audit Team - A/E(N/MP/RS) RVPNL, BHILWARA
 (iv) Name of representative from utility whose audit being carried out - X/E/N 220KV GSS RVPNL, HAMIRGARH
 (v) Name of Voltage Level of Sub-Station - 220/132 KV
 (vi) Type of Bus Switching Scheme - Two Main Bus and Aux Bus

B. Check List for Protection Audit

S No	Check	Functional/Non-functional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
Distance Protection Panel-M/D11					
(1)	Name of Line	220KV Hamirgarh-Bhilwara line			
	Pole Discrepancy Relay	YES	Functional		
	PI/CC Panel	Yes	Functional	1 sec	
	Zone-1, 2, 3, 4, 5 (Settings)	Yes	Enabled		
	Time Check-Z/1, 2, 3, 4, 5(Settings)	Yes	Enabled		
	SO/T	YES	Disabled		
	Aided Scheme	YES	Enabled		
	Fault Locator	YES	Enabled		
	Power Swing (Setting R & X)	Yes	Enabled		
	All Zone Block	Yes	Enabled		
	DR	Yes	Enabled		
	Binary Inputs	Yes	ENABLED		
	Breaker Contacts	Yes	ENABLED		
	Carrier Receive	YES	ENABLED		
	Time Synchronization	YES	ENABLED		
			Numerical	As per latest Code of Configuration	

(1)	Name of Line	220KV Hamirgarh-Bhilwara line			
	Pole Discrepancy Relay	YES	Functional		
	PI/CC Panel	Yes	Functional	1 sec	
	Zone-1, 2, 3, 4, 5 (Settings)	Yes	Enabled		
	Time Check-Z/1, 2, 3, 4, 5(Settings)	Yes	Enabled		
	SO/T	YES	Disabled		
	Aided Scheme	YES	Enabled		
	Fault Locator	YES	enabled		
	Power Swing (Setting R & X)	Yes	Enabled		
	All Zone Block	Yes	Enabled		
	DR	Yes	Enabled		
	Binary Inputs	Yes	ENABLED		
	Breaker Contacts	Yes	ENABLED		
	Carrier Receive	YES	ENABLED		
	Time Synchronization	YES	ENABLED		
			Numerical	As per latest Code of Configuration	

Sd/-
ASSISTANT ENGINEER (MP/RS)
 RVPNL, BHILWARA

Date of Audit - 22.05.2024.

Rajasthan Rajya Vidyut Prasaran Nigam
Report of the Protection Audit

- A. General Information
- (i) Name of Feeder - 220 KV GSS HAMIRGARH
- (ii) Name of Voltage Level of Sub Station - 220/132 KV
- (iii) Date of Commissioning - 20/03/1996
- (iv) Type of Bus Switching Scheme - Two Main Buses and Aux Bus
- (v) Name and Organization of Audit Team - AIN (MPT&S) RVPNL BHILWARA
- (vi) Name of representative from utility whose audit being carried out - XEN 220KV GSS RVPNL HAMIRGARH

B. Check List for Protection Audit

S No	Check	1	Functional/Nonfunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
1	DC System	1	Functional	Electromechanical	20%	
	No. Of Independent DC Source	116 V				
	Potential Between -ve & Earth (Source-1)	118 V				
	Potential Between -ve & Earth (Source-1)					
2	Event Logger Panel	No				
3	Event Logger Time Synchronised	No				
	Disturbance Recorder	No				
	DR Time Synchronised	No				
4	Bus Bar Protection	Yes				
	Supply Check	Yes				
	TL Output for this Event	Yes				
	DR of Available	Yes				
5	DC Set	No				
	Mock Testing of Sample Protection Associated with Transmission line	Yes				
6	LBB/BPR	No				
	Retrip	No				
	Current and Time Setting	No				
	Separate Single and Three Phase Initiation	No				
	Earth Fault	No				
	Event Logger Operation	No				

Lokesh

ASSISTANT ENGINEER (MPT&S)
RVPNL, BHILWARA

Date of Audit - 22.05.2024.

Rajasthan Rajya Vidhyut Prasaram Nigam
Report of the Protection Audit

- A. General Information
- (i) Name of Utility - 220 KV GSS HAMIRGARH
(ii) Date of Commissioning - 20.03.1996
(iii) Name and Organization of Audit Team - MEN (MPT&S) RVPNL, BHILWARA
(iv) Type of Bus Switching Scheme - Two Main Bus and Aux Bus
(v) Name of representative from utility whose audit being carried out - XEN 220KV GSS RVPNL, HAMIRGARH

B. Check List for Protection Audit

S No	Check		Functional/Non-functional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Reactor Protection Panel:	NA	No reactor installed			
	Tripping by Buchholz relay (Alarm)	No				
	Differential Protection	No				
	2nd Harmonic Block (Setting)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (HV Side)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (LV Side)	No				
	Event logger Operation	No				
	Backup Over Current	No				
	Event logger Operation	No				
	Earth Fault Protection	No				
	Event logger Operation	No				
	Over Flux Protection	No				
	Event logger Operation	No				

Subhash Kumar

ASSISTANT ENGINEER (PT&S)
RVPNL, BHILWARA

RRVPN 220kV IG Nagar S/s

Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information


i)	Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kV GSS Indira Gandhi Nagar
iii)	Date of Commissioning:	25.02.2011
iv)	Type of Bus Switching Scheme	Two Main Bus (One & Half scheme)
v)	Name and Organization of Audit Team	Sh. Mukul Yadav, AEN-III (MPT&S), RVPN, Jaipur
		Sh. Munesh Kumar Meena , JEN-I O/o AEN-III (MPT&S), RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh. D.K. Jain, SE (Prot. Engg.) RVPNL Jaipur

B. Checklist for Protection Audit


S.No.	Check		Functional/ Non- Functional/ Enabled/Di sabled	Type of Relay*(Numerical/St atic/Electromechani cal)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
Distance protection Panel:M-I/II						
(i)	Name of Line	220 kV PGCIL Bassi Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=4.897 Ohm, T1=0 ms Z2=9.162 Ohm, T2=350 ms Z3=13.958 Ohm, T3=1000 ms Z4(Rev.)=408 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional			
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying

S.No.	Check		Functional/ Non- Functional/ Enabled/Di sabled	Type of Relay*(Numerical/St atic/Electromechani cal)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
	Power swing(S(settings R and X)				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of Numerical Distance	-	Complying
	DR	Yes	Enabled	Protection Relays	-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying
(ii)	Name of Line	220 kV Heerapura Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 Sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=5.877 Ohm, T1=0 ms Z2= 7.989 Ohm, T2=350 ms Z3=10.825 Ohm, T3=1000 ms Z4(Rev.)=408 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional			
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, 1 Phase Z1 Z2+CR	Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying
	Power swing(S(settings R and X)				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of	-	Complying
	DR	Yes	Enabled	Numerical Distance	-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying
	Distance protection Panel:M-I/II	220 KV Sitapura Line				
(iii)	Name of Line	220 KV Sitapura Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional			
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=1.722 Ohm, T1=0 ms Z2=3.275 Ohm, T2=350 ms Z3=4.622 Ohm, T3=1000 ms Z4(Rev.)=408 mOhm, T4=160 ms	Complying

S.No.	Check		Functional/ Non- Functional/ Enabled/Di sabled	Type of Relay*(Numerical/St atic/Electromechani cal)	Setting as found in field**	Compliance status w.r.t. regulatory provisions
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying
	Power swing(S(settings R and X)				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of	-	Complying
	DR	Yes	Enabled	Numerical Distance	-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying

Name. Signature & Contact No. of team Carrying out Protection audit:	1. Mukul Yadav, AEN-III (MPT&S), Jaipur 9413382334	
	2. Munesh Kr. Meena, JEN-I O/o AEN-III (MPT&S), Jaipur 9413383124	
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:	1. Dinesh Kumar Jain, SE (Prot.Engg.), RVPN, Jaipur, 9413393540	

Distance relay calculation for 220 KV IG Nagar-PGCIL Bassi Line



EARTH FAULT COMPENSATION

$$R_E/R_L = 1/3((R_o/R_1)-1)$$

$$X_E/X_L = 1/3((X_o/X_1)-1)$$

$$kZ_0 \text{ Res. Comp.} = kZ_0 = (Z_0 - Z_1) / 3Z_1$$

Principle line Length : 30 KM.
Shortest Line Length considered on Remote Bus : 29.8 KM.
Longest line length Considered on Remote Bus : 34.91 KM.

Conductor Used : Zebra
Conductor Parameters :

	R	X	Z	Angle
Positive Sequence(Z₁):	0.081	0.4	0.408	78.55
Zero Sequence(Z₀):	0.2875	1.275	1.307	77.29
CTR:	1000/1 Amp= 1000			
PTR:	220000/110 V= 2000			
CTR/PTR:	0.5			

kZ₀ : 0.734
kZ₀ angle : -1.83

Zone 1(Forward) Reach: 80 % of the Line to be Protected
Zone 2(Forward) Reach: 50 % of the Shortest Line on remote Bus+100 % of the Protected Line

Zone 3(Forward) Reach: 110 % Longest line length on Remote Bus+100 % of the Protected Line
 Zone 4(Reverse) Reach: 2 Km

Zone 1 forward Reach= 80% of line length (IG Nagar to PGCIL)* +ve Sequence impedance of conductor/km*(CTR/PTR)

= 4.897 Ohm T1= Instt.

Zone 2 forward Reach= 100% of line length (IG Nagar to PGCIL)+50 % of the Shortest Line on remote Bus(PGCIL-Dausa)*+ve Sequence impedance of conductor/km*(CTR/PTR)

= 9.162 Ohm T2=350 ms

Zone 3 forward Reach=100% of line length (IG Nagar to PGCIL)+110 % Longest line length on Remote Bus(PGCIL-KKD)*+ve Sequence impedance of conductor/km*(CTR/PTR)

= 13.958 Ohm T3=1000 ms

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)

= 0.408 Ohm T4=160 ms

Directional O/C & E/F relay calculation for 220 kV IG Nagar-PGCIL Bassi Line

Fault MVA of 220 kV BUS : 8555 MVA
 3 Phase Short Circuit Current : 15891 Amp
 Phase-Phase Short Circuit Current : 13762 Amp
 Phase to Earth Short Circuit Current : 8581 Amp


Directional Overcurrent Element Setting

CT Ratio 1000/1
 Plug Setting 100% i.e. 1000 Amp
 Plug Setting Multiplier 13.762
 Time of Operation 0.5 Seconds
 TMS 0.192

Directional Earthfault Element Setting

CT Ratio 1000/1
 Plug Setting 20 % i.e. 200 Amp
 Plug Setting Multiplier 42.905
 Time of Operation 0.5 Seconds
 TMS 0.227

Distance relay calculation for 220KV IG NAGAR -Heerapura Line



Principle line Length : 36 KM.
Shortest Line Length considered on Remote Bus : 6.3 KM.
Longest line length Considered on Remote Bus : 15.5 KM.

Conductor Used : Zebra
Conductor Parameters :

	R	X	Z	Angle
Positive Sequence(Z1):	0.081	0.4	0.408	78.55
Zero Sequence(Z0):	0.2875	1.275	1.307	77.29
CTR:	1000/1 Amp= 1000			
PTR:	220000/110 V= 2000			
CTR/PTR:	0.5			

Zone 1(Forward) Reach: 80 % of the Line to be Protected
Zone 2(Forward) Reach: 50 % of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach: 110 % Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach: 2 Km

EARTH FAULT COMPENSATION

$$RE/RL=1/3((Ro/R1)-1)$$

$$XE/XL=1/3((Xo/X1)-1)$$

$$kZ0 \text{ Res. Comp.} = kZ0 = (Z0 - Z1) / 3Z1$$

kZ0 : 0.734
kZ0 angle : -1.83

Zone 1 forward Reach= 80% of line length (IG Nagar to Heerapura)* +ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{5.877} \text{ Ohm} \quad T1 = \text{Instt.}$$

Zone 2 forward Reach= 100% of line length (IG Nagar to Heerapura)+50 % of the Shortest Line on remote Bus(Heerapura-Mansarover)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{7.989} \text{ Ohm} \quad T2 = 350 \text{ ms}$$

Zone 3 forward Reach=100% of line length (IG Nagar to Heerapura)+110 % Longest line length on Remote Bus(Heerapura-VKIA)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{10.825} \text{ Ohm} \quad T3 = 1000 \text{ ms}$$

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{0.408} \text{ Ohm} \quad T4 = 160 \text{ ms}$$

Directional O/C & E/F relay calculation for 220 kV IG Nagar-Heerapura Line

Fault MVA of 220 kV BUS	:	8555 MVA
3 Phase Short Circuit Current	:	15891 Amp
Phase-Phase Short Circuit Current	:	13762 Amp
Phase to Earth Short Circuit Current	:	8581 Amp


Directional Overcurrent Element Setting

CT Ratio	1000/1	
Plug Setting	100 % i.e.	1000 Amp
Plug Setting Multiplier	13.762	
Time of Operation	0.5	Seconds
TMS	0.192	

Directional Earthfault Element Setting

CT Ratio	1000/1	
Plug Setting	20 % i.e.	200 Amp
Plug Setting Multiplier	42.905	
Time of Operation	0.5	Seconds
TMS	0.227	

Distance relay calculation for 220 KV IG Nagar -Sitapura Line



Principle line Length 10.55 KM.
Shortest Line Length considered on Remote Bus 11 KM.
Longest line length Considered on Remote Bus 11 KM.

EARTH FAULT COMPENSATION

$$R_E/R_L = 1/3((R_o/R_1)-1)$$

$$X_E/X_L = 1/3((X_o/X_1)-1)$$

$$kZ_0 \text{ Res. Comp.} = kZ_0 = (Z_0 - Z_1) / 3Z_1$$

kZ0 **kZ0 angle**
0.734 **-1.83**

Conductor Used	:	Zebra			
Conductor Parameters	:	R	X	Z	Angle
Positive Sequence(Z1):		0.081	0.4	0.408	78.55
Zero Sequence(Z0):		0.2875	1.275	1.307	77.29
CTR:		1000/1 Amp= 1000			
PTR:		220000/110 V= 2000			
CTR/PTR:		0.5			

Zone 1(Forward) Reach: 80 % of the Line to be Protected
Zone 2(Forward) Reach: 50 % of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach: 110 % Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach: 2 Km

Zone 1 forward Reach= 80% of line length (IG Nagar to Sitapura)* +ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{1.722} \text{ Ohm} \quad T1 = \text{Instt.}$$

Zone 2 forward Reach= 100% of line length (IG Nagar to Sitapura)+50 % of the Shortest Line on remote Bus(Sitapura-Sanganer)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{3.275} \text{ Ohm} \quad T2=350 \text{ ms}$$

Zone 3 forward Reach=100% of line length (IG Nagar to Sitapura)+110 % Longest line length on Remote Bus(Sitapura-Sanganer)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{4.622} \text{ Ohm} \quad T3=1000 \text{ ms}$$

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{0.408} \text{ Ohm} \quad T4=160 \text{ ms}$$

Directional O/C & E/F relay calculation for 220 kV IG Nagar -Sitapura Line

Fault MVA of 220 kV BUS	:	8555 MVA
3 Phase Short Circuit Current	:	15891 Amp
Phase-Phase Short Circuit Current	:	13762 Amp
Phase to Earth Short Circuit Current	:	8581 Amp

Directional Overcurrent Element Setting

CT Ratio	1000/1		
Plug Setting	100% i.e.	1000	Amp
Plug Setting Multiplier	13.762		
Time of Operation	0.5	Seconds	
TMS	0.192		

Directional Earthfault Element Setting

CT Ratio	1000/1		
Plug Setting	20 % i.e.	200	Amp
Plug Setting Multiplier	42.905		
Time of Operation	0.5	Seconds	
TMS	0.227		

Rajasthan Rajya Vidhyut Prasaran Nigam Limited

Report of the Protection Audit



A. General Information

i)	Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kV GSS Indira Gandhi Nagar
iii)	Date of Commissioning:	25.02.2011
iv)	Type of Bus Switching Scheme	Two Main Bus (One & Half scheme)
v)	Name and Organization of Audit Team	Sh. Mukul Yadav, AEN-III (MPT&S), RVPN, Jaipur
		Sh. Munesh Kumar Meena, JEN-I O/o AEN-III (MPT&S), RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh. D.K. Jain, SE (Prot. Engg.) RVPNL Jaipur

B. Checklist for Protection Audit

S.No.	Check	Functional/ Non-Functional/Enabled/Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
Transformer Protection Panel					
(i)	Name of Transformer (Rating/Capacity)	220/132 kV, 100 MVA Areva make Transformer-I			
	Tripping by Buchholz Relay (Alarm)	Yes	Enabled	Electromechanical	Complying
	Differential Protection	Yes	Enabled	Numerical	Complying
	2nd Harmonic Block (Setting)		Enabled	15%	Complying
	Event Logger Operation	Yes	In built feature of numerical differential relay		
	Restricted Earth Fault Protection (HV Side)(Auto X-mer)	Yes	Functional	Numerical	41.9 V
	Event Logger Operation	Yes	In built feature of numerical REF relay		
	REF Protection (LV Side)	NA			
	Event Logger Operation	NA			
	Backup Over Current	Yes	Enabled	Numerical	0.3/0.197
	Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay		
	Earth Fault Protection	Yes	Enabled	Numerical	0.1/0.254
	Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay		
	Over Flux Protection	Yes	Enabled		Complying
	Event Logger Operation	Yes	In built feature of numerical differential relay		
	Local Breaker Back Up	Yes			
	Retrip	Yes	Enabled		Complying
	Current and Time Setting			120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	No (3 phase only)			
	Earth Fault	No			
	Event logger	Yes	In built feature of numerical LBB relay		
(i)	Name of Transformer (Rating/Capacity)	220/132 kV, 100 MVA Areva make Transformer-II			
	Tripping by Buchholz Relay (Alarm)	Yes	Enabled	Electromechanical	Complying
	Differential Protection	Yes	Enabled	Numerical	Complying
	2nd Harmonic Block (Setting)		Enabled	15%	Complying

S.No.	Check		Functional/ Non-Functional/Enabled/Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field**	Compliance status w.r.t. regulatory provisions
	Event Logger Operation	Yes		In built feature of numerical differential relay		
	Restricted Earth Fault Protection (HV Side)(Auto X-mer)	Yes	Functional	Numerical	41.8 V	Complying
	Event Logger Operation	Yes		In built feature of numerical REF relay		
	REF Protection (LV Side)	NA				
	Event Logger Operation	NA				
	Backup Over Current	Yes	Enabled	Numerical	0.3/0.197	Complying
	Event Logger Operation	Yes		In built feature of numerical O/C & E/F relay		
	Earth Fault Protection	Yes	Enabled	Numerical	0.1/0.253	Complying
	Event Logger Operation	Yes		In built feature of numerical O/C & E/F relay		
	Over Flux Protection	Yes	Enabled			Complying
	Event Logger Operation	Yes		In built feature of numerical differential relay		
	Local Breaker Back Up	Yes				
	Retrip	Yes	Enabled			Complying
	Current and Time Setting				120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	No(3 phase only)				Complying
	Earth Fault	No				Complying
	Event logger	Yes		In built feature of numerical LBB relay		

Name. Signature & Contact No. of team Carrying out Protection audit:	1. Mukul Yadav, AEN-III (MPT&S), Jaipur 9413382334	
	2. Munesh Kr. Meena, JEN-I O/o AEN-III (MPT&S), Jaipur 9413383124	
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:	1. Dinesh Kumar Jain, SE (Prot.Engg.), RVPN, Jaipur, 9413393540	

Non Directional O/C & E/F relay calculation for 220/132 kV, 100 MVA Transformer-I

Fault MVA of 220 kV BUS	8555 MVA
P.U. Impedance of 220 kV BUS	0.0117
% Impedance of transformer at Normal Tap	12.17 %
Transformer HV Voltage rating	220000 Volts
Transformer LV Voltage rating	132000 Volts
Transformer MVA Capacity	100 MVA
P.U. Impedance of Transformer	0.1217
Total P.U. Impedance	0.1334
Fault MVA of 132 kV BUS	750 MVA
3 Phase through fault Short Circuit Current	3280 Amp
Phase-Phase through fault Short Circuit Current	2840 Amp
Phase to Earth through fault Short Circuit Current	1771 Amp

Non Directional Overcurrent Element Setting

CT Ratio	1000/1		
Plug Setting	30 % i.e.	300	Amp
Plug Setting Multiplier	9.466667		
Time of Operation	0.6	Seconds	
TMS	0.197		

Non Directional Earthfault Element Setting

CT Ratio	1000/1		
Plug Setting	10 % i.e.	100	Amp
Plug Setting Multiplier	17.71		
Time of Operation	0.6	Seconds	
TMS	0.254		

Stablizing Resistor calculation for Restricted Earth fault relay

Transformer Full load current HV	262 Amp
Transformer Full load current LV	437 Amp
Maximum fault current on through fault (If)	3591 Amp
Bushing CT Ratio	600
Lead resistance	1 Ohm
Rct	5 Ohm
Vk= $I_f^*(R_{ct}+2R_l)$	
Vk=	41.9 Volts
REF Operating Current	0.1 Amp
Stablizing Resistor	419 Ohm

Non Directional O/C & E/F relay calculation for 220/132 kV, 100 MVA Transformer-II

Fault MVA of 220 kV BUS	:	8555 MVA
P.U. Impedance of 220 kV BUS		0.0117
% Impedance of transformer at Normal Tap		12.21 %
Transformer HV Voltage rating		220000 Volts
Transformer LV Voltage rating		132000 Volts
Transformer MVA Capacity		100 MVA
P.U. Impedance of Transformer		0.1221
Total P.U. Impedance		0.1338
Fault MVA of 132 kV BUS	:	747 MVA
3 Phase through fault Short Circuit Current		3267 Amp
Phase-Phase through fault Short Circuit Current		2829 Amp
Phase to Earth through fault Short Circuit Current		1764 Amp

Non Directional Overcurrent Element Setting

CT Ratio	1000/1			
Plug Setting	30 % i.e.	300	Amp	
Plug Setting Multiplier	9.43			
Time of Operation	0.6	Seconds		
TMS	0.197			

Non Directional Earthfault Element Setting

CT Ratio	1000/1			
Plug Setting	10 % i.e.	100	Amp	
Plug Setting Multiplier	17.64			
Time of Operation	0.6	Seconds		
TMS	0.253			

Stablizing Resistor calculation for Restricted Earth fault relay


Transformer Full load current HV	262	Amp
Transformer Full load current LV	437	Amp
Maximum fault current on through fault (If)	3579	Amp
Bushing CT Ratio	600	
Lead resistance	1	Ohm
Rct	5	Ohm
Vk= $I_f^*(R_{ct}+2R_l)$	41.8	Volts
REF Operating Current	0.1	Amp
Stablizing Resistor	418	Ohm

Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information

i) Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii) Name of Voltage level of Substation:	220 kV GSS Indira Gandhi Nagar
iii) Date of Commissioning:	25.02.2011
iv) Type of Bus Switching Scheme	Two Main Bus (One & Half scheme)
v) Name and Organization of Audit Team	Sh. Mukul Yadav, AEN-III (MPT&S), RVPN, Jaipur
	Sh. Munesh Kumar Meena, JEN-I O/o AEN-III (MPT&S), RVPN, Jaipur
vi) Name of representative from utility whose audit being carried out	Sh. D.K. Jain, SE (Prot. Engg.) RVPNL Jaipur

B. Checklist for Protection Audit

S.No.	Check		Functional/ Non-Functional/Enabled/ Disabled	Type of Relay*(Numerical /Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
1	DC system					
	No. of independent DC Sources	2 nos. 220 VDC	Functional			
	Potential between +ive & earth (Source-1)	64.3 V	-	-	-	-
	Potential between -ive & earth (Source-1)	186 V	-	-	-	-
	Potential between +ive & earth (Source-2)	118 V	-	-	-	-
	Potential between -ive & earth (Source-2)	110 V	-	-	-	-
2	Event Logger panel	No	-	-	-	-
3	Event Logger Time Synchronised	NA	-	-	-	-
	Disturbance Recorder	NA	-	-	-	-
	DR Time Synchronised	NA	-	-	-	-
4	Bus bar Protection	Yes	Functional	Numerical	120 % Pickup	Complying
	Stability Check	Yes(On Running load)	-	-	-	-
	EL output for this event	No	-	-	-	-
	DR if available	No	-	-	-	-
5	DG Set	No	-	-	-	-
	Mock testing of a sample protection associated with transmission line***	Yes/ No	i. If Yes then observation..... ii. If no, the reason for the same.....			
6	Local Breaker Back Up(For Line)		-	Numerical	-	-
	Retrip	Yes	Enabled	-	-	Complying
	Current and Time Setting	Yes	-	-	PU-120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	Yes	Functional	-	-	Complying
	Earth Fault	No	Disabled	-	-	Complying
	Event logger operation	Yes	In built feature of numerical LBB relay			
Name. Signature & Contact No. of team Carrying out Protection audit:		1. Mukul Yadav, AEN-III (MPT&S), Jaipur 9413382334 2. Munesh Kr. Meena, JEN-I O/o AEN-III (MPT&S), Jaipur 9413383124				
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:		1. Dinesh Kumar Jain, SE (Prot.Engg.), RVPN, Jaipur, 9413393540				

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit dt 28.6.24

A. General Information

(i) Name of Utility:- 220 KV GSS Madri

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:-19.02.1977


(iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus

(v) Name and Organization of Audit Team:- XEN / AEN (MPT&S) RVPNL, Udaipur

(vi) Name of representative from utility whose audit being carried out:-XEN / AEN(MPT&S) RVPNL, Madri

B. Check List for Protection Audit


S.No	Check	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
Transformer Protection Panel:					
(i)	Name of Transformer (Rating/Capacity)	220/132KV, 100MVA TELK T/F			
	Tripping by Buchholz relay (Alarm)	YES	Functional	Conventional	
	Differential Protection	YES	Functional	Numerical	As per code of configuration.
	2nd Harmonic Block (Setting)	YES	Enable		
	Event logger Operation	NO			
	Restricted Earth Fault Protection (HV Side)	YES	Enable		20%
	Event logger Operation	Yes/No			
	Restricted Earth Fault Protection (LV Side)	YES	Enable		20%
	Event logger Operation	Yes/No			
	Backup Over Current	YES	Enable		65%, .16
	Event logger Operation	NO			
	Earth Fault Protection	YES	Enable		20%, 0.16
	Event logger Operation	NO			
	Over Flux Protection	YES	Enable		110%, 5Sec.
	Event logger Operation	NO			120%, 1Sec.
	Local Breaker Back Up	Yes	Disable		10%
	Retrip	YES			250m
	Current and Time Setting	Yes/No			500m
	Separate Single and three Phase Initiation	NO			
	Earth Fault	Yes/No			
	Event logger Operation	NO			
(ii)	Name of Transformer (Rating/Capacity)	220/132KV, 160MVA TELK T/F			
	Tripping by Buchholz relay (Alarm)	YES	Functional	Conventional	
	Differential Protection	YES	Functional	Numerical	As per code of configuration.
	2nd Harmonic Block (Setting)	YES	Enable		
	Event logger Operation	No			
	Restricted Earth Fault Protection (HV Side)	YES	Enable		
	Event logger Operation	Yes/No			
	Restricted Earth Fault Protection (LV Side)	YES	Enable		
	Event logger Operation	Yes/No			
	Backup Over Current	YES	Enable		
	Event logger Operation	Yes/No			
	Earth Fault Protection	YES	Enable		
	Event logger Operation	Yes/No			
	Over Flux Protection	Yes	Enabled		


Executive Engineer (MPT&S)
R.R.V.P.N.L., Udaipur


Assistant Engineer (MPT&S)
RRVPNL, UDAIPUR

Event logger Operation	No			
Local Breaker Back Up	Yes	Disable		
Retrip	Yes			
Current and Time Setting				
Separate Single and three Phase Initiation	No			
Earth Fault	No			
Event logger Operation	No			
(iii) Name of Transformer (Rating/Capacity)	132/33KV, 20/25 MVA T/F - 1			
Tripping by Buchholz relay (Alarm)	YES	Functional	Conventional	
Differential Protection	YES/NO	Functional	EM- DTH31	30% bias
2nd Harmonic Block (Setting)	NO			20% P/U
Event logger Operation	NO			
Restricted Earth Fault Protection (HV Side)	NO			
Event logger Operation	Yes/No			
Restricted Earth Fault Protection (LV Side)	NO			
Event logger Operation	Yes/No			
Backup Over Current	YES			2.5A, 0.18
Event logger Operation	NO			
Earth Fault Protection	YES			1A, 0.2
Event logger Operation	NO			
Over Flux Protection	NO			
Event logger Operation	Yes/No			
Local Breaker Back Up	NO			
Retrip	NO			
Current and Time Setting				
Separate Single and three Phase Initiation	NO			
Earth Fault	NO			
Event logger Operation	NO			

(iv) Name of Transformer (Rating/Capacity)	132/33KV, 20/25 MVA T/F - 2			
Tripping by Buchholz relay (Alarm)	YES	Functional	Conventional	
Differential Protection	YES		EM-DTH 32	20%, P/U
2nd Harmonic Block (Setting)	NO			30%, P/U
Event logger Operation	NO			
Restricted Earth Fault Protection (HV Side)	NO			
Event logger Operation	NO			
Restricted Earth Fault Protection (LV Side)	NO			
Event logger Operation	NO			
Backup Over Current	YES			5A, 0.18%
Event logger Operation	NO			
Earth Fault Protection	YES			1A, 0.2
Event logger Operation	NO			
Over Flux Protection	YES			105%
Event logger Operation	NO			120%
Local Breaker Back Up	NO			
Retrip	NO			
Current and Time Setting				
Separate Single and three Phase Initiation	NO			
Earth Fault	NO			
Event logger Operation	NO			


 Executive Engineer (MPT&S)
 R.R.V.P.N.L. Mdeipur



(iv)	Name of Transformer (Rating/Capacity)	132/33KV, 40/50 MVA T/F - 3			
	Tripping by Buchholz relay (Alarm)	YES	Functional	Conventional	
	Differential Protection	YES	Functional	ABB RADSB	20% , P/U
	2nd Harmonic Block (Setting)	NO			
	Event logger Operation	NO			
	Restricted Earth Fault Protection (HV Side)	NO			
	Event logger Operation	NO			
	Restricted Earth Fault Protection (LV Side)	NO			
	Event logger Operation	NO			
	Backup Over Current	YES			90% , 0.2
	Event logger Operation	NO			
	Earth Fault Protection	YES			20% , 0.23
	Event logger Operation	NO			
	Over Flux Protection	YES			110% , 0.5Sec
	Event logger Operation	NO			115% , 1Sec
	Local Breaker Back Up	NO			
	Retrip	NO			
	Current and Time Setting	NO			
	Separate Single and three Phase Initiation	NO			
	Earth Fault	NO			
	Event logger Operation	NO			

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS Madri

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:-19.02.1977


(iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus

(v) Name and Organization of Audit Team:- XEN / AEN (MPT&S) RVPNL , Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN / AEN(MPT&S) RVPNL , Madri

B. Check List for Protection Audit

S.No	Check	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Distance Protection Panel:M-I/II	Functional	Numerical		
(V)	Name of Line	220KV Debari-M-I/M-II		As per code of configuration	
	Pole Discrepancy Relay	Yes			
	PLCC Panel	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes			
	Time Check-Z-1/2/3/4/5(Settings)	Yes			
	SOTF	Yes/No			
	Aided Scheme	Yes			
	Fault Locator	Yes			
	Power Swing (Setting R & X)				
	All Zone Block	Yes			
	DR	Yes			
	Binary Inputs				
	Breaker Contacts	Yes			
	Carrier Receive	Yes			
	Time Synchronization	NO			
(VI)	Name of Line	220KV Banswara-M-I/M-II		As per code of configuration	
	Pole Discrepancy Relay	Yes	Functional	Numerical	
	PLCC Panel	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes			
	Time Check-Z-1/2/3/4/5(Settings)	Yes			
	SOTF	Yes/No			
	Aided Scheme	Yes			
	Fault Locator	Yes			
	Power Swing (Setting R & X)				
	All Zone Block	Yes			
	DR	Yes			
	Binary Inputs				
	Breaker Contacts	Yes			
	Carrier Receive	Yes			
	Time Synchronization	Yes/No			


 Executive Engineer (MPT&S)
 R.R.V.P.N.S. Udaipur



 Assistant Engineer (MPT&S)
 RVPNL, UDAIPUR


Distance Protection Panel:M-I/II					
(VII)	Name of Line		132KV Debari		
	Pole Discrepancy Relay	NO	Functional	Numerical	As per code of configuration
	PLCC Panel	Yes/No			
	Zone-1/2/3/4/5 (Settings)	Yes/No			
	Time Check-Z-1/2/3/4/5(Settings)	Yes/No			
	SOTF	Yes/No			
	Aided Scheme	Yes			
	Fault Locator	Yes			
	Power Swing (Setting R & X)				
	All Zone Block	Yes			
	DR	Yes			
	Binary Inputs	Yes/No			
	Breaker Contacts	Yes			
	Carrier Receive	Yes			
	Time Synchronization	Yes/No			
(VIII)	Name of Line		132KV Balicha		
	Pole Discrepancy Relay	NO	Functional	Numerical	As per code of configuration
	PLCC Panel	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes			
	Time Check-Z-1/2/3/4/5(Settings)	Yes			
	SOTF	No			
	Aided Scheme	Yes			
	Fault Locator	Yes			
	Power Swing (Setting R & X)				
	All Zone Block	Yes			
	DR	Yes			
	Binary Inputs				
	Breaker Contacts	Yes			
	Carrier Receive	Yes			
	Time Synchronization	Yes/No			
(V)	Name of Line		132KV Pratap nagar		
	Pole Discrepancy Relay	NO	Functional	ABB RAZOA	As per code of configuration
	PLCC Panel	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes			
	Time Check-Z-1/2/3/4/5(Settings)	Yes			
	SOTF	Yes/No			
	Aided Scheme	NO			
	Fault Locator	NO			
	Power Swing (Setting R & X)	NO			
	All Zone Block	Yes/No			
	DR	NO			
	Binary Inputs	NO			
	Breaker Contacts	NO			
	Carrier Receive	NO			
	Time Synchronization	NO			
(VI)	Name of Line		132KV Reliance Chem-TOSHIBA		
	Pole Discrepancy Relay	NO	Non-Functional	ABB RAZOA	As per code of configuration
	PLCC Panel	NO			
	Zone-1/2/3/4/5 (Settings)	NO			
	Time Check-Z-1/2/3/4/5(Settings)	NO			
	SOTF	NO			
	Aided Scheme	NO			
	Fault Locator	NO			
	Power Swing (Setting R & X)	NO			
	All Zone Block	NO			
	DR	NO			
	Binary Inputs	NO			
	Breaker Contacts	NO			
	Carrier Receive	NO			
	Time Synchronization	NO			

Executive Engineer (MPT&S)
R.R.V.P.N., Udaipur

Assistant Engineer (MPT&S)
BRYFNL UDAIPUR

Distance Protection Panel: M-I/II					
(VII)	Name of Line		132KV RSMM		
	Pole Discrepancy Relay	NO	Functional	Numerical	As per code of configuration .
	PLCC Panel	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes			
	Time Check-Z-1/2/3/4/5(Settings)	Yes			
	SOTF	NO			
	Aided Scheme	NO			
	Fault Locator	Yes			
	Power Swing (Setting R & X)	Yes			
	All Zone Block	Yes			
	DR	Yes			
	Binary Inputs	NO			
	Breaker Contacts	NO			
	Carrier Receive	NO			
	Time Synchronization	NO			
(VIII)	Name of Line		132KV Dakan Kotda		
	Pole Discrepancy Relay	NO	Functional	Numerical	As per code of configuration .
	PLCC Panel	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes			
	Time Check-Z-1/2/3/4/5(Settings)	Yes			
	SOTF	Yes			
	Aided Scheme	NO			
	Fault Locator	Yes			
	Power Swing (Setting R & X)	Yes			
	All Zone Block	Yes			
	DR	Yes			
	Binary Inputs	Yes/No			
	Breaker Contacts	No			
	Carrier Receive	No			
	Time Synchronization	No			


 Executive Engineer (MPT&S)
 R.R.V.P.N. Udaipur


 Assistant Engineer (MPT&S)
 RRVPNL UDAIPUR

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

- (i) Name of Utility:- 220 KV GSS Madri (ii) Name of Voltage Level of Sub Station:- 220/132 KV
 (iii) Date of Commissioning:-19.02.1977 (iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus
 (v) Name and Organization of Audit Team:- XEN / AEN (MPT&S) RVPNL , Udaipur
 (vi) Name of representative from utility whose audit being carried out:-XEN / AEN(MPT&S) RVPNL , Madri

B. Check List for Protection Audit

S.No	Check	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
1	DC System	Functional	117V		
	No. Of Independent DC Source	2			
	Potential Between +ve & Earth (Source-I)	115 V			
	Potential Between -ve & Earth (Source-I)	002 V			
	Potential Between +ve & Earth (Source-II)	116V	Functional	226V	
	Potential Between -ve & Earth (Source-II)	110V			
2	Event Logger Panel	No			
3	Event Logger Time Synchronised	No			
	Disturbance Recorder	No			
	DR Time Synchronised	No			
4	Bus Bar Protection	No			
	Stability Check				
	EL Output for this Event	No			
	DR if Available	No			
5	DG Set	No			
	Mock Testing of Sample Protection Associated with Transmission line	No			
7	LBB/BFR	No			
	Retrip	No			
	Current and Time Setting	No			
	Separate Single and Three Phase initiation	No			
	Earth Fault	No			
	Event Logger Operation	No			

Rajasthan Rajya Vidhyut Prasaran Nigam


Report of the Protection Audit


A. General Information

- (i) Name of Utility:- 220 KV GSS Madri (ii) Name of Voltage Level of Sub Station:- 220/132 KV
 (iii) Date of Commissioning:-19.02.1977 (iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus
 (v) Name and Organization of Audit Team:- XEN / AEN (MPT&S) RVPNL , Udaipur
 (vi) Name of representative from utility whose audit being carried out:-XEN / AEN(MPT&S) RVPNL , Madri

B. Check List for Protection Audit

S.No	Check	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Reactor Protection Panel:	NA	No Reactor installed		
	Tripping by Buchholz relay (Alarm)	No			
	Differential Protection	No			
	2nd Harmonic Block (Setting)	No			
	Event logger Operation	No			
	Restricted Earth Fault Protection (HV Side)	No			
	Event logger Operation	No			
	Restricted Earth Fault Protection (LV Side)	No			
	Event logger Operation	No			
	Backup Over Current	No			
	Event logger Operation	No			
	Earth Fault Protection	No			
	Event logger Operation	No			
	Over Flux Protection	No			
	Event logger Operation	No			


 Executive Engineer (MPT&S)
 R.R.V.P.N.L., Udaipur



Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information



i)	Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kV GSS Niwana
iii)	Date of Commissioning:	29.03.2016
iv)	Type of Bus Switching Scheme	Two main One Auxillary Bus
v)	Name and Organization of Audit Team	Avdesh Gupta, AEN-II(MPT&S), RVPN, Jaipur
		Kamal Singh Gurjar, JEN-I(O/o AEN-II(MPT&S) RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh.D.K.Jain, SE(PROT.ENGG.), RVPN, Jaipur

B. Checklist for Protection Audit


S.No.	Check		Functional / Non-Functional / Enabled / Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
Distance protection Panel:M-I/II						
(i)	Name of Line	220 kV HEERAPURA Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=7.369 Ohm, T1=0 ms Z2=9.898 Ohm, T2=350 ms Z3=12.690 Ohm, T3=1000 ms Z4(Rev.)=408 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional			
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying

	Power swing(S(settings R and X)				R=5 Ohm, X=5 Ohm	Complying	
	All Zone block	Yes	Enabled	In built feature of Numerical Distance Protection Relays	-	Complying	
	DR	Yes	Enabled		-	Complying	
	Binary Input						
	Breaker Contacts	Yes	Functional	-	-	Complying	
	Carrier Receive	Yes	Functional	-	-	Complying	
	Time Synchronization	Yes	Functional	-	-	Complying	
(ii)	Name of Line	220 kV BABAI Line					
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 Sec.		
	PLCC panel	Yes	Functional				
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=11.159 Ohm, T1=0 ms Z2=17.694 Ohm, T2=350 ms Z3=27.240 Ohm, T3=1000 ms Z4(Rev.)=408 mOhm, T4=160 ms	Complying	
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional		-	-	Complying
	SOTF	No	Disabled	-	-	Complying	
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying	
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying	
	Power swing(S(settings R and X)				R=5 Ohm, X=5 Ohm	Complying	
	All Zone block	Yes	Enabled	In built feature of Numerical Distance	-	Complying	
	DR	Yes	Enabled		-	Complying	
	Binary Input						
	Breaker Contacts	Yes	Functional	-	-	Complying	
	Carrier Receive	Yes	Functional	-	-	Complying	
	Time Synchronization	Yes	Functional	-	-	Complying	

* Complying with the Code of Configuration issued by the CE(MPT&S), RVPN, Jaipur by Letter no. RVPN/CE/MPT&S/JPR/Tech./F./ Rajkaj ref No. 5221696/D.166 Dated 21.12.2023

Name. Signature & Contact No. of team Carrying out Protection audit:	1. Avdesh Gupta AEN-II(MPT&S), RVPNL,Jaipur 94143346180	
	2. Kamal Singh Gurjar, JEN O/o AEN-II(MPT&S), RVPNL,Jaipur 9413393612	
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:	1. Dinesh Kumar Jain, SE(Prot.Engg.), RVPN, Jaipur, 9413393540	

Distance relay calculation for 220 kV NIWANA-HEERAPURA Line



Principle line Length : 45.14 KM.
 Shortest Line Length considered on Remote Bus : 6.73 KM.
 Longest line length Considered on Remote Bus : 15.5 KM.

EARTH FAULT COMPENSATION

RE/RL=1/3((Ro/R1)-1)
 XE/XL=1/3((Xo/X1)-1)
 kZ0 Res. Comp.= kZ0 = (Z0 - Z1) / 3Z1

kZ0	kZ0 angle
0.734	-1.83

Conductor Used	Zebra			
Conductor Parameters	R	X	Z	Angle
Positive Sequence(Z1):	0.081	0.4	0.408	78.55
Zero Sequence(Z0):	0.2875	1.275	1.307	77.29
CTR:	1000/1 Amp= 1000			
PTR:	220000/110 V= 2000			
CTR/PTR:	0.5			

Zone 1(Forward) Reach:	80	% of the Line to be Protected
Zone 2(Forward) Reach:	50	% of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach:	110	% Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach:	2	Km


Zone 1 forward Reach= 80% of line length (SEZ to PGCIL)* +ve Sequence impedance of conductor/km*(CTR/PTR)
 = 7.369 Ohm T1= Instt.

Zone 2 forward Reach= 100% of line length (SEZ to PGCIL)+50 % of the Shortest Line on remote Bus(PGCIL-Chaksu)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 9.898 Ohm T2=350 ms

Zone 3 forward Reach=100% of line length (SEZ to PGCIL)+110 % Longest line length on Remote Bus(PGCIL-Vatika)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 12.690 Ohm T3=1000 ms

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 0.408 Ohm T4=160 ms

Distance relay calculation for 220 kV SEZ-Heerapura Line



Principle line Length : 68.358 KM.
 Shortest Line Length considered on Remote Bus : 36.7 KM.
 Longest line length Considered on Remote Bus : 59.21 KM.

EARTH FAULT COMPENSATION

$RE/RL = 1/3((Ro/R1)-1)$
 $XE/XL = 1/3((Xo/X1)-1)$
 $kZ0 \text{ Res. Comp.} = kZ0 = (Z0 - Z1) / 3Z1$
kZ0 **kZ0 angle**
0.734 **-1.83**

Conductor Used :	Zebra			
Conductor Parameters :	R	X	Z	Angle
Positive Sequence(Z1):	0.081	0.4	0.408	78.55
Zero Sequence(Z0):	0.2875	1.275	1.307	77.29
CTR:	1000/1 Amp= 1000			
PTR:	220000/110 V= 2000			
CTR/PTR:	0.5			

Zone 1(Forward) Reach: 80 % of the Line to be Protected
Zone 2(Forward) Reach: 50 % of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach: 110 % Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach: 2 Km

Zone 1 forward Reach= 80% of line length (SEZ to Heerapura)* +ve Sequence impedance of conductor/km*(CTR/PTR)
 = 11.159 Ohm T1= Instt.

Zone 2 forward Reach= 100% of line length (SEZ to Heerapura)+50 % of the Shortest Line on remote Bus(Heerapura-NPH)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 17.694 Ohm T2=350 ms

Zone 3 forward Reach=100% of line length (SEZ to Heerapura)+110 % Longest line length on Remote Bus(Heerapura-Sanganer)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 27.240 Ohm T3=1000 ms

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 0.408 Ohm T4=160 ms

Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information

i)	Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kV GSS Niwana
iii)	Date of Commissioning:	29.03.2016
iv)	Type of Bus Switching Scheme	Two main One Auxillary Bus
v)	Name and Organization of Audit Team	Avdesh Gupta, AEN-II(MPT&S), RVPN, Jaipur
		Kamal Singh Gurjar, JEN-I(O/o AEN-II(MPT&S) RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh.D.K.Jain, SE(PROT.ENGG.) ,RVPN, Jaipur

B. Checklist for Protection Audit

S.No.	Check	Functional/ Non-Functional/Enabled/Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field**/**	Compliance status w.r.t. regulatory provisions	
Transformer Protection Panel						
(i)	Name of Transformer (Rating/Capacity)	220/132 kV, 160 MVA BBL make Transformer				
	Tripping by Buchholz Relay (Alarm)	Yes	Enabled	Electromechanical	Complying	
	Differential Protection	Yes	Enabled	Numerical	Complying	
	2nd Harmonic Block (Setting)		Enabled	15%	Complying	
	Event Logger Operation	Yes	In built feature of numerical differential relay			
	Restricted Earth Fault Protection (HV Side)(Auto X-mer)	Yes	Functional	Numerical	42.3 V	Complying
	Event Logger Operation	Yes	In built feature of numerical REF relay			
	REF Protection (LV Side)	NA				
	Event Logger Operation	NA				
	Backup Over Current	Yes	Enabled	Numerical	0.42/0.200	Complying
	Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay			
	Earth Fault Protection	Yes	Enabled	Numerical	0.2/0.220	Complying
	Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay			
	Over Flux Protection	Yes	Enabled			Complying
	Event Logger Operation	Yes	In built feature of numerical differential relay			
	Local Breaker Back Up	Yes				
	Retrip	Yes	Enabled			Complying
	Current and Time Setting				120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	No(3 phase only)				Complying

Non Directional O/C & E/F relay calculation for 220/132 kV, 160 MVA Transformer-1

Fault MVA of 220 kV BUS	:	4725 MVA
P.U. Impedance of 220 kV BUS		0.0212
% Impedance of transformer at Normal Tap		11.59 %
Transformer HV Voltage rating		220000 Volts
Transformer LV Voltage rating		132000 Volts
Transformer MVA Capacity		160 MVA
P.U. Impedance of Transformer		0.072438
Total P.U. Impedance		0.0936
Fault MVA of 132 kV BUS	:	1068 MVA
3 Phase through fault Short Circuit Current		4671 Amp
Phase-Phase through fault Short Circuit Current		4045 Amp
Phase to Earth through fault Short Circuit Current		2522 Amp

Non Directional Overcurrent Element Setting

CT Ratio	1000/1		
Plug Setting	42 % i.e.	420	Amp
Plug Setting Multiplier	9.630952		
Time of Operation	0.6	Seconds	
TMS	0.199		

Non Directional Earthfault Element Setting

CT Ratio	1000/1		
Plug Setting	20 % i.e.	200	Amp
Plug Setting Multiplier	12.61		
Time of Operation	0.6	Seconds	
TMS	0.223		

Stablizing Resistor calculation for Restricted Earth fault relay

Transformer Full load current HV	420 Amp
Transformer Full load current LV	700 Amp
Maximum fault current on through fault (If)	6040 Amp
Bushing CT Ratio	1000
Lead resistance	1 Ohm
Rct	5 Ohm
Vk= If*(Rct+2Rl)	
Vk=	42.3 Volts
REF Operating Current	0.1 Amp
Stablizing Resistor	423 Ohm

Non Directional O/C & E/F relay calculation for 220/132 kV, 160 MVA Transformer2

Fault MVA of 220 kV BUS	:	4725 MVA
P.U. Impedance of 220 kV BUS		0.0212
% Impedance of transformer at Normal Tap		11.59 %
Transformer HV Voltage rating		220000 Volts
Transformer LV Voltage rating		132000 Volts
Transformer MVA Capacity		160 MVA
P.U. Impedance of Transformer		0.072438
Total P.U. Impedance		0.0936
Fault MVA of 132 kV BUS	:	1068 MVA
3 Phase through fault Short Circuit Current		4671 Amp
Phase-Phase through fault Short Circuit Current		4045 Amp
Phase to Earth through fault Short Circuit Current		2522 Amp

Non Directional Overcurrent Element Setting

CT Ratio	1000/1		
Plug Setting	42 % i.e.	420	Amp
Plug Setting Multiplier	9.630952		
Time of Operation	0.6	Seconds	
TMS	0.199		

Non Directional Earthfault Element Setting

CT Ratio	1000/1		
Plug Setting	20 % i.e.	200	Amp
Plug Setting Multiplier	12.61		
Time of Operation	0.6	Seconds	
TMS	0.223		

Stablizing Resistor calculation for Restricted Earth fault relay

Transformer Full load current HV	420 Amp
Transformer Full load current LV	700 Amp
Maximum fault current on through fault (If)	6040 Amp
Bushing CT Ratio	1000
Lead resistance	1 Ohm
Rct	5 Ohm
$V_k = I_f * (R_{ct} + 2R_l)$	
Vk=	42.3 Volts
REF Operating Current	0.1 Amp
Stablizing Resistor	423 Ohm


Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information



i)	Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kv GSS Niwana
iii)	Date of Commissioning:	29.03.2016
iv)	Type of Bus Switching Scheme	Two main One Auxillary Bus
v)	Name and Organization of Audit Team	Avdesh Gupta, AEN-II(MPT&S), RVPN, Jaipur
		Kamal Singh Gurjar, JEN-I(O/o AEN-II(MPT&S) RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh.D.K.Jain, SE(PROT.ENGG.), RVPN, Jaipur

B. Checklist for Protection Audit

S.No.	Check		Functional/ Non-Functional/Enabled/ Disabled	Type of Relay*(Numerical /Static/Electromechanical)	Setting as found in field**	Compliance status w.r.t. regulatory provisions
1	DC system					
	No. of independent DC Sources	1 nos. 220 VDC	Functional			
	Potential between +ive & earth (Source-1)	118 V	-	-	-	-
	Potential between -ive & earth (Source-1)	115 V	-	-	-	-
	Potential between +ive & earth (Source-2)	-	-	-	-	-
	Potential between -ive & earth (Source-2)	-	-	-	-	-
2	Event Logger panel	No	-	-	-	-
3	Event Logger Time Synchronised	NA	-	-	-	-
	Disturbance Recorder	NA	-	-	-	-
	DR Time Synchronised	NA	-	-	-	-
4	Bus bar Protection	NA	-	-	-	-
	Stability Check	-	-	-	-	-
	EL output for this event	-	-	-	-	-
	DR if available	-	-	-	-	-
5	DG Set	NA	-	-	-	-
	Mock testing of a sample protection associated with transmission line***	Yes/ No	i. If Yes then observation..... ii. If no, the reason for the same.....			
6	Local Breaker Back Up(For Line)		-	Numerical	-	-
	Retrip	Yes	Enabled	-	-	Complying
	Current and Time Setting	Yes	-	-	PU-120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	Yes	Functional	-	-	Complying
	Earth Fault	No	Disabled	-	-	Complying
	Event logger operation	Yes	In built feature of numerical LBB relay			

Name. Signature & Contact No. of team Carrying out Protection audit:	1. Avdesh Gupta AEN-II(MPT&S), RVPNL, Jaipur 94143346180	
	2. Kamal Singh Gurjar, JEN O/o AEN-II(MPT&S), RVPNL, Jaipur 9413393612	
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:	1. Dinesh Kumar Jain, SE(Prot.Engg.), RVPN, Jaipur. 9413393540	

Earth Fault	No				Complying
Event logger	Yes	In built feature of numerical LBB relay			
(ii) Name of Transformer (Rating/Capacity)	220/132 kV, 160 MVA BBL make Transformer				
Tripping by Buchholz Relay (Alarm)	Yes	Enabled	Electromechanical		Complying
Differential Protection	Yes	Enabled	Numerical		Complying
2nd Harmonic Block (Setting)		Enabled		15%	Complying
Event Logger Operation	Yes	In built feature of numerical differential relay			
Restricted Earth Fault Protection (HV Side)(Auto X-mer)	Yes	Functional	Numerical	42.3 V	Complying
Event Logger Operation	Yes	In built feature of numerical REF relay			
REF Protection (LV Side)	NA				
Event Logger Operation	NA				
Backup Over Current	Yes	Enabled	Numerical	0.42/0.200	Complying
Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay			
Earth Fault Protection	Yes	Enabled	Numerical	0.2/0.220	Complying
Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay			
Over Flux Protection	Yes	Enabled			Complying
Event Logger Operation	Yes	In built feature of numerical differential relay			
Local Breaker Back Up	Yes				
Retrip	Yes	Enabled			Complying
Current and Time Setting				120%/100 ms+100 ms External timer	Complying
Separate Single and three phase initiation	No(3 phase only)				
Earth Fault	No				Complying
Event logger	Yes	In built feature of numerical LBB relay			

Name. Signature & Contact No. of team Carrying out Protection audit:	1. Avdesh Gupta AEN-II(MPT&S), RVPNL,Jaipur 94143346180 2. Kamal Singh Gurjar, JEN O/o AEN-II(MPT&S), RVPNL,Jaipur 9413393612	 
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:	1. Dinesh Kumar Jain, SE(Prot.Engg.), RVPN, Jaipur, 9413393540	



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
Corporate Identity Number (CIN):U40109RJ2000SGCO16485
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

RVPN
AN ISO: 9001:2015
Certified Company

OFFICE OF THE SUPERINTENDING ENGINEER (PROT.-ENGG),
Room No.317, Vidyut Bhawan, Jaipur Tel. No.0141-2740381(Ext.1350)
E-mail: se.prot.engg@rvpn.co.in, Website: [www.http://energy.rajasthan.gov.in/rvpnl](http://energy.rajasthan.gov.in/rvpnl)

No. RVPN/SE/JPR/ (Prot.-Engg)/Tech./F./D.- 33

Jaipur, Dated: 31.05.2024

The Chief Engineer (LD/MPT&S)
RVPN, Jaipur.

Sub:- Regarding internal Protection Audit plan.

Ref:- 1. No. 4/MTGS/SG/NPC/CEA/2023/353 dated 18.09.2023
2. NO.RVPN/SE(Prot.Engg)/JPR/Tech./F./ Raj Kaj No. 6987851 dated 07.05.2024.

Kindly find attach the Internal Protection Audit report of 220 kV GSS MIA, Alwar. The Incharge of the concern GSS was informed to rectify the observations raised during audit with Protection wing, Alwar.

Submitted for further needful action and to appraise NRPC.

Copy forwarded:

1. Superintending Engineer (MPT&S), Jaipur
2. Executive Engineer, 220 kV GSS, MIA, Alwar

RajKaj Ref
7766661



Signature valid

Digitally signed by Dinesh Kumar Jain
Designation : Superintending
Engineer
Date: 2024.06.04 17:46:35 IST
Reason: Approved

**Northern Regional Power Committee
Report of the Protection Audit**

A. General Information:

- i. Name of utility :- Rajasthan Rajya Vidyut Prasaran Nigam Ltd.
- ii. Name of Voltage level of sub-station :- 220 kV GSS MIA Alwar
- iii. Date of commissioning :- 08.02.2011
- iv. Type of bus-switching scheme :- 220 KV Main Bus
- v. Name and Organization of Audit Team :- Rajasthan Rajya Vidyut Prasaran Nigam Ltd.
- vi. Name of representative from utility whose audit is being carried out :- Sh. R.R Gupta & Sh. A.K. Meena

B. Check List for Protection Audit

S.No	Check	1/2/3/4	Functional/ Nonfunctional/ Enabled/Disa bled	Type of relay ^a (Numerical/Static/ Electromechanical)	Setting as found in field ^{b,c,d}	Compliance status w.r.t. regulatory provisions
1.	DC system	1/2/3/4	1&2 Nonfunctional			01 No DC battery set Required, Purchase case under process Complied
	No. of independent DC Sources	-----V	Nonfunctional			
	Potential between live & earth (Source-1)	-----V	Nonfunctional			
	Potential between live & earth (Source-2)	-----V	Functional		125 V	
	Potential between live & earth (Source-3)	-----V	Functional		400 V	
	Potential between live & earth (Source-4)	-----V				
2	Potential between live & earth (Source-1)	-----V	No			
3	Event logger panel	Yes/No	No			
	Disturbance Recorder	Yes/No	No			
4.i	DR Time Synchronised	Yes/No	NO			Complied
	Transformer Protection Panel:		220/132 KV, 100 MVA, BHEL	TR 01		
	Typing by Buchholz relay (Alarm)	Yes/No	Yes			
	Differential Protection	Yes/No	Yes	Numerical Relay	0.20, 8.0	
	2 nd Terminal Block (Setting)	Yes/No	Yes		15%	
	Event logger operation	Yes/No	Yes	In Relay		
	Restricted Earth Fault Protection (F-V side)	Yes/No	Yes	MIT	0.10 In Instt.	
	Event logger operation	Yes/No	No			
	REF Protection (Y side)	Yes/No				
	Event logger operation	Yes/No				
	Backup over current	Yes/No	Yes	Numerical Relay	0.7 In, 0.20	
	Event logger operation	Yes/No	Yes	In Relay		
	Earth Fault Protection	Yes/No	Yes	Numerical Relay	0.20 In, 0.26	
	Event logger operation	Yes/No	Yes	In Relay		
	Over Flux Protection	Yes/No	Yes	Numerical Relay	110 % 5s, 120 % 1s	
	Event logger operation	Yes/No	Yes	In Relay		
	Local Breaker Back up	Yes/No	Yes	In Bus Bar Relay	100 ms	
	Relay	Yes/No	Yes			
	Current and Time setting	Yes/No	Yes		1.2 In, 100+100ms	
	Separating land free phase in 110kV	Yes/No	No		Single phase	
	Earth fault	Yes/No	No			
	Event logger	Yes/No	Yes	In Relay		

1.2	Transformer Protection Panel:	Yes/No	220/132 KV, 100 MVA, TELK	TR 02	Completed
	Tripping by Buchholz relay (Alarm)	Yes/No	Yes	Numerical Relay	0.20 - 8.0 15%
	Differential Protection	Yes/No	Yes	In Relay	0.10 In Instt.
	2 nd Harmonic Block (Setting)	Yes/No	Yes	Numerical	
	Event Log operation	Yes/No	Yes	In relay	
	Restricted Earth Fault Protection (H/V side)	Yes/No	Yes		
	Event Log operation	Yes/No	Yes		
	REF Protection (V side)	Yes/No	Yes	Numerical Relay	0.7 In, 0.20
	Event Log operation	Yes/No	Yes	In Relay	
	Backup overcurrent	Yes/No	Yes	Numerical Relay	0.20 In, 0.25
	Earth Fault Protection	Yes/No	Yes	In Relay	
	Event Log operation	Yes/No	Yes	Numerical Relay	140 % Ss, 120 % 1s
	Over Flux Protection	Yes/No	Yes	In Relay	
	Event Log operation	Yes/No	Yes	In Bus Bar Relay	
	Local Breaker Back up	Yes/No	Yes		100 ms
	Reltrip	Yes/No	Yes		1.2 In, 100*100ms
	Current and Time setting	Yes/No	Yes		Single phase
	Separatesingleandthree phasesetpoint	Yes/No	No		
	Earthfault	Yes/No	Yes		
	Event Logger	Yes/No	Not available		
5	Reactor Protection Panel:				
	Tripping by Buchholz relay (Alarm)	Yes/No			
	Differential Protection	Yes/No			
	2 nd Harmonic Block (Setting)	Yes/No			
	Event Log operation	Yes/No			
	REF Protection (H/V side)	Yes/No			
	Event Log operation	Yes/No			
	REF Protection (V side)	Yes/No			
	Event Log operation	Yes/No			
	Backup overcurrent	Yes/No			
	Event Log operation	Yes/No			
	E/F Protection	Yes/No			
	Event Log operation	Yes/No			
	Over Flux Protection	Yes/No			
	Event Log operation	Yes/No			
	LBB/BFR	Yes/No			
	Reltrip	Yes/No			
	Current and Time setting	Yes/No			
	Separatesingleandthree phasesetpoint	Yes/No			
	Earthfault	Yes/No			
	Event Log operation	Yes/No			
6.1	Distance Protection Panel: M-Hill				
	Event Log operation	Yes/No	220 kV MHA - Adani (400 kV) Line		1.5 Sec
	Distance Protection Relay	Yes/No	Yes		As per Line Length
	Floating relay	Yes/No	Yes		0.350, 1000, 160 s
	FLC Panel	Yes/No	1, 2, 3, 4 Enable	Numerical Relay	
	Zone-1/2/3/4/5 (Settings)	Yes/No	Yes		
	Timecheck-Z-1/2/3/4/5 (Settings)	Yes/No	Disable		
	SOFT	Yes/No	Yes		
	Alarmschemes	Yes/No	Yes	In relay	
	FAULT localer	Yes/No	Enable		Available
	Powerswing (Settings Range X)	Yes/No	Yes		Available
	All Zone block	Yes/No	Yes		
	DR	Yes/No	Yes		
	Binary Inputs	Yes/No	Yes		
	Breaker Contacts	Yes/No	Yes		
	CarrierReceive	Yes/No	Yes		
	TimeSynchronization	Yes/No	Yes		

Distance Protection Panel: M-III		220 KV MIA - BADARPUR Line		1.5 Sec	Complied
6.2	Field: relay/relay	Yes/No	Yes		
	PLC Panel	Yes/No	Yes		
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay	As per Line Length
	Timecheck-Z-1/2/3/4/5(Settings)	Yes/No	Yes	Disable	0.350, 1000, 160 s
	SOTF	Yes/No	Yes	Disable	
	Aided schemes	Yes/No	Yes		
	Fault locator	Yes/No	Yes		In relay
	Power swing (Settings/RandX)	Yes/No	Enable		
	All Zone block	Yes/No	Yes		
	DR	Yes/No	Yes		
	Binary Inputs	Yes/No	Yes		Available
	Breaker Contacts	Yes/No	Yes		Available
	Carrier/Receive	Yes/No	Yes		Available
	Time Synchronization	Yes/No	Yes		
6.3	Distance Protection Panel: M-III	Yes/No	Yes		
	Power swing relay	Yes/No	Yes		
	PLC Panel	Yes/No	Yes		
	Zone-1/2/3/4/5 (Settings)	Yes/No	Yes		1.5 Sec
	Timecheck-Z-1/2/3/4/5(Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay	As per Line Length
	SOTF	Yes/No	Yes	Disable	0.350, 1000, 160 s
	Aided schemes	Yes/No	Yes		
	Fault locator	Yes/No	Yes		In relay
	Power swing (Settings/RandX)	Yes/No	Enable		
	All Zone block	Yes/No	Yes		
	DR	Yes/No	Yes		
	Binary Inputs	Yes/No	Yes		Available
	Breaker Contacts	Yes/No	Yes		Available
	Carrier/Receive	Yes/No	Yes		Available
	Time Synchronization	Yes/No	Yes		
7	Bus Bar Protection	Yes/No	Yes		
	Stability/Check	Yes/No	Yes		Numerical
	EL output for this event	Yes/No	Yes		
8	Single Phase Auto Re-closer Scheme	Yes/No	Yes		Available
	CT	Yes/No	Yes		AR feature enable in numerical DPS relays
	Suitable as per level	Yes/No	Yes		
10	DG Set	Yes/No	No		
11	Mock Testing of a sample protection associated with transmission line**	Yes/No	I. If Yes then observation Yes operated properly II. If No, the reason for the same	Line tripped on dated 03.05.2024 on 220 KV MIA Adant Line with adopted parameters.	Complied

* This column is applicable for relays only

** Method and Calculation to arrive at this setting has to be submitted by the utility to NRPC secretary within 07 days of the protection audit

*** Purpose is to check whether the operation of that protection relay energises the breaker Trip coil.

C. Observation w.r.t. compliance to NRPC protection philosophy

D. Any other Observation/Suggestion by the team of protection experts:
(Name, Signature and Contact Number of Members of team comprising for carrying out protection audit and the representative of the utility whose audit is being carried out)

Copy to: (i) Station In-charge where audit has been carried out
(ii) Representative of the utility present with the protection audit team
(iii) SE (O), NRPC

R. R. Gupta
AEn (Prot. Engg.) RVPN Jaipur
9413393611

5.7.2024

A. K. Weena
AEn (Prot. Engg.) RVPN Jaipur
9413393550

RRV/PN 220kV Chittorgarh S/s

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the Protection Audit

Date: 09/07/24

- A. General Information:
- I. Name of Utility:- RVP/NL
 - II. Name of Voltage Level of sub-station: 220kV
 - III. Date of Commissioning 28.06.1991
 - IV. Type of bus-switching scheme:- Main and Aux Bus
 - V. Name of Organization of Audit Team :- AEN (MPT&S) RVP/NL Chittorgarh
 - VI. Name of Representative from utility whose audit being carried out :- XEN 220kV GSS Chittorgarh

B. Check list for Protection Audit

S.NO.	Check		Functional/ Non-functional/ Enabled/ Disabled	Type of Relay* (Numerical/Static/ Electro-mechanical)	Setting as Found in Field**	Compliance status w.r.t. regulatory provisions
Transformer Protection Panel:						
1	Name of Transformer(Rating/Capacity)	220/132kV 100 MVA T-1				
	Tripping by Buchholz relay(Alarm)	TELK Make	YES			
	Differential Protection		YES	Static	Bias: 20% (CTR: 300/1) Instt: 8A	
	2nd Harmonic Block(Setting)		Internal			
	Event Logger operation		NO			
	Restricted Earth Fault Protection(HV side)		NO			
	Event Logger operation		NO			
	REF Protection(LV side)		NO			
	Event Logger operation		NO			
	Backup over current		YES	Electro-mechanical	Ps: 1A (CTR: 300/1) TMS: 0.35	
	Event Logger operation		NO			
	Earth Fault Protection		YES	Electro-mechanical	Ps: 0.2A (CTR: 300/1) TMS: 0.40	
	Event Logger operation		NO			
	Over Flux Protection		YES	Electro-mechanical	K:1.2, t:12s	
	Event Logger operation		NO			
	Local Breaker Back up		NO			
	Retrip		NO			
	Current and Time Setting		NO			
	Separate single and three phase initiation		NO			
	Earth Fault		NO			
	Event Logger		NO			

Assistant Engineer (MPT&S)
RVP/NL CHITTORGARH

Date: 09/07/24

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the Protection Audit

- A. General Information:**
 I. Name of Utility:- RVPNL
 III. Date of Commissioning 28.06.1991
 V. Name of Organization of Audit Team :- AEN (MPT&S) RVPNL Chittorgarh
 VI. Name of Representative from utility whose audit being carrier out :- XEN 220KV GSS Chittorgarh
B. Check list for Protection Audit

2. Name of Transformer(Rating/Capacity)	220/132KV 100 MVA Tr-2				
Tripping by Buchholz relay(Alarm)	BHEL Make	YES			
Differential Protection	YES/NO	YES	Static	Bias: 35% (CTR: 600/1)	
	YES/NO	YES		Instr: 8A	
2nd Harmonic Block(Setting)		Internal			
Event Logger operation	YES/NO	NO			
Restricted Earth Fault Protection(HV side)	YES/NO	NO			
Event Logger operation	YES/NO	NO			
REF Protection(LV side)	YES/NO	NO			
Event Logger operation	YES/NO	NO			
Backup over current	YES/NO	YES	Electro-mechanical	Ps: 0.5A (CTR: 600/1)	
Event Logger operation	YES/NO	NO		TMS: 0.35	
Earth Fault Protection	YES/NO	YES	Electro-mechanical	Ps: 0.2A (CTR: 600/1)	
Event Logger operation	YES/NO	NO		TMS: 0.40	
Over Flux Protection	YES/NO	NO			
Event Logger operation	YES/NO	NO			
Local Breaker Back up	YES/NO	NO			
Retrip	YES/NO	NO			
Current and Time Setting					
Separate single and three phase initiation	YES/NO	NO			
Earth Fault	YES/NO	NO			
Event Logger	YES/NO	NO			

Assistant Engineer (MPT&S)
RVPNL, CHITTORGARH

M. S. /

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the Protection Audit

Date: 09/07/24

- A. General Information:**
 I. Name of Utility:- RVPNL
 II. Name of Voltage Level of sub-station: 220kV
 III. Date of Commissioning 28.06.1991
 IV. Type of bus-switching scheme:- Main and Aux Bus
 V. Name of Organization of Audit Team :- AEN (MPT&S) RVPNL Chittorgarh
 VI. Name of Representative from utility whose audit being carrier out :- XEN 220KV GSS Chittorgarh

B. Check list for Protection Audit

3	Name of Transformer(Rating/Capacity)	220/132KV 100 MVA Tr-3	TELK Make	YES/NO	Internal	YES/NO	Numerical	CTR:400/1 Instt: 5A Per Diff. ID: 0.200 A Diff. IR1: 0.656 A Diff IR2: 3A Diff Slop S1: 0.00 Diff Slop S2: 0.200
	Tripping by Buchholz relay(Alarm)	YES/NO	YES					
	Differential Protection	YES/NO	YES					
	2nd Harmonic Block(Setting)		Internal					Diff. 2nd HAR Ratio: 0.150 Diff. 5th HAR Ratio: 0.350
	Event Logger operation	YES/NO	YES					
	Restricted Earth Fault Protection(HV side)	YES/NO	YES	Static				Ps: 5%, Time: 0.2s
	Event Logger operation	YES/NO	YES					
	REF Protection(LV side)	YES/NO	YES					
	Event Logger operation	YES/NO	YES					
	Backup over current	YES/NO	YES	Numerical				Ps: 1A (CTR: 400/1) TMS: 0.35
	Event Logger operation	YES/NO	YES					
	Earth Fault Protection	YES/NO	YES	Numerical				Ps: 20% (CTR: 400/1) TMS: 0.40
	Event Logger operation	YES/NO	YES					
	Over flux Protection	YES/NO	YES	Numerical				Alarm: 110%, Time: 5s Trip: 120%, Time: 1s
	Event Logger operation	YES/NO	YES					
	Local Breaker Back up	YES/NO	NO					
	Retrip	YES/NO	NO					
	Current and Time Setting	YES/NO	NO					
	Separate single and three phase initiation	YES/NO	NO					
	Earth Fault	YES/NO	NO					
	Event Logger	YES/NO	NO					

Assistant Engineer (MPT&S)
RVPNL, CHITTORGARH

Date: 09/07/24

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the protection Audit

A. General Information:

I. Name of Utility:- RVPNL

II. Name of Voltage Level of sub-station: 220kV

III. Date of Commissioning 28.06.1991

IV. Type of bus-switching scheme:- 2 Main Bus and Aux. Bus

V. Name of Organization of Audit Team :- R¹

VI. Name of Representative from utility whose audit being carrier out :- XEN 220kV GSS Chittorgarh

B. Check list for Protection Audit

S.NO.	Check		Functional/ Non-functional/ Enabled/ Disabled	Type of Relay* (Numerical/ Static/ Electro- mechanical)	Setting as Found in Field**	Compliance status w.r.t. regulatory provisions
	Distance Protection Panel: M-I			Numerical		
1	Name of Line	220kV Chittorgarh -RAPPB-I				
	Pole discrepancy relay	YES/NO	YES		YES	
	PLCC panel	YES/NO	YES		YES	
	Zone-1/2/3/4(Setting)	YES/NO	ENABLED		Z1-16.2 Ω/ Z2-31.15Ω/ Z3-69.59 Ω/ Z4-0.326 Ω(reverse)	
	Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0.0.35,1.0.160 sec.	
	SOTF	YES/NO	DISABLED		DISABLED	
	Aided schemes	YES/NO	ENABLED		ENABLED	
	Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL	
	Power swing (Settings R and X)				4.10/4.10	
	All Zone Block	YES/NO	YES		YES	
	DR	YES/NO	YES		DR	
	Binary Inputs					
	Breaker Contacts	YES/NO	YES		YES	
	Carrier Receive	YES/NO	YES		YES	
	time Synchronization	YES/NO	NO		NO	
	Distance Protection Panel: M-II			Numerical		
	Pole discrepancy relay	YES/NO	YES		YES	
	PLCC panel	YES/NO	YES		YES	
	Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED		R1-15.92Ω,X1-16.370Ω/ R2-15.92Ω, X2-30.690Ω/ R3-15.92Ω,X3-68.550Ω/ R4-15.92Ω,X4-0.830Ω	
	Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0.0.35,1.0.160 sec.	
	SOTF	YES/NO	DISABLED		DISABLED	
	Aided schemes	YES/NO	ENABLED		ENABLED	
	Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL	
	Power swing (Settings R and X)				4.10/4.10	
	All Zone Block	YES/NO	YES		YES	
	DR	YES/NO	YES		DR	
	Binary Inputs					
	Breaker Contacts	YES/NO	YES		YES	
	Carrier Receive	YES/NO	YES		YES	
	time Synchronization	YES/NO	NO		NO	

Jw
Assistant Engineer (MPT&SI)
RVPNL, CHITTORGARH

Date: 09/07/24

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the protection Audit

A. General Information:

I. Name of Utility:- RVPNL

II. Name of Voltage Level of sub-station: 220kV

III. Date of Commissioning 28.06.1991

IV. Type of bus-switching scheme:- 2 Main Bus and Aux. Bus

V. Name of Organization of Audit Team :- R\

VI. Name of Representative from utility whose audit being carrier out :- XEN 220kV GSS Chittorgarh

B. Check list for Protection Audit

Distance Protection Panel: M-I				Numerical	
1	Name of Line	220kV Chittorgarh -RAPPB-II			
	Pole discrepancy relay	YES/NO	YES		YES
	PLCC panel	YES/NO	YES		YES
	Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED		Z1-16.2 Ω/ Z2-31.15Ω/ Z3-69.59 Ω/ Z4-0.326 Ω(reverse)
	Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0,0.35,1,0.160 sec.
	SOTF	YES/NO	DISABLED		DISABLED
	Aided schemes	YES/NO	ENABLED		ENABLED
	Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL
	Power swing (Settings R and X)				4.10/4.10
	All Zone Block	YES/NO	YES		YES
	DR	YES/NO	YES		DR
	Binary Inputs				
	Breaker Contacts	YES/NO	YES		YES
	Carrier Receive	YES/NO	YES		YES
	time Synchronization	YES/NO	NO		NO
Distance Protection Panel: M-II				Numerical	
	Pole discrepancy relay	YES/NO	YES		YES
	PLCC panel	YES/NO	YES		YES
	Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED		R1-15.92Ω, X1-16.370Ω/ R2-15.92Ω, X2-30.690Ω/ R3-15.92Ω, X3-68.550Ω/ R4-15.92Ω, X4-0.830Ω
	Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0,0.35,1,0.160 sec.
	SOTF	YES/NO	DISABLED		DISABLED
	Aided schemes	YES/NO	ENABLED		ENABLED
	Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL
	Power swing (Settings R and X)				1/1
	All Zone Block	YES/NO	YES		YES
	DR	YES/NO	YES		DR
	Binary Inputs				
	Breaker Contacts	YES/NO	YES		YES
	Carrier Receive	YES/NO	YES		YES
	time Synchronization	YES/NO	NO		NO

Signature
Assistant Engineer (MPT&S)
RVPNL CHITTORGARH

date: 09/01/24

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the protection Audit

A. General Information:

- I. Name of Utility:- RVPNL
 II. Name of Voltage Level of sub-station: 220kV
 III. Date of Commissioning 28.06.1991
 IV. Type of bus-switching scheme:- 2 Main Bus and Aux. Bus
 V. Name of Organization of Audit Team :- R¹
 VI. Name of Representative from utility whose audit being carrier out :- XEN 220kV GSS Chittorgarh

B. Check list for Protection Audit

Distance Protection Panel: M-I			Numerical
Name of Line	220kV Chittorgarh - Hamirgarh		
Pole discrepancy relay	YES/NO	YES	YES
PLCC panel	YES/NO	YES	YES
Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED	Z1-6.149Ω/ Z2-9.213Ω/ Z3-10.74 Ω/ Z4-0.326Ω(reverse)
Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED	0,0.35,1,0.160 sec.
SOTF	YES/NO	DISABLED	DISABLED
Aided schemes	YES/NO	ENABLED	ENABLED
Fault locator	YES/NO	FUNCTIONAL	FUNCTIONAL
Power swing (Settings R and X)			1/ 1
All Zone Block	YES/NO	YES	YES
DR	YES/NO	YES	DR
Binary Inputs			
Breaker Contacts	YES/NO	YES	YES
Carrier Receive	YES/NO	YES	YES
time Synchronization	YES/NO	NO	NO
Distance Protection Panel: M-II			Numerical
Pole discrepancy relay	YES/NO	YES	YES
PLCC panel	YES/NO	YES	YES
Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED	R1-30Ω, X1-6.029 Ω/ R2-30Ω, X2-9.213Ω/ R3-30Ω, X3-10.528Ω/ R4-30Ω, X4-0.320Ω
Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED	0,0.35,1,0.160 sec.
SOTF	YES/NO	DISABLED	DISABLED
Aided schemes	YES/NO	ENABLED	ENABLED
Fault locator	YES/NO	FUNCTIONAL	FUNCTIONAL
Power swing (Settings R and X)			1/ 1
All Zone Block	YES/NO	YES	YES
DR	YES/NO	YES	DR
Binary Inputs			
Breaker Contacts	YES/NO	YES	YES
Carrier Receive	YES/NO	YES	YES
time Synchronization	YES/NO	NO	NO

ms
Assistant Engineer (MPT&S)
 RVPNL, CHITTORGARH

Date: 09/07/24

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the protection Audit

A. General Information:
 I. Name of Utility:- RVPNL II. Name of Voltage Level of sub-station: 220kV
 III. Date of Commissioning 28.06.1991 IV. Type of bus-switching scheme:- 2 Main Bus and Aux. Bus
 V. Name of Organization of Audit Team :- R
 VI. Name of Representative from utility whose audit being carrier out :- XEN 220kV GSS Chittorgarh

B. Check list for Protection Audit

Distance Protection Panel: M-I				Numerical	
4	Name of Line	220kV Chittorgarh - Chittorgarh (400kV GSS)			
	Pole discrepancy relay	YES/NO	YES		YES
	PLCC panel	YES/NO	YES		YES
	Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED		Z1-0.266mΩ/ Z2-0.762mΩ/ Z3-4.080 Ω/ Z4-0.065Ω(reverse)
	Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0.0.35,1.0.160 sec.
	SOTF	YES/NO	DISABLED		DISABLED
	Aided schemes	YES/NO	ENABLED		ENABLED
	Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL
	Power swing (Settings R and X)				1/1
	All Zone Block	YES/NO	YES		YES
	DR	YES/NO	YES		DR
	Binary Inputs				
	Breaker Contacts	YES/NO	YES		YES
	Carrier Receive	YES/NO	YES		YES
	time Synchronization	YES/NO	NO		NO
Distance Protection Panel: M-II				Numerical	
	Pole discrepancy relay	YES/NO	YES		YES
	PLCC panel	YES/NO	YES		YES
	Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED		R1 6Ω, X1 0.260 Ω/ R2 6Ω, X2 0.748Ω/ R3 6Ω, X3 4.0100Ω/ R4 6Ω, X4 0.650Ω(Rev.)
	Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0.0.35,1.0.160 sec.
	SOTF	YES/NO	DISABLED		DISABLED
	Aided schemes	YES/NO	ENABLED		ENABLED
	Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL
	Power swing (Settings R and X)				1/1
	All Zone Block	YES/NO	YES		YES
	DR	YES/NO	YES		DR
	Binary Inputs				
	Breaker Contacts	YES/NO	YES		YES
	Carrier Receive	YES/NO	YES		YES
	time Synchronization	YES/NO	NO		NO

ms
 Assistant Engineer (MPT&S)
 RVPNL, CHITTORGARH

Date: 09/07/24

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM
Report of the protection Audit

A. General Information:

- I. Name of Utility:- RVPNL
 II. Name of Voltage Level of sub-station: 220kV
 III. Date of Commissioning 28.06.1991
 IV. Type of bus-switching scheme:- 2 Main Bus and Aux. Bus
 V. Name of Organization of Audit Team :- R
 VI. Name of Representative from utility whose audit being carrier out :- XEN 220kV GSS Chittorgarh

B. Check list for Protection Audit

Distance Protection Panel: M-I				Numerical	
Name of Line	220kV Chittorgarh -Sawa				
Pole discrepancy relay	YES/NO	YES		YES	
PLCC panel	YES/NO	YES		YES	
Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED		Z1-3.347Ω/ Z2-5.949Ω / Z3-8.480 Ω/ Z4-0.326Ω(reverse)	
Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0,0.35,1,0.160 sec.	
SOTF	YES/NO	DISABLED		DISABLED	
Aided schemes	YES/NO	ENABLED		ENABLED	
Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL	
Power swing (Settings R and X)				1/1	
All Zone Block	YES/NO	YES		YES	
DR	YES/NO	YES		DR	
Binary Inputs					
Breaker Contacts	YES/NO	YES		YES	
Carrier Receive	YES/NO	YES		YES	
time Synchronization	YES/NO	NO		NO	
Distance Protection Panel: M-II				Numerical	
Pole discrepancy relay	YES/NO	YES		YES	
PLCC panel	YES/NO	YES		YES	
Zone-1/2/3/4/5(Setting)	YES/NO	ENABLED		R1-30Ω, X1- 3.280Ω/ R2- 30Ω, X2-5.836Ω/ R3- 30Ω, X3-8.320Ω/ R4-30Ω, X4-0.320Ω	
Time check-Z-1/2/3/4/5(Setting)	YES/NO	ENABLED		0,0.35,1,0.160 sec.	
SOTF	YES/NO	DISABLED		DISABLED	
Aided schemes	YES/NO	ENABLED		ENABLED	
Fault locator	YES/NO	FUNCTIONAL		FUNCTIONAL	
Power swing (Settings R and X)				1/1	
All Zone Block	YES/NO	YES		YES	
DR	YES/NO	YES		DR	
Binary Inputs					
Breaker Contacts	YES/NO	YES		YES	
Carrier Receive	YES/NO	YES		YES	
time Synchronization	YES/NO	NO		NO	

Li
Assistant Engineer: (MPT&S)
RVPNL, CHITTORGARH

Date: 09/07/24

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM

Report of the protection Audit

A. General Information:

- I. Name of Utility:- RVPNL
- II. Name of Voltage Level of sub-station: 220kV
- III. Date of Commissioning 28.06.1991
- IV. Type of bus-switching scheme:- Main and Aux Bus
- V. Name of Organization of Audit Team :- AEN (MPT&S) RVPNL Chittorgarh
- VI. Name of Representative from utility whose audit being carrier out :- XEN 220kV GSS Chittorgarh

B. Check list for Protection Audit

S.NO.	Check		Fuctional/ Non- fuctional/ Enabeled/ Disabled	Type of Yearly* (Numerical/S tatic/ Electo- mechanical)	Setting as Found in Field**	Compliance status w.r.t. regulatory provisions
1	DC System 220V DC system					
	No. of independent DC Sources	1/2/3/4			2	
	Potential between +ive & earth (Source-1)V	Functional		100 V	
	Potential between -ive & earth (Source-1)V			120 V	
	Potential between +ive & earth (Source-2)V	Defective		Defective	
	Potential between -ive & earth (Source-2)V			Defective	
	Potential between +ive & earth (Source-3)V			NA	
	Potential between -ive & earth (Source-3)V			NA	
	Potential between +ive & earth (Source-4)V			NA	
	Potential between -ive & earth (Source-4)V			NA	
2	Event Logger panel	YES/NO	NO			
3	Event Logger Time Synchronised	YES/NO	NO			
	Distance Recorder	YES/NO	NO			
	DR Tme Synchronised	YES/NO	NO			
4	Bus Bar Protection	YES/NO	NO			
	Stability Check					
	EL output for this event	YES/NO				
	DR if available	YES/NO				
5	DG Set	YES/NO	NO			
	Mock Testing for a sample protection associated with transmission line***	YES/NO				
	LBB/BFR	YES/NO	NO			
	Retrip	YES/NO	NO			
	Current and Time Setting					
	Separate single and three phase initiation	YES/NO	NO			
	Earth Fault	YES/NO	NO			
	Event Logger operation	YES/NO	NO			


Assistant Engineer (MPT&S)
RVPNL, CHITTORGARH

Report of the Protection Audit


A. General Information

i)	Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kV GSS Sitapura
iii)	Date of Commissioning:	31.03.2015
iv)	Type of Bus Switching Scheme	One and Half Breaker Scheme
v)	Name and Organization of Audit Team	Kapish Sharma, AEN(MPT&S), RVPN, Jaipur
		Seema Choudhary, JEN o/o AEN(MPT&S), RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh. D.K.Jain, SE (Prot. Engg.), RVPN , Jaipur

B. Checklist for Protection Audit

S.No.	Check		Functional/ Non-Functional/Enabled/ Disabled	Type of Relay*(Numerical /Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
1	DC system					
	No. of independent DC Sources	1 nos. 220 VDC	Functional			
	Potential between +ive & earth (Source-1)	122.2 V	-	-	-	-
	Potential between -ive & earth (Source-1)	123.0 V	-	-	-	-
2	Event Logger panel	No	-	-	-	-
3	Event Logger Time Synchronised	NA	-	-	-	-
	Disturbance Recorder	NA	-	-	-	-
	DR Time Synchronised	NA	-	-	-	-
4	Bus bar Protection	Yes	Functional	Numerical	120 % Pickup	Complying
	Stability Check	Yes(On Running load)	-	-	-	-
	EL output for this event	No	-	-	-	-
	DR if available	No	-	-	-	-
5	DG Set	No	-	-	-	-
	Mock testing of a sample protection associated with transmission line***	Yes/ No	i. If Yes then observation..... ii. If no, the reason for the same.....			
6	Local Breaker Back Up(For Line)		-	Numerical	-	-
	Retrip	Yes	Enabled	-	-	Complying
	Current and Time Setting	Yes	-	-	PU-120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	Yes	Functional	-	-	Complying
	Earth Fault	No	Disabled	-	-	Complying
	Event logger operation	Yes	In built feature of numerical LBB relay			

*complying with the code of configuration issued by The CE (MPT&S) RVPN, Jaipur by letter no. RVPN/SE/MPT&S/JPR/Tech./F./ Rajkaj ref. No. 5221696/D.166 dated 21.12.2023

Name. Signature & Contact No. of team carrying out	Kapish Sharma, AEN(MPT&S), RVPN, Jaipur Seema Choudhary, JEN o/o AEN(MPT&S), RVPN, Jaipur	
Name. Signature & Contact No. of representative of Utility	Sh. D.K.Jain, SE (Prot. Engg.), RVPN , Jaipur	

Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit


A. General Information

i) Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii) Name of Voltage level of Substation:	220 kV GSS Sitapura
iii) Date of Commissioning:	31.03.2015
iv) Type of Bus Switching Scheme	One and Half Breaker Scheme
v) Name and Organization of Audit Team	Kapish Sharma, AEN(MPT&S), RVPN, Jaipur
	Seema Choudhary, JEN o/o AEN(MPT&S), RVPN, Jaipur
vi) Name of representative from utility whose audit being carried out	Sh. D.K.Jain, SE (Prot. Engg.), RVPN , Jaipur

B. Checklist for Protection Audit

S.No.	Check	Functional/ Non-Functional/Enabled/Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field**/**	Compliance status w.r.t. regulatory provisions
Transformer Protection Panel					
(i)	Name of Transformer (Rating/Capacity)	220/132 kV, 100 MVA IMP make Transformer			
	Tripping by Buchholz Relay (Alarm)	Yes	Enabled	Electromechanical	Complying
	Differential Protection	Yes	Enabled	Numerical	Complying
	2nd Harmonic Block (Setting)		Enabled	15%	Complying
	Event Logger Operation	Yes	In built feature of numerical differential relay		
	Restricted Earth Fault Protection (HV Side)(Auto X-mer)	Yes	Functional	Numerical	42.28 Complying
	Event Logger Operation	Yes	In built feature of numerical REF relay		
	REF Protection (LV Side)	NA			
	Event Logger Operation	NA			
	Backup Over Current	Yes	Enabled	Numerical	0.42/0.208 Complying
	Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay		
	Earth Fault Protection	Yes	Enabled	Numerical	0.2/0.232 Complying
	Event Logger Operation	Yes	In built feature of numerical O/C & E/F relay		
	Over Flux Protection	Yes	Enabled		Complying
	Event Logger Operation	Yes	In built feature of numerical differential relay		
	Local Breaker Back Up	Yes			
	Retrip	Yes	Enabled		Complying
	Current and Time Setting			120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	No(3 phase only)			
	Earth Fault	No			
	Event logger	Yes	In built feature of numerical LBB relay		

*complying with the code of configuration issued by The CE (MPT&S) RVPN, Jaipur by letter no. RVPN/SE/MPT&S/JPR/Tech./F./ Rajkaj
ref. No. 5221696/D.166 dated 21.12.2023

Name. Signature & Contact No. of team carrying out	Kapish Sharma, AEN(MPT&S), RVPN, Jaipur Seema Choudhary, JEN o/o AEN(MPT&S), RVPN, Jaipur	
Name. Signature & Contact No. of representative of Utility	Sh. D.K.Jain, SE (Prot. Engg.), RVPN , Jaipur	

Non Directional O/C & E/F relay calculation for 220/132 kV, 100 MVA Transformer

Fault MVA of 220 kV BUS	:	8519 MVA
P.U. Impedance of 220 kV BUS		0.0117
% Impedance of transformer at Normal Tap		11.59 %
Transformer HV Voltage rating		220000 Volts
Transformer LV Voltage rating		132000 Volts
Transformer MVA Capacity		160 MVA
P.U. Impedance of Transformer		0.072438
Total P.U. Impedance		0.0842
Fault MVA of 132 kV BUS	:	1188 MVA
3 Phase through fault Short Circuit Current		5196 Amp
Phase-Phase through fault Short Circuit Current		4500 Amp
Phase to Earth through fault Short Circuit Current		2806 Amp

Non Directional Overcurrent Element Setting

CT Ratio	1000/1		
Plug Setting	420 % i.e.	420	Amp
Plug Setting Multiplier	10.71429		
Time of Operation	0.6	Seconds	
TMS	0.208		

Non Directional Earthfault Element Setting -

CT Ratio	1000/1		
Plug Setting	20 % i.e.	200	Amp
Plug Setting Multiplier	14.03		
Time of Operation	0.6	Seconds	
TMS	0.232		

Stablizing Resistor calculation for Restricted Earth fault relay

Transformer Full load current HV	420 Amp
Transformer Full load current LV	700 Amp
Maximum fault current on through fault (If)	6040 Amp
Bushing CT Ratio	1000
Lead resistance	1 Ohm
Rct	5 Ohm
$V_k = I_f^*(R_{ct} + 2R_l)$	
Vk=	42.3 Volts
REF Operating Current	0.1 Amp
Stablizing Resistor	423 Ohm

Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information


i)	Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kV GSS Sitapura
iii)	Date of Commissioning:	31.03.2015
iv)	Type of Bus Switching Scheme	One and Half Breaker Scheme
v)	Name and Organization of Audit Team	Kapish Sharma, AEN(MPT&S), RVPN, Jaipur
		Seema Choudhary, JEN o/o AEN(MPT&S), RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh. D.K.Jain, SE (Prot. Engg.), RVPN ; Jaipur

B. Checklist for Protection Audit


S.No.	Check		Functional / Non-Functional / Enabled/ Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
Distance protection Panel:M-1/II						
(i) Name of Line		220 kV IG Nagar Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=1.632 Ohm, T1=0 ms Z2=5.101 Ohm, T2=350 ms Z3=10.121 Ohm, T3=1000 ms Z4(Rev.)=408 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional			
	SOTF	No	Disabled			Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays		Complying

S.No.	Check		Functional / Non-Functional / Enabled / Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
	Power swing(S(settings R and X))				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of Numerical Distance Protection Relays	-	Complying
	DR	Yes	Enabled		-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying
	220 kV Sanganer Line					
(ii)	Name of Line					
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 Sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=1.796 Ohm, T1=0 ms Z2=3.469 Ohm, T2=350 ms Z3=5.791 Ohm, T3=1000 ms Z4(Rev.)=408 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional		-	-
	SOTF	No	Disabled			
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying
	Power swing(S(settings R and X))				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of Numerical Distance	-	Complying
	DR	Yes	Enabled		-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying

*complying with the code of configuration issued by The CE (MPT&S) RVPN, Jaipur by letter no. RVPN/SE/MPT&S/JPR/Tech./F./ Rajkaj ref. No. 5221696/D.166 dated 21.12.2023

Name. Signature & Contact No. of team carrying out	Kapish Sharma, AEN(MPT&S), RVPN, Jaipur Seema Choudhary, JEN o/o AEN(MPT&S), RVPN, Jaipur	
Name. Signature & Contact No. of representative of Utility	Sh. D.K.Jain, SE (Prot. Engg.), RVPN, Jaipur	

Distance relay calculation for 220 kV Sitapura-IG Nagar Line



Principle line Length : 10 KM.
 Shortest Line Length considered on Remote Bus : 30 KM.
 Longest line length Considered on Remote Bus : 36 KM.

EARTH FAULT COMPENSATION

$RE/RL = 1/3((Ro/R1)-1)$
 $XE/XL = 1/3((Xo/X1)-1)$
 $kZ0 \text{ Res. Comp.} = kZ0 = (Z0 - Z1) / 3Z1$

kZ0	kZ0 angle
0.734	-1.83

Conductor Used	:	Zebra			
Conductor Parameters	:	R	X	Z	Angle
Positive Sequence(Z1):		0.081	0.4	0.408	78.55
Zero Sequence(Z0):		0.2875	1.275	1.307	77.29
CTR:		1000/1 Amp= 1000			
PTR:		220000/110 V= 2000			
CTR/PTR:		0.5			

Zone 1(Forward) Reach:	80	% of the Line to be Protected
Zone 2(Forward) Reach:	50	% of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach:	110	% Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach:	2	Km

Zone 1 forward Reach= 80% of line length (SEZ to PGCIL)* +ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{1.632} \text{ Ohm} \quad T1 = \text{Instt.}$$

Zone 2 forward Reach= 100% of line length (SEZ to PGCIL)+50 % of the Shortest Line on remote Bus(PGCIL-Chaksu)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{5.101} \text{ Ohm} \quad T2 = 350 \text{ ms}$$


Zone 3 forward Reach=100% of line length (SEZ to PGCIL)+110 % Longest line length on Remote Bus(PGCIL-Vatika)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{10.121} \text{ Ohm} \quad T3 = 1000 \text{ ms}$$

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{0.408} \text{ Ohm} \quad T4 = 160 \text{ ms}$$

Distance relay calculation for 220 kV Sitapura-Heerapura Line



Principle line Length : 11 KM.
Shortest Line Length considered on Remote Bus : 12 KM.
Longest line length Considered on Remote Bus : 15.8 KM.

EARTH FAULT COMPENSATION

$$R_E/R_L = 1/3((R_o/R_1)-1)$$

$$X_E/X_L = 1/3((X_o/X_1)-1)$$

$$kZ_0 \text{ Res. Comp.} = kZ_0 = (Z_0 - Z_1) / 3Z_1$$

kZ0 : 0.734
kZ0 angle : -1.83

Conductor Used	:	Zebra			
Conductor Parameters	:	R	X	Z	Angle
Positive Sequence(Z1):		0.081	0.4	0.408	78.55
Zero Sequence(Z0):		0.2875	1.275	1.307	77.29
CTR:		1000/1 Amp = 1000			
PTR:		220000/110 V = 2000			
CTR/PTR:		0.5			

Zone 1(Forward) Reach: 80 % of the Line to be Protected
Zone 2(Forward) Reach: 50 % of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach: 110 % Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach: 2 Km

Zone 1 forward Reach= 80% of line length (Sitapura to Sanganer)* +ve Sequence impedance of conductor/km*(CTR/PTR)
 = 1.796 Ohm T1= Instt.

Zone 2 forward Reach= 100% of line length (Sitapura to Sanganer)+50 % of the Shortest Line on remote Bus(Sanganer to Heerapura)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 3.469 Ohm T2=350 ms

Zone 3 forward Reach=100% of line length (Sitapura to Sanganer)+110 % Longest line length on Remote Bus(Sanganer to Mansarovar)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 5.791 Ohm T3=1000 ms

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = 0.408 Ohm T4=160 ms

RRVPN 400kV Bhilwara S/s

Rajasthan Rajya Vidhyut Prasaran Nigam Report of the Protection Audit on dated 14.06.2024

A. General Information

(i) Name of Utility - 400KV GSS BHILWARA
(ii) Date of Commissioning - 30.03.2010
(iii) Name and Organization of Audit Team - XEN (MPT&S) RVPNI, BHILWARA
(vi) Name of representative from utility whose audit being carried out - XEN 400KV GSS RVPNI, BHILWARA

(iii) Name of Voltage Level of Sub Station - 400.220 kV
(iv) Type of Bus Switching Scheme - 400KV Main Bus I & II

B. Check List for Protection Audit

S.No	Check	Functional/Non-Functional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
Transformer Protection Panel:					
(i)	Name of Transformer/ICT (Rating/Capacity)	400/220/33KV, 500 MVA Transformer-I	(SIEMENSEMake)		
	Tripping by Buchholz relay (Alarm)	Yes/ No	Functional	Conventional	
	Differential Protection	Yes/ No	Functional	Numerical	0.20, 8.0
	2nd Harmonic Block (Setting)	Yes/ No	Enabled		15%
	Event logger Operation	Yes/ No	SAS Installed		
	Restricted Earth Fault Protection (HV Side)	Yes/ No	Functional	Numerical	20% Inst
	Event logger Operation	Yes/ No	SAS Installed		
	Restricted Earth Fault Protection (LV Side)	Yes/ No	Functional	Numerical	20% Inst
	Event logger Operation	Yes/ No	SAS Installed		
	Backup Over Current	Yes/ No	Functional	Numerical	0.81, 0.230
	Event logger Operation	Yes/ No	SAS Installed		
	Earth Fault Protection	Yes/ No	Functional	Numerical	0.2, 0.350
	Event logger Operation	Yes/ No	SAS Installed		
	Over Flux Protection	Yes/ No	Enabled	Numerical	Alarm 110%, 5 Sec and Trip
	Event logger Operation	Yes/ No	SAS Installed		
	Local Breaker Back Up	Yes/ No	Functional	Numerical	
	Retrip	Yes/ No	Enabled		100 mSec
	Current and Time Setting	Yes/ No	Enabled		120%, 100+100 mSec
	Separate Single and three Phase Initiation	Yes/ No	Enabled		Single phase initiation
	Earth Fault	Yes/ No	Disable		
	Event logger Operation	Yes/ No	SAS Installed		
(ii)	Name of Transformer (Rating/Capacity)	400/220/33 KV 315 MVA make AREVA			
	Tripping by Buchholz relay (Alarm)	Yes/ No	Functional	Conventional	
	Differential Protection	Yes/ No	Functional	Numerical	0.2, 8.0
	2nd Harmonic Block (Setting)	Yes/ No	Enabled		15%
	Event logger Operation	Yes/ No	SAS Installed		
	Restricted Earth Fault Protection (HV Side)	Yes/ No	Functional	Numerical	0.2 Inst
	Event logger Operation	Yes/ No	SAS Installed		
	Restricted Earth Fault Protection (LV Side)	Yes/ No	Functional	Numerical	0.2 Inst
	Event logger Operation	Yes/ No	SAS Installed		
	Backup Over Current	Yes/ No	Functional	Numerical	0.51, 0.230
	Event logger Operation	Yes/ No	SAS Installed		
	Earth Fault Protection	Yes/ No	Functional	Numerical	0.2, 0.310
	Event logger Operation	Yes/ No	SAS Installed		
	Over Flux Protection	Yes/ No	Enabled	Numerical	Alarm 110%, 5 Sec and Trip
	Event logger Operation	Yes/ No	SAS Installed		
	Local Breaker Back Up	Yes/ No	Functional	Numerical	
	Retrip	Yes/ No	Enabled		100 mSec
	Current and Time Setting	Yes/ No	Enabled		120%, 100+100 mSec
	Separate Single and three Phase Initiation	Yes/ No	Enabled		Single phase initiation
	Earth Fault	Yes/ No	Disable		
	Event logger Operation	Yes/ No	SAS Installed		

JH

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

(i) Name of Utility - 400KV GSS BHILWARA
 (ii) Date of Commissioning - 30/03/2010

(iii) Name of Voltage Level of Sub Station - 400/220 kv

(iv) Type of Bus Switching Scheme - 400KV Main Bus I & II

(v) Name and Organization of Audit Team - XEN (MPT&S) RVPNL BHILWARA

(vi) Name of representative from utility whose audit being carried out - XEN 400KV GSS RVPNL BHILWARA

B. Check List for Protection Audit

S No.	Check	Functional/Non functional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w r t regulatory provisions
Distance Protection Panel:M-I/II					
(I)	Name of Line	400KV Bhilwara Chhabra			
	Pole Discrepancy Relay	Yes/ No Functional	Electromechanical	1.5s	
	PLCC Panel	Yes/ No Functional			
	Zone-1/2/3/4/5 (Settings)	Yes/ No Enabled	Numerical	As per Line length 0, 0.350, 1.00, 0.160 s	
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No Enabled			
	SOTF	Yes/ No Disabled			
	Aided Scheme	Yes/ No Disabled			
	Fault Locator	Yes/ No Enabled			
	Power Swing (Setting R & X)	Yes/ No Enabled			
	All Zone Block	Yes/ No Enabled			
	DR	Yes/ No Enabled			
	Binary Inputs	Yes/ No Enabled			
	Breaker Contacts	Yes/ No Enabled			
	Carrier Receive	Yes/ No Enabled			
	Time Synchronization	Yes/ No Enabled	Through SAS		
Distance Protection Panel:M-I/II					
(II)	Name of Line	400KV Bhilwara - Chittorgarh-I			
	Pole Discrepancy Relay	Yes/ No Functional	Electromechanical	1.5s	
	PLCC Panel	Yes/ No Functional			
	Zone-1/2/3/4/5 (Settings)	Yes/ No Enabled	Numerical	As per Line length 0, 0.350, 1.00, 0.160 s	
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No Enabled			
	SOTF	Yes/ No Disabled			
	Aided Scheme	Yes/ No Disabled			
	Fault Locator	Yes/ No Enabled			
	Power Swing (Setting R & X)	Yes/ No Enabled			
	All Zone Block	Yes/ No Enabled			
	DR	Yes/ No Enabled			
	Binary Inputs	Yes/ No Enabled			
	Breaker Contacts	Yes/ No Enabled			
	Carrier Receive	Yes/ No Enabled			
	Time Synchronization	Yes/ No Enabled	Through SAS		
Distance Protection Panel:M-I/II					
(I)	Name of Line	400KV Bhilwara - Chittorgarh-II			
	Pole Discrepancy Relay	Yes/ No Functional	Electromechanical	1.5s	
	PLCC Panel	Yes/ No Functional			
	Zone-1/2/3/4/5 (Settings)	Yes/ No Enabled	Numerical	As per Line length 0, 0.350, 1.00, 0.160 s	
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No Enabled			
	SOTF	Yes/ No Disabled			
	Aided Scheme	Yes/ No Enabled			
	Fault Locator	Yes/ No Enabled			
	Power Swing (Setting R & X)	Yes/ No Enabled			
	All Zone Block	Yes/ No Enabled			
	DR	Yes/ No Enabled			
	Binary Inputs	Yes/ No Enabled			
	Breaker Contacts	Yes/ No Enabled			
	Carrier Receive	Yes/ No Enabled			
	Time Synchronization	Yes/ No Enabled	Through SAS		

(i)	Name of Line	400KV Bhilwara-Ajmer -I					
	Pole Discrepancy Relay	Yes/ No	Functional	Electromechanical	1.5s		
	PLCC Panel	Yes/ No	Functional				
	Zone-1/2/3/4/5 (Settings)	Yes/ No	Enabled	Numerical	As per Line length 0.0350, 1.00, 0.160 s		
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No	Enabled				
	SOTF	Yes/ No	Disabled				
	Aided Scheme	Yes/ No	Disabled				
	Fault Locator	Yes/ No	Enabled				
	Power Swing (Setting R & X)	Yes/ No	Enabled				
	All Zone Block	Yes/ No	Enabled				
	DR	Yes/ No	Enabled				
	Binary Inputs	Yes/ No	Enabled				
	Breaker Contacts	Yes/ No	Enabled				
	Carrier Receive	Yes/ No	Enabled				
	Time Synchronization	Yes/ No	Enabled			Through SAS	

(i)	Name of Line	400KV Bhilwara-Ajmer -II					
	Pole Discrepancy Relay	Yes/ No	Functional	Electromechanical	1.5s		
	PLCC Panel	Yes/ No	Functional				
	Zone-1/2/3/4/5 (Settings)	Yes/ No	Enabled	Numerical	As per Line length 0.0350, 1.00, 0.160 s		
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No	Enabled				
	SOTF	Yes/ No	Disabled				
	Aided Scheme	Yes/ No	Disabled				
	Fault Locator	Yes/ No	Enabled				
	Power Swing (Setting R & X)	Yes/ No	Enabled				
	All Zone Block	Yes/ No	Enabled				
	DR	Yes/ No	Enabled				
	Binary Inputs	Yes/ No	Enabled				
	Breaker Contacts	Yes/ No	Enabled				
	Carrier Receive	Yes/ No	Enabled				
	Time Synchronization	Yes/ No	Enabled			Through SAS	

220 kv feeders

(i)	Name of Line	220KV Bhilwara- Inter connector -I					
	Pole Discrepancy Relay	Yes/ No	Functional	Electromechanical	1.5s		
	PLCC Panel	Yes/ No	Functional				
	Zone-1/2/3/4/5 (Settings)	Yes/ No	Enabled	Numerical	As per Line length 0.0350, 1.00, 0.160 s		
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No	Enabled				
	SOTF	Yes/ No	Disabled				
	Aided Scheme	Yes/ No	Enabled				
	Fault Locator	Yes/ No	Enabled				
	Power Swing (Setting R & X)	Yes/ No	Enabled				
	All Zone Block	Yes/ No	Enabled				
	DR	Yes/ No	Enabled				
	Binary Inputs	Yes/ No	Enabled				
	Breaker Contacts	Yes/ No	Enabled				
	Carrier Receive	Yes/ No	Enabled				
	Time Synchronization	Yes/ No	Enabled			Through SAS	

(i)	Name of Line	220KV Bhilwara- Inter connector -II					
	Pole Discrepancy Relay	Yes/ No	Functional	Electromechanical	1.5s		
	PLCC Panel	Yes/ No	Functional				
	Zone-1/2/3/4/5 (Settings)	Yes/ No	Enabled	Numerical	As per Line length 0.0350, 1.00, 0.160 s		
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No	Enabled				
	SOTF	Yes/ No	Disabled				
	Aided Scheme	Yes/ No	Enabled				
	Fault Locator	Yes/ No	Enabled				
	Power Swing (Setting R & X)	Yes/ No	Enabled				
	All Zone Block	Yes/ No	Enabled				
	DR	Yes/ No	Enabled				
	Binary Inputs	Yes/ No	Enabled				
	Breaker Contacts	Yes/ No	Enabled				
	Carrier Receive	Yes/ No	Enabled				
	Time Synchronization	Yes/ No	Enabled			Through SAS	

(i)	Name of Line	220KV Bhilwara- Baman Tukada					
	Pole Discrepancy Relay	Yes/ No	Functional	Electromechanical	1.5s		
	PLCC Panel	Yes/ No	Functional				
	Zone-1/2/3/4/5 (Settings)	Yes/ No	Enabled	Numerical	As per Line length 0.0350, 1.00, 0.160 s		
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No	Enabled				
	SOTF	Yes/ No	Disabled				
	Aided Scheme	Yes/ No	Enabled				
	Fault Locator	Yes/ No	Enabled				
	Power Swing (Setting R & X)	Yes/ No	Enabled				
	All Zone Block	Yes/ No	Enabled				
	DR	Yes/ No	Enabled				
	Binary Inputs	Yes/ No	Enabled				
	Breaker Contacts	Yes/ No	Enabled				
	Carrier Receive	Yes/ No	Enabled				
	Time Synchronization	Yes/ No	Enabled			Through SAS	

(i)	Name of Line	220KV Bhillwara- Pali					
	Pole Discrepancy Relay	Yes/ No	Functional	Electromechanical	1.5s		
	PLCC Panel	Yes/ No	Functional	Numerical	As per Line length 0, 0.350, 1.00, 0.160 s		
	Zone-1/2/3/4/5 (Settings)	Yes/ No	Enabled				
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No	Enabled				
	SOTI	Yes/ No	Disabled				
	Aided Scheme	Yes/ No	Enabled				
	Fault Locator	Yes/ No	Enabled				
	Power Swing (Setting R & X)	Yes/ No	Enabled				
	All Zone Block	Yes/ No	Enabled				
	DR	Yes/ No	Enabled				
	Binary Inputs	Yes/ No	Enabled				
	Breaker Contacts	Yes/ No	Enabled				
	Carrier Receive	Yes/ No	Enabled				
	Time Synchronization	Yes/ No	Enabled			Through SAS	

(i)	Name of Line	220KV Bhillwara- JSW					
	Pole Discrepancy Relay	Yes/ No	Functional	Electromechanical	1.5s		
	PLCC Panel	Yes/ No	Functional	Numerical	As per Line length 0, 0.350, 1.00, 0.160 s		
	Zone-1/2/3/4/5 (Settings)	Yes/ No	Enabled				
	Time Check-Z-1/2/3/4/5(Settings)	Yes/ No	Enabled				
	SOTI	Yes/ No	Disabled				
	Aided Scheme	Yes/ No	Enabled				
	Fault Locator	Yes/ No	Enabled				
	Power Swing (Setting R & X)	Yes/ No	Enabled				
	All Zone Block	Yes/ No	Enabled				
	DR	Yes/ No	Enabled				
	Binary Inputs	Yes/ No	Enabled				
	Breaker Contacts	Yes/ No	Enabled				
	Carrier Receive	Yes/ No	Enabled				
	Time Synchronization	Yes/ No	Enabled			Through SAS	

Rajasthan Rajya Vidhyut Prasaran Nigam
Report of the Protection Audit

A. General Information

(i) Name of Utility - 400KV GSS BHILWARA

(ii) Name of Voltage Level of Sub Station - 400/220 kv

(iii) Date of Commissioning - 30/03/2010

(iv) Type of Bus Switching Scheme - 400KV Main Bus I & II

(v) Name and Organization of Audit Team - XEN (MPT&S) RVPNL BHILWARA

(vi) Name of representative from utility whose audit being carried out - XEN 400KV GSS RVPNL BHILWARA

B. Check List for Protection Audit

S.No	Check	Yes/ No	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
1	DC System		Functional			
	No. Of Independent DC Source	2	1 & 2			
	Potential Between -ve & Earth (Source-I)	V	Functional		140 V	
	Potential Between -ve & Earth (Source-II)	V	Functional		80 V	
	Potential Between -ve & Earth (Source-I)	V	Functional		130 V	
	Potential Between -ve & Earth (Source-II)	V	Functional		100 V	
2	Event Logger Panel	Yes/ No	No			
3	Event Logger Time Synchronised	Yes/ No	No			
	Disturbance Recorder	Yes/ No	No			
	DR Time Synchronised	Yes/ No	No			
4	Bus Bar Protection	Yes/ No	Yes, Functional			
	Stability Check	Yes/ No	Yes, Functional			
	EL Output for this Event	Yes/ No	Yes, Functional			
	DR if Available	Yes/ No	Yes, Functional			
5	DG Set	Yes/ No	Manual			
6	Mock Testing of Sample Protection Associated with Transmission line	Yes/ No	Satisfactory			
	LBB/BFR	Yes/ No	Functional	Numerical		
	Retrip	Yes/ No	Enabled		100 mSec	
	Current and Time Setting	Yes/ No	Enabled		120 th , 100 mSec	
	Separate Single and Three Phase initiation	Yes/ No	Enabled		Three phase initiation	
	Earth Fault	Yes/ No	Disable			
	Event Logger Operation	Yes/ No	SAS Installed			

Ⓟ

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

(i) Name of Utility - 400KV GSS BHILWARA

(ii) Name of Voltage Level of Sub Station - 400/220 kV

(iii) Date of Commissioning - 30.03.2010

(iv) Type of Bus Switching Scheme - 400KV Main Bus I & II

(v) Name and Organization of Audit Team - XEN (MPT&S) RVPNL BHILWARA

(vi) Name of representative from utility whose audit being carried out - XEN 400KV GSS RVPNL BHILWARA

B. Check List for Protection Audit: Bus Reactor

S.No	Check	Yes/No	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Reactor Protection Panel:	Yes/No	Yes	Numerical		
	Tripping by Buchholz relay (Alarm)	Yes/No	Functional			
	Differential Protection	Yes/No	Yes	Numerical	0.2 & 8.0	
	2nd Harmonic Block (Setting)	Yes/No	Yes		15%	
	Event logger Operation	Yes/No	SAS Installed			
	Restricted Earth Fault Protection (HV Side)	Yes/No	Yes	Numerical	0.2 Inst	
	Event logger Operation	Yes/No	SAS Installed			
	Restricted Earth Fault Protection (LV Side)	Yes/No	No			
	Event logger Operation	Yes/No				
	Backup Over Current	Yes/No	Yes	Numerical	0.5, 0.350ms	
	Event logger Operation	Yes/No	SAS Installed			
	Earth Fault Protection	Yes/No	Yes	Numerical	0.2, 0.350ms	
	Event logger Operation	Yes/No	SAS Installed			
	Over Flux Protection	Yes/No	No			
	Event logger Operation	Yes/No	No			

A. General Information

(i) Name of Utility - 400KV GSS BHILWARA

(ii) Name of Voltage Level of Sub Station - 400/220 kV

(iii) Date of Commissioning - 30.03.2010

(iv) Type of Bus Switching Scheme - 400KV Main Bus I & II

(v) Name and Organization of Audit Team - XEN (MPT&S) RVPNL BHILWARA

(vi) Name of representative from utility whose audit being carried out - XEN 400KV GSS RVPNL BHILWARA

B. Check List for Protection Audit: - Line Reactor

S.No	Check	Yes/No	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Reactor Protection Panel:	Yes/No	Yes	Numerical		
	Tripping by Buchholz relay (Alarm)	Yes/No	Functional			
	Differential Protection	Yes/No	Yes	Numerical	0.2 & 8.0	
	2nd Harmonic Block (Setting)	Yes/No	Yes		15%	
	Event logger Operation	Yes/No	SAS Installed			
	Restricted Earth Fault Protection (HV Side)	Yes/No	Yes	Numerical	0.2, Inst	
	Event logger Operation	Yes/No	SAS Installed			
	Restricted Earth Fault Protection (LV Side)	Yes/No	No			
	Event logger Operation	Yes/No				
	Backup Over Current	Yes/No	No			
	Event logger Operation	Yes/No				
	Earth Fault Protection	Yes/No	No			
	Event logger Operation	Yes/No				
	Over Flux Protection	Yes/No	No			
	Event logger Operation	Yes/No	No			



Executive Engineer (MPT&S)
RVPNL, Bhitwara



RRVPN 220kV Amberi S/s

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit dt 23.08.24

A. General Information

(i) Name of Utility:- 220 KV GSS Amberi

(ii) Date of Commissioning:- 08.09.2017

(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL, Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS Amberi

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus

B. Check List for Protection Audit

S.No	Check	Functional	NonFunctional	Type of Relay (Numerical Static El ectromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
		Enabled	Disabled			
Transformer Protection Panel:						
(i)	Name of Transformer (Rating/Capacity)	220/132KV, 160MVA BHEL				
	Tripping by Buchholz relay (Alarm)	YES	Enable			
	Differential Protection			Numerical	As per code of configuration 20%	
	2nd Harmonic Block (Setting)	YES	Enable			
	Event logger Operation	NO				
	Restricted Earth Fault Protection (HV Side)	YES	Enable		20%	
	Event logger Operation	Yes No				
	Restricted Earth Fault Protection (LV Side)	YES	Enable		20%	
	Event logger Operation	Yes No				
	Backup Over Current	YES	Enable		.42% 0.25%	
	Event logger Operation	NO				
	Earth Fault Protection	YES	Enable		20% , 0.30	
	Event logger Operation	NO				
	Over Flux Protection				110% , 5Sec. 120% , 1Sec.	
	Event logger Operation	NO				
	Local Breaker Back Up in bus bar	YES	Enable			
	Retrip	YES	Enable			
	Current and Time Setting	Yes No			1200A	
	Separate Single and three Phase Initiation	NO				
	Earth Fault	Yes No				
	Event logger Operation	NO				
(ii)	Name of Transformer (Rating/Capacity)	132/33KV, 20/25MVA TR				
	Tripping by Buchholz relay (Alarm)	YES	Enable			
	Differential Protection	YES	Enable	Numerical	As per code of configuration .15%	
	2nd Harmonic Block (Setting)	YES	Enable			
	Event logger Operation	No				
	Restricted Earth Fault Protection (HV Side)	YES	Enable		20%	
	Event logger Operation	Yes No				
	Restricted Earth Fault Protection (LV Side)	YES	Enable		20%	
	Event logger Operation	Yes No				
	Backup Over Current	YES	Enable		.42% 0.18%	
	Event logger Operation	Yes No				
	Earth Fault Protection	YES	Enable		20% , 0.25	
	Event logger Operation	Yes No				
	Over Flux Protection	Yes	Enabled		110% , 5Sec. 120% , 1Sec.	
	Event logger Operation	No				
	Local Breaker Back Up	YES				
	Retrip	Yes				
	Current and Time Setting					
	Separate Single and three Phase Initiation	No				
	Earth Fault	No				
	Event logger Operation	No				
	Earth Fault	NO				
	Event logger Operation	NO				


XEN (MPT & S)
RRVPNL, Udaipur


Assistant Engineer (MPT&S)
RRVPNL, UDAIPUR

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS Amberi

(iii) Date of Commissioning:-08.09.2017

(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN , 220KV GSS RVPNL Amberi

(ii) Name of Voltage Level of Sub Station:- 220 132 KV

(iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus

B. Check List for Protection Audit

S.No	Check	Functional	NonFunctional	Type of Relay (Numerical Static EI ectromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Distance Protection Panel:M-I/II					
III	Name of Line : 220KV Debari-M-I/M-II		Functional	Numerical	As per code of configuration .	
	Pole Discrepancy Relay	Yes	Enabled			
	PLCC Panel	Yes	Enabled			
	Zone-1 2 3 4 5 (Settings)	Yes	Enabled			
	Time Check-Z-1 2 3 4 5(Settings)	Yes	Enabled			
	SOTF	NO				
	Aided Scheme	Yes	Enabled			
	Fault Locator	Yes	Enabled			
	Power Swing (Setting R & X)					
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs					
	Breaker Contacts	Yes	Enabled			
	Carrier Receive	Yes	Enabled			
	Time Synchronization	NO	Enabled			
	Distance Protection Panel:M-I/II					
IV	Name of Line : 220KV PGCIL-M-I/M-II		Functional	Numerical	As per code of configuration .	
	Pole Discrepancy Relay	Yes	Enabled			
	PLCC Panel	Yes	Enabled			
	Zone-1 2 3 4 5 (Settings)	Yes	Enabled			
	Time Check-Z-1 2 3 4 5(Settings)	Yes	Enabled			
	SOTF	NO				
	Aided Scheme	Yes	Enabled			
	Fault Locator	Yes	Enabled			
	Power Swing (Setting R & X)					
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs					
	Breaker Contacts	Yes	Enabled			
	Carrier Receive	Yes	Enabled			
	Time Synchronization	Yes No	Enabled			
V	Name of Line : 132KV Sukher -I		Functional	Numerical	As per code of configuration .	
	Pole Discrepancy Relay	NO				
	PLCC Panel	NO				
	Zone-1 2 3 4 5 (Settings)	Yes No	Enabled			
	Time Check-Z-1 2 3 4 5(Settings)	Yes No	Enabled			
	SOTF	NO				
	Aided Scheme	NO				
	Fault Locator	Yes	Enabled			
	Power Swing (Setting R & X)					
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs					
	Breaker Contacts	Yes	Enabled			
	Carrier Receive	NO				
	Time Synchronization	Yes No	Enabled			

(Signature)
XEN (MPT & S)
RRVPNL, Udaipur

(Signature)
Assistant Engineer (MPT&S)
RRVPNL UDAIPUR

VI	Name of Line : 132KV Sukher-II		Functional	Numerical	As per code of configuration .
	Pole Discrepancy Relay	NO			
	PLCC Panel	NO			
	Zone-1 2 3 4 5 (Settings)	Yes	Enabled		
	Time Check-Z-1 2 3 4 5(Settings)	Yes	Enabled		
	SOTF	No			
	Aided Scheme	NO			
	Fault Locator	Yes	Enabled		
	Power Swing (Setting R & X)				
	All Zone Block	Yes	Enabled		
	DR	Yes	Enabled		
	Binary Inputs				
	Breaker Contacts	Yes	Enabled		
	Carrier Receive	NO			
	Time Synchronization	Yes No	Enabled		
VII	Name of Line : 132KV Sisarama		Functional	Numerical	As per code of configuration .
	Pole Discrepancy Relay	NO			
	PLCC Panel	NO			
	Zone-1 2 3 4 5 (Settings)	Yes	Enabled		
	Time Check-Z-1 2 3 4 5(Settings)	Yes	Enabled		
	SOTF	No			
	Aided Scheme	NO			
	Fault Locator	Yes	Enabled		
	Power Swing (Setting R & X)				
	All Zone Block	Yes	Enabled		
	DR	Yes	Enabled		
	Binary Inputs				
	Breaker Contacts	Yes	Enabled		
	Carrier Receive	NO			
	Time Synchronization	Yes No	Enabled		
VIII	Name of Line : 132KV Debari		Functional	Numerical	As per code of configuration .
	Pole Discrepancy Relay	NO			
	PLCC Panel	NO			
	Zone-1 2 3 4 5 (Settings)	Yes	Enabled		
	Time Check-Z-1 2 3 4 5(Settings)	Yes	Enabled		
	SOTF	No			
	Aided Scheme	NO			
	Fault Locator	Yes	Enabled		
	Power Swing (Setting R & X)				
	All Zone Block	Yes	Enabled		
	DR	Yes	Enabled		
	Binary Inputs				
	Breaker Contacts	Yes	Enabled		
	Carrier Receive	NO			
	Time Synchronization	Yes No	Enabled		

(Signature)

KEN (MPT & S)
RRVPL, Udaipur

(Signature)

Assistant Engineer (MPT&S)
RRVPL, UDAIPUR

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS Amberi

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:- 08.9.2017

(iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus

(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN , 220KV GSS RVPNL, Amberi

B. Check List for Protection Audit

S.No	Check	Functional Enabled	NonFunctional Disabled	Type of Relay (Numerical Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
1	DC System		Functional			
	No. Of Independent DC Source	1				
	Potential Between +ve & Earth (Source-I)	117 V				
	Potential Between -ve & Earth (Source-I)	116V				
	Potential Between +ve & Earth (Source-II)					
	Potential Between -ve & Earth (Source-II)					
2	Event Logger Panel	No				
3	Event Logger Time Synchronised	No				
	Disturbance Recorder	No				
	DR Time Synchronised	No				
4	Bus Bar Protection	Yes	Functional			
	Stability Check					
	FL Output for this Event	No				
	DR if Available	Yes	Enable			
5	DG Set	No				
6	Mock Testing of Sample Protection Associated with Transmission line	No				
7	LBB/BFR	Yes	Enable			
	Retrip	Yes	Enable			
	Current and Time Setting	Yes	Enable			
	Separate Single and Three Phase initiation	Yes	Enable		1200A	
	Earth Fault	No				
	Event Logger Operation	No				

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS Madri

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:-

(iv) Type of Bus Switching Scheme:- Main Bus and Aux. Bus

(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN , 220KV GSS RVPNL Madri

B. Check List for Protection Audit

S.No	Check	Functional Enabled	NonFunctional Disabled	Type of Relay (Numerical Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Reactor Protection Panel:	NA	No Reactor Installed			
	Tripping by Buchholz relay (Alarm)	No				
	Differential Protection	No				
	2nd Harmonic Block (Setting)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (HV Side)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (LV Side)	No				
	Event logger Operation	No				
	Backup Over Current	No				
	Event logger Operation	No				
	Earth Fault Protection	No				
	Event logger Operation	No				
	Over Flux Protection	No				
	Event logger Operation	No				

(Signature)
XEN (MPT & S)
RVPNL, Udaipur

(Signature)
Assistant Engineer (MPT&S)
RVPNL, UDAIPUR

RRVPN 220kV Kota (Sakatpura) S/s



RVPN
AN ISO: 9001:2015
Certified Company

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
Corporate Identity Number (CIN):U40109RJ2000SGCO16485
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

OFFICE OF THE SUPERINTENDING ENGINEER (PROT.-ENGG),
Room No.317, Vidyut Bhawan, Jaipur Tel. No.0141-2740381(Ext.1350)
E-mail: se.prof.engg@rvpn.co.in, Website:[www.http://energy.rajasthan.gov.in/rvpnl](http://energy.rajasthan.gov.in/rvpnl)

No. RVPN/SE/JPR/ (Prot.-Engg)/Tech./F./D.- 42

Jaipur, Dated: 12.06.2024

The Chief Engineer (LD/MPT&S)
RVPN, Jaipur.

Sub:- Regarding internal Protection Audit plan.

Ref:- 1. No. 4/MTGS/SG/NPC/CEA/2023/353 dated 18.09.2023
2. NO.RVPN/SE(Prot.Engg)/JPR/Tech./F./ Raj Kaj No. 6987851 dated 07.05.2024.

Kindly find attach the Internal Protection Audit report of 220 kV GSS Sakatpura, Kota. The Incharge of the concern GSS was informed to rectify the observations raised during audit with Protection wing, Kota.

Submitted for further needful action and to appraise NRPC.

Copy forwarded:

1. Superintending Engineer (MPT&S), Kota
2. Executive Engineer, 220 kV GSS, Sakatpura, Kota

RajKaj Ref
7999582



Signature valid

Digitally signed by Dinesh Kumar Jain
Designation : Superintending
Engineer
Date: 2024.06.12 16:02:55 IST
Reason: Approved

Report of the Protection Audit

- A. General Information:**
- Name of utility :- Rajasthan Rajya Vidyut Prasaran Nigam Ltd.
 - Name of Voltage level of sub-station :- 220 KV GSS RVPN, Sakalpur, Kota
 - Date of commissioning :- 11.07.1971
 - Type of bus-switching scheme :- A to B, A to D, B to C
 - Name and Organization of Audit Team :- Rajasthan Rajya Vidyut Prasaran Nigam Ltd.
 - Name of representative from utility whose audit is being carried out :- Sh. R.R Gupta & Sh. A.K. Meena

B. Check List for Protection Audit

S.No	Check	Functional/ Nonfunctional/ Enabled/ Disabled	Type of relay * (Numerical/ Static/ Electro mechanical)	Setting as found in field**	Compliance status w.r.t. regulatory provisions
1.	DC system				complied
	No. of independent DC Sources	1/2/3/4			
	Potential between +ive & earth (Source-1)	--- V		148.9	To be replaced
	Potential between -ive & earth (Source-1)	--- V		85.2	
	Potential between +ive & earth (Source-2)	--- V		123.7	
	Potential between -ive & earth (Source-2)	--- V		118.2	
	Potential between +ive & earth (Source-3)	--- V			
	Potential between -ive & earth (Source-3)	--- V			
	Potential between +ive & earth (Source-4)	--- V			
	Potential between -ive & earth (Source-4)	--- V			
2.	Event Logger panel	Yes/No			
	Event Logger Time Synchronised	Yes/No			
3.	Disturbance Recorder	Yes/No			
	DR Time Synchronised	Yes/No			
	Transformer Protection Panel:	Yes/No			
4.1	Tapping by Buchholz relay(Akrm)	Yes/No	Numerical Relay	0.20 , 8.0	complied
	Differential Protection	Yes/No			
	2 nd Harmonic Block(Setting)	Yes/No	In Relay	15%	
	Event Logger operation	Yes/No			
	Restricted Earth Fault Protection (HV side)	Yes/No			
	Event Logger operation	Yes/No			
	REF Protection (LV side)	Yes/No			
	Event Logger operation	Yes/No			
	Backup over current	Yes/No	Numerical Relay	0.9 In, 0.20	
	Event Logger operation	Yes/No			
	Earth Fault protection	Yes/No	In Relay	0.20 In, 0.26	
	Event Logger operation	Yes/No			
	Over Flux Protection	Yes/No	Numerical Relay	110 % 5s , 120 % 1s	
	Event Logger operation	Yes/No	In Relay		

	Local Breaker Back up	Yes/No	No				
	Retrip	Yes/No	-				
	Current and Time setting	Yes/No	-				
	Separate single and three phase initiation	Yes/No	-				
	Earth fault	Yes/No	-				
	Event Logger	Yes/No	-		In Relay		
42	Transformer Protection Panel:						
	Tripping by Buchholz relay(Alarm)	Yes/No	Yes		220/132 KV 100 MVA GCL TR-02		completed
	Differential Protection	Yes/No	Yes		Numerical Relay	0.20, 8.0	
	2 nd Harmonic Block(Setting)	Yes/No	Enabled			15%	
	Event Logger operation	Yes/No	Yes		In Relay		
	Restricted Earth Fault Protection (HV side)	Yes/No	NO		JVS	0.10 In Instt.	
	Event Logger operation	Yes/No	-				
	REF Protection (LV side)	Yes/No	-				
	Event Logger operation	Yes/No	-				
	Backup over current	Yes/No	Yes		Numerical Relay	0.7 In, 0.20	
	Event Logger operation	Yes/No	Yes		In Relay		
	Earth Fault protection	Yes/No	Yes		Numerical Relay	0.20 In, 0.26	
	Event Logger operation	Yes/No	Yes		In Relay		
	Over Flux Protection	Yes/No	Yes		Numerical Relay	110 % 5s , 120 % 1s	
	Event Logger operation	Yes/No	Yes		In Relay		
	Local Breaker Back up	Yes/No	No				
	Retrip	Yes/No	-				
	Current and Time setting	Yes/No	-				
	Separate single and three phase initiation	Yes/No	-				
	Earth fault	Yes/No	-				
	Event Logger	Yes/No	-		In Relay		
43	Transformer Protection Panel:						
	Tripping by Buchholz relay(Alarm)	Yes/No	Yes		220/132 KV 100 MVA BHEL TR-03		completed
	Differential Protection	Yes/No	Yes		In Relay		
	2 nd Harmonic Block(Setting)	Yes/No	Enabled			0.20 , 8.0 , 15%	
	Event Logger operation	Yes/No	No		Static Relay		
	Restricted Earth Fault Protection (HV side)	Yes/No	No				
	Event Logger operation	Yes/No	-				
	REF Protection (LV side)	Yes/No	-				
	Event Logger operation	Yes/No	-				
	Backup over current	Yes/No	Yes		Electro mechanical	0.7 In, 0.20	
	Event Logger operation	Yes/No	Yes		Electro mechanical	0.20 In, 0.26	
	Earth Fault protection	Yes/No	Yes				
	Event Logger operation	Yes/No	Yes				
	Over Flux Protection	Yes/No	No				
	Event Logger operation	Yes/No	No				
	Local Breaker Back up	Yes/No	NO				
	Retrip	Yes/No	-				
	Current and Time setting	Yes/No	-				
	Separate single and three phase initiation	Yes/No	-				
	Earth fault	Yes/No	-				
	Event Logger	Yes/No	-		In Relay		
44	Transformer Protection Panel:						
	Event Logger	Yes/No	-		220/132 KV 100 MVA BHEL TR-04		completed

	Tripping by Buchholz relay(Alarm)	Yes/No	Yes				
	Differential Protection	Yes/No	Yes	Numerical Relay	0.20 , 8.0		
	2 nd Harmonic Block(Setting)	Yes/No	Enabled		15%		
	Event Logger operation	Yes/No	Yes	In Relay			
	Restricted Earth Fault Protection (HV side)	Yes/No	No	MIT	0.10 In Instt.		
	Event Logger operation	Yes/No	-				
	REF Protection (LV side)	Yes/No	-				
	Event Logger operation	Yes/No	Yes	Numerical Relay	0.7 In, 0.20		
	Backup over current	Yes/No	Yes	In Relay			
	Event Logger operation	Yes/No	Yes	Numerical Relay	0.20 In, 0.26		
	Earth Fault protection	Yes/No	-	In Relay			
	Event Logger operation	Yes/No	Yes	Electro mechanical	110 % 5s , 120%1s		
	Over Flux Protection	Yes/No	Yes				
	Event Logger operation	Yes/No	No				
	Local Breaker Back up	Yes/No	No				
	Retrip	Yes/No	-				
	Current and Time setting	Yes/No	-				
	Separate single and three phase initiation	Yes/No	-				
	Earth fault	Yes/No	-				
	Event Logger	Yes/No	-	In Relay			
5.	Reactor Protection Panel:	Yes/No	No				
	Tripping by Buchholz relay(Alarm)	Yes/No					
	Differential Protection	Yes/No					
	2 nd Harmonic Block (Setting)	Yes/No					
	Event Logger operation	Yes/No					
	REF Protection (HV side)	Yes/No					
	Event Logger operation	Yes/No					
	REF Protection (LV side)	Yes/No					
	Event Logger operation	Yes/No					
	Backup over current	Yes/No					
	Event Logger operation	Yes/No					
	EIF protection	Yes/No					
	Event Logger operation	Yes/No					
	Over Flux Protection	Yes/No					
	Event Logger operation	Yes/No					
	LBB/BFR	Yes/No					
	Retrip	Yes/No					
	Current and Time setting	Yes/No					
	Separate single and three phase initiation	Yes/No					
	Earth fault	Yes/No					
	Event Logger operation	Yes/No					
6.1	Distance Protection Panel: M-III	Yes/No	220 kV Sakatpura-Dahra				compiled
	Pole discrepancy relay	Yes/No	Yes		1.5 Sec		
	PLCC panel	Yes/No	Yes				
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay	As per Line Length		
	Time check-Z-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable		0,350,1000,160 s		
	SOTF	Yes/No	No				
	Aided schemes	Yes/No	Yes				
	Fault Locator	Yes/No	Yes	In relay			
	Power swing (Settings R and X)	Yes/No	Yes				

	All Zone block	Yes/No	Yes				
	DR	Yes/No	Yes				
	Binary Inputs	Yes/No	Yes			Available	
	Breaker Contacts	Yes/No	Yes			Available	
	Carrier Receive	Yes/No	Yes				
	Time Synchronization	Yes/No	No			GPS not available	
6.2	Distance Protection Panel: M-III	Yes/No	220 KV SAKATPURA-RAPP A CKT-1			0.6 Sec	compiled Revised 1.0 to 0.6s
	Pole discrepancy relay	Yes/No	Yes				
	PLCC panel	Yes/No	Yes				
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable				
	Time check-Z-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay		As per Line Length	
	SOFT	Yes/No	No			0,350,1000,160 s	
	Aided schemes	Yes/No	Yes				
	Fault Locator	Yes/No	Yes				
	Power swing (Settings R and X)	Yes/No	Yes	In relay			
	All Zone block	Yes/No	Yes				
	DR	Yes/No	Yes				
	Binary Inputs	Yes/No	Yes			Available	
	Breaker Contacts	Yes/No	Yes			Available	
	Carrier Receive	Yes/No	Yes				
	Time Synchronization	Yes/No	No			GPS not available	
6.3	Distance Protection Panel: M-III	Yes/No	220 KV SAKATPURA-RAPP A CKT-2			0.6 Sec	compiled Revised 1.0 to 0.6s
	Pole discrepancy relay	Yes/No	Yes				
	PLCC panel	Yes/No	Yes				
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay		As per Line Length	
	Time check-Z-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable			0,350,1000,160 s	
	SOFT	Yes/No	No				
	Aided schemes	Yes/No	Yes				
	Fault Locator	Yes/No	Yes				
	Power swing (Settings R and X)	Yes/No	Yes	In relay			
	All Zone block	Yes/No	Yes				
	DR	Yes/No	Yes				
	Binary Inputs	Yes/No	Yes			Available	
	Breaker Contacts	Yes/No	Yes			Available	
	Carrier Receive	Yes/No	Yes				
	Time Synchronization	Yes/No	Yes				
	Distance Protection Panel: M-III	Yes/No	No			GPS not available	
6.4	Distance Protection Panel: M-III	Yes/No	220 KV SAKATPURA-RAPP A CKT-3			0.6 Sec	compiled Revised 1.0 to 0.6s
	Pole discrepancy relay	Yes/No	Yes				
	PLCC panel	Yes/No	Yes				
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay		As per Line Length	


	Time check-Z-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable		0,350,1000,160 s	
	SOTF	Yes/No	No			
	Aided schemes	Yes/No	Yes			
	Fault Locator	Yes/No	Yes	In relay		
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes			
	Time Synchronization	Yes/No	No		GPS not available	
6.5	Distance Protection Panel: M-III		220 KV Sakatpura-Mandalgarh			completed
	Pole discrepancy relay	Yes/No	Yes		1.5 Sec	
	PLCC panel	Yes/No	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay	As per Line Length	
	Time check-Z-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable		0,350,1000,160 s	
	SOTF	Yes/No	No			
	Aided schemes	Yes/No	Yes			
	Fault Locator	Yes/No	Yes	In relay		
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes			
	Time Synchronization	Yes/No	No		GPS not available	
6.6	Distance Protection Panel: M-III		220 KV Sakatpura-Rampur			completed
	Pole discrepancy relay	Yes/No	Yes		1.5 Sec	
	PLCC panel	Yes/No	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay	As per Line Length	
	Time check-Z-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable		0,350,1000,160 s	
	SOTF	Yes/No	No			
	Aided schemes	Yes/No	Yes			
	Fault Locator	Yes/No	Yes	In relay		
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes			
	Time Synchronization	Yes/No	No		GPS not available	
6.7	Distance Protection Panel: M-III		220 KV Sakatpura-Anta			completed
	Pole discrepancy relay	Yes/No	Yes		1.5 Sec	
	PLCC panel	Yes/No	Yes			

	Zone-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable	Numerical Relay	As per Line Length	
	Time check-2-1/2/3/4/5 (Settings)	Yes/No	1,2,3,4 Enable		0,350,1000,160 s	
	SOTF	Yes/No	No			
	Aided schemes	Yes/No	Yes			
	Fault Locator	Yes/No	Yes	In relay		
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes		Available	
	Time Synchronization	Yes/No	No		GPS not available	
6.8	Distance Protection Panel: M-III		220 KV SAKATPURA-KTFS-1			complied
	Pole discrepancy relay	Yes/No	Yes		0.5 Sec	
	PLCC panel	Yes/No	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,4 Enable	Numerical Relay	As per Line Length	Line differential relay in used
	Time check-2-1/2/3/4/5 (Settings)	Yes/No	1,4 Enable		0,160 s	
	SOTF	Yes/No	No			
	Aided schemes	Yes/No	Yes			
	Fault Locator	Yes/No	Yes	In relay		
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes		GPS not available	
	Time Synchronization	Yes/No	No			
6.9	Distance Protection Panel: M-III		220 KV SAKATPURA-KTFS-II			complied
	Pole discrepancy relay	Yes/No	Yes		0.5 Sec	
	PLCC panel	Yes/No	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,4 Enable	Numerical Relay	As per Line Length	Line differential relay in used
	Time check-2-1/2/3/4/5 (Settings)	Yes/No	1,4 Enable		0,160 s	
	SOTF	Yes/No	No			
	Aided schemes	Yes/No	Yes			
	Fault Locator	Yes/No	Yes	In relay		
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes		GPS not available	
	Time Synchronization	Yes/No	No			
6.10	Distance Protection Panel: M-III		220 KV SAKATPURA-KTFS-II			complied

	Pole discrepancy relay	Yes/No	Yes		0.5 Sec	
	PLCC panel	Yes/No	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,4 Enable	Numerical Relay	As per Line Length	Line differential relay in used
	Time check-2/1/2/3/4/5 (Settings)	Yes/No	1,4 Enable		0,150 s	
	SOTF	Yes/No	No			
	Added schemes	Yes/No	Yes	In relay		
	Fault Locator	Yes/No	Yes			
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes			
	Time Synchronization	Yes/No	No		GPS not available	
7.	Bus Bar Protection	Yes/No	No			To be installed
	Stability Check	Yes/No				
	EL output for this event	Yes/No				
	DR if available	Yes/No				
8.	Single Phase Auto Recloser Scheme	Yes/No	No			
	CT	Yes/No	Yes			
9.	Suitable as per fault level	Yes/No	No			
10.	DG Set	Yes/No	No			
11.	Mock Testing of a sample protection associated with transmission line***	Yes/No	No	i. If Yes then observation ii. If no, the reason for the same	220 KV Sakatpura RAPP-B Ckt-I-AR lockout C-G trip time 59 ms Distance 36.1 km	
6.11	Distance Protection Panel: M-III	Yes/No	220 KV SAKATPURAKTIPS -III			completed
	Pole discrepancy relay	Yes/No	Yes		0.5 Sec	
	PLCC panel	Yes/No	Yes			
	Zone-1/2/3/4/5 (Settings)	Yes/No	1,4 Enable			
	Time check-2/1/2/3/4/5 (Settings)	Yes/No	1,4 Enable	Numerical Relay	As per Line Length	Line differential relay in used
	SOTF	Yes/No	No		0,150 s	
	Aided schemes	Yes/No	Yes			
	Fault Locator	Yes/No	Yes	In relay		
	Power swing (Settings R and X)	Yes/No	Yes			
	All Zone block	Yes/No	Yes			
	DR	Yes/No	Yes			
	Binary Inputs	Yes/No	Yes		Available	
	Breaker Contacts	Yes/No	Yes		Available	
	Carrier Receive	Yes/No	Yes			
	Time Synchronization	Yes/No	No		GPS not available	

* This column is applicable for relays only
** Method and Calculation to arrive at this setting has to be submitted by the utility to NRPC secretariat within 07 days of the protection audit.
** Purpose is to check whether the operation of that protection relay emerges the breaker Trip coil.
C. Observation w.r.t. compliance to NRPC protection philosophy
D. Any other Observation/Suggestion by the team of protection expert:
(Name, Signature and Contact Number of Members of team comprising for carrying out protection audit and the representative of the utility whose audit is being carried out)


R. R. Gupta
AEn (Prot. Engrg.) RVPN Jaipur
9413393811


A. K. Meena
AEn (Prot. Engrg.) RVPN Jaipur
9413393550

Copy to: (i) Station In-charge where audit has been carried out
(ii) Representative of the utility present with the protection audit team
(iii) SE (O), NRPC

RRVPN 220kV Banswara S/s

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

Protection Audit for the month July 2024 (Date of audit 09.07.2024)

A. General Information

(i) Name of Utility:- 220 KV GSS BANSWARA

(iii) Date of Commissioning:-24.03.2004

(v) Name and Organization of Audit Team:- AEN (MPT&S) RVPNL BANSWARA

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL BANSWARA

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iv) Type of Bus Switching Scheme:- Two Main Bus and Aux. Bus

B. Check List for Protection Audit

S.No.	Check	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
Transformer Protection Panel:					
(i)	Name of Transformer (Rating/Capacity)	220/132, 100MVA Transformer-I (BHEL Make)			
	Tripping by Buchholz relay (Alarm)	Yes	Functional	Conventional	
	Differential Protection	Yes	Functional	Numerical Pickup- 0.2 pu, Slope 1 - 0.3, Slope 2- 0.7	
	2nd Harmonic Block (Setting)	Yes	Enabled		15%
	Event logger Operation	No	(No Event logger Installed)		
	Restricted Earth Fault Protection (HV Side)	Yes	Functional	Numerical	20%
	Event logger Operation	No	(No Event logger Installed)		
	Restricted Earth Fault Protection (LV Side)	Yes	Functional	Numerical	20%
	Event logger Operation	No	(No Event logger Installed)		
	Backup Over Current	Yes	Functional	Numerical	88%, CTR-300/1
	Event logger Operation	No	(No Event logger Installed)		
	Earth Fault Protection	Yes	Functional	Numerical	20%
	Event logger Operation	No	(No Event logger Installed)		
	Over Flux Protection	Yes	Enabled	Numerical	Alarm -110%, 5 sec , Trip As per inverse curve characteristics
	Event logger Operation	No	(No Event logger Installed)		
	Local Breaker Back Up	YES	Functional	Static	
	Retrip		Enabled		100 msec
	Current and Time Setting	yes			120% Inormal,100 msec
	Separate Single and three Phase Initiation	no			three phase initiation
	Earth Fault	no	DISABLED		
	Event logger Operation	no			


Assistant Engineer (MPT&S)
RVPNL, Banswara

(ii)	Name of Transformer (Rating/Capacity)	220/132, 100MVA Transformer-I (TELK Make)		
	Tripping by Buchholz relay (Alarm)	Yes	Functional	Conventional
	Differential Protection	Yes	Functional	Static Pickup- 0.2 pu, Slope 1- 0.2, Slope 2- 0.7 15% (Inbuilt)
	2nd Harmonic Block (Setting)	Yes		
	Event logger Operation	No	(No Event logger Installed)	
	Restricted Earth Fault Protection (HV Side)	No		20%
	Event logger Operation	No	(No Event logger Installed)	
	Restricted Earth Fault Protection (LV Side)	No		20%
	Event logger Operation	No	(No Event logger Installed)	
	Backup Over Current	Yes	Functional	numerical 66% CTR-400, 1 A
	Event logger Operation	No	(No Event logger Installed)	
	Earth Fault Protection	Yes	Functional	numerical 20%
	Event logger Operation	No	(No Event logger Installed)	
	Over Flux Protection	Yes	Enabled	numerical Alarm -110%,5 sec Trip- As per inverse curve characteristics
	Event logger Operation	No	(No Event logger Installed)	
	Local Breaker Back Up	YES	Functional	Numerical
	Retrip	No	Enabled	100 msec
	Current and Time Setting	No		120% Inormal,100 msec
	Separate Single and three Phase Initiation	No		three phase initiation
	Earth Fault	No	DISABLED	
	Event logger Operation	No	(No Event logger Installed)	


Assistant Engineer (MPT&S)
RVPNL, Banswara

Rajasthan Rajya Vidhyut Prasaran Nigam
Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS BANSWARA

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:- 24.03.2004

(iv) Type of Bus Switching Scheme:- Two Main Bus and Aux. Bus

(v) Name and Organization of Audit Team:- AEN (MPT&S) RVPNL BANSWARA


(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL BANSWARA

B. Check List for Protection Audit

S.N o.	Check		Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Distance Protection Panel:M-I/II					
(I)	Name of Line	220KV BANSWARA-ASPUR LINE				
	Pole Discrepancy Relay	YES	Functional	ELECTROMECHANICAL	1.5 sec	
	PLCC Panel	Yes	Functional			
	Zone-1/2/3/4/5 (Settings)	Yes	Enabled	Numerical	As per latest Code of Configuration	
	Time Check-Z-1/2/3/4/5(Settings)	Yes	Enabled			
	SOTF	YES	Disabled			
	Aided Scheme	YES	Enabled			
	Fault Locator	YES	Enabled			
	Power Swing (Setting R & X)	Yes	Enabled			
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs	Yes	ENABLED			
	Breaker Contacts	Yes	ENABLED			
	Carrier Receive	YES	ENABLED			
	Time Synchronization	YES				


Assistant Engineer (MPT&S)
RVPNL, Banswara

(II)	Name of Line	220KV BANSWARA-MADRI LINE				
	Pole Discrepancy Relay	YES	Functional	ELECTROMECHANICAL	1.5 sec	
	PLCC Panel	Yes	Functional			
	Zone-1/2/3/4/5 (Settings)	Yes	Enabled	Numerical	As per latest Code of Configuration	
	Time Check-Z-1/2/3/4/5(Settings)	Yes	Enabled			
	SOTF	YES	Disabled			
	Aided Scheme	YES	Enabled			
	Fault Locator	YES	Enabled			
	Power Swing (Setting R & X)	Yes	Enabled			
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs	Yes	ENABLED			
	Breaker Contacts	Yes	ENABLED			
	Carrier Receive	YES	ENABLED			
	Time Synchronization	YES				


Assistant Engineer (MPT&S)
RVPNL, Banswara

Rajasthan Rajya Vidhyut Prasaran Nigam
Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS BANSWARA

(ii) Name of Voltage Level of Sub Station - 220/132 KV

(iii) Date of Commissioning:-24.03.2004


(iv) Type of Bus Switching Scheme:- Two Main Bus and Aux. Bus

(v) Name and Organization of Audit Team:- AEN (MPT&S) RVPNL BANSWARA

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL BANSWARA

B. Check List for Protection Audit

S.No.	Check	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
1	DC System (220V DC)	Functional	Static	20%	
	No. Of Independent DC Source	1			
	Potential Between +ve & Earth (Source-I)	190 V			
	Potential Between -ve & Earth (Source-I)	50 V			
2	Event Logger Panel	No			
3	Event Logger Time Synchronised	No			
	Disturbance Recorder	No			
	DR Time Synchronised	No			
4	Bus Bar Protection	yes			
	Stability Check	yes			
	EL Output for this Event	yes			
	DR if Available	yes			
5	DG Set	No			
6	Mock Testing of Sample Protection Associated with Transmission line	yes			
7	LBB/BFR	No			
	Retrip	No			
	Current and Time Setting	No			
	Separate Single and Three Phase initiation	No			
	Earth Fault	No			
	Event Logger Operation	No			


Assistant Engineer (MPT&S)
RVPNL, Banswara

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS BANSWARA

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:-24.03.2004

(iv) Type of Bus Switching Scheme:- Two Main Bus and Aux. Bus

(v) Name and Organization of Audit Team:- AEN (MPT&S) RVPNL BANSWARA

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL BANSWARA

B. Check List for Protection Audit

S.N o.	Check		Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Reactor Protection Panel:	NA	No reactor Installed			
	Tripping by Buchholz relay (Alarm)	No				
	Differential Protection	No				
	2nd Harmonic Block (Setting)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (HV Side)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (LV Side)	No				
	Event logger Operation	No				
	Backup Over Current	No				
	Event logger Operation	No				
	Earth Fault Protection	No				
	Event logger Operation	No				
	Over Flux Protection	No				
	Event logger Operation	No				


Assistant Engineer (MPT&S)
RVPNL, Banswara

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit dt 01.08.2024

A. General Information

(i) Name of Utility:- 220 KV GSS Reengus

(iii) Date of Commissioning:-12.01.1984

(v) Name and Organization of Audit Team:- AEN/O/SE (Prot. Engg.) RVPNL, Jaipur

(vi) Name of representative from utility whose audit being carried out:-SE (Prot. Engg.) RVPNL, Jaipur






(ii) Name of Voltage Level of Sub Station:- 220 KV
(iv) Type of Bus Switching Scheme:- 02 NO's Main Bus and Aux. Bus

B. Check List for Protection Audit

S.No.	Check	220/132KV, 160MVA	BBL Make	T/F-1	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
Transformer Protection Panel:							
(i)	Name of Transformer (Rating/Capacity)	220/132KV, 160MVA	BBL Make	T/F-1	Conventional		Complying
	Tripping by Buchholz relay (Alarm)	YES	Enable		Numerical	As per code of configuration	Complying
	Differential Protection	YES	Enable		In built feature in Diff. Relay	15.00%	Complying
	2nd Harmonic Block (Setting)	YES	Enable				Complying
	Event logger Operation	YES	Enable				Complying
	Restricted Earth Fault Protection (HV Side)	YES	Functional		STATIC	20%	Complying
	Event logger Operation	YES					Complying
	Restricted Earth Fault Protection (LV Side)	NA					Complying
	Event logger Operation	NA					Complying
	Backup Over Current	YES	Enable		Numerical	2.5/0.21	Complying
	Event logger Operation	YES	Enable		Numerical	2.5/0.23	Complying
	Earth Fault Protection	YES	Enable				Complying
	Event logger Operation	YES	Enable		In built feature in Diff. Relay		Complying
	Over Flux Protection	YES	Enable				Complying
	Event logger Operation	YES	Functional		Numerical		Complying
	Local Breaker Back Up	YES	Enable				Complying
	Retrip	YES	Functional				Complying
	Current and Time Setting	YES	Functional		Numerical	120% for 100 ms+External timer 100 ms	Complying
	Separate Single and three Phase Initiation	No (3 Phase only)					
	Earth Fault	No					
	Event logger Operation	No					
(ii)	Name of Transformer (Rating/Capacity)	220/132KV, 160MVA, INIP Make	T/F-2	Conventional			Complying
	Tripping by Buchholz relay (Alarm)	YES	Enable		Numerical	As per code of configuration	Complying
	Differential Protection	YES	Enable		In built feature in Diff. Relay	15.00%	Complying
	2nd Harmonic Block (Setting)	YES	Enable			20%	Complying
	Event logger Operation	YES	Functional				Complying
	Restricted Earth Fault Protection (HV Side)	YES	Functional				Complying
	Event logger Operation	YES					Complying
	Restricted Earth Fault Protection (LV Side)	NA					Complying

Event logger Operation	NA						
Backup Over Current	YES	Enable	Numerical		1.0/0.22	Complying	
Event logger Operation	YES						
Earth Fault Protection	YES	Enable	Numerical		1.0/0.26	Complying	
Event logger Operation	YES						
Over Flux Protection	YES	Enable		In built feature in Diff. Relay		Complying	
Event logger Operation	YES						
Local Breaker Back Up	YES	Functional	Numerical			Complying	
Retrip	YES	Enable					
Current and Time Setting	YES	Functional	Numerical		120% for 100 ms+External timer 100 ms	Complying	
Separate Single and three Phase Initiation	No (3 Phase only)						
Earth Fault	No						
Event logger Operation	No						

* Complying with the code of configuration issued by the CE(MPT&S) ,RVPN, Jaipur by letter No. RVPN/CE/MPT&S/PR/Tech/JF./Rajkaj ret No.5221696/D.166 Dated 21.12.2023

Name: Signature & Contact no. Team carrying out Protection audit:	Sh. R.R.Gupta, AEN O/O SE (Prot. Engg.) RVPNL, Jaipur	
	A. K. Lamoria, AEN(MPT&S) ,RVPN , Jhunjhunu	
	Pragya Pandey ,AEN(MPT&S) ,RVPN , Sikar	
	Ramawatar Dhaka, JEN(MPT&S) RVPN, Sikar	
Name: Signature & Contact no. Representative of utility whose protection audit is being carried out: Team carrying out Protection audit:	Sh. D.K. Jain ,SE(Prot. Engg.) RVPN , Jaipur	

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

- A. General Information**
- (i) Name of Utility:- 220 KV GSS Reengus
 (iii) Date of Commissioning:-12.01.1984
 (v) Name and Organization of Audit Team:- AEN/O/SE (Prot. Enng.) RVPNL, Jaipur
 (vi) Name of representative from utility whose audit being carried out:- SE (Prot. Enng.) RVPNL, Jaipur
- (ii) Name of Voltage Level of Sub Station:- 220 KV
 (iv) Type of Bus Switching Scheme:- 02 NO's Main Bus and Aux. Bus

B. Check List for Protection Audit

S.No.	Check	Functional/ Nonfunctional/Enabled/ Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
220 KV REENGUS-SIKAR I					
(V)	Distance Protection Panel:M-I		DIST. M-I SIEMENS		
	Name of Line				
	Pole Discrepancy Relay	YES			
	PLCC Panel	YES			
	Zone-1/2/3/4/5 (Settings)	YES	Numerical	X1=1.48 Ω T1=0.00 ms, X2=2.03 Ω T2=350 ms, X3=2.26 Ω T3=1000 ms, X4(rev.) = 65 mΩ T4=160 ms	Complying
	Time Check-Z-1/2/3/4/5(Settings)	YES			
	SOTF	YES		permissive under reach phase, Z1 Z2+CR	
	Aided Scheme	YES			
	Fault Locator	YES			
	Power Swing (Setting R & X)	YES		R=1 Ω and X=1 Ω	
	All Zone Block	YES	In built feature in Dist. Relay		Complying
	DR	YES			
	Binary Inputs	YES			
	Breaker Contacts	YES			
	Carrier Receive	YES			
	Time Synchronization	YES			
	Distance Protection Panel:M-II		DIST M-II- MICOM P442		
(VI)	Name of Line		220 KV REENGUS-SIKAR I		
	Pole Discrepancy Relay	YES			
	PLCC Panel	YES			
	Zone-1/2/3/4/5 (Settings)	YES	Numerical	Z1=1.514 Ω T1=0.00 ms Z2=2.07 Ω T2=350 ms Z3=2.30 Ω T3=1000 ms Z4(rev.) = 65 mΩ T4=160 ms	Complying
	Time Check-Z-1/2/3/4/5(Settings)	YES			
	SOTF	YES			

Page *Rajesh Kumar* *RL*

Aided Scheme	YES	Functional	In built feature in Dist. Relay	DIST M I - MICOM P442	permissive under reach phase, Z1 Z2+CR	Complying
Fault Locator	YES	Enable				
Power Swing (Setting R & X)	YES	Enable				
All Zone Block	YES	Enable				
DR	YES	Enable				
Binary Inputs	YES	Enable				
Breaker Contacts	YES	Enable				
Carrier Receive	YES	Enable				
Time Synchronization	YES	Enable				
Distance Protection Panel:M-I						
Name of Line			220 KV REENGUS-SIKAR II			
Pole Discrepancy Relay	YES	Functional				
PLCC Panel	YES	Functional				
Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical		Z1=7.57 Ω T1=0.00 ms Z2=10.36 Ω T2=350 ms Z3=11.53 Ω T3=1000 ms Z4(rev.) = 326mΩ T4=160 ms	
Time Check-Z-1/2/3/4/5(Settings)	YES	Functional				
SOTF	YES	Disable				
Aided Scheme	YES	Functional				
Fault Locator	YES	Enable	In built feature in Dist. Relay		Z2+CR	
Power Swing (Setting R & X)	YES	Enable			R=5 Ω and X=5 Ω	
DIST M II - GE D 60						
220 KV REENGUS-SIKAR II						
Name of Line	YES	Functional				
Pole Discrepancy Relay	YES	Functional				
PLCC Panel	YES	Functional				
Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical		Z1=7.57 Ω T1=0.00 ms Z2=10.36 Ω T2=350 ms Z3=11.53 Ω T3=1000 ms Z4(rev.) = 326mΩ T4=160 ms	
Time Check-Z-1/2/3/4/5(Settings)	YES	Functional				
SOTF	YES	Disable				
Aided Scheme	YES	Functional				
Fault Locator	YES	Enable	In built feature in Dist. Relay		Z2+CR	
Power Swing (Setting R & X)	YES	Enable			R=5 Ω and X=5 Ω	






All Zone Block		YES	Enable				
DR		YES	Enable				
Binary Inputs		YES	Enable				
Breaker Contacts		YES	Enable				
Carrier Receive		YES	Enable				
Time Synchronization		YES	Enable				
Distance Protection Panel:M-I							
DIST. M-I SIEMENS							
Name of Line		YES	Functional				
Pole Discrepancy Relay		YES	Functional				
PLCC Panel		YES	Functional				
Zone-1/2/3/4/5 (Settings)		YES	Functional				
Time Check-Z-1/2/3/4/5(Settings)		YES	Functional				
SOTF		YES	Disable				
Aided Scheme		YES	Functional				
Fault Locator		YES	Enable				
Power Swing (Setting R & X)		YES	Enable				
All Zone Block		YES	Enable				
DR		YES	Enable				
Binary Inputs		YES	Enable				
Breaker Contacts		YES	Enable				
Carrier Receive		YES	Enable				
Time Synchronization		YES	Enable				
Distance Protection Panel:M-I							
DIST. M-II Q-MHO							
220 KV REENGUS-LAXMANGARH							
Name of Line		YES	Functional				
Pole Discrepancy Relay		YES	Functional				
PLCC Panel		YES	Functional				
Zone-1/2/3/4/5 (Settings)		YES	Functional				
Time Check-Z-1/2/3/4/5(Settings)		YES	Functional				
SOTF		NO	NA				
Aided Scheme		YES	Functional				
Fault Locator		NO	NA				
Power Swing (Setting R & X)		YES	Enable				
All Zone Block		YES	Enable				
DR		NO	NA				
Binary Inputs		YES	Enable				
Breaker Contacts		NO	NA				
Carrier Receive		YES	Enable				

In built feature in Dist. Relay

Numerical

X1=8.88 Ω T1=0.00 ms X2=18.08 Ω
T2=350 ms X3=23.45 Ω T3=1000
ms X4(rev.) = 326 mΩ T4=160 ms

permissive under reach phase, Z1
Z2+CR

R=5 Ω and X=5 Ω

Complying

STATIC

Z1=4.32 Ω T1=0.00 ms Z2=9.56 Ω
T2=350 ms Z3=15.21 Ω T3=1000
ms Z4(rev.) = 326mΩ T4=160 ms

permissive under reach phase, Z1
Z2+CR

R=5 Ω and X=5 Ω

Complying

In built feature in Dist. Relay

In built feature in Dist. Relay

Complying

Complying

3302
Q. Singh
Senior Engineer
RL

	Time Synchronization	NO	NA					
	Distance Protection Panel: M-I							
(VIII)	Name of Line	YES	Functional		DIST. M-I SIEMENS			
	Pole Discrepancy Relay	YES	Functional					
	PLCC Panel	YES	Functional					
	Zone-1/2/3/4/5 (Settings)	YES	Functional					
	Time Check-Z-1/2/3/4/5(Settings)	YES	Functional		Numerical	X1=1.48 Ω T1=0.00 ms X2=2.03 Ω T2=350 ms X3=4.01 Ω T3=1000 ms X4(rev.) = 65 mΩ T4=160 ms	Complying	
	SOTF	YES	Disable					
	Aided Scheme	YES	Functional			permissive under reach phase, Z1 Z2+CR		
	Fault Locator	YES	Enable					
	Power Swing (Setting R & X)	YES	Enable			R=1 Ω and X=1 Ω		
	All Zone Block	YES	Enable					
	DR	YES	Enable		In built feature in Dist. Relay			Complying
	Binary Inputs	YES	Enable					
	Breaker Contacts	YES	Enable					
	Carrier Receiver	YES	Enable					
	Time Synchronization	YES	Enable					
(VIII)	Distance Protection Panel: M-II				DIST M-II- MICOM P442			
	Name of Line							
	Pole Discrepancy Relay	YES	Functional					
	PLCC Panel	YES	Functional					
	Zone-1/2/3/4/5 (Settings)	YES	Functional		Numerical	Z1=1.35 Ω T1=0.00 ms Z2=2.22 Ω T2=350 ms Z3=4.09 Ω T3=1000 ms Z4(rev.) = 65 mΩ T4=160 ms	Complying	
	Time Check-Z-1/2/3/4/5(Settings)	YES	Functional					
	SOTF	YES	Disable					
	Aided Scheme	YES	Functional			permissive under reach phase, Z1 Z2+CR		
	Fault Locator	YES	Enable					
	Power Swing (Setting R & X)	YES	Enable			R=1 Ω and X=1 Ω		
	All Zone Block	YES	Enable					
	DR	YES	Enable		In built feature in Dist. Relay			Complying
	Binary Inputs	YES	Enable					
	Breaker Contacts	YES	Enable					
	Carrier Receiver	YES	Enable					
	Time Synchronization	YES	Enable					

Check
Zone-1/2/3/4
PLCC Panel

[Handwritten Signature]
[Handwritten Signature]
[Handwritten Signature]

[Handwritten Initials]

Distance Protection Panel: M-I		DIST. M-I SIEMENS	
Name of Line	YES	Functional	
Pole Discrepancy Relay	YES	Functional	
PLCC Panel	YES	Functional	
Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical
Time Check-Z-1/2/3/4/5(Settings)	YES	Functional	
SOTF	YES	Disable	
Aided Scheme	YES	Functional	
Fault Locator	YES	Enable	
Power Swing (Setting R & X)	YES	Enable	
All Zone Block	YES	Enable	
DR	YES	Enable	
Binary Inputs	YES	Enable	
Breaker Contacts	YES	Enable	
Carrier Receive	YES	Enable	
Time Synchronization	YES	Enable	
Distance Protection Panel: M-II			
DIST M-II- MICOM P442			
Name of Line	YES	Functional	
Pole Discrepancy Relay	YES	Functional	
PLCC Panel	YES	Functional	
Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical
Time Check-Z-1/2/3/4/5(Settings)	YES	Functional	
SOTF	YES	Disable	
Aided Scheme	YES	Functional	
Fault Locator	YES	Enable	
Power Swing (Setting R & X)	YES	Enable	
All Zone Block	YES	Enable	
DR	YES	Enable	
Binary Inputs	YES	Enable	
Breaker Contacts	YES	Enable	
Carrier Receive	YES	Enable	
Time Synchronization	YES	Enable	
Distance Protection Panel: M-I			
DIST. M-I SIEMENS			
220 KV REENGUS-BABAI			
Name of Line	YES	Functional	
Pole Discrepancy Relay	YES	Functional	
PLCC Panel	YES	Functional	
Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical
Time Check-Z-1/2/3/4/5(Settings)	YES	Functional	

X1=0.97 Ω T1=0.00 ms X2=1.6 Ω
 T2=350 ms X3=2.06 Ω
 T3=1000 ms X4(rev.) = 65 mΩ
 T4=160 ms

permissive under reach phase, Z1
 Z2+CR

R=1 Ω and X=1 Ω

Complying

Z1=0.99 Ω T1=0.00 ms Z2=1.63 Ω
 T2=350 ms Z3=2.10 Ω
 T3=1000 ms Z4(rev.) = 65 mΩ
 T4=160 ms

permissive under reach phase, Z1
 Z2+CR

R=1 Ω and X=1 Ω

Complying

In built feature in Dist. Relay

DIST. M-I SIEMENS

220 KV REENGUS-BABAI

X1=1.48 Ω T1=0.00 ms X2=2.0 Ω
 T2=350 ms X3=3.14 Ω T3=1000
 ms X4(rev.) = 65 mΩ T4=160 ms

Complying

22KV
 Singh
 Samudra
 DR

	SOTF	YES	Disable				
	Aided Scheme	YES	Functional				
	Fault Locator	YES	Enable			permissive under reach phase, Z1 Z2+CR	
	Power Swing (Setting R & X)	YES	Enable			R=1 Ω and X=1 Ω	Complying
	All Zone Block	YES	Enable	In built feature in Dist. Relay			
	DR	YES	Enable				
	Binary Inputs	YES	Enable				
	Breaker Contacts	YES	Enable				
	Carrier Receive	YES	Enable				
	Time Synchronization	YES	Enable				
(XIII)	Distance Protection Panel:M-II						
	Name of Line	YES	Functional				
	Pole Discrepancy Relay	YES	Functional				
	PLCC Panel	YES	Functional				
	Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical		Z1=1.51 Ω T1=0.00 ms Z2=2.04 Ω T2=350 ms Z3=3.21 Ω T3=1000 ms Z4(rev.) = 65 mΩ T4=160 ms	Complying
	Time Check-Z-1/2/3/4/5(Settings)	YES	Functional				
	SOTF	YES	Disable			permissive under reach phase, Z1 Z2+CR	
	Aided Scheme	YES	Functional				
	Fault Locator	YES	Enable				
	Power Swing (Setting R & X)	YES	Enable			R=1 Ω and X=1 Ω	Complying
	All Zone Block	YES	Enable	In built feature in Dist. Relay			
	DR	YES	Enable				
	Binary Inputs	YES	Enable				
	Breaker Contacts	YES	Enable				
	Carrier Receive	YES	Enable				
	Time Synchronization	YES	Enable				
(XIII)	Distance Protection Panel:M-I						
	Name of Line	YES	Functional				
	Pole Discrepancy Relay	YES	Functional				
	PLCC Panel	YES	Functional				
	Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical		X1=1.48 Ω T1=0.00 ms X2=2.03 Ω T2=350 ms X3=2.26 Ω T3=1000 ms X4(rev.) = 326mΩ T4=160 ms	Complying
	Time Check-Z-1/2/3/4/5(Settings)	YES	Functional				
	SOTF	YES	Disable			permissive under reach phase, Z1 Z2+CR	
	Aided Scheme	YES	Functional				
	Fault Locator	YES	Enable				
	Power Swing (Setting R & X)	YES	Enable			R=5 Ω and X=5 Ω	Complying
	All Zone Block	YES	Enable	In built feature in Dist. Relay			
	DR	YES	Enable				

220 KV REENGUS-DECC-1
DIST. M-I SIEMENS

220 KV REENGUS-BABAI
DIST M-II- MICOM P442

SM

Rajesh Kumar

RL





Aided S
Fault Lo
Power Sw
All Zone I

	Input	YES	Enable				
	Breaker Contacts	YES	Enable				
	Carrier Receive	YES	Enable	In built feature in Dist. Relay			
	Time Synchronization	YES	Enable				
(XIV)	Distance Protection Panel:M-II			DIST M.II- MICOM P442			
	Name of Line	YES	Functional	220 KV REENGUS-DFCC-I			
	Pole Discrepancy Relay	YES	Functional				
	PLCC Panel	YES	Functional				
	Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical		Z1=4.32 Ω T1=0.00 ms Z2=9.56 Ω T2=350 ms Z3=15.21 Ω T3=1000 ms Z4(rev.) = 326mΩ T4=160 ms	Complying
	Time Check-Z-1/2/3/4/5(Settings)	YES	Functional				
	SOTF	YES	Disable				
	Aided Scheme	YES	Functional			permissive under reach phase, Z1 Z2+CR	
	Fault Locator	YES	Enable				
	Power Swing (Setting R & X)	YES	Enable			R=5 Ω and X=5 Ω	
	All Zone Block	YES	Enable				
	DR	YES	Enable				
	Binary Inputs	YES	Enable				
	Breaker Contacts	YES	Enable				
	Carrier Receive	YES	Enable				
	Time Synchronization	YES	Enable				
(XV)	Distance Protection Panel:M-I			DIST. M-I SIEMENS			
	Name of Line	YES	Functional	220 KV REENGUS-DFCC-II			
	Pole Discrepancy Relay	YES	Functional				
	PLCC Panel	YES	Functional				
	Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical		X1=1.48 Ω T1=0.00 ms X2=2.03 Ω T2=350 ms X3=2.26 Ω T3=1000 ms X4(rev.) = 326mΩ T4=160 ms	Complying
	Time Check-Z-1/2/3/4/5(Settings)	YES	Functional				
	SOTF	YES	Disable				
	Aided Scheme	YES	Functional			permissive under reach phase, Z1 Z2+CR	
	Fault Locator	YES	Enable				
	Power Swing (Setting R & X)	YES	Enable			R=5 Ω and X=5 Ω	
	All Zone Block	YES	Enable				
	DR	YES	Enable				
	Binary Inputs	YES	Enable				
	Breaker Contacts	YES	Enable				
	Carrier Receive	YES	Enable				
	Time Synchronization	YES	Enable				
(XVI)	Distance Protection Panel:M-II			DIST M.II- MICOM P442			
	Name of Line			220 KV REENGUS-DFCC II			

Signature: *[Handwritten Signature]*
 Date: *[Handwritten Date]*
 Name: *[Handwritten Name]*
 Initials: *[Handwritten Initials]*

Pole Discrepancy Relay	YES	Functional				
PLCC Panel	YES	Functional				
Zone-1/2/3/4/5 (Settings)	YES	Functional	Numerical		Z1=4.32 Ω T1=0.00 ms Z2=9.56 Ω T2=350 ms Z3=15.21 Ω T3=1000 ms Z4(rev.) = 326mΩ T4=160 ms	Complying
Time Check-Z-1/2/3/4/5(Settings)	YES	Functional				
SOTF	YES	Disable				
Aided Scheme	YES	Functional			permissive under reach phase, Z1 Z2+CR	
Fault Locator	YES	Enable				
Power Swing (Setting R & X)	YES	Enable			R=5 Ω and X=5 Ω	
All Zone Block	YES	Enable				
DR	YES	Enable				
Binary Inputs	YES	Enable				
Breaker Contacts	YES	Enable				
Carrier Receive	YES	Enable				
Time Synchronization	YES	Enable				

* Complying with the code of configuration issued by the CE(MPT&S) RVPN, Jaipur by letter No. RVPN/CE/MPT&S/JPR/Tech./F/Raikai ref No.5221696/D.166 Dated 21.12.2023

Name: Signature & Contact no. Team carrying out Protection audit:		Sh. R.R.Gupta, AEN O/O SE (Prot. Engg.) RVPNL, Jaipur		
Name: Signature & Contact no. Team carrying out Protection audit:		A. K. Lamoria, AEN(MPT&S) RVPN, Jhunjhunu		
Name: Signature & Contact no. Representative of utility whose protection audit is being carried out: Team carrying out Protection audit:		Pragya Pandey, AEN(MPT&S) RVPN, Sikar		
		Ramawatar Dhaka, JEN(MPT&S) RVPN, Sikar		
		Sh. D.K. Jain, SE(Prot. Engg.) RVPN, Jaipur		

General Info
(i) Name of Utility
(ii) Date of Commissioning
(iii) Name and Address of the Project
(iv) Name and Address of the Contractor
(v) Name and Address of the Engineer
(vi) Name and Address of the Supervisor
(vii) Name and Address of the In-charge

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit

General Information

- (i) Name of Utility:- 220 KV GSS Reengus
 (ii) Name of Voltage Level of Sub Station:- 220 KV
 (iii) Date of Commissioning:-12.01.1984
 (iv) Type of Bus Switching Scheme:- 02 NO's Main Bus and Aux. Bus
 (v) Name and Organization of Audit Team:- AEN O/O SE (Prot. Engg.) RVPNL, Jaipur
 (vi) Name of representative from utility whose audit being carried out:- SE (Prot. Engg.) RVPNL, Jaipur

B. Check List for Protection Audit						
S.No.	Check	Functional/ Non-Functional/Enabled/ Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions	
1	DC System	Functional			Complying	
	No. Of Independent DC Source	2 nos (220 V DC)				
	Potential Between +ve & Earth (Source-I)	119 V				
	Potential Between -ve & Earth (Source-I)	112 V				
	Potential Between +ve & Earth (Source-II)	114 V				
	Potential Between -ve & Earth (Source-II)	110V				
2	Event Logger Panel	No				
3	Event Logger Time Synchronised	No				
	Disturbance Recorder	No				
	DR Time Synchronised	No				
4	Bus Bar Protection	Functional	Numerical		Complying	
	Stability Check					
	EL Output for this Event					
	DR if Available					
5	DG Set	No				
	Mock Testing of Sample Protection Associated with	No				
6	Transmission line	Functional	Numerical		Complying	
7	LBB/BFR	Enable			Complying	
	Retrip	Enable			Complying	
	Current and Time Setting	Enable		PU = 120%/100ms + 100ms External timer	Complying	
	Separate Single and Three Phase Initiation	Enable			Complying	
	Earth Fault	Disable			Complying	
	Event Logger Operation	Enable			Complying	

* Complying with the code of configuration issued by the CE(MPT&S) RVPNL, Jaipur by letter No. RVPNL/CE/MPT&S/PR/Tech/JF/Rajkaj ref No.5221696/D.166 Dated 21.12.2023

Name: Signature & Contact no. Team carrying out Protection audit:

Name: Signature & Contact no. Representative of utility whose protection audit is being carried out: Team carrying out Protection audit:

Sh. R.R. Gupta, AEN O/O SE (Prot. Engg.) RVPNL, Jaipur	Sh. D.K. Jain, SE(Prot. Engg.) RVPNL, Jaipur
A. K. Lamoria, AEN(MPT&S) RVPNL, Jhunjhunu	
Pragya Pandey, AEN(MPT&S) RVPNL, Sikar	
Ramawatar Dhaka, JEN(MPT&S) RVPNL, Sikar	

R.R. Gupta
 Assistant Engineer (MPT&S)
 R.R.V.P.N.L., SIKAR

Pragya Pandey
 Assistant Engineer (MPT &
 RVPNL, Jhunjhunu

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit *carried out 3.09.2024*

A. General Information

(i) Name of Utility:- 220 KV GSS Kankroli

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:- 31.03.1997

(iv) Type of Bus Switching Scheme:- Double Main Bus and Single Aux. Bus

(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL Kankroli

B. Check List for Protection Audit

S.No.	Check		Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Transformer Protection Panel:					
(i)	Name of Transformer (Rating/Capacity)	220/132,100MVA Transformer-I (BHEL Make)				
	Tripping by Buchholz relay (Alarm)	Yes	Functional	Conventional		
	Differential Protection	Yes	Functional	Static	PickUp 20%	
	2nd Harmonic Block (Setting)	No	Feature Not Available			
	Event logger Operation	No	(No Event logger Installed)			
	Restricted Earth Fault Protection (HV Side)	Yes	Functional	Electromechanical	20%	
	Event logger Operation	No	(No Event logger Installed)			
	Restricted Earth Fault Protection (LV Side)	No	Not Required			
	Event logger Operation	No	(No Event logger Installed)			
	Backup Over Current	Yes	Functional	Electromechanical	75%	
	Event logger Operation	No	(No Event logger Installed)			
	Earth Fault Protection	Yes	Functional	Electromechanical	20%	
	Event logger Operation	No	(No Event logger Installed)			
	Over Flux Protection	Yes	Enabled	Electromechanical	As per Code of Configuration	
	Event logger Operation	No	(No Event logger Installed)			
	Local Breaker Back Up					
	Retrip					

Executive Engineer (MPT&S)
RVPNL Udaipur

XEN (MPT&S)
RVPNL KANKROLI

2

	Current and Time Setting				
	Separate Single and three Phase Initiation				
	Earth Fault				
	Event logger Operation				
(ii)	Name of Transformer (Rating/Capacity)	220/132,100MVA Transformer-II (TELK Make)			
	Tripping by Buchholz relay (Alarm)	Yes	Functional	Conventional	
	Differential Protection	Yes	Functional	Numerical	As per Code of Configuration
	2nd Harmonic Block (Setting)	Yes			
	Event logger Operation	NA	(No Event logger Installed)		
	Restricted Earth Fault Protection (HV Side)	Yes		Numerical	20%
	Event logger Operation	NA	(No Event logger Installed)		
	Restricted Earth Fault Protection (LV Side)	No	Not required		
	Event logger Operation	NA	(No Event logger Installed)		
	Backup Over Current	Yes	Functional	Numerical	65.6%
	Event logger Operation	NA	(No Event logger Installed)		
	Earth Fault Protection	Yes	Functional	Numerical	20%
	Event logger Operation	NA	(No Event logger Installed)		
	Over Flux Protection	Yes	Enabled	Numerical	As per Code of Configuration
	Event logger Operation	NA	(No Event logger Installed)		
	Local Breaker Back Up				
	Retrip				
	Current and Time Setting				
	Separate Single and three Phase Initiation				
	Earth Fault				
	Event logger Operation				

[Handwritten Signature]

[Handwritten Signature]
 AEM (MPT&S)
 ERVPNL, KANKROLI

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit *carried out on 03.09.2024*

A. General Information

(i) Name of Utility:- 220 KV GSS Kankroli

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:- 31.03.1997

(iv) Type of Bus Switching Scheme:- Double Main Bus and Single Aux. Bus


(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL Kankroli

B. Check List for Protection Audit

S.No.	Check	Yes/No	Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Distance Protection Panel:M-I/II					
(I)	Name of Line	220KV PGCIL-I				
	Pole Discrepancy Relay	Yes	Functional	Numerical(M-I) Static (M-II)	As per Code of Configuration	
	PLCC Panel	Yes	Functional			
	Zone-1/2/3/4/5 (Settings)	Yes	Enabled			
	Time Check-Z-1/2/3/4/5(Settings)	Yes	Enabled			
	SOTF	No	Disabled			
	Aided Scheme	Yes	Enabled			
	Fault Locator	No				
	Power Swing (Setting R & X)	Yes	Enabled			
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs	Yes				
	Breaker Contacts	Yes				
	Carrier Receive	Yes	Enabled			
	Time Synchronization	No				





 XEN (MPT&S)
 RVPNL KANKROLI

4


(2)	Name of Line	220KV PGCIL-II				
	Pole Discrepancy Relay	Yes	Functional			
	PLCC Panel	Yes	Functional			
	Zone-1/2/3/4/5 (Settings)	Yes	Enabled	Numerical	As per Code of Configuration	
	Time Check-Z-1/2/3/4/5(Settings)	Yes	Enabled			
	SOTF	No	Disabled			
	Aided Scheme	Yes	Enabled			
	Fault Locator	No				
	Power Swing (Setting R & X)	Yes	Enabled			
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs	Yes				
	Breaker Contacts	Yes				
	Carrier Receive	Yes	Enabled			
	Time Synchronization	No				

(3)	Name of Line	220KV HZL-I				
	Pole Discrepancy Relay	Yes	Functional			
	PLCC Panel	Yes	Functional			
	Zone-1/2/3/4/5 (Settings)	Yes	Enabled	Numerical	As per Code of Configuration	
	Time Check-Z-1/2/3/4/5(Settings)	Yes	Enabled			
	SOTF	No	Disabled			
	Aided Scheme	Yes	Enabled			
	Fault Locator	No				
	Power Swing (Setting R & X)	Yes	Enabled			
	All Zone Block	Yes	Enabled			
	DR	Yes	Enabled			
	Binary Inputs	Yes				
	Breaker Contacts	Yes				
	Carrier Receive	Yes	Enabled			
	Time Synchronization	No				


Executive Engineer (MF T&S)
R.R.M.F.N., Udaipur


AEN (MPT&S)
RRVNL, KANKROLI

(4)	Name of Line	220KV HZL-II			
	Pole Discrepancy Relay	Yes	Functional	Numerical	As per Code of Configuration
	PLCC Panel	Yes	Functional		
	Zone-1/2/3/4/5 (Settings)	Yes	Enabled		
	Time Check-Z-1/2/3/4/5(Settings)	Yes	Enabled		
	SOTF	No	Disabled		
	Aided Scheme	Yes	Enabled		
	Fault Locator	No			
	Power Swing (Setting R & X)	Yes	Enabled		
	All Zone Block	Yes	Enabled		
	DR	Yes	Enabled		
	Binary Inputs	Yes			
	Breaker Contacts	Yes			
	Carrier Receive	Yes	Enabled		
	Time Synchronization	No			
(5)	Name of Line	220KV Bamantukda			
	Pole Discrepancy Relay	Yes	Functional	Numerical	As per Code of Configuration
	PLCC Panel	Yes	Functional		
	Zone-1/2/3/4/5 (Settings)	Yes	Enabled		
	Time Check-Z-1/2/3/4/5(Settings)	Yes	Enabled		
	SOTF	No	Disabled		
	Aided Scheme	Yes	Enabled		
	Fault Locator	No			
	Power Swing (Setting R & X)	Yes	Enabled		
	All Zone Block	Yes	Enabled		
	DR	Yes	Enabled		
	Binary Inputs	Yes			
	Breaker Contacts	Yes			
	Carrier Receive	Yes	Enabled		
	Time Synchronization	No			


 EXECUTIVE ENGINEER (MPT&S)
 R.R.V.N.L. Udaipur


 AEN (MPT&S)
 R.R.V.N.L. KANKROLI

6

Rajasthan Rajya Vidhyut Prasaran Nigam Report of the Protection Audit

A. General Information

(i) Name of Utility:- 220 KV GSS Kankroli

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:- 31.03.1997

(iv) Type of Bus Switching Scheme:- Double Main Bus and Single Aux. Bus

(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL Kankroli

B. Check List for Protection Audit

S.No.	Check		Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
1	DC System		Functional	Electromechanical	20%	
	No. Of Independent DC Source	1				
	Potential Between +ve & Earth (Source-I)	118 V				
	Potential Between -ve & Earth (Source-I)	118 V				
2	Event Logger Panel	No				
3	Event Logger Time Synchronised	No				
	Disturbance Recorder	No				
	DR Time Synchronised	No				
4	Bus Bar Protection	Yes	Functional	Numerical	As per Code of Configuration	
	Stability Check					
	EL Output for this Event	No				
	DR if Available	No				
5	DG Set	No				

[Handwritten Signature]

[Handwritten Signature]
XEN (MPT&S)
RVPNL, KANKROLI

6	Mock Testing of Sample Protection Associated with Transmission line	No				
	LBB/BFR					
	Retrip					
	Current and Time Setting					
	Separate Single and Three Phase initiation					
	Earth Fault					
	Event Logger Operation					

Rajasthan Rajya Vidhyut Prasaran Nigam

Report of the Protection Audit *carried out on 3-09-2024*

A. General Information

(i) Name of Utility:- 220 KV GSS Kankroli

(ii) Name of Voltage Level of Sub Station:- 220/132 KV

(iii) Date of Commissioning:- 31.03.1997

(iv) Type of Bus Switching Scheme:- Double Main Bus and Single Aux. Bus

(v) Name and Organization of Audit Team:- XEN (MPT&S) RVPNL Udaipur

(vi) Name of representative from utility whose audit being carried out:- XEN 220KV GSS RVPNL Kankroli

B. Check List for Protection Audit


S.No.	Check		Functional/NonFunctional/Enabled/Disabled	Type of Relay (Numerical/Static/Electromechanical)	Setting as found in field	Compliance Status w.r.t regulatory provisions
	Reactor Protection Panel:	NA	No reactor Installed			
	Tripping by Buchholz relay (Alarm)	No				
	Differential Protection	No				
	2nd Harmonic Block (Setting)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (HV Side)	No				
	Event logger Operation	No				
	Restricted Earth Fault Protection (LV Side)	No				
	Event logger Operation	No				

Executive Engineer
RVPNL Udaipur

AEN (MPT&S)
KANKROLI

8

Backup Over Current	No				
Event logger Operation	No				
Earth Fault Protection	No				
Event logger Operation	No				
Over Flux Protection	No				
Event logger Operation	No				


Executive Engineer (MPT&S)
R.R.V.P.N.L., Udaipur


AEN (MPT&S)
R.R.V.P.N.L., KANKROLI

Rajasthan Raja Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information


i)	Name of utility:	Rajasthan Raja Vidhyut Prasaran Nigam Limited
ii)	Name of Voltage level of Substation:	220 kV GSS Kukas
iii)	Date of Commissioning:	13.10.1999
iv)	Type of Bus Switching Scheme	Two Main Bus
v)	Name and Organization of Audit Team	Sh. Mukul Yadav, AEN-III (MPT&S), RVPN, Jaipur
		Sh. Munesh Kumar Meena , JEN-I O/o AEN-III (MPT&S), RVPN, Jaipur
vi)	Name of representative from utility whose audit being carried out	Sh. D.K. Jain, SE (Prot. Engg.) RVPNL Jaipur

B. Checklist for Protection Audit


S.No.	Check		Functional / Non-Functional /Enabled/ Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field**	Compliance status w.r.t. regulatory provisions
Distance protection Panel:M-I/II						
(i)	Name of Line	220 kV PGCIL Bassi Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=4.44 Ohm, T1=0 ms Z2=7.983 Ohm, T2=350 ms Z3=10.938 Ohm, T3=1000 ms Z4(Rev.)=326 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional			
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying

S.No.	Check		Functional / Non-Functional / Enabled / Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
	Power swing(S(settings R and X)				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of Numerical Distance Protection Relays	-	Complying
	DR	Yes	Enabled		-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying
(ii)	Name of Line	220 kV KKD Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 Sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=901 mOhm, T1=0 ms Z2=3.976 Ohm, T2=350 ms Z3=7.395 Ohm, T3=1000 ms Z4(Rev.)=326 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional			
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR	1 Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying
	Power swing(S(settings R and X)				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of Numerical Distance Protection Relays	-	Complying
	DR	Yes	Enabled		-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying
Distance protection Panel:M-I/II						
(iii)	Name of Line	220 KV Manoharpur Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	M1-Numerical Distance	Z1=10.164 Ohm, T1=0 ms	

S.No.	Check		Functional / Non-Functional / Enabled/ Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional	Protection Relay M2-Electrostatic Distance Protection Relay	Z2=15.942 Ohm, T2=350 ms Z3=21.925 Ohm, T3=1000 ms Z4(Rev.)=326 mOhm, T4=160 ms	Complying
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relay	Permissive Under Reach, Phase Z1 Z2+CR 1	Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relay	-	Complying
	Power swing(S(settings R and X))				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of Numerical Distance Protection Relay	-	Complying
	DR	Yes	Enabled	In built feature of Numerical Distance Protection Relay	-	Complying
	Binary Input					
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying
Distance protection Panel:M-I/II						
(iv)	Name of Line	220 KV Alwar Line				
	Pole discrepancy relay	Yes	Functional(On CB)	Electromechanical	2 sec.	
	PLCC panel	Yes	Functional			
	Zone-1/2/3/4/5(settings)	Yes	Functional	Numerical Distance Protection Relays	Z1=13.504 Ohm, T1=0 ms Z2=17.671 Ohm, T2=350 ms Z3=19.484 Ohm, T3=1000 ms Z4(Rev.)=326 mOhm, T4=160 ms	Complying
	Time check-Zone-1/2/3/4/5(settings)	Yes	Functional			
	SOTF	No	Disabled	-	-	Complying
	Aided schemes	Yes	Functional	In built feature of Numerical Distance Protection Relays	Permissive Under Reach, Phase Z1 Z2+CR 1	Complying
	Fault locator	Yes	Functional	In built feature of Numerical Distance Protection Relays	-	Complying
	Power swing(S(settings R and X))				R=5 Ohm, X=5 Ohm	Complying
	All Zone block	Yes	Enabled	In built feature of Numerical Distance Protection Relays	-	Complying
	DR	Yes	Enabled	In built feature of Numerical Distance Protection Relays	-	Complying
	Binary Input					

S.No.	Check		Functional / Non-Functional / Enabled / Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
	Breaker Contacts	Yes	Functional	-	-	Complying
	Carrier Receive	Yes	Functional	-	-	Complying
	Time Synchronization	Yes	Functional	-	-	Complying
Name. Signature & Contact No. of team Carrying out Protection audit:			1. Mukul Yadav, AEN-III (MPT&S), Jaipur 9413382334			
			2. Munesh Kr. Meena, JEN-I O/o AEN-III (MPT&S), Jaipur 9413383124			
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:			1. Dinesh Kumar Jain, SE (Prot.Engg.), RVPN, Jaipur, 9413393540			

Distance relay calculation for 220 KV Kukas-PGCIL Bassi Line



EARTH FAULT COMPENSATION

$$R_E/R_L = 1/3((R_o/R_1)-1)$$

$$X_E/X_L = 1/3((X_o/X_1)-1)$$

$$k_{Z0} \text{ Res. Comp.} = k_{Z0} = (Z_0 - Z_1) / 3Z_1$$

Principle line Length : 34 KM.
Shortest Line Length considered on Remote Bus : 29.8 KM.
Longest line length Considered on Remote Bus : 30 KM.

Conductor Used : Zebra
Conductor Parameters :

R	X	Z	Angle
0.081	0.4	0.408	78.55

k_{Z0} : 0.734
k_{Z0} angle : -1.83

Zero Sequence(Z0): 0.2875 1.275 1.307 77.29
CTR: 800/1 Amp= 800
PTR: 220000/110 V= 2000
CTR/PTR: 0.4

Zone 1(Forward) Reach: 80 % of the Line to be Protected
Zone 2(Forward) Reach: 50 % of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach: 110 % Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach: 2 Km

Zone 1 forward Reach= 80% of line length (Kukas to PGCIL Bassi)* +ve Sequence impedance of conductor/km*(CTR/PTR)
 = **4.440** Ohm T1= Instt.

Zone 2 forward Reach= 100% of line length (Kukas to PGCIL Bassi)+50 % of the Shortest Line on remote Bus(PGCIL-Dausa)*+ve Sequence impedance of conductor/km*(CTR/PTR)

= **7.983** Ohm T2=350 ms

Zone 3 forward Reach=100% of line length (Kukas to PGCIL Bassi)+110 % Longest line length on Remote Bus(PGCIL-IG NAGAR)*+ve Sequence impedance of conductor/km*(CTR/PTR)

= **10.938** Ohm T3=1000 ms

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)

= **0.326** Ohm T4=160 ms

Directional O/C & E/F relay calculation for 220 kV Kukas-PGCIL Bassi Line

Fault MVA of 220 kV BUS : 6885 MVA
 3 Phase Short Circuit Current : 15891 Amp
 Phase-Phase Short Circuit Current : 13762 Amp
 Phase to Earth Short Circuit Current : 8581 Amp


Directional Overcurrent Element Setting

CT Ratio 800/1
 Plug Setting 100% i.e. 800 Amp
 Plug Setting Multiplier 17.2025
 Time of Operation 0.5 Seconds
 TMS 0.209

Directional Earthfault Element Setting

CT Ratio 800/1
 Plug Setting 20 % i.e. 160 Amp
 Plug Setting Multiplier 53.6313
 Time of Operation 0.5 Seconds
 TMS 0.227

Distance relay calculation for 220KV Kukas - KKD Line



Principle line Length : 6.9 KM.
Shortest Line Length considered on Remote Bus : 34.91 KM.
Longest line length Considered on Remote Bus : 34.91 KM.

Conductor Used : Zebra

Conductor Parameters	R	X	Z	Angle
Positive Sequence(Z1):	0.081	0.4	0.408	78.55
Zero Sequence(Z0):	0.2875	1.275	1.307	77.29
CTR:	800/1 Amp= 800			
PTR:	220000/110 V= 2000			
CTR/PTR:	0.4			

EARTH FAULT COMPENSATION

$$RE/RL=1/3((Ro/R1)-1)$$

$$XE/XL=1/3((Xo/X1)-1)$$

$$kZ0 \text{ Res. Comp.} = kZ0 = (Z0 - Z1) / 3Z1$$

kZ0 : 0.734
kZ0 angle : -1.83

Zone 1(Forward) Reach:	80	% of the Line to be Protected
Zone 2(Forward) Reach:	50	% of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach:	110	% Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach:	2	Km

Zone 1 forward Reach= 80% of line length (Kukas to KKD)* +ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{0.901} \text{ Ohm} \quad T1= \text{Instt.}$$

Zone 2 forward Reach= 100% of line length (Kukas to KKD)+50 % of the Shortest Line on remote Bus (KKD to PGCIL Bassi)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{3.976} \text{ Ohm} \quad T2=350 \text{ ms}$$

Zone 3 forward Reach=100% of line length (Kukas to KKD)+110 % Longest line length on Remote Bus(KKD to PGCIL Bassi)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{7.395} \text{ Ohm} \quad T3=1000 \text{ ms}$$

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{0.326} \text{ Ohm} \quad T4=160 \text{ ms}$$

Directional O/C & E/F relay calculation for 220 kV Kukas-KKD Line

Fault MVA of 220 kV BUS	:	6885 MVA
3 Phase Short Circuit Current	:	15891 Amp
Phase-Phase Short Circuit Current	:	13762 Amp
Phase to Earth Short Circuit Current	:	8581 Amp


Directional Overcurrent Element Setting

CT Ratio	800/1		
Plug Setting	100 % i.e.	800	Amp
Plug Setting Multiplier	17.2025		
Time of Operation	0.5	Seconds	
TMS	0.209		

Directional Earthfault Element Setting

CT Ratio	800/1		
Plug Setting	20 % i.e.	160	Amp
Plug Setting Multiplier	53.6313		
Time of Operation	0.5	Seconds	
TMS	0.227		

Distance relay calculation for 220 KV Kukas -Manoharpur Line



Principle line Length 77.83 KM.
Shortest Line Length considered on Remote Bus 39.65 KM.
Longest line length Considered on Remote Bus 51.34 KM.

Conductor Used : Zebra
Conductor Parameters :

	R	X	Z	Angle
Positive Sequence(Z1):	0.081	0.4	0.408	78.55
Zero Sequence(Z0):	0.2875	1.275	1.307	77.29
CTR:	800/1 Amp= 800			
PTR:	220000/110 V= 2000			
CTR/PTR:	0.4			

EARTH FAULT COMPENSATION

$$R_E/R_L = 1/3((R_0/R_1)-1)$$

$$X_E/X_L = 1/3((X_0/X_1)-1)$$

$$kZ_0 \text{ Res. Comp.} = kZ_0 = (Z_0 - Z_1) / 3Z_1$$

kZ0 **kZ0 angle**
0.734 **-1.83**

Zone 1(Forward) Reach:	80	% of the Line to be Protected
Zone 2(Forward) Reach:	50	% of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach:	110	% Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach:	2	Km

Zone 1 forward Reach= 80% of line length (Kukas to Manoharpur)* +ve Sequence impedance of conductor/km*(CTR/PTR)
 = **10.164** Ohm T1= Instt.

Zone 2 forward Reach= 100% of line length (Kukas to Manoharpur)+50 % of the Shortest Line on remote Bus(Manoharpur-PGCIL Kheina)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = **15.942** Ohm T2=350 ms

Zone 3 forward Reach=100% of line length(Kukas to Manoharpur)+110 % Longest line length on Remote Bus(Manoharpur-VKIA)*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = **21.925** Ohm T3=1000 ms

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)
 = **0.326** Ohm T4=160 ms

Directional O/C & E/F relay calculation for 220 kV Kukas-Manoharpur Line

Fault MVA of 220 kV BUS	:	6885 MVA
3 Phase Short Circuit Current	:	15891 Amp
Phase-Phase Short Circuit Current	:	13762 Amp
Phase to Earth Short Circuit Current	:	8581 Amp


Directional Overcurrent Element Setting

CT Ratio	800/1
Plug Setting	100% i.e. 800 Amp
Plug Setting Multiplier	17.2025
Time of Operation	0.5 Seconds
TMS	0.209

Directional Earthfault Element Setting

CT Ratio	800/1
Plug Setting	20 % i.e. 160 Amp
Plug Setting Multiplier	53.6313 .
Time of Operation	0.5 Seconds
TMS	0.227

Distance relay calculation for 220 KV Kukas -Alwar Line



Principle line Length : 103.4 KM.
Shortest Line Length considered on Remote Bus : 9.69 KM.
Longest line length Considered on Remote Bus : 14.5 KM.

Conductor Used : Zebra
Conductor Parameters :

	R	X	Z	Angle
Positive Sequence(Z1):	0.081	0.4	0.408	78.55
Zero Sequence(Z0):	0.2875	1.275	1.307	77.29
CTR:	800/1 Amp= 800			
PTR:	220000/110 V= 2000			
CTR/PTR:	0.4			

EARTH FAULT COMPENSATION

$RE/RL=1/3((Ro/R1)-1)$
 $XE/XL=1/3((Xo/X1)-1)$
 $kZ0 \text{ Res. Comp.} = kZ0 = (Z0 - Z1) / 3Z1$

kZ0	kZ0 angle
0.734	-1.83

Zone 1(Forward) Reach:	80	% of the Line to be Protected
Zone 2(Forward) Reach:	50	% of the Shortest Line on remote Bus+100 % of the Protected Line
Zone 3(Forward) Reach:	110	% Longest line length on Remote Bus+100 % of the Protected Line
Zone 4(Reverse) Reach:	2	Km

Zone 1 forward Reach= 80% of line length (Kukas to Alwar)* +ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{13.504} \text{ Ohm} \quad T1= \text{Instt.}$$

Zone 2 forward Reach= 100% of line length (Kukas to Alwar)+50 % of the Shortest Line on remote Bus(Alwar-MIA)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{17.671} \text{ Ohm} \quad T2=350 \text{ ms}$$

Zone 3 forward Reach=100% of line length (Kukas to Alwar)+110 % Longest line length on Remote Bus(Alwar-Kairvajat)*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{19.484} \text{ Ohm} \quad T3=1000 \text{ ms}$$

Zone 4 reverse Reach=2 km*+ve Sequence impedance of conductor/km*(CTR/PTR)

$$= \boxed{0.326} \text{ Ohm} \quad T4=160 \text{ ms}$$

Directional O/C & E/F relay calculation for 220 kV Kukas-Alwar Line

Fault MVA of 220 kV BUS	:	6885 MVA
3 Phase Short Circuit Current	:	15891 Amp
Phase-Phase Short Circuit Current	:	13762 Amp
Phase to Earth Short Circuit Current	:	8581 Amp

Directional Overcurrent Element Setting

CT Ratio	800/1		
Plug Setting	100% i.e.	800	Amp
Plug Setting Multiplier	17.2025		
Time of Operation	0.5	Seconds	
TMS	0.209		

Directional Earthfault Element Setting

CT Ratio	800/1		
Plug Setting	20 % i.e.	160	Amp
Plug Setting Multiplier	53.6313		
Time of Operation	0.5	Seconds	
TMS	0.227		


Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information

i) Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii) Name of Voltage level of Substation:	220 kV GSS Kukas
iii) Date of Commissioning:	13.10.1999
iv) Type of Bus Switching Scheme	Two Main Bus
v) Name and Organization of Audit Team	Sh. Mukul Yadav, AEN-III (MPT&S), RVPN, Jaipur
	Sh. Munesh Kumar Meena, JEN-I O/o AEN-III (MPT&S), RVPN, Jaipur
vi) Name of representative from utility whose audit being carried out	Sh. D.K. Jain, SE (Prot. Engg.) RVPNL Jaipur

B. Checklist for Protection Audit

S.No.	Check	Functional/ Non-Functional/Enabled/Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions	
Transformer Protection Panel						
(i)	Name of Transformer (Rating/Capacity)	220/132 kV, 100 MVA CGL make Transformer-I				
	Tripping by Buchholz Relay (Alarm)	Yes	Enabled	Electromechanical	Complying	
	Differential Protection	Yes	Enabled	Electrostatic	Complying	
	2nd Harmonic Block (Setting)		Enabled	15%	Complying	
	Event Logger Operation	No				
	Restricted Earth Fault Protection (HV Side)(Auto X-mer)	No				
	Event Logger Operation	No				
	REF Protection (LV Side)	NA				
	Event Logger Operation	NA				
	Backup Over Current	Yes	Enabled	Electromechanical	1/0.215	Complying
	Event Logger Operation	No				
	Earth Fault Protection	Yes	Enabled	Electromechanical	0.2/0.273	Complying
	Event Logger Operation	No				
	Over Flux Protection	Yes	Enabled			Complying
	Event Logger Operation	No				
	Local Breaker Back Up	Yes				
	Retrip	Yes	Enabled			Complying
	Current and Time Setting			120%/100 ms+100 ms External timer	Complying	
	Separate Single and three phase initiation	No(3 phase only)			Complying	
	Earth Fault	No			Complying	
	Event logger	No				
(i)	Name of Transformer (Rating/Capacity)	220/132 kV, 100 MVA CGL make Transformer-III				
	Tripping by Buchholz Relay (Alarm)	Yes	Enabled	Electromechanical	Complying	
	Differential Protection	Yes	Enabled	Numerical	Complying	
	2nd Harmonic Block (Setting)		Enabled	15%	Complying	

S.No.	Check		Functional/ Non-Functional/Enabled /Disabled	Type of Relay*(Numerical/ Static/Electromechanical)	Setting as found in field**/**	Compliance status w.r.t. regulatory provisions
	Event Logger Operation	Yes		In built feature of numerical differential relay		
	Restricted Earth Fault Protection (HV Side)(Auto X-mer)	Yes	Functional	Numerical	40.1 V	Complying
	Event Logger Operation	Yes		In built feature of numerical REF relay		
	REF Protection (LV Side)	NA				
	Event Logger Operation	NA				
	Backup Over Current	Yes	Enabled	Numerical	0.66/0.203	Complying
	Event Logger Operation	Yes		In built feature of numerical O/C & E/F relay		
	Earth Fault Protection	Yes	Enabled	Numerical	0.2/0.273	Complying
	Event Logger Operation	Yes		In built feature of numerical O/C & E/F relay		
	Over Flux Protection	Yes	Enabled			Complying
	Event Logger Operation	Yes		In built feature of numerical differential relay		
	Local Breaker Back Up	Yes				
	Retrip	Yes	Enabled			Complying
	Current and Time Setting				120%/100 ms+100 ms External timer	Complying
	Separate Single and three phase initiation	No(3 phase only)				Complying
	Earth Fault	No				Complying
	Event logger	Yes		In built feature of numerical LBB relay		
Name. Signature & Contact No. of team Carrying out Protection audit:			1. Mukul Yadav, AEN-III (MPT&S), Jaipur 9413382334			
			2. Munesh Kr. Meena, JEN-I O/o AEN-III (MPT&S), Jaipur 9413383124			
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:			1. Dinesh Kumar Jain, SE (Prot.Engg.), RVPN, Jaipur, 9413393540			

Non Directional O/C & E/F relay calculation for 220/132 kV, 100 MVA Transformer-I

Fault MVA of 220 kV BUS	:	6885 MVA
P.U. Impedance of 220 kV BUS		0.0145
% Impedance of transformer at Normal Tap		9.47 %
Transformer HV Voltage rating		220000 Volts
Transformer LV Voltage rating		132000 Volts
Transformer MVA Capacity		100 MVA
P.U. Impedance of Transformer		0.0947
Total P.U. Impedance		0.1092
Fault MVA of 132 kV BUS	:	916 MVA
3 Phase through fault Short Circuit Current		4007 Amp
Phase-Phase through fault Short Circuit Current		3470 Amp
Phase to Earth through fault Short Circuit Current		2164 Amp

Non Directional Overcurrent Element Setting

CT Ratio	300/1		
Plug Setting	100 % i.e.	300	Amp
Plug Setting Multiplier	11.56667		
Time of Operation	0.6	Seconds	
TMS	0.215		

Non Directional Earthfault Element Setting

CT Ratio	300/1		
Plug Setting	20 % i.e.	60	Amp
Plug Setting Multiplier	36.06667		
Time of Operation	0.6	Seconds	
TMS	0.273		

Stablizing Resistor calculation for Restricted Earth fault relay

Transformer Full load current HV	262	Amp
Transformer Full load current LV	437	Amp
Maximum fault current on through fault (If)	4615	Amp
Bushing CT Ratio	600	
Lead resistance	1	Ohm
Rct	5	Ohm
$V_k = I_f^* (R_{ct} + 2R_l)$		
Vk=	53.8	Volts
REF Operating Current	0.1	Amp
Stablizing Resistor	538	Ohm

Non Directional O/C & E/F relay calculation for 220/132 kV, 100 MVA Transformer-III

Fault MVA of 220 kV BUS	:	6885 MVA
P.U. Impedance of 220 kV BUS		0.0145
% Impedance of transformer at Normal Tap		12.71 %
Transformer HV Voltage rating		220000 Volts
Transformer LV Voltage rating		132000 Volts
Transformer MVA Capacity		100 MVA
P.U. Impedance of Transformer		0.1271
Total P.U. Impedance		0.1416
Fault MVA of 132 kV BUS	:	706 MVA
3 Phase through fault Short Circuit Current		3088 Amp
Phase-Phase through fault Short Circuit Current		2674 Amp
Phase to Earth through fault Short Circuit Current		1668 Amp

Non Directional Overcurrent Element Setting

CT Ratio	400/1		
Plug Setting	66 % i.e.	264	Amp
Plug Setting Multiplier	10.12879		
Time of Operation	0.6	Seconds	
TMS	0.203		

Non Directional Earthfault Element Setting

CT Ratio	400/1		
Plug Setting	20 % i.e.	80	Amp
Plug Setting Multiplier	20.85		
Time of Operation	0.6	Seconds	
TMS	0.273		

Stablizing Resistor calculation for Restricted Earth fault relay

Transformer Full load current HV	262 Amp
Transformer Full load current LV	437 Amp
Maximum fault current on through fault (If)	3438 Amp
Bushing CT Ratio	600
Lead resistance	1 Ohm
Rct	5 Ohm
$V_k = If * (Rct + 2RI)$	
Vk=	40.1 Volts
REF Operating Current	0.1 Amp
Stablizing Resistor	401 Ohm



Rajasthan Rajya Vidhyut Prasaran Nigam Limited
Report of the Protection Audit

A. General Information

i) Name of utility:	Rajasthan Rajya Vidhyut Prasaran Nigam Limited
ii) Name of Voltage level of Substation:	220 kV GSS Kukas
iii) Date of Commissioning:	13.10.1999
iv) Type of Bus Switching Scheme	Two Main Bus
v) Name and Organization of Audit Team	Sh. Mukul Yadav, AEN-III (MPT&S), RVPN, Jaipur
	Sh. Munesh Kumar Meena, JEN-I O/o AEN-III (MPT&S), RVPN, Jaipur
vi) Name of representative from utility whose audit being carried out	Sh. D.K. Jain, SE (Prot. Engg.) RVPNL Jaipur

B. Checklist for Protection Audit

S.No.	Check		Functional/ Non-Functional/Enabled/DIsabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field**/**	Compliance status w.r.t. regulatory provisions
1	DC system					
	No. of independent DC Sources	2 nos. 220 VDC	01 Nos. Functional & 01 Nos. Non-functional			
	Potential between +ive & earth (Source-1)	114.2 V	-	-	-	-
	Potential between -ive & earth (Source-1)	115.7 V	-	-	-	-
	Potential between +ive & earth (Source-2)	-	-	-	-	-
	Potential between -ive & earth (Source-2)	-	-	-	-	-
2	Event Logger panel	No	-	-	-	-
3	Event Logger Time Synchronised	NA	-	-	-	-
	Disturbance Recorder	NA	-	-	-	-
	DR Time Synchronised	NA	-	-	-	-
4	Bus bar Protection	Yes	Functional	Numerical	120 % Pickup	Complying
	Stability Check	Yes(On Running load)	-	-	-	-
	EL output for this event	No	-	-	-	-
	DR if available	No	-	-	-	-
5	DG Set	No	-	-	-	-
	Mock testing of a sample protection associated with transmission line***	Yes/ No	i. If Yes then observation..... ii. If no, the reason for the same.....			
6	Local Breaker Back Up(For Line)		-	Electrostatic	-	-
	Retrip	Yes	Enabled	-	-	Complying
	Current and Time Setting	Yes	-	-	PU-120%/100 ms+100 ms External timer	Complying

S.No.	Check		Functional/ Non-Functional/Enabled/Disabled	Type of Relay*(Numerical/Static/Electromechanical)	Setting as found in field*/**	Compliance status w.r.t. regulatory provisions
	Separate Single and three phase initiation	Yes	Functional	-	-	Complying
	Earth Fault	No	Disabled	-	-	Complying
	Event logger operation	No				
Name. Signature & Contact No. of team Carrying out Protection audit:			1. Mukul Yadav, AEN-III (MPT&S), Jaipur 9413382334			
			2. Munesh Kr. Meena, JEN-I O/o AEN-III (MPT&S), Jaipur 9413383124			
Name. Signature & Contact No. of representative of utility whose Protection audit is being carried out:			1. Dinesh Kumar Jain, SE (Prot.Engg.), RVPN, Jaipur, 9413393540			

Internal Protection Audit Report

Jaypee Vishnuprayag Hydro Electric Plant, Vishnuprayag

Date : 27.07.2024

(a)	General Information		
(i)	Name of the project	Jaypee Vishnuprayag Hydro-Electric Project (4x100 MW)	
(ii)	Name of Owner Utility	Jaiprakash Power Ventures Ltd.	
(iii)	Voltage Level (s) or highest voltage level	400 KV	
(iv)	Short circuit current rating of all equipment (for all voltage level)	40 KA(rms) for 1 second (Value of AC component)	
(v)	Date of commissioning of the substation	2006	
(vi)	Checking and validation date	24-Jul-24	
(vii)	Record of previous tripping"s (in last one year) and details of protection operation	Annexure-V	
(viii)	Previous Relay Test Reports	Annexure-VI	
(ix)	Overall single line diagram (SLD)	Annexure-I	
(x)	AC aux SLD	Annexure-II (415V & 11 KV)	
(xi)	DC aux SLD	Annexure-III	
(xii)	SAS architecture diagram	Annexure-IV	
(xiii)	SPS scheme implemented (if any)	NA	

(b)	Plant details		
	Date of commissioning	Unit 1	13.09.2006
		Unit 2	22.09.2006
		Unit 3	01.10.2006
		Unit 4	01.11.2006
	Type of bus-switching scheme:	Double Bus Bar Scheme	
	Wheather SLD connected or Not:	Connected	
	Name and Organization of Audit Team	Mr. Rakesh Malviya	Internal Audit
		Mr. Ajay Parashar	Internal Audit
		Mr. Manish Rana	Internal Audit

(c)	The relay configuration checklist for available power system elements at station:		
(i)	Transmission Line	Refer (c - i)	
(ii)	Bus Reactor/Line Reactor	Refer (c - ii)	
(iii)	Inter-connecting Transformer	NA	
(iv)	Busbar Protection Relay	Refer (c - iv)	
(v)	AC auxiliary system	Refer (c - v)	
(vi)	DC auxiliary system	Refer (c - vi)	
(vii)	Communication system	Refer (c - vii)	
(viii)	Circuit Breaker Details	Refer (c - viii)	
(ix)	Current Transformer Details	Refer (c - ix)	

(x)	Capacitive Voltage Transformers Details	Refer (c - x)
(xi)	Any other equipment/system relevant for protection system operation	

(c - i)	Transmission Line Distance Protection/Differential Protection	
----------------	--	--

a.	Name and Length of Line	Line-1:- 283.1 KM (Vishnuprayag - Muzzaffarnagar 400 KV Line) Line-2:- 106 KM (Vishnuprayag - Alaknanda 400 KV Line)																												
b.	Whether series compensated or not	Not Applicable																												
c.	Mode of communication used (PLCC/OPGW)	PLCC																												
d.	Relay Make and Model for Main-I and Main-II	Main-I:- ABB (REL 670) Main-II Siemens (Siprotec 7SA522)																												
e.	List of all active protections & settings	Refer B Check List for Protection Audit																												
f.	Carrier aided scheme if any	Yes																												
g.	Status of Power Swing/Out of Step/SOTF/Breaker Failure/Broken Conductor/STUB/Fault Locator/DR/VT fuse fail/Overvoltage Protection/Trip Circuit supervision/Auto reclose/Load encroachment etc.	Refer B Check List for Protection Audit																												
h.	Relay connected to Trip Coil-1 or 2 or both	Both																												
i.	CT ratio and PT ratio	Line-1 & 2:- 1000/1A 400 kV / $\sqrt{3}$ / 110 V / $\sqrt{3}$																												
j.	Feed from DC supply-1 or 2	Both																												
k.	Connected to dedicated CT core (mention name)	<table border="1"> <tr> <td rowspan="6">CT L101 & CT L201</td> <td>CORE-1</td> <td>PS</td> </tr> <tr> <td>CORE-2</td> <td>PS</td> </tr> <tr> <td>CORE-3</td> <td>0.1</td> </tr> <tr> <td>CORE-4</td> <td>0.2</td> </tr> <tr> <td>CORE-5</td> <td>PS</td> </tr> <tr> <td>CORE-6</td> <td>PS</td> </tr> <tr> <td rowspan="4">CT R101 (for Shunt Reactors)</td> <td>CORE-1</td> <td>PS</td> </tr> <tr> <td>CORE-2</td> <td>PS</td> </tr> <tr> <td>CORE-3</td> <td>5P20</td> </tr> <tr> <td>CORE-4</td> <td>PS</td> </tr> <tr> <td>CT R102 (for Shunt Reactors)</td> <td>CORE-1</td> <td>PS</td> </tr> <tr> <td>CT R103 (for Shunt Reactors)</td> <td>CORE-1</td> <td>PS</td> </tr> </table>	CT L101 & CT L201	CORE-1	PS	CORE-2	PS	CORE-3	0.1	CORE-4	0.2	CORE-5	PS	CORE-6	PS	CT R101 (for Shunt Reactors)	CORE-1	PS	CORE-2	PS	CORE-3	5P20	CORE-4	PS	CT R102 (for Shunt Reactors)	CORE-1	PS	CT R103 (for Shunt Reactors)	CORE-1	PS
CT L101 & CT L201	CORE-1	PS																												
	CORE-2	PS																												
	CORE-3	0.1																												
	CORE-4	0.2																												
	CORE-5	PS																												
	CORE-6	PS																												
CT R101 (for Shunt Reactors)	CORE-1	PS																												
	CORE-2	PS																												
	CORE-3	5P20																												
	CORE-4	PS																												
CT R102 (for Shunt Reactors)	CORE-1	PS																												
CT R103 (for Shunt Reactors)	CORE-1	PS																												
l.	Other requirements for protection checking and validation	Nil																												

(c - ii)	Shunt Reactor Protection	
-----------------	---------------------------------	--

a.	Relay Make and Model	ABB & RET 670									
b.	List of all active protections along with settings	Attached									
c.	Status of Oil Temperature Indicator/Winding Temperature Indicator/Bucholz/Pressure Release Device etc.	All OK									
d.	Relay connected to Trip Coil-1 or 2 or both	Both									
e.	CT ratio and PT ratio	250/1A 400 kV / $\sqrt{3}$ / 110 V / $\sqrt{3}$									
f.	Feed from DC supply-1 or 2	Both									
g.	Connected to dedicated CT core (mention name) *CTs mounted on Reactors	<table border="1"> <tr> <td>Line Bushing</td> <td>Neutral End</td> <td>WTI CT</td> </tr> <tr> <td>Core-1 - PS</td> <td>Core-1 - PS</td> <td>5 (7.5 VA)</td> </tr> <tr> <td>Core-2 - PS</td> <td></td> <td></td> </tr> </table>	Line Bushing	Neutral End	WTI CT	Core-1 - PS	Core-1 - PS	5 (7.5 VA)	Core-2 - PS		
Line Bushing	Neutral End	WTI CT									
Core-1 - PS	Core-1 - PS	5 (7.5 VA)									
Core-2 - PS											

	CTS mounted on reactors	Core-3 - PS		
		Core-4 - 5P20 (10VA)		
h.	Other requirements for protection checking and validation	Nil		

(c - iii)	NA			
(c - iv)	Busbar Protection Relay			
a.	Busbar and redundant relay make and model	ABB & REB 670		
b.	Type of Busbar arrangement	Double Bus Bar		
c.	Zones	Zone 1 to 4		
d.	Dedicated CT core for each busbar protection (Yes/No)	Bus-I:- B101-1(spare), B101-2(Protection) Bus-II:- B102-1(BB prot.), B102-2(Metering)		
e.	Breaker Failure relay included (Yes/No), if additional then furnish make and model	Yes		
f.	Trip issued to both Busbar protection in case of enabling	Yes		
g.	Isolator indication and check relays	Yes		
h.	Other requirements for protection checking and validation	Nil		

(c - v)	AC Auxiliary system			
a.	Source of AC auxiliary system	SSB & UAB		
b.	Supply changeover between sources (Auto/Manual)	Auto & Manual both		
c.	Diesel generator (DG) details	2*1010 KVA		
d.	Maintenance plan and supply changeover periodicity in DG	Annually & Quaterly		
e.	Single Line Diagram	Attached		
f.	Other requirements for protection checking and validation	Nil		

(c - vi)	DC Auxiliary system			
a.	Type of Batteries (Make, vintage, model)	Lead acid, Make: Exide, Vintage: TH1000H		
b.	Status of battery Charger	Working		
c.	Measured voltage (positive to earth and negative to earth)	Positive to earth Source -1/Source-2: Unearthed system Negative to earth Source -1/Source-2: Unearthed system		
d.	Availability of ground fault detectors	Available		
e.	Protection relays and trip circuits with independent DC sources	Yes		
f.	Other requirements for protection checking and validation	Nil		

(c - vii)	Communication system			
(i)	Mode of communication for Main-1 and Main-2 protection	PLCC		
(ii)	Mode of communication for data and speech communication	PLCC		
(iii)	Status of PLCC channels	Working		
(iv)	Time synchronization equipment details	GPS Receiver, interconnecting cable with matching connector.		

(v)	OPGW on geographically diversified paths for Main-1 and main-2 relay	Not available
(vi)	Other requirements for protection checking and validation	Nil

(c - viii) Circuit Breaker Details

a.	Details and Status	Make: GE T&D Type: T155-2&3 compact CB, Single break Rated voltage: 420 KV
b.	Healthiness of Tripping Coil and Trip circuit supervision relay	Healthy
c.	Single Pole/Multi pole operation	Multi-pole
d.	Pole Discrepancy Relay available(Y/N)	Yes
e.	Monitoring Devices for checking the dielectric medium	Density monitor for SF6 Pressure
f.	Other requirements for protection checking and validation	Nil

(c - ix) Current Transformer (CT) Details

a.	CT core connection details								
	Core	CT U101 (1000-500-250/1A)	CT G101 (6000/5A)	CT G102 (6000/5A)	CT G103 (6000/5A)	CT G104 (6000/5A)	CT G105 (500-250/1A)	CT G106 (1500/1A)	CT G107 (1500/1A)
	1	PS	PS	0.5 cl, 30 VA	PS	PS	PS	PS	PS
	2	PS	PS	0.5 cl, 30 VA	5P20, 10VA (200/5A)	5P20, 10VA (100/1A)	5P20, 10 VA	0.1, 15 VA (Metering)	-
	3	5P20, 30 VA	PS (Spare)	PS	-	-	-	5P20, 5 VA	-
	4	PS	Metering, 30VA	-	-	-	-	-	-
	5	PS	PS	-	-	-	-	-	-
	Adoted Ratio	1000/1A	6000/5A	6000/5A	6000/5A	6000/5A	500/1A	1500/1A	1500/1A
	Make	GE T&D (Earlier Areva)	Prayog Electricals	Prayog Electricals	Prayog Electricals	Prayog Electricals	Prayog Electricals	Prayog Electricals	Prayog Electricals
	Type	T155-CT	Cast Resin Ring Type	Cast Resin Ring Type	Cast Resin Ring Type	Cast Resin Ring Type	Cast Resin Ring Type	Cast Resin Ring Type	Cast Resin Ring Type
	Voltage level	420 KV	13.8 Kv	13.8 Kv	13.8 Kv	13.8 Kv	13.8 Kv	13.8 Kv	415 V
	Location	GIS	Generator Neutral side	Generator Phase side	Excitatin transformer CT	GT primary CT	GT Neutral CT	UAT CT	UAT LT side CT

(c - x) Capacitive Voltage Transformer (CVT) Details

	CVT name and voltage level	Line CVT - 400 KV
	CVT core connection details	Core 1/2/3
	Wdg-I	100 VA
	Wdg-II	0.2 Cl./300 VA

	Wdg-III	3P
c.	Accuracy Class	CT - 0.5 cl CVT - 0.2 cl
d.	Whether Protection/Metering	Both
e.	CVT ratio available and ratio adopted	400 kV / $\sqrt{3}$ / 110 V / $\sqrt{3}$
f.	Details of last checking and validation of CVT healthiness	Feb-24
g.	Other requirements for protection checking and validation	Nil

B. Check List for Protection Audit

S.No	Check		Functional / Non-functional / Enabled / Disabled	Type of relay * (Numerical / Static / Electro mechanical)	Setting as found in field**/**	Remarks
1.	DC system					
	No. of independent DC Sources	2	NA	NA	NA	220 V DC System
	Potential between +ive & earth (Source-1)	-	NA	NA	NA	Unearthed system (220 V DC System)
	Potential between -ive & earth (Source-1)	-	NA	NA	NA	Unearthed system (220 V DC System)
	Potential between +ive & earth (Source-2)	-	NA	NA	NA	Unearthed system (220 V DC System)
	Potential between -ive & earth (Source-2)	-	NA	NA	NA	Unearthed system (220 V DC System)
	Earth Fault / Over voltage Protection relay	-	Functional	Static	IE>0.7IN OV-110%Un	
2.	Event Logger panel	Yes	Functional	NA	NA	Inbuilt function of SCADA / protection system
3.	Event Logger Time Synchronised	Yes	Functional	NA	NA	Inbuilt function of SCADA / protection system
	Disturbance Recorder	Yes	Functional	NA	NA	Inbuilt function of SCADA / protection system
	DR Time Synchronised	Yes	Functional	NA	NA	Inbuilt function of SCADA / protection system
4.	Transformer Protection Panel:					
	Tripping by Buchholz relay (Alarm)	Yes	Functional	Numerical	NA	
	Differential Protection	Yes	Functional			
	2 nd Harmonic Block(Setting)		Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	Numerical	Attached	

Restricted Earth Fault Protection (LV side)	No				Primary winding is in Delta Connection
Event Logger operation	No		NA	NA	
REF Protection (HV side)	Yes	Functional	Numerical	Attached	
Event Logger operation	Yes	Functional	NA	NA	
Over current	Yes	Functional	Numerical	Attached	
Event Logger operation	Yes	Functional	NA	NA	
Earth Fault protection	Yes	Functional	Numerical	Attached	
Event Logger operation	Yes	Functional	NA	NA	
Over Flux Protection	Yes	Functional	Numerical	Attached	
Event Logger operation	Yes	Functional	NA	NA	

5.	Reactor Protection Panel:				
	Tripping by Buchholz relay(Alarm)	Yes	Functional	Numerical	NA
	Differential Protection	Yes	Functional	Numerical	Attached
	2 nd Harmonic Block (Setting)	Yes	Functional	Numerical	Attached
	5 th Harmonic Block (Setting)	Yes	Functional	Numerical	Attached
	Event Logger operation	Yes	Functional	NA	NA
	REF Protection (LV side)	Yes	Functional	Numerical	Attached
	Event Logger operation	Yes	Functional	NA	NA
	Backup Impedance	Yes	Functional	Numerical	Attached
	Event Logger operation	Yes	Functional	NA	NA

6.	Line Protection Panel: M-I/II				
	Pole discrepancy relay	Yes	Functional	Through Schematic	1 seconds
	PLCC panel	Yes	Functional	NA	NA
	Distance Protection	Yes	Functional	Numerical	Attached
	Zone-1/2/3/4/5 (Settings)	Yes	Functional	Numerical	Attached
	Time check-Z-1/2/3/4/5 (Settings)	Yes	Functional	Numerical	Attached
	SOTF	Yes	Functional	Numerical	Attached
	Fault Locator	Yes	Functional	Numerical	Attached
	Power swing(Settings R and X)	Yes	Functional	Numerical	Attached
	All Zone block	Yes	Functional	NA	NA
	DR	Yes	Functional	in built in numerical relay also	NA
	Breaker Contacts	Yes	Functional	NA	NA
	Carrier Receive	Yes	Functional	NA	NA
	Time Synchronization	Yes	Functional	NA	NA

7.	Single Phase Auto Recloser Scheme	Yes	Functional	Numerical	Attached	
8.	Bus Bar Protection	Yes	Functional	Numerical	Attached	
	Stability Check	Yes	Functional	Numerical		
	Slope check	Yes	Functional	Numerical		
	EL output for this event	Yes	Functional	Numerical		
	DR if available	Yes	Functional	Numerical		
	Local Breaker Back up	Yes	Functional	Numerical	Attached	
	Retrip	Yes	Functional			
	Current and Time setting	Yes	Functional		Attached	
	Seperate single and three phase initiation	Yes	Functional	Numerical	Attached	
	Earth fault	Yes	Functional	Numerical	Attached	
Event Logger	Yes	Functional	Numerical	Attached		
9.	Bus Coupler Protection	Yes	Functional	Numerical	Attached	
	Over Current	Yes	Functional	Numerical		
	Earth Fault protection	Yes	Functional	Numerical		
	EL output for this event	Yes	Functional	Numerical		
	DR if available	Yes	Functional	Numerical		
10.	Generator & Generator Transformer Protection Panel:					
	Main 1 Protection					
10-A1	Generator Differential Protection	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A2	Generator Backup Protection	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A3	Gen. Loss of Excitation (U/V)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A4	Gen AC Inst Over Current	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A5	Gen AC Time delayed Over	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A6	Gen O/V protection Stage 1	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A7	Gen O/V protection Stage 2	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A8	Gen Reverse Power Protection	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A9	Gen Neg Phase Seq Protection	Yes	Functional	Numerical	Attached	

	Event Logger operation	Yes	Functional	NA	NA	
10-A10	Generator Thermal Protection	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A11	Gen Volt Balance Protection	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A12	GT Restricted Earth Fault	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A13	UAT O/c & E/F Protection	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-A14	Gen Stator 100% Earth Fault	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
Main 2 Protection						
10-B1	Over Voltage Stage-1 (59)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B2	Over Voltage Stage-2 (59)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B3	Under Voltage Stage-1 (27)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B4	Under Voltage Stage-2 (27)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B5	Over Frequency Stage-1 (81)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B6	Over Frequency Stage-2 (81)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B7	Under Frequency Stage-1 (81)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B8	Under Frequency Stage-2 (81)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B9	Over Fluxing Stage-1 (24)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B10	Over Fluxing Stage-2 (24)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B11	UAT Restricted E/F Protn. (64R)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B12	GT/F Time Delayed O/C (51GT)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B13	Gen. Trans. Neu. O/C (51NGT)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B14	95% Stator E/F(59/27)	Yes	Functional	Numerical	Attached	
	Event Logger operation	Yes	Functional	NA	NA	
10-B15	Overall Differential (87T)	Yes	Functional	Numerical	Attached	

	Event Logger operation	Yes	Functional	NA	NA	
11.	DG Set	Yes	Functional	Auto/Manual		In built in DG sets function of DG set controller

	System	Time Synchronising	Availability (In service or
i)	400 kV System	Masibus	In service

A) Transmission Line Protection-I

	Name of Line	Main-I Protection (Make & Model)	Availability (In service or
i)	400 kV Vishnuprayag-Muzaffarnagar Line-1	ABB; REL-670	In service
ii)	400 kV Vishnuprayag-Alaknanda Line-2	ABB; REL-670	In service

Transmission Line Protection-II

	Name of Line	PLCC/Protection coupler (Make and Model)
i)	400 kV Vishnuprayag-Muzaffarnagar Line-1	ABB; ETI41/NSD41
ii)	400 kV Vishnuprayag-Muzaffarnagar Line-2	ABB; ETI41/NSD41

B) Reactor Protection

	Name of Reactor	Differential Protection (Make and Model)	REF Protection (Make and Model)
i)	Line-1 Reactor	Hitachi; RET-670	Hitachi; RET-670
ii)	Line-2 Reactor	Hitachi; RET-670	Hitachi; RET-670
iii)	Bus Reactor-1		
iv)	Bus Reactor-2		

C) Generator & Generator Transformer Protection

	Name of Reactor	Main 1
i)	Unit 1 (100 MW)	Hitachi - REG 670
i)	Unit 2 (100 MW)	Hitachi - REG 670
i)	Unit 3 (100 MW)	Hitachi - REG 670

i) Unit 4 (100 MW)	Hitachi - REG 670
--------------------	-------------------

Summary of Protection system Uprayag Hydro Electric Plant, Vishnuprayag

Date of Installation	Event Logger (Make)	Availability (In service or not)	Synchronising Facility Available or
Jan. 2024	Hitachi and ABB	In service	Available

Date of Testing	Main-II Protection (Make & Model)	Availability (In service or not)	Date of Testing	LBE (Ma
Feb. 2024	Siemens, 7SA522	In service	Feb. 2024	AB
Feb. 2024	Siemens, 7SA522	In service	Feb. 2024	AB

Availability (In service or not)	Disturbance Recorder(DR)	Details of O/V Protection
In service	Provided in line Main-1&2 Protections	Provided in line Main-1&2 Protections
In service		

Back-up Impedance Protection (Make and Model)	OTI/WTI Indication working or not	Buchholz/ PRD	Any other Protection	Date of Testing
Hitachi; RET-670	working	working	--	Feb-24
Hitachi; RET-670	working	working	--	Feb-24

Bus Reactors Not Installed

Main 2	OTI/WTI Indication working or not	Buchholz/ PRD	Any other Protection	Date of Testing
Hitachi - REG 670	working	working	--	Feb-24
Hitachi - REG 670	working	working	--	Feb-24
Hitachi - REG 670	working	working	--	Feb-24

Hitachi - REG 670	working	working	--	Feb-24
-------------------	---------	---------	----	--------


Synchro Check Relay	Remarks
SKD 11	

Protection (Type & Model)	Availability (In service)	Date of Testing
B; REB-670	In service	Jan. 2024
B; REB-670	In service	Jan. 2024

Availability (In service or not)
In service
In service

LA Rating HV side
360kV,20kA, Class IV
360kV,20kA, Class IV


Remarks



Annexure-I

BAY FEEDER 1
(TO MUTAFARNAGAR)

BAY FEEDER 2
(TO ILO AT ALAKNANDA HEP)



SCHEDULE OF VOLTAGE TRANSFORMERS

SNO.	DESCRIPTION/CORE	NOMINAL VOLTAGE	V _t RATIO	CLASS	BURDEN	PURPOSE
1	VT G1.1 (rel. 6.18 kV)	13.8 kV	13.8 kV/3110V/√3	0.5	30VA	METERING
2	VT G1.2	13.8 kV	13.8 kV/3110V/√3	0.5	30VA	METERING
3	VT B 1.1 (for 13.8 kV)	400 V	400 V/5110V/√3	0.2	30VA	METERING
4	VT B 1.2 (for 13.8 kV)	400 V	400 V/5110V/√3	0.2	30VA	METERING

- NOTE:**
- METERING AND PROTECTION SCHEME OF UNIT 2,3 AND 4 SHALL BE SIMILAR TO THAT OF UNIT 1.
 - METERING AND PROTECTION SCHEME OF FEEDER 2 SHALL BE SIMILAR TO THAT OF FEEDER 1.
 - SHORT TIME CURRENT RATING OF 400 kV BUS BARS SHALL BE 40 KA FOR 1 SEC.
 - GROUPING OF GENERATOR PROTECTIONS IS INDICATIVE ONLY AND MAY CHANGE DURING DETAIL ENGINEERING.

SCHEDULE OF CURRENT TRANSFORMERS

sno	Description	Rated Current	CT Ratio	App. Sec. (Ohm)	Time Point (sec)	Burden (VA)	Purpose
1	CT 1010	13.8 kV	800/5A	<1.5	>115	-	OVERALL DEF PROT
2	CT 1020	13.8 kV	800/5A	<1.5	>115	-	PROT MAIN 2
3	CT 1030	13.8 kV	800/5A	<1.5	>115	-	METERING
4	CT 1040	13.8 kV	800/5A	<1.5	>115	-	METERING
5	CT 1050	13.8 kV	800/5A	<1.5	>115	-	PROT MAIN 1
6	CT 1060	13.8 kV	800/5A	<1.5	>115	-	PROT
7	CT 1070	13.8 kV	800/5A	<1.5	>115	-	PROT
8	CT 1080	13.8 kV	800/5A	<1.5	>115	-	PROT
9	CT 1090	13.8 kV	800/5A	<1.5	>115	-	PROT
10	CT 1100	13.8 kV	800/5A	<1.5	>115	-	PROT
11	CT 1110	13.8 kV	800/5A	<1.5	>115	-	PROT
12	CT 1120	13.8 kV	800/5A	<1.5	>115	-	PROT

JAI PRAKASH POWER VENTURES LIMITED

PROJECT: VISHNUPRAYAG HYDROELECTRIC PROJECT (400 MW)

TITLE: SINGLE LINE PROTECTION AND METERING DIAGRAM

CLIENT: JAYPEE VENTURES LIMITED
PLOT 64/4, SITE-IV, INDUSTRIAL AREA, SAHIBABAD - 201 010, U.P.





SCALE: NTS DRAWING NO: 1100 - 2132 - 0011 REV. 10

Rev.	Description	Date	By	Appr.
1	Issue for Design	27/07/2003	AS	AS
2	Issue for Procurement	27/07/2003	AS	AS
3	Issue for Construction	27/07/2003	AS	AS
4	Issue for Commissioning	27/07/2003	AS	AS

Print Issue Date: 27/07/2003

Project Engineer: ANIL CHAUDHARY
Checked: K.K. SINGH (V.P.)
Drawing No: 1100-2132-0011

Annexure - II



NOTE

- Synchronising arrangement between DC Sets to be provided
- Short circuit rating of Circuit Breakers : 415 V Circuit Breakers - 50 kA, 1 Sec for Power House & 20 kA, 1 Sec for Barrage House
- All the transducers shall have 4-20 mA dual output. Power Monitor will have modulus connection.
- The energy meters shall have provision of pulse output if facility does not exist in Power Monitor
- The connection of UABs, SSTs to respective SSBs and interconnection between UABs & SSBs as shown in the SLD shall be through sandwich type LT Bus trunking system
- OTC Cables will be laid on 11KV line from Power House to Barrage Chamber & 11KV line from Power House to Barrage Site
- For details of PLCC System refer Drawing 1100-2132-0001

415V AC Barrage Power Dist. Board
(For detail refer Dwg. No. 1100-2132-0043)

415V DC BOARD
(For detail refer Dwg. No. 1100-2132-0043)



IN THE SCOPE OF D.G. SET SUPPLIER

IN THE SCOPE OF D.G. SET SUPPLIER

IN THE SCOPE OF D.G. SET SUPPLIER

Sl. No.	Rev.	Description	Date	By	Checked
R7	1	10100A D.C. System Modified, 200A TR. Added	24/07/24	S. Chandra	S. Chandra
R6	1	10100A D.C. System Modified, 200A TR. Added	24/07/24	S. Chandra	S. Chandra
R5	1	10100A D.C. System Modified, 200A TR. Added	24/07/24	S. Chandra	S. Chandra
R4	1	Capacity of UAB, SST, DC Set revised to 1000kVA	20/04/24	T. S. S. S. M.	S. Chandra
R3	1	Power Monitor & equipment marking added	19/03/24	S. Mohi	S. Chandra
R2	1	PLCC 3W & Station equipment marking added	02/02/24	S. Mohi	S. Chandra
R1	1	Power Transformer added & CT rating modified	20/11/23	S. Mohi	S. Chandra

CLIENT : JAYPRAKASH POWER VENTURES LIMITED
PROJECT : WSHNUPRAVAG HYDROELECTRIC PROJECT (400 MW)
TITLE : 11KV/415V AC POWER DISTRIBUTION SYSTEM - SINGLE LINE DIAGRAM
SCALE : NTS
DRAWING NO. : 1100-2132-0025
REV. : R8



REFERENCE DRAWINGS


	TITLE	DRG. NO.
1.	SINGLE LINE DIAGRAM FOR BATTERY & CHARGER FOR 220 V DC SYSTEM	1100-2147-0002
2.	UPS DISTRIBUTION BOARD	1100-2147-0005

- NOTES :-
- CONNECTION FOR SDB-2A, FOR UNIT 2 IS SIMILAR TO SDB-1A. SIMILARLY, CONNECTION FOR SDB-2B, FOR UNIT 2 IS SIMILAR TO SDB-1B.
 - CONNECTION FOR SDB-4A, FOR UNIT 4 IS SIMILAR TO SDB-3A. SIMILARLY, CONNECTION FOR SDB-3B, FOR UNIT 4 IS SIMILAR TO SDB-3B.
 - DCDB-I & DCDB-II ARE PROTECTED WITH D.C. UNDERVOLTAGE, OVERTAGE RELAY AND EARTH FAULT RELAYS.
 - ALL THE MCCBS ARE PROVIDED WITH POTENTIAL FREE CONTACTS FOR 'ON' AND 'TRIP' STATES. SIMILARLY, ALL THE MCCBS ARE PROVIDED WITH POTENTIAL FREE CONTACT FOR 'ON' STATE.

R7	MCCB ratings updated	Amit Jauhari	Suresh Chandra	13/09/05
R6	Revised as per present details	Amit Jauhari	Suresh Chandra	05/02/05
R5	MCCBs changed to MCBs	Gopal Sharma	Suresh Chandra	30/10/04
R4	100 A MCCBs changed to 100 A MCBs	Amit Jauhari	Suresh Chandra	10/09/04
R3	LT Board supply from DCDB-II included	Amit Jauhari	Suresh Chandra	12/05/04
R2	SDB-5 AX&B DC HP pump supply modified.	Amit Jauhari	Suresh Chandra	16/03/04
R1	Feeders revised/equipment codes by Alstom added	S. Maiti	S. Chandra	30/01/04
Rev.	Description	BY	Approved By:	Date
		D:\AMIT\Acad-2\VISHNU\DC SYSTEM\1100-2147-0004_R0		
DATE	13/10/2003	Drawing Checked	AK Sinha	V.P.
Designed	Amit Jauhari Sr. Engr.	Recommended/App.	S. CHANDRA	Jt. President
Drawing issued for information only unless signed as approved				
CLIENT				
JAIPRAKASH POWER VENTURES LIMITED				
PROJECT VISHNUPRAYAG HYDROELECTRIC PROJECT (400 MW)				
TITLE DC SYSTEM – SINGLE LINE DIAGRAM				
JAYPEE VENTURES LIMITED				
PLOT 64/4, SITE-IV, INDUSTRIAL AREA, SAHIBABAD – 201 010, U.P.				
SCALE	N.T.S.	DRAWING NO.	1100-2147-0004	REV. R7

COMMUNICATION CONNECTIVITY DIAGRAM

Refurbishment of Main Protection Relays at 400MW Vishnuprayag Hydroelectric project



LEGEND :

ARMoured FO CABLE	
DUPLEX FO PATCH CABLE	
LAN CABLE CAT-6	

FX - MULTI MODE FIBER OPTIC PORT
TX - COPPER PORT (RJ45)
LIU - MULTI MODE LIGHT INTERFACE UNIT

Based on: SALE ORDER No:3100137415		Title: VISHNUPRAYAG HYDROELECTRIC PROJECT (400 MW)	
Prepared: SMB		COMMUNICATION CONNECTIVITY DIAGRAM	
Approved: PSK		Ref. des.:	
Project: Vishnuprayag Hydroelectric project		Doc. des.: COMMUNICATION CONNECTIVITY DIAGRAM	
Jaiprakash Power Ventures Limited		Ref. ind.: 02	
HITACHI		Lang.: English:	
		Doc. No.: 1MNS801835-ZSA	
		Rev. ind.: 02	
		Sheet: 01	
		No. of sh.: 01	

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden. © HITACHI 2023

SHUT DOWN LOG (June 2023 - June 2024)					Annexure-V	
Sl. No.	Unit/ Feeder	Date / Time		Duration during month	Type of Fault	Purpose / Reason
		From	To	(Hrs : Mts)		
1	400 kV VP – MZN Line	<u>30.06.2023</u> 02:28	<u>30.06.2023</u> 04:11	01 Hrs 43 Mts	Transmission line fault	400 kV VP-MZN line CB at VP end was tripped at 02:28 Hrs on 30.06.2023 on receipt of Direct trip command from MZN end. After receiving line charging codes, 400 kV VP-MZN line was charged from MZN end at 04:10 Hrs and CB at VP end was closed at 04:11 Hrs on 30.06.2023 respectively. (400 kV VP-ALK Line remained in service)
2	400 kV VP – MZN Line	<u>05.07.2023</u> 12:38	<u>05.07.2023</u> 15:07	02 Hrs 29 Mts	Transmission line fault	400 kV VP-MZN Line tripped on R-Y Fault (Dist. 92.0 km), from both ends at 1238 Hrs on 05.07.2023. 400 kV VP-MZN Line was charged from MZN end at 1506 Hrs and CB at VP end was tried to close at 1507 Hrs, but again tripped on Y-N Fault (Dist. 97.81 km) on 05.07.2023. 400 kV VP - MZN line shutdown availed by UPPTCL from 0905 Hrs on 06.07.2023.
	400 kV VP – MZN Line	<u>05.07.2023</u> 15:07	<u>12.07.2023</u> 15:13	168 Hrs 06 Mts	Transmission line fault	After attending the fault 400 kV VP-MZN Line was charged from MZN end at 15:12 Hrs and at VP end CB was Closed at 15:13 Hrs on 12.07.2023. (400 kV VP-ALK Line remained in service)
3	Unit - 2	<u>14.07.2023</u> 17:16	<u>14.07.2023</u> 21:48	04 Hrs 32 Mts	Governor	Unit-2 Tripped on Quick shutdown (QSD) due to Governor oil level too low at 17:16 Hrs on 14.07.2023. After attending the fault Unit-2 Synchronized with grid at 21:48 Hrs on 14.07.2023.
4	400 kV VP – ALK Line	<u>04.08.2023</u> 03:09	<u>04.08.2023</u> 04:42	01 Hrs 33 Mts	Transmission line fault	400 kV ALK-MZN line tripped, simultaneously CB of 400 kV VP - MZN line at VP end also tripped. As power evacuation system was not available; running unit 1, 2, 3 & 4 also tripped at 03:09 hrs on 04.08.2023. 400 kV VP – ALK line was charged at 04:42 hrs with restoration of 400kV ALK – MZN line. After receiving line charging codes VP-MZN line CB at VP end was closed at 05:03 hrs on 04.08.2023. Unit 1, 2, 3 & 4 were synchronized with grid at 05:54 hrs, 05:48 hrs, 05:22
	400 kV VP – MZN Line	<u>04.08.2023</u> 03:09	<u>04.08.2023</u> 05:03	01 Hrs 54 Mts	Transmission line fault	
	Unit - 1	<u>04.08.2023</u> 03:09	<u>04.08.2023</u> 05:54	02 Hrs 45 Mts	Transmission line fault	
	Unit - 2	<u>04.08.2023</u> 03:09	<u>04.08.2023</u> 05:48	02 Hrs 39 Mts	Transmission line fault	

	Unit - 3	<u>04.08.2023</u> 03:09	<u>04.08.2023</u> 05:22	02 Hrs 13 Mts	Transmission line fault	hrs & 05:40 hrs respectively.
	Unit - 4	<u>04.08.2023</u> 03:09	<u>04.08.2023</u> 05:40	02 Hrs 31 Mts	Transmission line fault	
5	400 kV VP – MZN Line	<u>10.08.2023</u> 03:50	<u>10.08.2023</u> 05:23	01 Hrs 33 Mts	Transmission line fault	400 kV VP - MZN line CB at VP End tripped on over current at 03:50 Hrs on 10.08.2023, due to tripping of 400 kV ALK - MZN line and excess power flow, resulting in tripping of running units 1, 2, 3 & 4 at 03:50 Hrs After receiving line charging codes, 400 kV VP-MZN line CB closed at VP end at 05:23 hrs on 10.08.2023. Units 1, 2, 3 & 4 were synchronized with grid at 06:06 hrs, 05:52 hrs, 05:40 hrs & 05:48 hrs respectively on 10.08.2023. After receiving opening codes, 400 kV VP-ALK Line was opened at 05:28 Hrs and on receipt of charging codes, 400 kV VP-ALK Line was charged from ALK End at 06:22 Hrs & CB at VP End was closed at 06:23 Hrs on 10.08.2023
	400 kV VP – ALK Line	<u>10.08.2023</u> 05:28	<u>10.08.2023</u> 06:23	00 Hrs 55 Mts	Transmission line fault	
	Unit - 1	<u>10.08.2023</u> 03:50	<u>10.08.2023</u> 06:06	02 Hrs 16 Mts	Transmission line fault	
	Unit - 2	<u>10.08.2023</u> 03:50	<u>10.08.2023</u> 05:52	02 Hrs 02 Mts	Transmission line fault	
	Unit - 3	<u>10.08.2023</u> 03:50	<u>10.08.2023</u> 05:40	01 Hrs 50 Mts	Transmission line fault	
	Unit - 4	<u>10.08.2023</u> 03:50	<u>10.08.2023</u> 05:48	01 Hrs 58 Mts	Transmission line fault	
6	400 kV VP – ALK Line	<u>18.08.2023</u> 16:37	<u>19.08.2023</u> 15:15	22 Hrs 38 Mts	Transmission line fault	400 kV VP-ALK Line tripped on Y-B Fault (Dist. 56.60 km) at 1637 Hrs on 18.08.2023, resulting in tripping of all running Units 1, 2, 3 & 4 at 1637 Hrs, due to non-availability of Power Evacuation. After Charging 400 kV VP-MZN Line at 1748 Hrs, Units 1, 2, 3 & 4 were synchronised with grid at 1820 Hrs, 1804 Hrs, 1808 Hrs & 1753 Hrs respectively on 18.08.2023. also after receiving line charging codes of 400 kV VP - ALK line, 400 kV VP-ALK line was charged from ALK end at 15:14 hrs and CB of VP end was closed at 15:15 hrs on 19.08.2023. 400 kV VP-MZN Line Shutdown was availed by UPPTCL from 1612 Hrs to 1748 Hrs on 18.08.2023.
	Unit - 1	<u>18.08.2023</u> 16:37	<u>18.08.2023</u> 18:20	01 Hrs 43 Mts	Transmission line fault	
	Unit - 2	<u>18.08.2023</u> 16:37	<u>18.08.2023</u> 18:04	01 Hrs 27 Mts	Transmission line fault	
	Unit - 3	<u>18.08.2023</u> 16:37	<u>18.08.2023</u> 18:08	01 Hrs 31 Mts	Transmission line fault	
	Unit - 4	<u>18.08.2023</u> 16:37	<u>18.08.2023</u> 17:53	01 Hrs 16 Mts	Transmission line fault	
7	Unit - 3	<u>20.08.2023</u> 23:09	<u>21.08.2023</u> 00:45	01 Hrs 36 Mts	Governor	Unit – 3 tripped (QSD) due to TSLG major fault at 23:09 hrs on 20.09.2023. After attending the fault Unit - 3 was synchronized with grid at 00:45 hrs on 21.08.2023.
8	400 kV VP – MZN Line	<u>22.08.2023</u> 07:15	<u>22.08.2023</u> 07:53	00 Hrs 38 Mts	Transmission line fault	400 kV VP - MZN line CB at VP End tripped on Y-N fault and auto-reclosed at 07:15 Hrs at VP end but CB did not close at MZN end on 22.08.2023, after receiving charging code 400 kV VP - MZN line CB at MZN end closed at 07:53 at MZN end on 22.08.2023.

9	400 kV VP – MZN Line	<u>22.08.2023</u> 18:35	<u>22.08.2023</u> 19:05	00 Hrs 30 Mts	Transmission line fault	400kV VP-MZN line tripped at VP end on receipt of direct trip command from MZN end at 18:35 hrs on 22.08.2023. After receiving line charging codes, CB of VP-MZN line was closed at VP end at 19:05 hrs on 22.08.2023.
10	400 kV VP – MZN Line	<u>23.08.2023</u> 09:31	<u>23.08.2023</u> 10:40	01 Hrs 09 Mts	Transmission line fault	400 kV VP- MZN line CB tripped at VP end on receipt of Direct Trip Command (DTR) at 09:59 Hrs on 23.08.2023. After receiving line charging codes, 400 kV VP - MZN line CB at VP end closed at 10:40 Hrs on 23.08.2023.
11	Unit - 1	15.03.2024 02:49	15.03.2024 05:29 (U#4)	02 Hrs 40 Mts	Transmission line fault	400 kV VP-MZN and 400 KV VP- ALK Lines tripped due to bus bar protection operated at 0249 Hrs resulting in tripping of running Units 1 & 3 on 15.03.2024. 400 KV VP -ALK Line was restored at 0519 Hrs & Plant Generation resumed at 0529 Hrs on 15.03.2024. Shutdown of 400 kV VP-MZN Line is availed by VPHEP, as foul smell was observed in the B phase compartment of Circuit Breaker, from 1238 Hrs on 15.03.2024 for inspection and attending the fault. A foul smell was observed in the B- phase compartment of Circuit Breaker at VPHEP end. <u>After replacement of B – phase pole of circuit breaker 400 kV VP-MZN line</u> 400 kV VP-MZN line tripped and Auto Reclosed at VP end but tripped at MZN end at 22:59 Hrs on 29-04-2024. After receiving S/D codes for 400 kV VP-MZN line, C.B was opened at VP end at 00:11 Hrs on 30.04.2024. 400 kV ALK-MZN line tripped as Bus Bar protection operated at MZN end at 00:16 Hrs on 30-04-2024. but C.B did not opened at VP end, resulting in tripping of running Unit-2 (QSD) due to non-availability of power evacuation system. 400 kV VP-MZN line was charged from MZN end at 00:45 Hrs and C.B at V.P end was closed at 00:46 Hrs on 30-04-2024. Unit-02 was synchronised with grid at 00:48 Hrs.
	Unit - 3	15.03.2024 02:49	15.03.2024 05:29 (U#4)	02 Hrs 40 Mts	Transmission line fault	
	400 kV VP – MZN Line	15.03.2024 02:49	19.03.2024 19:14	112 Hrs 25 Mts	Transmission line fault	
	400 kV VP – MZN Line	15.03.2024 02:49	15.03.2024 05:19	02 Hrs 30 Mts	Transmission line fault	
12	400 kV VP - MZN Line	29.04.2024 22:59	30.04.2024 00:46	01 Hrs 47 Mts	Transmission line fault	400 kV VP-MZN line tripped and Auto Reclosed at VP end but tripped at MZN end at 22:59 Hrs on 29-04-2024. After receiving S/D codes for 400 kV VP-MZN line, C.B was opened at VP end at 00:11 Hrs on 30.04.2024. 400 kV ALK-MZN line tripped as Bus Bar protection operated at MZN end at 00:16 Hrs on 30-04-2024. but C.B did not opened at VP end, resulting in tripping of running Unit-2 (QSD) due to non-availability of power evacuation system. 400 kV VP-MZN line was charged from MZN end at 00:45 Hrs and C.B at V.P end was closed at 00:46 Hrs on 30-04-2024. Unit-02 was synchronised with grid at 00:48 Hrs.
13	Unit - 2	30.04.2024 00:16	30.04.2024 00:48	00 Hrs 32 Mts	Transmission line fault	400 kV VP-MZN line tripped and Auto Reclosed at VP end but tripped at MZN end at 22:59 Hrs on 29-04-2024. After receiving S/D codes for 400 kV VP-MZN line, C.B was opened at VP end at 00:11 Hrs on 30.04.2024. 400 kV ALK-MZN line tripped as Bus Bar protection operated at MZN end at 00:16 Hrs on 30-04-2024. but C.B did not opened at VP end, resulting in tripping of running Unit-2 (QSD) due to non-availability of power evacuation system. 400 kV VP-MZN line was charged from MZN end at 00:45 Hrs and C.B at V.P end was closed at 00:46 Hrs on 30-04-2024. Unit-02 was synchronised with grid at 00:48 Hrs.

14	400 kV VP - MZN Line	02.05.2024 01:54	02.05.2024 20:02	18 Hrs 08 Mts	Transmission line fault	400 kV VP - MZN Line tripped on R→N fault (Dist-213.84 km) at 01:54 Hrs on 02.05.2024. After receiving charging codes 400 kV VP - MZN Line charged from MZN end at 20:01 Hrs and CB at VP end closed at 20:02 Hrs on 02.05.2024. (400 kV VP - ALK Line remained in service)
15	400 kV VP - MZN Line	04.05.2024 19:12	05.05.2024 11:28	16 Hrs 16 Mts	Transmission line fault	400 kV VP - MZN Line tripped on Y→B fault (Dist-39.71 km) at 19:12 Hrs on 04.05.2024. 400 KV VP-MZN Line was under shut down from 20:34 Hrs on 04.05.2024(Shut down availed by UPPTCL). 400KV VP-MZN Line was charged from MZN end at 11:27 Hrs. and CB at VP end was closed at 11:28 Hrs on 5.05.2024. (400 kV VP - ALK Line remained in service)
16	Unit-3	09.05.2024 16:44	09.05.2024 17:54	01 Hrs 10 Mts	Breakdown	Unit- 03 tripped (QSD) at 16:44 Hrs on 09.05.2024 due to TSLG Major Fault (Governor). After attending Fault Unit-03 Synchronized with Grid at 17:54 Hrs
17	400 kV VP - MZN Line	31.05.2024 16:03	31.05.2024 16:03	00 Hrs 00 Mts	Breakdown	400 kV VP-MZN line tripped and Auto Reclosed at 16:03 Hrs on 31.05.2024.
18	400 kV VP - MZN Line	01.06.2024 18:13	01.06.2024 19:03	00 Hrs 50 Mts	Breakdown	400 kV VP - MZN Line tripped on Y→N fault (Dist-160.90km) at 18:13 Hrs on 01.06.2024. After receiving charging codes 400 kV VP - MZN Line charged from MZN end at 19:03 Hrs and CB at VP end closed at 19:03 Hrs on 01.06.2024. (400 kV VP - ALK Line remained in service)
19	400 kV VP - MZN Line	05.06.2024 14:40	05.06.2024 20:02	05 Hrs 22 Mts	Breakdown	400 kV VP - MZN Line tripped on Y→B fault (Dist-93.21 km) at 14:40 Hrs on 05.06.2024. After receiving codes 400 kV VP - MZN Line charged from MZN end at 20:01 Hrs and CB at VP end closed at 20:02 Hrs on 05.06.2024. (400 kV VP - ALK Line remained in service)

Legends	
	For Transmission Lines
	For 1, 2, 3, 4 Units



ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(भारत सरकार का उद्यम)
GRID CONTROLLER OF INDIA LIMITED
(A Government of India Enterprise)



[formerly Power System Operation Corporation Limited (POSOCO)]

राष्ट्रीय भार प्रेषण केन्द्र / **National Load Despatch Centre**

कार्यालय : बी-9, प्रथम एवं द्वितीय तल, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराय, नई दिल्ली - 110016
Office : 1st and 2nd Floor, B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi -110016
CIN : U40105DL2009GOI188682, Website : www.grid-india.in, E-mail : gridindiacc@grid-india.in, Tel.: 011- 42785855

संदर्भ: Grid-India/NLDC/2024/August/

दिनांक: 21.08.2024

सेवा मे,

- [1] Member Secretary, Northern Regional Power Committee, 18-A, Qutab Institutional Area, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110 016
[2] Member Secretary, Eastern Regional Power Committee, 14 Golf Club Road, Tollygunje, Kolkata-700033

महोदय/महोदया,

विषय/Subject: 220 केवी और उससे अधिक वोल्टेज वर्ग की अंतर-क्षेत्रीय लाइनों की ट्रिपिंग में सुरक्षा मानक के उल्लंघन की अधिसूचना

Notifying violation of protection standard in case of tripping of the Inter-Regional lines of voltage class 220 kV and above

220 केवी और उससे अधिक वोल्टेज वर्ग की अंतर क्षेत्रीय लाइनों की ट्रिपिंग के मामले में, केंद्रीय विद्युत प्राधिकरण, 2010 के ग्रिड मानक नियमन की धारा 3.ई के अनुसार फ़ाल्ट निम्नलिखित समय सीमा में निर्बाधित किया जाना है:

This has reference to violation of protection standard in case of tripping of Inter Regional Lines of voltage class 220 kV and above. As per section 3.e of Grid Standards Regulation of CEA, 2010, fault is to be cleared within the following time:

क्र.स./ Sl. No.	मामूली प्रणाली वोल्टेज (केवी आरएमएस)/ Nominal System Voltage in kV rms	फ़ाल्ट निर्बाधन का अधिकतम समय (मिली सेकंड)/ Maximum time of fault clearing in msec
1	400	100
2	220	160

जुलाई 2024 माह के दौरान 220 केवी और उससे अधिक वोल्टेज वर्ग की अंतर-क्षेत्रीय लाइनों की ट्रिपिंग की सूची संलग्न है, जिनमें उल्लंघन पाए गए हैं। यह देखा गया है कि इन घटनाओं के दौरान निर्दिष्ट समय के भीतर फ़ाल्ट को निर्बाधित नहीं किया गया था। चूंकि, ये घटनाएं चिंता का विषय हैं, यह अनुरोध किया जाता है कि उल्लिखित लाइनों/सबस्टेशनों के संबंधित स्वामियों को उपयुक्त कार्रवाई करने की सलाह दी जाए।

The list of tripping of Inter Regional Lines of voltage class 220 kV and above, during the month of **July 2024** in which violations have been observed is enclosed. It has been observed that fault had not cleared within specified time during these incidents. Since, these events are matter of concern, it is requested that the corresponding owners of mentioned lines/substations may be advised to take suitable actions.

सधन्यवाद,

भवदीय,

(मानस रंजन चंद)

उप महाप्रबंधक, रा.भा.प्रे.कें.

प्रतिलिपि सूचनार्थ :


1. कार्यपालक निदेशक, ऊतरी क्षेत्रीय भार प्रेषण केंद्र / पूर्वी क्षेत्रीय भार प्रेषण केंद्र

Violation of Standards in case of tripping of Inter-Regional lines for July 2024

S.No.	Name of Transmission Line	Regions Involved	Tripping Date and Time	Brief Reason/ Relay Indication	Restoration Date and Time	Fault Clearing Time (in msec as per nearest PMU)
1	400 kV Biharsariff - Sahupuri I	ER/NR	10-Jul-2024 15:54	Y-N Phase	10-Jul-2024 17:53	520
2	400 kV Biharsariff - Sahupuri II	ER/NR	10-Jul-2024 15:54	Y-N Phase	10-Jul-2024 17:54	520
3	400 kV Biharsariff - Sahupuri I	ER/NR	10-Jul-2024 18:37	Y-N Phase	10-Jul-2024 23:03	520
4	400 kV Biharsariff - Sahupuri II	ER/NR	10-Jul-2024 18:37	Y-N Phase	10-Jul-2024 23:02	520


Note: Fault clearing time calculated as per nearest PMU voltage

3-Phase Voltage PMU of Biharshariff Bus for tripping of 400 kV Biharsariff - Sahupuri D/C at 15:54 hrs of 10 - Jul - 2024



3-Phase Voltage PMU of Biharshariff Bus for tripping of 400 kV
Biharsariff - Sahupuri D/C at 18:37 hrs of 10 - Jul - 2024

R-Phase Y-Phase B-Phase





RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]

Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

RVPN
An ISO 9001:2015
Certified Company

OFFICE OF THE CHIEF ENGINEER (LD)

New Prasaran Bhawan, TCC Building, Heerapura, Jaipur Tel. No. 0141-2948293

E-mail: ce.ld@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvponl](http://energy.rajasthan.gov.in/rvponl)

No. RVPN/ CE (LD)/SE(SOLD)/XEN-III/ F. / D. 138 Jaipur, D.12/08/24

The Member Secretary
NRPC, New Delhi

Sub:- Agenda Item for inclusion in next Protection Sub-Committee (PSC) meeting-
Regarding tripping of 400/220 kV, 315 MVA ICT at 2x600 MW Kalisindh Thermal
Power Station, Jhalawar on Sensitive Earth Fault Relay.

On the above captioned subject, it is intimated that Sensitive Earth fault
protection (SEF) is used on 400/220kV , 315 MVA ICT at Kalisindh with tripping
mode, and recently few tripping occurred on 400/220 kV, 315 MVA ICT due to SEF
Protection (details attached) causing a large area disturbance i.e. Jhalawar,
Bhawanimandi & Aklera.

So, in view of above a Agenda Item is enclosed herewith for including the above
issue in upcoming PSC Meeting Agenda.

Encl: As above

(Manish Athaiya)
Chief Engineer (LD)
RVPN, Jaipur

Copy to the following for information and necessary action :-

1. The Chief Engineer(MPT&S). RVPN. Jaipur.
2. The Chief Engineer, Kalisindh Thermal Power Station, RVUN, Jhalawar.
3. The Superintending Engineer(Prot.Engg.). RVPN. Jaipur
4. The Superintending Engineer(Elect./Operations), Kalisindh Thermal Power Station,
RVUN, Jhalawar.

RajKaj Ref
9694644



Signature valid

Chief Engineer (LD)
RVPN, Jaipur
Digitally signed by Manish Athaiya
Designation: Chief Engineer
Date: 2024.08.22 14:42:45 IST
Reason: Approved

**Agenda :-Sensitive Earth Fault relay (to be kept on Alarm Mode only) of 440/220KV
315MVA ICT at 2X600MW Kalisindh Thermal Power Station, Jhalawar**

1. It is to inform that 220KV GSS Jhalawar, Bhawanimandi and Aklera supply is presently fed radially through(400/220 KV,315 MVA ICT)Kalisindh Generating Station (KSTPS).
2. SEF (Sensitive Earth Fault) protection is used in 440/220KV 315MVA ICT with tripping mode having time 1.5 Sec. (DT)
3. Recently few tripping occurred on 440/220KV, 315MVA ICT on SEF (Sensitive Earth Fault) Because of jumper snapping (Broken Conductor) in 220 KV lines. Due to this, supply of large area having 03 Nos. above 220 KV GSS & connected 132 KV GSS disturbed.
4. SEF Protection may operate because of unbalance current that due to broken conductor of 220 kV line.The RVPN has enabled broken conductor protection in 220 & 132 KV lines on alarm mode. In case any alarm observed, the line shall be manually tripped after checking current in all phases.
5. SEF relay is connected on neutral CT having CT ratio 500/1 and current plug setting is 0.1A (i.e. 45.4 Amp only), TMS – 1.5 Sec. DT mode.
6. At Kalisindh Thermal Power Station, Jhalawar the backup protection is also available on ICT which may take care of unbalance current in case of jumper snapping or actual phase to earth fault.
7. Such protection with tripping mode is **nowhere used in RVPN** Transmission system, this protection (SEF) is also **not included in the recent Protection Philosophy**.
8. Therefore Please arrange to disable tripping through SEF relay or increase the setting from existing value & keep it on alarm mode only for 440/220KV, 315MVA ICT at **Kalisindh Thermal Power Station, Jhalawar**.

EHV Tripping details on 220 KV GSS Jhalawar

S.NO.	NAME OF CIRCLE	NAME OF GSS	Name of Line	Tripping Date	Tripping Time	Closing Date	Closing Time	Relay Indication			Remarks
								JWR End	B.Mandi End	Katpp End	
1	SE (T&C) RVPN KOTA	220 KV GSS Jhalawar	220 KV JWR- KATPPI- Bhawanimandi Line	23.02.2024	8:50	23.02.2024	14:56	Supply Fail	Supply Fail	ICT Tripped on SEF	Due to jumper open at 220 KV JWR-Aklera line, Supply affected at 220 KV GSS Jhalawar, 220 KV Bhawanimandi, Aklera GSS
1	SE (T&C) RVPN KOTA	220 KV GSS Jhalawar	220 KV JWR- KATPPI- Bhawanimandi Line	07.07.2024	22:05	07.07.2024	23:11	Supply Fail	Supply Fail	ICT Tripped on SEF	Due to jumper open at 220 KV Aklera-CTPS line at loc. No. 130, Supply affected at 220 KV GSS Jhalawar, 220 KV Bhawanimandi, Aklera, Kawai GSS



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]

Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

RVPN

An ISO 9001:2015
Certified Company

OFFICE OF THE CHIEF ENGINEER (LD)

New Prasaran Bhawan, TCC Building, Heerapura, Jaipur Tel. No. 0141-2948293

E-mail: ce.ld@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvpn/](http://energy.rajasthan.gov.in/rvpn/)

No. RVPN/ CE (LD)/ F. / D.148

Jaipur,

dt. 20/08/2024

The Member Secretary
NRPC, New Delhi

Sub: - Agenda Item for inclusion in next Protection Sub-Committee (PSC) meeting – regarding excessive trippings of SPS on 400/220kV 2X315 MVA ICT's at STPS Suratgarh

Ref:- MoM of 49th PSC meeting held on 25.1.2024

On the above captioned subject. it is submitted there was excessive trippings on SPS at 400/220kV 2X 315 MVA ICT's at STPS, Suratgarh causing a large area disturbance. SPS of 400/220kV 2x315 MVA ICT's at STPS Suratgarh was approved in the 49th PSC meeting held on 25.1.2024.

So. in view of above a Agenda item is enclosed herewith for including the above issue in upcoming PSC Meeting Agenda.

Encl: 1. Agenda item for upcoming PSC.

2. Detail of tripping on ICT's due to SPS.

(Manish Athaiya)
Chief Engineer (LD)
RVPN, Jaipur

Copy to the following for information and necessary action :-

1. The Chief Engineer(MPT&S), RVPN, Jaipur.
2. The Chief Engineer, STPS, RVUN, Suratgarh.
3. The Superintending Engineer(Prot.Engg.), RVPN, Jaipur
4. The Superintending Engineer(Elect. Operations), STPS, RVUN, Suratgarh
5. The Superintending Engineer(MPI &S),RVPN, Bikaner.

Chief Engineer (LD)
RVPN, Jaipur

RajKaj Ref
9818344



Signature valid

Digitally signed by Manish Athaiya
Designation: Chief Engineer
Date: 2024.08.27 14:46:46 IST
Reason: Approved

**AGENDA NOTE FOR EXCESSIVE SPS TRIPPING OF 2X315 MVA, 400/220 KV
ICT's AT STPS SURATGARH**

Ref.-(1) MoM of 49th PSC of NRPC held on dated 25.01.2024.

- (1) Recently the SPS on 400/220 KV, 2X315 MVA ICT's at STPS Suratgarh has been commissioned on dated 06.05.2024 to meet out the N-1 contingency .
- (2) Excessive interruptions (i.e. 39 Nos w.e.f. 18/5/24 to 22/7/24) has been observed due to operation of newly commissioned SPS at STPS Suratgarh since commissioning and a large load approx. 150 MW was affected due to same.
- (3) After analysis of trippings it is observed that these trippings were due to operation of Over Current element of relay either by gradual overloading, poor power factor, poor voltage profile, Traction load etc. or some other reasons instead of "N-1 contingency".
- (4) After analyzing fault records /DR & discussion with RVUN officials, It is found that the present settings of Over current protection element of numerical relay used for SPS initiation is "Any one Phase" on full Load current.
- (5) It is recommended to update in the existing approved SPS scheme of STPS Suratgarh to avoid the power supply disturbance caused by gradual overloading instead of "N-1 Contingency".
 - a. To update the settings of over current element used for SPS start on "ALL Phase" instead of "Any Phase". As in most of the trippings, there is very much unbalance between the phases and the same may cause undesired initiation of SPS.
 - b. To update the Current Setting ($I>$) from full load to 125 % of load on each ICT as per thermal capability of each ICT's.
 - c. To incorporate C.B. status in the tripping circuit of SPS on each 220 KV lines at both end to avoid unnecessary tripping's.
 - d. To Split the first stage of time delay of 1.0 sec (approx load relief of 150MW) at 220 KV GSS Bhadrachalam by providing timer with 0.85 Sec (with load relief of 20 MW) and with 1.0 Sec (with load relief of rest 140 MW).

Raj. Raj Ref
318344

Signature valid

Digitally signed by M. Sush Athaiya
Designation: Chief Engineer
Date: 2024.07.27 15:46:46 IST
Reason: Approved

DATED-22.07.2024

Details of Phase Wise Loading of 400/220 KV,2X315 MVA ILT's of STPS Suratgarh at the time of trippings																					
SR.NO	ILT-/MLT-II	TIMING		400/220 KV ILT-/MLT-II(400 KV Side)						TIE CT						Summation of Main & TIE CT 400/220 KV ILT-/MLT-II(400 KV Side)					
		DATE	FROM	R-PH	Angle (Deg)	Y-PH	Angle (Deg)	B-PH	Angle (Deg)	R-PH	Angle (Deg)	Y-PH	Angle (Deg)	B-PH	Angle (Deg)	R-PH	Angle (Deg)	Y-PH	Angle (Deg)	B-PH	Angle (Deg)
1	ILT-2	18.05.2024	1:34:19	500	47.9	495	289.3	477	168.1	58	240.9	41	139.7	30	8.3	444	37.83494156	511	19.948	450	89.858
2	ILT-2	21.05.2024	13:26:30	556	221.6	399	92.8	421	354.8	43	234.7	24	174.5	1.773	185.7	593	-81.14297438	423	-82.89	423	-11.33
				470	221.6	394	92.8	419	354.1	44	234.7	24	174.5	1.252	185.7	508	-80.73201164	418	-82.89	419	-51.4
3	ILT-2	30.05.2024	10:11:01	441	189	453	76.1	457	313.2	0.959	52.8	50	327.4	27	202.3	441	29.01411956	503	40.053	442	-52.12
			10:50:35	445	344	459	231	460	108	1.248	42.4	53	121.6	30	356.3	446	89.74701399	415	-88.54	430	67.489
4	ILT-1	31.05.2024	16:05:54	442	260	468	133.2	454	15.6	0.928	166.1	53	247.5	35	134.5	443	-43.05640942	490	77.595	485	-8.096
	ILT-2	31.05.2024	15:26:56	443	104.7	438	350.8	438	227.5	1.055	12.3	45	265.8	23	164.6	443	58.99944884	394	-59.49	461	74.595
5	ILT-2	01.06.2024	12:42:56	441	290.5	455	179.8	466	56.9	0.775	356.6	67	75.7	51	305.5	440	84.41121761	395	45.813	420	17.328
6	ILT-2	02.06.2024	10:10:59	412	74.7	511	323.7	517	197.4	1.015	343.1	85	188.7	57	38.4	412	-40.14350388	426	5.6345	500	-35.96
			12:47:31	452	295.6	495	180.6	497	54.6	0.926	269.8	57	34.4	40	214.8	453	16.55990178	492	81.005	457	68.456
7	ILT-2	03.06.2024	11:57:58	452	4.3	470	250.6	469	125.2	1.059	275.3	48	127.9	12	337.9	453	66.47012106	423	-40.53	476	-27.72
8	ILT-1	04.06.2024	14:01:14	452	189.7	488	66.6	489	310.3	0.77	28.1	39	208.6	38	135.3	452	69.10521639	457	33.024	513	-37.72
			15:04:53	456	256.8	496	134.9	493	80	0.784	229.3	35	293.1	41	12.6	455	-46.51278688	512	-7.272	489	88.424
			15:37:30	452	358.5	489	236.3	484	119.7	0.938	285.4	34	28.4	34	314.4	451	20.62588407	518	37.012	518	18.009
9	ILT-1	05.06.2024	11:19:47	450	80.7	484	316.9	482	200.4	0.706	119.7	39	88.5	33	23.5	450	-56.14399333	462	-26.87	501	-41.04
10	ILT-1	06.06.2024	16:18:22	455	265.2	498	143.3	489	26.5	0.776	200.4	37	312.8	44	222.1	455	74.75056303	535	-70.09	520	81.889
11	ILT-1	10.06.2024	14:56:14	453	248.3	501	127.8	506	9.6	0.999	182.2	40	301.2	55	202.4	452	6.558036086	469	-60.41	487	4.0866
12	ILT-1	11.06.2024	14:14:07	454	314	504	192.5	503	75.3	0.726	256.3	45	2.8	57	265.6	454	-9.208858114	522	44.819	493	0.8312

			16:15:00	454	7.4	506	246.4	507	128.1	0.894	303.3	46	52.6	53	312.6	455	64.05146432	533	81.787	474	-35.57
13	ILT-1	12.06.2024	1:00:44	455	298	464	146.3	464	59	0.973	213.5	16	284	11	273	454	-25.89667527	478	-78.6	474	-39.07
	ILT-2		1:31:13	456	69.6	452	311.8	452	189.8	1.154	33.2	17	223.2	10	228.3	456	27.92583905	466	43.583	459	75.635
14	ILT-1	13.06.2024	11:36:48	450	195.8	478	72.4	474	315.6	0.717	133.9	28	205.9	27	149.8	450	58.58684097	479	11.563	454	80.34
			11:54:49	450	171.1	478	47.5	473	290.7	1.379	115	28	180	26	121.3	451	83.38382537	502	23.228	498	-83.39
			12:34:26	440	183.3	486	60.3	482	300.9	0.617	99.8	30	191	25	128.4	440	62.23846775	496	31.651	458	-40.59
			14:59:39	450	351.2	486	227.8	480	110.6	0.903	263.6	33	15	33	295.2	451	-37.68131558	509	-85.28	457	39.75
			15:06:09	452	22.6	496	258.1	478	140.7	0.62	28.1	35	45.8	33	322.4	452	34.82922135	506	31.894	507	-40.31
			16:49:19	452	237.1	493	113.9	489	356.2	0.963	182.1	38	265.2	39	171.2	452	84.95135716	527	47.985	453	67.045
15	ILT-1	16.06.2024	12:47:52	450	272.6	470	151.4	469	32.5	0.669	187.1	17	280.8	15	219.1	449	-41.11708148	456	33.384	464	60.359
16	ILT-1	17.06.2024	13:55:07	458	317.5	470	194.3	472	77.5	0.82	288.1	23	288.2	15	278.2	458	11.50265258	492	-28.34	486	-60.2
17	ILT-1	18.06.2024	12:46:38	454	142.8	464	19.8	463	264.4	0.977	102.3	19	122.2	21	136.8	453	81.79603006	459	56.725	456	26.539
	ILT-1		13:42:12	454	148.1	471	24.7	471	268.8	0.848	92.1	30	135.5	14	105.6	455	25.56067315	452	-27.64	485	-78.63
18	ILT-1	19.06.2024	15:14:03	469	74.1	483	313.3	501	196.8	0.821	22.6	34	91.9	32	20.2	469	-74.4773637	487	-53.22	526	-66.36
	ILT-1		16:40:25	454	207.3	476	83.1	470	325.8	1.006	122.8	35	209.9	21	117.6	453	-2.625290522	503	83.908	484	-54.91
	ILT-1		16:44:01	464	305.5	485	178.7	464	63.1	0.789	224.9	37	309.8	21	209.9	464	43.94656408	467	-17.37	450	17.379
19	ILT-1	20.06.2024	11:46:09	451	319.2	490	198.3	497	80.7	1.024	245.1	30	11.5	48	277.7	451	-71.06196827	487	25.256	469	-51.56
20	ILT-1	05.07.2024	10:55:25	384.9	31.6	860.8	313.15	2881	148.7	45.752	326.1	30.68	26.3	154.14	327.7	418	5.998002923	844	-56.11	2727	60.111
21	ILT-2			428.1	43.9	885.2	339.4	2610	171.6	42.175	167.4	31.72	228.1	154.27	169.9	406	-9.657452906	879	8.2034	2594	-71.43
22	ILT-2	19.07.2024	13:33:34	490.4	158.5	418.5	35.1	429.6	276.5	26.868	353.3	25.07	318.2	15.254	282.3	497	-22.40212085	442	32.216	443	1.3667
23	ILT-1			438.8	284.4	440	161.7	457	49.7	27.148	306.2	24.82	273.6	15.492	235.3	411	-84.36192835	450	81.782	442	-32.89
24	ILT-1	20.07.2024	12:15:09	479	342.8	520	219.9	520	102.5	38.146	197.5	60.75	43.8	79.196	301.4	507	17.93738774	580	-1.678	480	-75.05
25	ILT-2	22.07.2024	15:54:48	461.1	263.4	445.5	144.3	434.5	22.4	19.807	198.2	37.61	90.8	35.239	2	447	-30.06507506	408	-11.73	437	18.797

SUB:Comments of RVUNL, STPS for the Agenda raised by RVPNL regarding SPS on 2x315MVA, 400/220KV ICTs at STPS, Suratgarh

Ref.:

- (1) MOM of 49th PSC of NRPC held on 25.01.24
 (2) Agenda submitted by RVPNL vide letter No. RVPN/CE (LD) /F. /D.148 dtd 20.08.24 (Enclosed)

On the above cited subject and references, pointwise reply of RVUNL, STPS on the agenda SPS on 2x315MVA, 400/220KV ICTs at STPS, Suratgarh submitted by RVPNL to NRPC are as under:

S. no.	RVPN proposal	RVUN Comments
1.	To update the settings of over current element used for SPS start on "All phase" instead of "Any phase". As in most of the trippings, there is very much unbalance between the phases and the same may cause undesired initiation of SPS	At Generating station the Tripping /alarms of over-current/overload protections on all the electrical equipment i.e. Generator, Transformer, HT Motors, feeders, LT Motors etc always operates on any phase basis . Being Generating station it is necessary to initiate alarm as well to isolate the faulty element at the first instance to protect the equipment and curb major damage so as to avoid its downtime and loss of generation. The proposal may be considered to be dropped.
2.	To Update the current setting (I>) from full load to 125% of load on each ICT as per thermal capability of each ICT's.	Presently, Over current setting for ILT is 110% i.e. 500A and setting of SPS is 100% FLC i.e 460A (approx). If SPS is to be operated at 125% of FLC then ILT shall trip first on overcurrent protection before the operation of SPS.
3.	To incorporate CB status in the tripping circuit of SPS on each 220 KV lines at both end to avoid unnecessary trippings.	Once the RVPNL suggestion at point no 4 is implemented then there will be no need to execute point no.3. Besides this, RVUNL also suggest to install underpower relay at the GSS end rather than to interlock of breaker contacts as the chances of malfunctioning of breaker contacts are more. However, this type of SPS scheme is already in function at various Generating Stations/GSS. So, RVUNL request to NRPC to provide guidance/ elaboration on this matter.
4	To Split the first stage of time delay of 1 sec (approx load relief of 150MW) at 220 KV GSS bhadra by providing timer with 0.85 sec (with load relief of 20 MW) and with 1 Sec (With load relief of rest 140 MW)	Agreed but RVUNL, STPS suggest to implement this bifurcation of load relief at each stage/GSS i.e. Bhadra, Halasar and Sriganganagar because lines are not always in service.

Dy. Chief Engineer (Elect.)
 RVUN, SSTPS, SURATGARH

Status of Bus bar protection				
Constituent Name	Name of Station	Status of Bus bar protection(as reported)	Expected date of revival(as reported)	Present Status
Uttarakhand	220 KV Substation, Ramnagar, Roorkee	Blocked due to more elements added at 220 KV Voltage level.		
	220 KV Sub Station, SIDCUL, Haridwar			
	220kV Jhajhra, Dehradun	Not commissioned yet		
	400kV Kashipur (220kV side)	Available but Non operational	31-Mar-24	Work is under process.
	220kv Haldwani	Not Available	31 December 2024	Budget for FY 2023-24.
	220kv Pantnagar	Available but Non operational	31-Mar-24	Work is under process.
	220kv Rishikesh	Available but Non operational	31 December 2024	It has been Taken in Budget for FY 2023-24.
220kV Chamba	Not commissioned yet	31 December 2024	It has been Taken in Budget for FY 2023-24.	
Haryana	220kV S/Stn Badshahpur	Installed and Operational		Commissioned on 20.02.2023
	220kV S/Stn Sec-52A, Gurgaon	Not Installed	31.12.2024	Panel has been installed. Commissioning pending due to non- availability of shutdown.
	220kV S/Stn Sec-1 Manesar	Installed and Operational		Commissioned on 26.02.2023
	220kV S/Stn Panchgaon	Installed and Operational		Commissioned on 05.01.2024
	220kV S/Stn Rewari	Not Installed	31.03.2025	Material is not allocated so far. Installation will be carried out after allocation of material.
	220kV S/Stn Narnaul	Not Installed	31.10.2024	Panel has been installed. Work in progress on turnkey basis. Isolators of 220 kV TFs have to be replaced thereafter the work shall be completed.
	220kV S/Stn Mohinder Garh	Installed and Operational		Commissioned on 28.10.2023
	220 KV S/Stn Palwal	Not Installed	31.12.2024	Panel has been installed. Commissioning is pending.
	220 KV S/Stn Rangala Rajpur	Installed and Operational		Commissioned on 22.06.2023
	220 kV Unisipur	Installed but Non-Operational	31.08.2024	5 Nos. Peripheral relay of bus bar protection are defective. The same shall be made operational by 31.03.2024.
	220 kV Nissing	Installed but Non-Operational	31.08.2024	Existing Bus bar panel is of old and obsolete design. New Bus Bar protection scheme panel has been drawn from the store & Commissioning& installation are pending. The same shall be made operational by 31.03.2024.
	220KV Pehowa	Installed but Non-Operational	31.03.2025	Old & Obsolete, Allocation of New BBP and allied material awaited.
	220kV Kaithal	Not Installed	31.03.2025	Control Cable for Bus-Bar Protection Scheme has been drawn from DD Stores, 220kV Bus-Bar Protection panel is awaited.
	220 KV Sonapat	Not Installed	31.08.2024	220 KV Bus Bar Protection Scheme will be installed / commissioned within 45 days after the availability of the necessary material i.e 220kV Duplex, Directional, Bus Bar Cum Bus Coupler C and R Panel, Auxiliary Voltage 220V DC (without SAS) required for commissioning. It has been gathered from the P&M wing that the material is likely to be available in DD stores by April 2024.
	220 KV REGC, Sonapat	Not Installed	30.09.2024	The 220KV C&R Panel for Bus Bar Protection has been drawn from DD Store on dated 20.04.2023 and the work for installation of Bus Bar protection scheme is under progress. Erection work & wiring work completed with all respect. Testing of relays is pending at the end of Firm M/s Shifang and Bus Bar protection scheme will be commissioned dt 15.03.2024.
	220KV Jind	Installed and Operational		Commissioned on dated 27.06.23.
	220 KV Fatehabad	Installed and Operational		Commissioned on dated 22.07.23
	220 KV Hukmawali	Installed but Non-Operational	30.10.2023	Bus-coupler CB defective & new panel withdrawn from DD store. Erection work under progress & the same will be completed 31.08.23.
	220 KV Bhuna	Installed but Non-Operational	31.12.2024	The Siemens make Bus Bar protection Scheme installed at the time of commissioning of the substation went out of order. The higher authority decided to replace with new one. M/s Schneider make new Scheme was then allocated and drawn from DDS Ballabgarh and installed at site, but while testing of same, three out of four relays of the Bus Bar Panel found faulty for which matter is under pursuance with firm.
	220 KV Sirsa	Not Installed		Not required being single source of supply
	220 KV Rania	Not Installed	31.03.2025	Estimate for Bus Bar Protection is sanctioned but C&R panel is not available in store.
	220 KV Bhiwani	Not Installed	31.03.2025	Bus Bar Protection scheme has been proposed in integrated planning meeting and requirement of material have been generated in PR.
	220kV Madanpur	Not Installed	31.08.2024	Material is not allocated so far. Installation will be carried out after allocation of material.
220kV Tepla	Installed but Non-Operational	31.08.2024	material allocation is awaited.	
220kV Rajokheri	Installed and Operational	31.03.2024	Made operational on dated 30.05.2024.	
BBMB	220kV Charkhi Dadri	Installed and Operational		commissioned on 31.01.2023
	220kV Samaypur	Installed and Operational		made operational on 23.12.2023
	220kV Dhulkote	Not Installed		Not feasible
	220kV Jagadhari	Not Installed		
	220kV Barnala	Not Installed		

UP	220kV Parichha	Installed but Non-Operational	30.06.2023	
	220kV Partapur	Installed but Non-Operational	Jan-23	
	220kV Bareilly (400/220kV)	Installed but Non-Operational	Dec-23	Old panel capacity exhausted. New relay panel supplied & need to be
	220kV Pilibhit	Installed and Operational		commissioned on 28.10.2023
	220kV Amariya	Installed and Operational		commissioned on 15th July 2023
	220kV Sultanpur	Installed and Operational		commissioned on 02.03.2024
	220kV New Tanda	Installed and Operational		commissioned on 20.04.2024
	220kV Shahjhanpur	Installed but Non-Operational	30.06.2024	Table partially received, work will start soon
	220kV Ajjipur	Installed but Non-Operational		1. HV side 220kV CT of 160MVA T/F-I & II has bot proper ratio for bus bar
	220kV Nirpura	Installed but Non-Operational	Jan-23	
	220kV IITGNL	Installed but Non-Operational	Mar-23	
	220kV Rampur	Installed but Non-Operational	31.03.2024	
	220kV Barahua	Installed and Operational		made operational on 28.01.2024
	220kV Bansi	Installed and Operational		commissioned on 10th August 2023
	220 KV S/S Azamgarh-2(Bargahan)	Installed and Operational		made operational on 28.01.2024
	220kV Chandausi	Installed and Operational		made operational on 13.10.2023
	220kV Rasara	Not Installed		
	220kV Rampur	Installed but Non-Operational	Jun-24	1) Central unit of bus bar protection faulty 2) Bus bar relay fefective of 100MVA T/F-III
	220kV Sec. - 148, Noida	Installed but Non-Operational	31.01.2024	Work has been completed. Testing is due.
	220kV sec. 38A, Botanicla Garden	Not Installed		Panel allotment pending
	220kV sec.-62, Noida	Installed and Operational		made operational on 12.10.2023
	220kV Dadri	Installed and Operational	Apr-24	made operational on 23.04.2024
	400kV S/S Agra	Installed and Operational		commissioned on 13th September 2023
	220kV S/S Bah	Not Installed		Requirement sent to design circle, awaited fro allotment.
	220kV Sirsaganj	Not Installed		Requirement sent to design circle, awaited fro allotment.
	220kV S/S Farrukhabad (New)	Installed and Operational		commissioned on 25th August 2023
	220kV Boner	Installed and Operational		commissioned on 19.03.2024
	220kV Kasganj (Soron)	Installed and Operational		
	220kV Khair	Installed but Non-Operational	30.04.2024	New 160MVA transformer-3 is not configured with bus bar
	220kV Kidwainagar	Installed but Non-Operational		
	220kV Chhata	Installed but Non-Operational	30.04.2024	New 160MVA transformer-3 is not configured with bus bar
	220kV Harduaganj	Installed but Non-Operational	31.12.2023	
	220kV Lalitpur	Installed and Operational		commissioned on 09.02.2024
	220kV Mahoba	Installed but Non-Operational		Relay is faulty since 29.01.2024
	220kV Sarnath	Installed but Non-Operational	Nov-23	
	220kV Sirathu, Kaushambi	Not Installed	Mar-23	
	220kV substation Fatehpur	Installed and Operational		Operational
	220kV S/S Bhelupur	Not Installed		Radial feeder
	220kV Hardoi Road, Lucknow	Installed and Operational		commissioned on 08th October 2023
	220kV CG City, Lucknow	Installed but Non-Operational	31.05.2024	Agency M/s. Electro Power is decided.
	220kV Barabanki	Installed but Non-Operational	31.05.2024	Agency M/s. Electro Power is decided. 02 no. Peripheral unit found defective.
	220kV Kursi Road, Lucknow	Installed but Non-Operational	31.05.2024	Retrofitting work of auxilliary relay completed. Dut to non-functioning of new
	220kV BKT, Lucknow	Installed but Non-Operational	31.05.2024	LOI issued on Dt. 28.02.24
	220kV Gomti Nagar, Lucknow	Installed but Non-Operational	31.05.2024	Agency M/s. Electro Power is decided.
	400 KV Substation Sarnath	Installed and Operational		Now operational
220kV S/S Raja Talab	Installed but Non-Operational	May-24	Relay Defective, concern firm service engineer is awaited	
20kV S/S Harahua	Installed but Non-Operational	Jun-24	NOT COMMISSIONED	
220kv Rewa Road	Installed but Non-Operational	Jun-24	Due to Isolator & CB status not Proper. Informed to Transmission wing but	
220kV S/S Sahupuri	Installed but Non-Operational	Jun-24	Defective, Requirement for New panel has been raised, not received from	
220kv Robertganj	partilly operational	May-24	Line and bus coupler and T/F-I under cover but T/F-II not cover	
220kV S/S Mirzapur	Not Installed	Jun-24	Bubar Protection Panel has been Recived, construction of	
HP	220kV Chamba	Installed and Operational		commissioned in Jan-2024
	220kV MattaSidh	Installed but Non-Operational		
	220kV kangoo	Installed but Non-Operational	31.12.2024	Work in under progress, issues are being taken up with ABB
	220kV Nangal	Installed but Non-Operational		
	220kV Katha Baddi	Installed but Non-Operational		
Punjab	220 KV S/S Kotlisurat Malhi	Not Installed		
	220 KV S/S Maur	Not Installed		
	220 KV S/S Science city	Not Installed	Dec-24	Commissioning is in process. Material has arrived, commissioning shall be done as per shutdown availability.
	220 KV S/S Banga	Not Installed		
	220 KV S/S Hoshiarpur	Not Installed		
	220 KV S/S Goraya	Not Installed		
	220 KV S/S Bhawanigarh	Not Installed		
	220 KV S/S Badhni kalan	Installed and Operational		Commissioned
220 KV S/S Bhari	Installed and Operational		Commissioned	
	765 KV GSS Phagi	Installed but non operational		CU of Alstom make Bus-Bar is defective. Purchas case will be taken up
	220 kV GSS Vatika	Not installed		As M/s ER did not finished the project, so it was awarded to M/s Kaycee infra on risk-cost basis , however the bus bar scheme has not been commissioned yet.
	220 kV GSS Niwana	Not installed	Sep-24	Matter has been taken up with firm
	220 kV GSS Alwar	Not installed		To be commissioned shortly
	220 kV GSS Bansur	Not installed		To be commissioned shortly
	220 kV GSS Behror	Not installed		To be commissioned shortly
	220KV GSS Hindaun	Not installed		To be commissioned shortly
	220KV GSS Dooni	Not installed		commissioned
	220KV GSS Bhawanimandi	Not installed		commissioned
	220 KV GSS Sakatpura, Kota	Not installed		commissioned on 09.07.2024
	400 KV GSS Ajmer (220 KV BUS)	Installed but non operational		Isolator status of in 87BB of respective 220 KV bay No. 213,214, 215 & 216 was not available due to this 220 KV Main Bus-bar-II is out of ckt. work under progress
	220 kV GSS, Beawar	Not installed		commissioned
220 KV GSS Jethana	Not installed		commissioned	
220 KV GSS Kuchaman City	Installed but non operational		Purchase has been taken up with the firm	

Rajasthan

220 KV GSS Bherunda	Not installed		commissioned
220 KV GSS Kuchera	Not installed		commissioned
220 KV GSS Reengus	Installed but non operational		commissioned
220 KV GSS Laxmangarh	Not installed		Commissioned
220KV GSS Khetri Nagar	Installed but non operational		commissioned
400 KV GSS, Babai	Installed but non operational		commissioned
220 KV GSS Chittorgarh	Installed but non operational	20.08.2024	To be commissioned shortly
400 KV GSS BHILWARA(220 KV BUS)	Installed but non operational		BAY UNIT OF 220 KV TBC DEFECTIVE. Matter has been taken up with firm
220 KV GSS MANDALGARH	Not installed		commissioned
220KV GSS Debari	Not installed	31.08.2024	To be commissioned shortly
220KV GSS Amberi	Not installed		commissioned
220KV GSS Madri	Not installed	14.08.2024	To be commissioned shortly
400 KV GSS Surpura (Jodhpur)	Installed but non operational	30.09.2024	To be commissioned shortly
400 KV GSS Akal (Jaisalmer) 220	Installed but non operational		One PU defective. Case has been taken up with firm
220 KV GSS Jodhpur	Installed but non operational		A&FS and TS issued. Case has been send for approval
220 KV GSS NPH Jodhpur	Not installed		Case file moved
220 KV GSS Badisid	Not installed		commissioned
220 KV GSS Bhadla	Not installed	25.09.2024	Allotted & Panel Received. To be commissioned shortly
220 KV GSS Pali	Installed but non operational		commissioned
220 KV GSS Ramgarh	Not installed	05.09.2024	Allotted & Panel Received. To be commissioned shortly
220 KV GSS Balotra	Installed but non operational		commissioned
220 KV GSS Sayla	Not installed		commissioned
400 KV GSS Bikaner 400 KV BUS	Installed but non operational		to be done with transformer work
220 KV GSS Ratangarh	Not installed		commissioned
220 KV GSS Sujangarh	Not installed	10.08.2024	Allotted & Panel Received. To be commissioned shortly
220 KV GSS Halasar	Not installed	25.07.2024	Allotted & Panel Received. To be commissioned shortly
220 KV GSS Tehandesar	Not installed	15.09.2024	Allotted & Panel Received. To be commissioned shortly
220 KV GSS Rawatsar	Not installed		commissioned

Status of Bus bar protection				
Constituent Name	Name of Station	Status of Bus bar protection(as reported)	Expected date of implementation (as reported in 51st PSC meeting)	Remarks
Uttarakhand	220 KV Substation, Ramnagar, Roorkee	Blocked due to more elements added at 220 KV Voltage level.		
	220 KV Sub Station, SIDCUL, Haridwar			
	220kv Jhajhra, Dehradun	Not commissioned yet		
	400KV Kashipur (220kv side)	Available but Non operational	Revised date not received	Work is under process.
	220kv Haldwani	Not Available	31 December 2024	Budget for FY 2023-24.
	220kv Pantnagar	Available but Non operational	Revised date not received	Work is under process.
	220KV Rishikesh	Available but Non operational	31 December 2024	It has been Taken in Budget for FY 2023-24.
	220kv Chamba	Not commissioned yet	31 December 2024	It has been Taken in Budget for FY 2023-24.
Haryana	220kV S/Stn Badshahpur	Installed and Operational		Commissioned on 20.02.2023
	220kV S/Stn Sec-52A, Gurgaon	Not Installed	31.12.2024	Panel has been installed. Commissioning pending due to non-availability of shutdown.
	220kV S/Stn Sec-1 Manesar	Installed and Operational		Commissioned on 26.02.2023
	220kV S/Stn Panchgaon	Installed and Operational		Commissioned on 05.01.2024
	220kV S/Stn Rewari	Not Installed	31.03.2025	Material is not allocated so far. Installation will be carried out after allocation of material.
	220kV S/Stn Narnaul	Not Installed	31.12.2024	Panel has been installed. Work in progress on turnkey basis. Isolators of 220 kV TFs have to be replaced thereafter the work shall be completed.
	220kV S/Stn Mohinder Garh	Installed and Operational		Commissioned on 28.10.2023
	220 KV S/Stn Palwal	Not Installed	31.12.2024	Panel has been installed. Commissioning is pending.
	220 KV S/Stn Rangala Rajpur	Installed and Operational		Commissioned on 22.06.2023
	220 kV Unisapur	Installed but Non-Operational	31.10.2024	5 Nos. Peripheral relay of bus bar protection are defective. The same shall be made operational by 31.03.2024.
	220 kV Nissing	Installed but Non-Operational	31.10.2024	Existing Bus bar panel is of old and obsolete design. New Bus Bar protection scheme panel has been drawn from the store & Commissioning& installation are pending. The same shall be made operational by 31.03.2024.
	220KV Pehowa	Installed but Non-Operational	31.03.2025	Old & Obsolete, Allocation of New BBP and allied material awaited.
	220kV Kaithal	Not Installed	31.03.2025	Control Cable for Bus-Bar Protection Scheme has been drawn from DD Stores, 220KV Bus-Bar Protection panel is awaited.
	220 KV Sonapat	Not Installed	31.10.2024	220 KV Bus Bar Protection Scheme will be installed / commissioned within 45 days after the availability of the necessary material i.e 220KV Duplex, Directional, Bus Bar Cum Bus Coupler C and R Panel, Auxiliary Voltage 220V DC (without SAS) required for commissioning. It has been gathered from the P&M wing that the material is likely to be available in DD stores by April 2024.
	220 KV REGC, Sonapat	Not Installed	30.09.2024	The 220KV C&R Panel for Bus Bar Protection has been drawn from DD Store on dated 20.04.2023 and the work for installation of Bus Bar protection scheme is under progress. Erection work & wiring work completed with all respect. Testing of relays is pending at the end of Firm M/s Shifang and Bus Bar protection scheme will be commissioned dt 15.03.2024.
	220KV Jind	Installed and Operational		Commissioned on dated 27.06.23.
	220 KV Fatehabad	Installed and Operational		Commissioned on dated 22.07.23
	220 KV Hukmawali	Installed but Non-Operational	30.10.2023	Bus-coupler CB defective & new panel withdrawn from DD store. Erection work under progress & the same will be completed 31.08.23.
	220 KV Bhuna	Installed but Non-Operational	31.12.2024	The Siemens make Bus Bar protection Scheme installed at the time of commissioning of the substation went out of order. The higher authority decided to replace with new one. M/s Schneider make new Scheme was then allocated and drawn from DDS Ballabgarh and installed at site, but while testing of same, three out of four relays of the Bus Bar Panel found faulty for which matter is under pursuance with firm.
	220 KV Sirsa	Not Installed		Not required being single source of supply
	220 KV Rania	Not Installed	31.03.2025	Estimate for Bus Bar Protection is sanctioned but C&R panel is not available in store.
	220 KV Bhiwani	Not Installed	31.03.2025	Bus Bar Protection scheme has been proposed in integrated planning meeting and requirement of material have been generated in PR.
	220kv Madanpur	Not Installed	30.11.2024	Material is not allocated so far. Installation will be carried out after allocation of material.
220KV Tepla	Installed but Non-Operational	30.11.2024	material allocation is awaited.	
220kv Rajokheri	Installed and Operational		Made operational on dated 30.05.2024.	
BBMB	220kV Charkhi Dadri	Installed and Operational		commissioned on 31.01.2023
	220kV Samaypur	Installed and Operational		made operational on 23.12.2023
	220kV Dhulkote	Not Installed		Not feasible
	220kV Jagadhari	Not Installed		
	220kV Barnala	Not Installed		
	220KV Parichha	Installed but Non-Operational	Revised date not received	
	220kV Partapur	Installed and Operational		made operational on 06.01.2023
	220kV Bareilly (400/220kV Bareilly)	Installed but Non-Operational	Revised date not received	Old panel capacity exhausted. New relay panel supplied & need to be
	220kV Pilibhit	Installed and Operational		commissioned on 28.10.2023
	220kV Amariya	Installed and Operational		commissioned on 15th July 2023
	220kV Sultanpur	Installed and Operational		commissioned on 02.03.2024

UP	220kV New Tanda	Installed and Operational		commissioned on 20.04.2024
	220kV Shahjhanpur	Installed but Non-Operational	Revised date not received	Cable partially received, work will start soon
	220kV Aijlpur	Installed but Non-Operational		1. HV side 220kV CT of 160MVA T/F-I & II has bot proper ratio for bus bar
	220kV Nirpura	Installed but Non-Operational	Revised date not received	
	220kV IITGNL	Installed and Operational		made operational on 19.02.2023
	220kV Rampur	Installed but Non-Operational	Revised date not received	
	220kV Barahua	Installed and Operational		made operational on 28.01.2024
	220kV Bansi	Installed and Operational		commissioned on 10th August 2023
	220 KV S/S Azamgarh-2(Bargahan)	Installed and Operational		made operational on 28.01.2024
	220kV Chandausi	Installed and Operational		made operational on 13.10.2023
	220kV Rasara	Not Installed		
	220kV Rampur	Installed but Non-Operational	31.10.2024	Central unit of bus bar protection faulty. Expected to revive by November-24.
	220kV Sec. - 148, Noida	Installed and Operational		made operational on 27.01.2024
	220kV sec. 38A, Botanicla Garden	Not Installed	31.11.2024	Bus Bar protection panel awaited
	220kV sec.-62, Noida	Installed and Operational		made operational on 12.10.2023
	220kV Dadri	Installed and Operational		made operational on 23.04.2024
	400kV S/S Agra	Installed and Operational		commissioned on 13th September 2023
	220kV S/S Bah	Not Installed		Requirement sent to design circle, awaited fro allotment.
	220kV Sirsaganj	Not Installed		Requirement sent to design circle, awaited fro allotment.
	220kV S/S Farrukhabad (New)	Installed and Operational		commissioned on 25th August 2023
	220kV Boner	Installed and Operational		commissioned on 19.03.2024
	220kV Kasganj (Soron)	Installed and Operational		
	220kV Khair	Installed but Non-Operational	Revised date not received	New 160MVA transformer-3 is not configured with bus bar
	220kV Kidwainagar	Installed but Non-Operational		
	220kV Chhata	Installed but Non-Operational	Revised date not received	New 160MVA transformer-3 is not configured with bus bar
	220kV Harduaganj	Installed but Non-Operational	Revised date not received	
	220kV Lalitpur	Installed and Operational		commissioned on 09.02.2024
	220kV Mahoba	Installed but Non-Operational		Relay is faulty since 29.01.2024
	220kV Sarnath	Installed but Non-Operational	Revised date not received	
	220kV Sirathu, Kaushambi	Not Installed	Revised date not received	
	220kV substation Fatehpur	Installed and Operational		Operational
	220kV S/S Bhelupur	Not Installed		Radial feeder
	220kV Hardoi Road, Lucknow	Installed and Operational		commissioned on 08th October 2023
	220kV CG City, Lucknow	Installed but Non-Operational	31.05.2024	Agency M/s. Electro Power is decided.
	220kV Barabanki	Installed but Non-Operational	31.05.2024	Agency M/s. Electro Power is decided. 02 no. Peripheral unit found defective.
	220kV Kursi Road, Lucknow	Installed but Non-Operational	31.05.2024	Retrofitting work of auxilliary relay completed. Dut to non-functioning of new
	220kV BKT, Lucknow	Installed but Non-Operational	31.05.2024	LOI issued on Dt. 28.02.24
	220kV Gomti Nagar, Lucknow	Installed but Non-Operational	31.05.2024	Agency M/s. Electro Power is decided.
	400 KV Substation Sarnath	Installed and Operational		Now operational
	220kV S/S Raja Talab	Installed but Non-Operational	Revised date not received	Relay Defective, concern firm service engineer is awaited
	20kV S/S HaraHua	Installed but Non-Operational	Revised date not received	NOT COMMISSIONED
	220kV Rewa Road	Installed but Non-Operational	Revised date not received	Due to Isolator & CB status not Proper. Informed to Transmission wing but
	220kV S/S Sahupuri	Installed but Non-Operational	Revised date not received	Defective, Requirement for New panel has been raised, not received from
	220kV Robertganj	partilly operational	Revised date not received	Line and bus coupler and T/F-I under cover but T/F-II not cover
	220kV S/S Mirzapur	Not Installed	Revised date not received	Bubar Protection Panel has been Recived, construction of Transfer bus is on progress
HP	220kV Chamba	Installed and Operational		commissioned in Jan-2024
	220kV MattaSidh	Installed but Non-Operational		
	220kV kangoo	Installed but Non-Operational	31.12.2024	Work in under progress, issues are being taken up with ABB
	220kV Nangal	Installed but Non-Operational		
	220kV Katha Baddi	Installed but Non-Operational		
Punjab	220 KV S/S Kotlisurat Malhi	Not Installed		
	220 KV S/S Maur	Not Installed		
	220 KV S/S Science city	Not Installed	Dec-24	Commissioning is in process. Material has arrived, commissioning shall be done as per shutdown availability.
	220 KV S/S Banga	Not Installed		
	220 KV S/S Hoshiarpur	Not Installed		
	220 KV S/S Goraya	Not Installed		
	220 KV S/S Bhawanigarh	Not Installed		
	220 KV S/S Badhni kalan	Installed and Operational		Commissioned
	220 KV S/S Bhari	Installed and Operational		Commissioned
Rajasthan	765 KV GSS Phagi	Installed but non operational		CU of Alstom make Bus-Bar is defective. Purchas case will be taken up
	220 kv GSS Vatika	Not installed		As M/s ER did not finished the project, so it was awarded to M/s Kaycee infra on risk-cost basis , however the bus bar scheme has not been commissioned yet. Matter has been taken up with firm
	220 kv GSS Niwana	Not installed	Sep-24	Commissioning work started, to be commissioned shortly
	220 kv GSS Alwar	Not installed		Commissioning work started, to be commissioned shortly
	220 kv GSS Bansur	Not installed		Commissioning work started, to be commissioned shortly
	220 kv GSS Behror	Not installed		Commissioning work started, to be commissioned shortly
	220KV GSS Hindaun	Not installed		Commissioning work started, to be commissioned shortly
	220KV GSS Dooni	Installed and Operational		commissioned
	220KV GSS Bhawanimandi	Installed and Operational		commissioned
	220 KV GSS Sakatpura, Kota	Installed and Operational		commissioned on 09.07.2024
	400 KV GSS Ajmer (220 KV BUS)	Installed but non operational	Revised date not received	One number of PU is defective. Isolator status is OK.
	220 kv GSS, Beawar	Installed and Operational		commissioned
	220 KV GSS Jethana	Installed and Operational		commissioned
	220 KV GSS Kuchaman City	Installed but non operational	Revised date not received	CU is defective. Purchase has been taken up with the firm
	220 KV GSS Bherunda	Installed and Operational		commissioned
	220 KV GSS Kuchera	Installed and Operational		commissioned
	220 KV GSS Reengus	Installed and Operational		commissioned
	220 KV GSS Laxmangarh	Installed and Operational		Commissioned
	220KV GSS Khetri Nagar	Installed and Operational		commissioned
	400 KV GSS, Babai	Installed and Operational		commissioned
	220 KV GSS Chittorgarh	Installed and Operational		commissioned
	400 KV GSS BHILWARA(220 KV BUS)	Installed and Operational		commissioned
	220 KV GSS MANDALGARH	Installed and Operational		commissioned
	220KV GSS Debari	Installed and Operational		commissioned
	220KV GSS Amberi	Installed and Operational		commissioned
	220KV GSS Madri	Installed and Operational		commissioned
	400 KV GSS Surpura (Jodhpur) 220 KV	Installed but non operational	30.09.2024	Commissioning work started, to be commissioned shortly

400 KV GSS Akal (Jaisalmer) 220 KV	Installed but non operational	Revised date not received	One PU defective. Case has been taken up with firm
220 KV GSS Jodhpur	Installed but non operational	Revised date not received	A&FS and TS issued. Case has been send for approval
220 KV GSS NPH Jodhpur	Not installed	Revised date not received	Case file moved
220 KV GSS Badisid	Installed and Operational		commissioned
220 KV GSS Bhadla	Not installed	25.09.2024	Commissioning work started, to be commissioned shortly
220 KV GSS Pali	Installed and Operational		commissioned
220 KV GSS Ramgarh	Not installed	05.09.2024	Commissioning work started, to be commissioned shortly
220 KV GSS Balotra	Installed and Operational		commissioned
220 KV GSS Sayla	Installed and Operational		commissioned
400 KV GSS Bikaner 400 KV BUS	Installed but non operational	Revised date not received	to be done with transformer work
220 KV GSS Ratangarh	Installed and Operational		commissioned
220 KV GSS Sujangarh	Installed and Operational		commissioned
220 KV GSS Halasar	Installed and Operational		commissioned
220 KV GSS Tehandesar	Not installed	15.09.2024	Commissioning work started, to be commissioned shortly
220 KV GSS Rawatsar	Installed and Operational		commissioned

Status of protection relay type					
Constituent Name	Name of Station	Element Name	Present Status	Remark	
Uttarakhand	220kV Rishikesh	SIDCUL line	Main-II is not installed		
		Chamba line			
		Dharasu line-2			
HP	220kV Chamba	Rishikesh line			
	220kV MattaSidh	220kV transformer bank-1 & 2	Static relay		
Rajasthan	220 kV GSS Sanganer	220 KV HEERAPURA	Static		
	220 kV GSS Phulera	220 KV HEERAPURA 220 KV Makrana	Static	Replaced by numerical relay	
	220 KV GSS CHOMU	220 kV Heerapura 220 KV Reengus Line	Static		
	220 kV GSS Kukas	220 kV Manoharpur Line 220 kV Alwar Line	Static	Replaced by numerical relay	
	220kV GSS Dausa		220 kV SawailMadhopur Line	Static	
			220 kV Bassi-I Line	Static	
			220 kV Bassi-II Line	Static	
			220 kV Alwar Line	Static	
		220 kV Mandawar Line	Static		
	220KV BHARATPUR GSS	220 KV DHOLPUR	Static	Replaced by numerical relay	
	220 KV GSS SAKATPURA	220 kV ANTA(NTPC)	Static		
	220 KV DAHRA		220 kV BARAN	Static	
			220 kV SAKATPURA	Static	
	220KV GSS MODAK		220 kV RANPUR	Static	
			220 kV Jhalawar	Static	
	220 KV GSS JHALAWAR	220 kV Modak	Static		
	220KV GSS HINDAUN	220KV Sikrai Line	Static	relay defective	
	220KV GSS DHOLPUR	220 kV DCPD	Static		
	220 KV GSS Reengus	220 KV Laxmangarh	Static		
	220 KV GSS Nagour		220KV NOKHA	Static	
			220KV KUCHERA	Static	
	220KV GSS Kankroli	220 KV PGCIL-I	Static		
	220 KV GSS SIROHI	220 KV (400) KV PGCIL Bhinmal	Static		
	220 KV GSS SIROHI	220 KV Jalore	Static		
	220 KV GSS BHINMAL	220 KV (400) KV PGCIL Bhinmal-I	Static		
	220 KV GSS BALI	220kV Sirohi	Static	Replaced by numerical relay	
	220 KV GSS Suratgarh		220 KV STPS-I	Static	
			220 KV STPS-II	Static	
			220 KV Hanumangarh Line	Static	
	220 KV GSS Sri Ganganagar	220 KV Hanumangarh Line	Static	Replaced by numerical relay	
	220 KV GSS Hanumangarh	220 KV Suratgarh	Static		
	220KV GSS Ratangarh	220KV Rawatsar	Static		
	220KV GSS Ratangarh	220KV Halasar	Static		
220KV GSS Ratangarh	220KV InterConnector-I	Static			
220KV GSS Ratangarh	220KV InterConnector-II	Static			
220KV GSS Sujangarh	220KV Ratangarh	Static			
220 KV GSS Bikaner	220 KV Badnu Line	Static			
220 KV GSS Bikaner	220 KV Interconnector-I Line	Static			
220 KV GSS Bikaner	220 KV Spare Line	Static			
220kV Madanpur		220/66kV 100 MVA PTF T-1	Electromechanical	Working properly, need to be replace with numerical relay	
		220/66kV 100 MVA PTF T-1 A	Electromechanical	Working properly, need to be replace with numerical relay	
		220kV Bus-Coupler	Backup relay -Numerical all other relays are	Working properly, need to be replace with numerical relay	
		220/66kV 100 MVA PTF T-1 A	Electromechanical Execept Differential relay (Numerical)	Working properly, need to be replace with numerical relay	
	220 KV S/Stn Shahbad		100 MVA 220/66 KV T/F T-1	Electrostatic	Working properly, need to be replace with numerical relay
			220 KV Bus Coupler	Electrostatic	Working properly, need to be replace with numerical relay
			Incomer of 220/66 KV T/F T-1	Electrostatic	Working properly, need to be replace with numerical relay
			Incomer of 220/66 KV T/F T-2	Electrostatic	Working properly, need to be replace with numerical relay
	220 KV S/STnTepla	220KV Bus Coupler	Electromechanical	Working properly, need to be replace with numerical relay	
		220KV Jorian -DCRTPP Ckt-1	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay	
		220KV Jorian -DCRTPP Ckt-2	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay	
		220KV Jorian -Shahbad Ckt-1	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay	

Haryana

220KV S/Stn Jorian	220KV Jorian -Shahbad Ckt-2	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220KV Jorian -Abdullapur Ckt-1	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220KV Jorian -Abdullapur Ckt-2	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220/66, 160MVA T/F T-1	Defferntial Relay = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220/66, 100MVA T/F T-2	All Electromechanical	Working properly, need to be replace with numerical relay
	220/66, 100MVA T/F T-3	Defferntial & REF Relay = Numerical all other	Working properly, need to be replace with numerical relay
220 kv Salempur	220 KV BAKANA--SALEMPUR CKT-I	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV BAKANA--SALEMPUR CKT-II	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV SALEMPUR-NISSING CKT-I	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV SALEMPUR-NISSING CKT-II	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV BUS-COUPLER	All electromechanical type	Working properly, need to be replace with numerical relay
	220/66 kv 100MVA T/F T-1	All electromechanical type,except Differential relays	Working properly, need to be replace with numerical relay
	220/66 kv 100MVA T/F T-2	All electromechanical type,except Differential relays	Working properly, need to be replace with numerical relay
TS Division Karnal	220kv Nissing-PTPS Ckt-I	All electromechanical type,except DPR relays	
	100 MVA 220/132kv T-8	All electromechanical type,except Differential relay	Differential relay replcaed with Numerical type
	220 kv Bus-coupler	All electromechanical type	C&R panel will be replaced soon
	220 KV DCRTPP--UNISPUR CKT-I	All electromechanical type,except DPR relays	
	220 KV DCRTPP--UNISPUR CKT-II	All electromechanical type,except DPR relays	
	220 KV KARNAL--UNISPUR LINE	All electromechanical type,except DPR relays	
	220/132 KV 100 MVA T/F T-1	All electromechanical type,except R.E.F & Differential relay	
	220/132 KV 100 MVA T/F T-2	All electromechanical type,except R.E.F & Differential relay	
220kv S/Stn Palla	220/132 KV 160 MVA T/F T-4	All electromechanical type,except R.E.F & Differential relay	
	100MVA 220/66kv T-1	REF & backup Electromechanical	
	100MVA 220/66kv T-2	REF & backup Electromechanical	
	100MVA 220/66kv T-7	Diff & Backup lectromechanical and REF static	
	220kv Palla - Sector 78	backup Electromechanical	
220 kv S/Stn. Pali	220kv Palla - FGPP ckt-II	backup Electromechanical	
	100 MVA 220/66 kv T-1	REF & backup Electromechanical	
	100 MVA 220/66 kv T-3	REF & backup Electromechanical	
	220 kv Pali-BBMB Samaypur Ckt 1	backup Electromechanical	
	220 kv Pali-BBMB Samaypur Ckt 2	backup Electromechanical	
	220 kv Pali-Sector 46 Ckt 1	backup Electromechanical	
	220 kv Pali-Sector 46 Ckt 2	backup Electromechanical	
	220 kv Pali-Sector 65 Ckt 1	backup Electromechanical	
	220 kv Pali-Badshahpur Ckt 2	backup Electromechanical	
	220 kv Pali-Sector 56 Ckt 1	backup Electromechanical	
220kv S/Stn Palwal	220 kv Pali-Sector 56 Ckt 2	backup Electromechanical	
	220/66kv 160MVA T-1 T/F	REF & backup Electromechanical	
	220/66kv 100MVA T-2 T/F	Diff, REF & Backup Electromechanical	
	220kv Prithala Palwal Ckt I	backup Electromechanical	
220kv S/Stn. Sector 52A GGM	220kv Prithala Palwal Ckt II	backup Electromechanical	
	Sec 56-Sec 52A ckt 1	NUMERICAL RELAY qty 02 and electromechanical qty 01 (backup)	LINE IS PROVIDED WITH 2 MAIN NUMERICAL DPR AND 01 ELECTROMECHANICAL FOR BACKUP
	Sec 56-Sec 52A ckt 2	NUMERICAL RELAY qty 02 and electromechanical qty 01 (backup)	LINE IS PROVIDED WITH 2 MAIN NUMERICAL DPR AND 01 ELECTROMECHANICAL FOR BACKUP
	Sec 72-Sec 52A	NUMERICAL RELAY qty 02 and electromechanical qty 01 (backup)	LINE IS PROVIDED WITH 2 MAIN NUMERICAL DPR AND 01 ELECTROMECHANICAL FOR BACKUP
220kv S/Stn. Sonapat	Sec 57-Sec 52A	NUMERICAL RELAY qty 02 and electromechanical qty 01 (backup)	LINE IS PROVIDED WITH 2 MAIN NUMERICAL DPR AND 01 ELECTROMECHANICAL FOR BACKUP
		(Diff.-3 , REF-3, O/C/E/F-4 , Electromechanical Relays	The electromechanical differential and DPR are not available in the store. However, the same shall be replaced after availability in the store.
220kv Rohtak		(REF-2, O/C/E/F-12) Electromechanical Relays	

UP	400 KV S/S Moradabad	400 KV MORADABAD - RAMPUR LINE	LBB- ABB(RAICA) / STATIC	UNDER PGCIL
		400 KV MORADABAD - KASHIPUR LINE	LBB- English Electric(CTIG) / Electromechanical	
		400 KV, TRANSFER BUS	LBB- English Electric(CTIG) / Electromechanical	
		400 KV, BUS COUPLER	LBB- English Electric(CTIG) / Electromechanical	
	220KV S/S BARAUT	220/132kv 200MVA TRANSFORMER-1	REF Protection - Electromechanical	
	220KV S/S BAGHPAT	220/132kv 160MVA TRANSFORMER-1	Backup (L.V. Side) - Electromechanical	
	220 kv KHURJA	220/132kv 200MVA Transformer-I	REF-Static	
	220 kv DEBAI	220/132kv 100MVA Transformer-I	Numerical	
	220 kv Jahangirabad	220/132kv 160MVA Transformer-I	REF-Static	
	400KV S/S MURAD NAGAR	220KV LONI LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	Will be replaced by July24
		220KV FARID NAGAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV INTER CONNECTOR-I MURAD NAGAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV INTER CONNECTOR-II MURAD NAGAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV SAHIBABAD LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV PRATAP VIHAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV TBC	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		400KV TBC	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		400KV ALIGARH LINE	LBB RELAY IS ELECTROMECHANICAL.	
		400KV ATOUR LINE	LBB RELAY IS ELECTROMECHANICAL.	
	220KV S/S MURAD NAGAR	220KV BUS COUPLER	O/C RELAY IS ELECTROMECHANICAL.	
	400KV S/S Gorakhpur	400KV TBC	Electromechanical	
		220KV TBC	Electromechanical	
	220KV S/S Barahua	220KV PGCIL	Back up relay electromechanical	
	220KV S/S Basti	220 KV Basti Tanda line	67N(2TJM12)(Electromechanical)	
		63MVA Transformer-II	HV Side directional o/c&e/f(Electromechanical)	
	400 KV SS Kasara,Mau	200MVA, 400/132KV ICT-1st	REF & Over flux relay Electromechanical	
		200MVA, 400/132KV ICT-2nd	REF & Over flux relay Electromechanical	
	220 KV SS Substation Hafizpur Azamgarh	160 MVA ICT -1	Electromechanical(EE Make)	Replaced with Siemens make numerical relay on 16.10.2023
	220kv Khara		Electromechanical	process of replacing electrochemical relay with numerical relay has been started, it will be completed within 2 3 months.
	220kv Gokul	160MVA ICT-1	Electromechanical (Diff and O/C)	
	220kv Meetai	200MVA ICT-1	Electromechanical (E/F and O/C), Diff:Static	New panels are available at S/s and replacement work is under process
		200MVA ICT-2	Electromechanical (E/F and O/C), Diff:Static	
220kv Atrauli	160MVA ICT-1	Electromechanical + Numerical	Tender process is complete.	
	160MVA ICT-2	Electromechanical + Numerical		
220kv Mainpuri	160MVA ICT-1	Electromechanical(REF) + Numerical	New panels are available at S/s and replacement work is under process	
	160MVA ICT-2	Electromechanical(REF) + Numerical		
220kv Panki	220kv Bus coupler	Electromechanical	Under process	
400kv S/S Sultanpur	240 MVA ICT-II	Non Numerical		
220kv S/S Sultanpur	50 MVAR Obra Line Reactor	Non Numerical		
	220kv B/C	Non Numerical		
	160 MVA T/F-I	Non Numerical		
NPCIL	220kv RAPP	220KV Anta line	Backup relay: Static relay(RAPDK3)	Completed
	220kv NAPP	NAPP-SAMBHAL		Completed
		NAPP-SIBHOLI		Completed
		NAPP-DIBAI		Completed
		NAPP-KHURJA		Completed
		NAPP-ATRAULI		Completed

Status of protection relay type				
Constituent Name	Name of Station	Element Name	Present Status	Remark
Uttarakhand	220kV Rishikesh	SIDCUL line	Main-II is not installed	
		Chamba line		
		Dharasu line-2		
		Rishikesh line		
HP	220kV MattaSidh	220kV transformer bank-1 & 2	Static relay	
	220 kV GSS Sanganer	220 kV HEERAPURA	Static	
		220 kV Phulera	220 kV HEERAPURA	Static
	220 kV GSS CHOMU	220 kV Makrana	Static	
220 kV Heerapura		Static		
220 kV GSS Reengus Line	220 kV Reengus Line	Static		
	220 kV Kukas	220 kV Manoharpur Line	Static	Replaced by numerical relay
220kV GSS Dausa	220 kV Alwar Line	220 kV Alwar Line	Static	
		220 kV SawaiMadhopur Line	Static	
		220 kV Bassi-I Line	Static	
		220 kV Bassi-II Line	Static	
220 kV Alwar Line	220 kV Alwar Line	Static		
	220 kV Mandawar Line	Static		
220KV BHARATPUR GSS	220 KV DHOLPUR	Static	Replaced by numerical relay	
220 KV GSS SAKATPURA	220 kV ANTA(NTPC)	Static		
220 KV DAHRA	220 kV BARAN	Static		
	220 kV SAKATPURA	Static		
220KV GSS MODAK	220 kV RANPUR	Static		
	220 kV Jhalawar	Static		
220 KV GSS JHALAWAR	220 kV Modak	Static		
220KV GSS HINDAUN	220KV Sikrai Line	Static	relay defective	
220KV GSS DHOLPUR	220 kV DCCP	Static	Replaced by numerical relay	
220 KV GSS Reengus	220 KV Laxmangarh	Static		
220 KV GSS Nagour	220KV NOKHA	Static		
	220KV KUCHERA	Static		
220KV GSS Kankroli	220 KV PGCIL-I	Static		
220 KV GSS SIROHI	220 KV (400) KV PGCIL Bhinmal	Static		
220 KV GSS SIROHI	220 KV Jalore	Static		
220 KV GSS BHINMAL	220 KV (400) KV PGCIL Bhinmal-I	Static		
220 KV GSS BALI	220KV Sirohi	Static	Replaced by numerical relay	
220 KV GSS Suratgarh	220 KV STPS-I	Static		
	220 KV STPS-II	Static		
	220 KV Hanumangarh Line	Static		
220 KV GSS Sri Ganganagar	220 KV Hanumangarh Line	Static	Replaced by numerical relay	
220 KV GSS Hanumangarh	220 KV Suratgarh	Static		
220KV GSS Ratangarh	220KV Rawatsar	Static		
220KV GSS Ratangarh	220KV Halasar	Static		
220KV GSS Ratangarh	220KV InterConnector-I	Static		
220KV GSS Ratangarh	220KV InterConnector-II	Static		
220KV GSS Sujangarh	220KV Ratangarh	Static		
220 KV GSS Bikaner	220 KV Badnu Line	Static		
220 KV GSS Bikaner	220 KV Interconnector-I Line	Static		
220 KV GSS Bikaner	220 KV Spare Line	Static		
	220kV Madanpur	220/66kV 100 MVA PTF T-1	Electromechanical	Working properly, need to be replace with numerical relay
		220/66kV 100 MVA PTF T-1 A	Electromechanical Except Differential relay (Numerical)	Working properly, need to be replace with numerical relay
		220kV Bus-Coupler	All relays are Numerical	New 220 KV C&R panel replaced on dated 26.05.2022
		220/66kV 100 MVA PTF T-1 A	Electromechanical Except Differential relay (Numerical)	Working properly, need to be replace with numerical relay
	220 KV S/Stn Shahbad	100 MVA 220/66 KV T/F T-1	All relays are electromechanical and static	New C&R panel laying at S/Stn.for commissioning
		220 KV Bus Coupler	Electromechanical	Working properly, need to be replace with numerical relay
	220 KV S/StnTepla	220KV Bus Coupler	Electromechanical	Working properly, need to be replace with numerical relay
	220KV Jorian -DCRTPP Ckt-1	220KV Jorian -DCRTPP Ckt-1	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
		220KV Jorian -DCRTPP Ckt-2	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
		220KV Jorian -Shahbad Ckt-1	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay

Haryana

220KV S/Stn Jorian	220KV Jorian -Shahbad Ckt-2	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220KV Jorian -Abdullapur Ckt-1	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220KV Jorian -Abdullapur Ckt-2	Main-1 & Main-2 = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220/66, 160MVA T/F T-1	Defferntial Relay = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
	220/66, 100MVA T/F T-2	All Electromechanical	Working properly, need to be replace with numerical relay
	220/66, 100MVA T/F T-3	Defferntial & REF Relay = Numerical all other Electromechanical	Working properly, need to be replace with numerical relay
220 kv Salempur	220 KV BAKANA-SALEMPUR CKT-I	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV BAKANA-SALEMPUR CKT-II	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV SALEMPUR-NISSING CKT-I	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV SALEMPUR-NISSING CKT-II	All electromechanical type,except DPR relays	Working properly, need to be replace with numerical relay
	220 KV BUS-COUPLER	All electromechanical type	Working properly, need to be replace with numerical relay
	220/66 KV 100MVA T/F T-1	All electromechanical type,except Differential relays	Working properly, need to be replace with numerical relay
	220/66 KV 100MVA T/F T-2	All electromechanical type,except Differential relays	Working properly, need to be replace with numerical relay
TS Division Karnal	220kv Nissing-PTPS Ckt-I	Main-1 & Main-2 = Numerical, other (O/C+E/F) Electromechanical	Only Backup relays are electromechanical
	100 MVA 220/132KV T-8	R. E. F & Differential relays are Numerical, other (O/C+E/F) Electromechanical	Working properly, need to be replace with numerical relay
	220 kv Bus-coupler	Bus bar protection and panel relay are Numerical	all relay are Numerical type
	220 KV DCRTPP-UNISPUR CKT-I	Main-1 & Main-2 = Numerical, other (O/C+E/F) Electromechanical	Only Backup relays are electromechanical relays need to be replaced with numerical
	220 KV DCRTPP-UNISPUR CKT-II	Main-1 & Main-2 = Numerical, other (O/C+E/F) Electromechanical	Only Backup relays are electromechanical
	220 KV KARNAL-UNISPUR LINE	Main-1 & Main-2 = Numerical, other (O/C+E/F) Electromechanical	Only Backup relays are electromechanical
	220/132 KV 100 MVA T/F T-1	R. E. F & Differential relays are Numerical, other (O/C) Electromechanical	Working properly, need to be replace with numerical relay
	220/132 KV 100 MVA T/F T-2	R. E. F & Differential relays are Numerical, other (O/C) Electromechanical	Working properly, need to be replace with numerical relay
220kv S/Stn Palla	220/132 KV 160 MVA T/F T-4	R. E. F & Differential relays are Numerical, other (O/C) Electromechanical	Working properly, need to be replace with numerical relay
	100MVA 220/66kv T-1	differential numerical, REF & Backup electromechanical	Working properly, need to be replace with numerical relay
	100MVA 220/66kv T-2	differential numerical, REF & Backup electromechanical	Working properly, need to be replace with numerical relay
	100MVA 220/66kv T-7	differential & Backup electromechanical, REF static	Working properly, need to be replace with numerical relay
	220kv Palla - Sector 78	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
220 kv S/Stn. Pali	220kv Palla - FGPP ckt-II	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	100 MVA 220/66 kv T-1	differential numerical, REF & Backup electromechanical	Working properly, need to be replace with numerical relay
	100 MVA 220/66 kv T-3	differential numerical, REF & Backup electromechanical	Working properly, need to be replace with numerical relay
	220 kv Pali-BBMB Samaypur Ckt 1	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	220 kv Pali-BBMB Samaypur Ckt 2	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	220 kv Pali-Sector 46 Ckt 1	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	220 kv Pali-Sector 46 Ckt 2	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	220 kv Pali-Sector 65 Ckt 1	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	220 kv Pali-Badshahpur Ckt 2	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	220 kv Pali-Sector 56 Ckt 1	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
220kv S/Stn Palwal	220 kv Pali-Sector 56 Ckt 2	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	220/66kv 160MVA T-1 T/F	differential numerical, REF & Backup electromechanical	Working properly, need to be replace with numerical relay
	220/66kv 100MVA T-2 T/F	all electromechanical	Working properly, need to be replace with numerical relay
	220kv Prithala Palwal Ckt I	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
220kv S/Stn. Sector 52A GGM	220kv Prithala Palwal Ckt II	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	Sec 56-Sec 52A ckt 1	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	Sec 56-Sec 52A ckt 2	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	Sec 72-Sec 52A	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
	Sec 57-Sec 52A	DPR numerical, Backup electromechanical	Only Backup relays are electromechanical
220kv Sonipat	220KV Barhi-Sonepat Line	DPR numerical, Backup electromechanical	Working properly and the respective C&R panels are to be changed with new C&R panels having all numerical /digital relays. The estimate 220/132KV 100MVA T-4 T/F is sanctioned and others is under preparation to replace the same.
	220/132KV 100MVA T-3 T/F	Differential,REF and O/C ,E/F relays are Electromechanical	
	220/132KV 100MVA T-4 T/F	Differential,REF and O/C ,E/F relays are Electromechanical	
	220/132KV 100MVA T-5 T/F	Differential,REF and O/C ,E/F relays are Electromechanical	

220kV Rohtak	220 KV Rohtak - Kabulpur line	DPR numerical but E/F are conventional	The Numerical O/c has been replaced.
	220 KV Rohtak - Sampla line	DPR numerical but E/F are conventional	
	220 KV Rohtak - PTPS Ckt-1	DPR numerical but E/F are conventional	
	220 KV Rohtak - PTPS Ckt-2	DPR numerical but E/F are conventional	
	100 MVA, 220/132 KV T-3 T/F,	Differential relay numerical but O/C conventional.	The relay has been replaced with the numerical relay.
	100 MVA, 220/132 KV T-4 T/F,	Differential relay numerical but O/C and REF conventional.	
	100 MVA, 220/132 KV T-6 T/F,	Differential relay numerical but O/C and REF conventional.	
220kV Bus-Coupler	all relays are conventional	The Numerical O/c has been replaced.	
220kV Nuna Majra	220 Kv Nuna Majra-Sampla Ckt-1	DPR Numerical, Earth fault electromechanical	Working properly, need to be replace with numerical relay in Phased manner. The estimates is under sanction to replace the same.
	220 Kv Nuna Majra-Sampla Ckt-2	DPR Numerical, Earth fault electromechanical	
	220 Kv Nuna Majra-PGCIL Ckt-1	DPR Numerical, Earth fault electromechanical	
	220 Kv Nuna Majra-PGCIL Ckt-2	DPR Numerical, Earth fault electromechanical	
	220 Kv Nuna Majra-Sector-107	DPR Numerical, Earth fault electromechanical	
	220 Kv Nuna Majra-Daultabad	DPR Numerical, Earth fault electromechanical	
	100 MVA,220/132 KV T/F T-1	Differential and REF Numerical,Non directional Over Current Electromechanical	
	100 MVA,220/132 KV T/F T-2	Differential and REF Numerical,Non directional Over Current Electromechanical	
	100 MVA,220/132 KV T/F T-4	Differential and REF Numerical,Non directional Over Current Electromechanical	

UP	400 KV S/S Moradabad	400 KV MORADABAD - RAMPUR LINE	LBB- ABB(RAICA) / STATIC	UNDER PGCIL
		400 KV MORADABAD - KASHIPUR LINE	LBB- English Electric(CTIG) / Electromechanical	
		400 KV, TRANSFER BUS	LBB- English Electric(CTIG) / Electromechanical	
		400 KV, BUS COUPLER	LBB- English Electric(CTIG) / Electromechanical	
	220kv S/S BARAUT	220/132kv 200MVA TRANSFORMER-1	REF Protection - Electromechanical	
	220kv S/S BAGHPAT	220/132kv 160MVA TRANSORMER-1	Backup (L.V. Side) - Electromechanical	
	220 kv KHURJA	220/132kv 200MVA Transformer-I	REF-Static	
	220 kv DEBAI	220/132kv 100MVA Transformer-I	Numerical	Will be replaced by July24
	220 KV Jahangirabad	220/132Kv 160MVA Transformer-I	REF-Static	
	400KV S/S MURAD NAGAR	220KV LONI LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV FARID NAGAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV INTER CONNECTOR-I MURAD NAGAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV INTER CONNECTOR-II MURAD NAGAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV SAHIBABAD LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV PRATAP VIHAR LINE	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		220KV TBC	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		400KV TBC	O/C & E/F RELAY IS ELECTROMECHANICAL.	
		400KV ALGARH LINE	LBB RELAY IS ELECTROMECHANICAL.	
		400KV ATOUR LINE	LBB RELAY IS ELECTROMECHANICAL.	
	220KV S/S MURAD NAGAR	220KV BUS COUPLER	O/C RELAY IS ELECTROMECHANICAL	
	400KV S/S Gorakhpur	400KV TBC	Electromechanical	
		220KV TBC	Electromechanical	
	220KV S/S Barahua	220KV PGCIL	Back up relay electromechanical	
	220KV S/S Basti	220 KV Basti Tanda line	67N(2TJM12)(Electromechanical)	
		63MVA Transformer-II	HV Side directional o/c&e/f(Electromechanical)	
	400 KV SS Kasara,Mau	200MVA, 400/132KV ICT-1st	REF & Over flux relay Electromechanical	
		200MVA, 400/132KV ICT-2nd	REF & Over flux relay Electromechanical	
	220 KV SS Substation Hafizpur Azamgarh	160 MVA ICT -1	Electromechanical(EE Make)	Replaced with Siemens make numerical relay on 16.10.2023
	220kv Khara		Electromechanical	process of replacing electrochemical relay with numerical relay has been started, it will be completed within 2-3 months.
	220kv Gokul	160MVA ICT-1	Electromechanical (Diff and O/C)	
	220kv Meetai	200MVA ICT-1	Electromechanical (E/F and O/C), Diff:Static	New panels are available at S/s and replacement work is under process
		200MVA ICT-2	Electromechanical (E/F and O/C), Diff:Static	
	220kv Atrauli	160MVA ICT-1	Electromechanical + Numerical	Tender process is complete.
160MVA ICT-2		Electromechanical + Numerical		
220kv Mainpuri	160MVA ICT-1	Electromechanical(REF) + Numerical	New panels are available at S/s and replacement work is under process	
	160MVA ICT-2	Electromechanical(REF) + Numerical		
220kv Panki	220KV Bus coupler	Electromechanical	Under process	
400kv S/S Sultanpur	240 MVA ICT-II	Non Numerical		
	50 MVAR Obra Line Reactor	Non Numerical		
220kv S/S Sultanpur	220kv B/C	Non Numerical		
	160 MVA T/F-I	Non Numerical		
NPCIL	220kv RAPP	220KV Anta line	Backup relay: Static relay(RAPDK3)	Completed
		NAPP-SAMBHAL		Completed
	220kv NAPP	NAPP-SIBHOLI		Completed
		NAPP-DIBAI		Completed
		NAPP-KHURJA		Completed
		NAPP-ATRAULI		Completed

Details Of Protection Relay

S. No.	Name of Division	Name of Substation	Element Name	Voltage Level	Protection Relays type Static/Electromechanical	Status of Action being taken		
						Tenative date for replacement of relay	Any other remarks	
1	T&CD, Shahjahanpur	220KV S/S Shahjahanpur	220KV Gola line	220KV	Backup Relay Electromechanical	30.06.2024		
		220KV S/S Hardoi	220KV Shahjahanpur line	220KV	Backup Relay Electromechanical	31.07.2024		
2	T&CD, Gonda	132 KV Sub Station Balrampur	132 KV Balrampur-Utraula line	132 kV	Electromechanical	30.05.2024		
			132 KV Balrampur- Chini Mill line	132 kV	Electromechanical	30.05.2024		
		132 KV Sub Station Mankapur	132 kv MCM line	132 kV	Electromechanical	30.05.2024	Main Distance Protection is Numerical but Back Up relay is Electromechanical	
		132 KV Sub Station Mankapur	5 MVA Ist(33 KV)	33 kV	Electromechanical	30.05.2024		
5 MVA IInd(33 KV)	33 kV		Electromechanical	30.05.2024				
3	T&CD, Sarojini Nagar	400/220kV UNNAO	400 KV UNNAO MOHANLALGANJ LINE	400 KV	STATIC(ABB RXEG21)	31.09.2024		
			400 KV UNNAO BAREILLY 1 LINE	400 KV	STATIC(ABB RXEG21)	31.09.2024		
			400 KV UNNAO BAREILLY 2 LINE	400 KV	STATIC(ABB RXEG21)	31.09.2024		
			400KV UNNAO- PANKI LINE	400 KV	STATIC(ABB RXEG21)	31.09.2024		
			400 KV UNNAO AGRA LINE	400 KV	STATIC(ABB RXEG21)	31.09.2024		
			400/220 KV 315 MVA ICT -1	400/220kV	STATIC(ABB RADSBRATUB,RADHD), Electromechanical(TJM12)	31.09.2024		
			50MVAR LINE REACTOR ON 400KV AGRA BAREILLY-1	400 KV	STATIC(ABB RADHA,RAKZB,RADHD)	31.09.2024		
			63MVAR BUS REACTOR	400 KV	STATIC(ABB RADHA,RAKZB,RADHD)	31.09.2024		
		220/132kV UNNAO	220 KV UNNAO-BITHOOR LINE	220KV	STATIC(ABB RXPE+RXIG)	31.09.2024		
			220 KV UNNAO-RPH LINE	220KV	STATIC(ABB RXPE+RXIG)	31.09.2024		
			220 KV UNNAO-GIS KANPUR ROAD LINE	220KV	STATIC(ABB RXPE+RXIG)	31.09.2024		
			220/132 KV 160 MVA ICT -1	220/132kV	STATIC(ABB RADSBRATUB,RADHD), Electromechanical(TJM12)	31.09.2024		
		220kV Sarojini Nagar		132kV TRT-1	132kV	Electro-Mechanical (EASUN REYROLLE (TJM12))	31.09.2024	
				132kV TRT-2	132kV	Electro-Mechanical (EASUN REYROLLE (TJM12))	31.09.2024	
				132kV RAHMABAD	132kV	Electro-Mechanical (EASUN REYROLLE (2TJM12))	31.09.2024	
				132kV SGGPI-1	132kV	Electro-Mechanical (EASUN REYROLLE (2TJM12))	31.09.2024	
				132kV BIJNOUR	132kV	Electro-Mechanical (EASUN REYROLLE (2TJM12))	31.09.2024	
200MVA T/F-2	132kV	Electro-Mechanical (AREVA (CAG14AF12A))	31.09.2024					
4	T&CD, Sultanpur	400kV S/S Sultanpur	400/220kV, 240MVA ICT-II	400/220kV	Diff:- (English Electric- DTH32), O/C&E/F:- (English Electric type-CDD)	31.08.2024		
			50MVAR Obra line Reactor	400kV	Diff:- (English Electric type-CAG), Backup:- (English Electric type-YTG33)	30.09.2024		
		220kV S/S Sultanpur	220kV Bus Coupler	220kV	English Electric type-CDG	31.07.2024		
5	T&CD, Bareilly	400KV S/S Bareilly	220/132kV, 160MVA T/F-I	220/132kV	Diff:- (English Electric DMH3232DF1A5), O/C&E/F (HV):- (English Electric CDG 61EG8081BX), O/C&E/F (LV):- (English Electric CDG 31EG164A5), REF:- (English Electric CAG 14AF12A)	30.06.2024		
			315 MVA ICT-1	400/220KV	Diff/ REF/ Over flux/ LBB/ HV & LV Backup Relay Electromechanical	Requisition of relay sent		
			80 MVAR Bus Reactor	400 KV	Diff/ REF/ Backup Impedance Relay Electromechanical	Requisition of relay sent		
			220 KV CB GANJ Ckt-1	220 KV	DIR E/F & LBB RELAY STATIC	Requisition of relay sent		
		220 KV PANTNAGAR	220 KV	DIR E/F & LBB RELAY STATIC	Requisition of relay sent			
220 KV PILBHIT CKT-2	220 KV	DIR E/F & LBB RELAY STATIC	Requisition of relay sent					
220 KV S/S CB Ganj	200/132 KV 200 MVA T/F-II	220KV	Main Reyrolle Duo Bias M / Backup(ERL-Electro Mechanical)	Requisition of relay sent				
6	T&CD, Lucknow	220 KV CHINHAT	220/132 KV 200 MVA T/F-II ADITYA	220KV	ELECTROMECHANICAL (ESUN REYROLL, 2TJM12,2TJM12)REF.HV &LV BU			
		220 KV GOMTINAGAR	220/33 KV 60 MVA T/F -I	220KV	ELECTROMECHANICAL AREVA MAKE HV & LV REF			
			220/33 KV 60 MVA T/F -II	220KV	ELECTROMECHANICAL AREVA MAKE HV & LV REF			

Sr No	Element Name	Outage Date	Outage Time	Reason
1	220 KV Anta(NT)-Sakatpura(RS) (RS) Ckt-1	01-Aug-24	05:29	Phase to earth fault B-N. As per PMU and DR (Sakatpura), B-N fault occurred, no auto-reclosing is observed. DR not received from Anta end.
		09-Aug-24	22:37	Phase to earth fault B-N. As per PMU and DR (Sakatpura), B-N fault occurred, no auto-reclosing is observed. DR not received from Anta end.
		13-Aug-24	21:39	Phase to earth fault B-N. As per PMU and DR (Sakatpura), B-N fault occurred, no auto-reclosing is observed. DR not received from Anta end.
		14-Aug-24	08:33	Phase to earth fault B-N. As per PMU and DR (Sakatpura), B-N fault occurred, no auto-reclosing is observed. DR not received from Anta end.
2	220 KV DandhariKalan(PS)-Ludhiana(PG) (PSTCL) Ckt-2	01-Aug-24	01:37	Phase to Phase Fault R-B. As per PMU & DR, R-N fault occurred, no auto-reclosing is observed.
		06-Aug-24	14:23	Phase to earth fault B-N. As per PMU & DR, B-N fault occurred, no auto-reclosing is observed.
		26-Aug-24	21:52	Phase to earth fault R-N. As per PMU & DR, R-N fault occurred, no auto-reclosing is observed.
3	220 KV NAPP(NP)-Khurja(UP) (UP) Ckt-1	14-Aug-24	23:09	Phase to earth fault R-N. As per PMU and DR, R-N fault occurred with no A/R operation at Khurja end and successful A/R operation at NAPP end is observed. dat/cfg file of DR not received from NAPP end.
		17-Aug-24	10:16	Phase to earth fault R-N. As per PMU and DR, R-N fault occurred with no A/R operation at Khurja end and successful A/R operation at NAPP end is observed. dat/cfg file of DR not received from NAPP end.
		21-Aug-24	15:14	Phase to earth fault R-N. As per PMU, R-N fault occurred, no auto-reclosing is observed. As per DR (Khurja end), R-N fault is observed in zone-3. As reported, line tripped on zone-3 distance protection from Khurja end only due to fault on 220kV Khurja-Debari line.
		24-Aug-24	08:54	Phase to earth fault R-N. As per PMU and DR (NAPP end), B-N fault with no A/R operation is observed. DR of Khurja end not received.
		24-Aug-24	20:54	Phase to earth fault R-N. As per PMU and DR, B-N fault with no A/R operation is observed. As reported, tripping time was 22:42hrs.
		28-Aug-24	05:16	Phase to earth fault B-N. As per PMU, no fault is observed. As per DR of NAPP end, B-N fault is observed. DR not received from Khurja end. Dat/cfg file of DR not received from NAPP end.
4	220 KV Saharanpur(PG)-Shamli(UP) (UP) Ckt-1	01-Aug-24	03:37	Phase to earth fault R-N. As per PMU and DR (Saharanpur end), R-N fault with no A/R operation at Saharanpur end and successful A/R operation at Shamli end. DR of Shamli end not received.
		11-Aug-24	22:09	Phase to earth fault R-N. As per PMU and DR, R-N fault with no A/R operation at Saharanpur end and successful A/R operation at Shamli end.
		13-Aug-24	05:13	Phase to earth fault Y-N. As per PMU and DR, Y-N fault with no A/R operation at Saharanpur end and successful A/R operation at Shamli end.
		17-Aug-24	23:58	Earth fault. As per PMU and DR (Shamli end), B-N fault with no A/R operation at Saharanpur end and successful A/R operation at Shamli end. DR of Saharanpur end not received.
5	400 KV Agra-Unnao (UP) Ckt-1	03-Aug-24	01:53	Phase to earth fault Y-N. As per PMU, Y-N fault occurred, no auto-reclosing is observed.
		12-Aug-24	18:03	Phase to earth fault R-N. As per PMU and DR, R-N fault with unsuccessful A/R operation at Unnao end is observed.
		28-Aug-24	04:37	Phase to earth fault R-N. As per PMU and DR, R-N fault is observed with A/R operation started from both ends. Line successfully closed from agra end and finally line tripped from Unnao end.
		28-Aug-24	08:05	Over Voltage. DR not received from both ends.
6	400 KV Bhadla-Merta (RS) Ckt-1	02-Aug-24	07:31	Phase to Phase Fault R-Y. As per PMU, R-Y fault is observed. DR of Bhadla end is not readable. DR not received from Merta end.
		02-Aug-24	18:06	Phase to Phase Fault R-Y. As per PMU and DR (Merta end), R-Y fault is observed. DR of Bhadla end is not readable. Time sync issue in DR of Merta end.
		04-Aug-24	15:37	Phase to Phase Fault Y-B. As per PMU, R-Y fault is observed. As per DR (Merta), Y-B fault is observed. DR of Bhadla end is not readable. Time sync issue in DR of Merta end.
		13-Aug-24	15:48	Phase to Phase Fault Y-B. As per PMU, R-Y fault is observed. As per DR (Merta), Y-B fault is observed. DR of Bhadla end is not received.
		27-Aug-24	17:44	DT received & 86 relay operated at Merta end. As per PMU, no fault is observed only fluctuation in voltage is observed. DR of Bhadla end is not readable. DR of Merta end is not received.
7	400 KV Dadri(NT)-Panipat(BB) (PG) Ckt-1	02-Aug-24	05:25	Phase to earth fault B-N. As per PMU and DR, Y-N fault with no A/R operation at Dadri end and successful A/R operation at Panipat end. Dat/cfg file of DR of Dadri end not received.
		18-Aug-24	03:24	Earth fault. As per PMU and DR (Panipat end), Y-N fault with no A/R operation at Dadri end and successful A/R operation at Panipat end. DR of Dadri end not received.
		20-Aug-24	10:51	Phase to earth fault R-N. As per PMU, B-N fault and unsuccessful auto-reclosing observed. As per DR of Dadri end, R-N fault is observed. As per DR of Panipat end, B-N fault with unsuccessful A/R operation at Panipat end is observed. Dat/cfg file of DR of Dadri end not received.

Sr No	Incident/tripping	Outage Date	Outage Time	Reason	Remedial actions
1	Frequent tripping of 220 KV Khara(UP)-Saharanpur(UP) (UP) Ckt-1 during July24	06-Jul-24	12:15	Phase to earth fault B-N. As per PMU, fluctuation in voltage is observed, no fault in the system. DR not received from both ends.	Static/electromechanical relays at Khara(UP) will be replaced by numerical relay
		07-Jul-24	16:37	Phase to earth fault B-N. As per PMU and DR (of Saharanpur end), B-N fault with no A/R operation at Saharanpur end and successful A/R operation at Khara end is observed. DR not received from Khara end.	
		08-Jul-24	19:41	Phase to earth fault R-N. As per PMU and DR (of Saharanpur end), R-N fault with delayed fault clearance time of 560ms and no A/R operation at Saharanpur end is observed. DR not received from Khara end.	
		18-Jul-24	17:06	Phase to earth fault B-N. As per PMU and DR (of Saharanpur end), Y-N fault with no A/R operation at Saharanpur end and unsuccessful A/R operation at Khara end is observed. DR not received from Khara end.	
		28-Jul-24	11:02	Phase to earth fault R-N. As per PMU, R-N fault occurred, no auto-reclosing is observed. As per DR (of Saharanpur end), R-Y fault is observed. Time sync issue in DR of Saharanpur end and DR not received from Khara end.	
2	Frequent tripping of 400 KV Bikaner-Bhadla (RS) Ckt-1 during July24	04-Jul-24	14:18	Phase to earth fault Y-N. As per PMU, R-N fault occurred, no auto-reclosing is observed.	a) issue in BCU at Bikaner end due to which command is not reaching to breaker. b) dead time setting in A/R, it seems that it is kept as 600msec which need to be ~1sec
		05-Jul-24	16:12	Phase to earth fault B-N. As per PMU, B-N fault and unsuccessful auto-reclosing observed. Auto-reclosing time is 600msec.	
		11-Jul-24	22:27	Transient fault. As per PMU, no fault is observed. As per DR of Bikaner end, Y-N fault is observed and line tripped on DT received from the remote end before completion of auto-reclosing action.	
3	Multiple elements tripping event at Baghat(PG) & Baghat(UP)	1-Jul-24	21:37	<p>i)220KV Baghat(UP) has main and transfer bus scheme at 220KV level.</p> <p>ii)During antecedent condition, incoming power at Baghat(UP) was approx. 80 MW through 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-1 & 2. 220 KV Baghat(PG)-Baghat(UP) (UP) D/C, 220/132KV 160MVA ICT-1 and 220/132KV 100MVA ICT-2 were connected to 220KV main bus. 220 KV Baghat(PG)-Baghat(UP) (UP) D/C is on the same towers.</p> <p>iii)As per SCADA S/OE, 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-2 tripped at 21:37:59.415hrs and 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-1 tripped at 21:37:59.525 hrs.</p> <p>iv)As reported, at 21:37 hrs, 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-2 tripped on Y-B-N double phase to earth fault and line tripped on zone-1 distance protection operation from both ends. As per Baghat(UP) reporting, initially a B-ph fault occurred on 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-2 with fault current -10.39kA in zone-1. At the same time, jumper at tower no 45 of 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-2 got broken which created line-line (Y-B) fault due to which line got tripped from both ends.</p> <p>v)Further 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-1 also tripped on B-N phase to earth fault with fault current of ~9.7kA and fault distance of 11.8km from Baghat(PG) end. As per DR of Baghat(PG) end, B-N phase to earth fault with no A/R operation is observed and line tripped on zone-1 distance protection operation. Since there was no source remaining at 220KV Baghat(UP) hence 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-1 didn't trip from Baghat(UP) end.</p> <p>vi)As per PMU at Meerut(PG), Y-B phase to phase fault with fault clearance time of 80ms is observed.</p> <p>vii)Due to tripping of 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-1 & 2, Baghat(UP) lost its connectivity from the grid and 220KV Baghat(UP) S/s became dead.</p> <p>viii) As per SCADA, change in demand of approx. 68 MW in UP control area. However, SLDC-UP reported 80MW load loss.</p>	A/R operation observed in 220 KV Baghat(PG)-Baghat(UP) (UP) Ckt-1 tripped on B-N fault.
4	Multiple elements tripping event at Ziankote(J&K) & Amargarh(INDIGRID)	18-Jul-24	11:01	<p>i)220/132KV Ziankote S/s have two bus at 220KV side i.e., main bus & reserve bus. 220KV Amargarh-Ziankote ckt-1&2 are on the same tower (D/C tower) and line length is ~21.4km.</p> <p>ii)During antecedent condition, 220KV Amargarh(INDIGRID)-Ziankote(JK) D/C was carrying 109 MW each and feeding Ziankote load.</p>	Status of carrier communication and A/R scheme implementation at Ziankote end. Z-2 time delay setting at Amargarh end.
		26-Aug-24	13:53	<p>i)220/132KV Ziankote S/s have two bus at 220KV side i.e., main bus & reserve bus. 220KV Amargarh-Ziankote ckt-1&2 are on the same tower (D/C tower) and line length is ~21.4km.</p> <p>ii)During antecedent condition, 220KV Amargarh(INDIGRID)-Ziankote(JK) D/C was carrying 104 MW each and feeding Ziankote load.</p> <p>iii)As reported, at 13:53 hrs, 220 KV Amargarh(INDIGRID)-Ziankote(JK) (PDD JK) Ckt-2 tripped from both ends on R-Y phase to phase fault with fault distance of 6.6km and fault current of Ir=2.15kA & Iy=2.37kA from Ziankote(JK) end. 220 KV Amargarh(INDIGRID)-Ziankote(JK) (PDD JK) Ckt-1 tripped only from Amargarh(INDIGRID) end on the same R-Y phase to phase fault (Exact reason of fault is yet to be received).</p> <p>iv)As per DR of Amargarh(INDIGRID) end of 220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-1, R-Y phase to phase fault is observed in zone-2 with fault current of Ir=2.5kA & Iy=2.1kA.</p> <p>v)As per DR of Amargarh(INDIGRID) end of 220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-2, R-Y phase to phase fault is observed in zone-1 with fault current of Ir=5.2kA & Iy=4.9kA.</p> <p>vi)As confirmed by Amargarh(INDIGRID), in view of non-availability of carrier communication and A/R scheme at Ziankote end, A/R has been kept disabled at Amargarh end and time delay of Z-2 also kept as instantaneous at Amargarh end.</p> <p>vii)As per PMU at Amargarh(PG), R-Y phase to phase fault which cleared within 120 msec is observed.</p> <p>viii)As per SCADA, change in demand of approx. 180MW is observed in J&K control area.</p>	
5	Multiple elements tripping event at Patiala(PG)	19-Jul-24	18:50	<p>i)400/220KV Patiala(PG) has one and half bus scheme at 400KV level and double main & transfer bus scheme at 220KV level.</p> <p>ii)During antecedent condition, 400/220KV 315 MVA ICT-1 & 500 MVA ICT-3, 220KV Bahadurgarh-I, Nabha-I, Ablowal-I were connected at 220KV Bus-1 and 400/220KV 315 MVA ICT-2 & 500 MVA ICT-4, 220KV Bahadurgarh-II, Nabha-II, Ablowal-II were connected at 220KV Bus-2. 400/220KV ICT-1,2,3 & 4 were carrying approx. 156MW, 153MW, 243MW & 238 MW respectively. 220KV D/C to Nabha, Bahadurgarh & Ablowal were carrying approx. 171MW, 98MW & 127MW respectively per circuit.</p> <p>iii)As reported at 18:50 hrs, B-N phase to earth fault occurred on 220 KV Patiala(PG)-Nabha(PS) (PSTCL) Ckt-1. Fault location was ~7.3km from Nabha end. Distance protection at Patiala end sensed fault in Z-2 and initiated tripping command however, breaker at Patiala end failed to open. This further led to the operation of LBB protection of Nabha-I bay at Patiala(PG).</p> <p>iv)On the result of LBB protection operation, 400/220KV 315 MVA ICT-1, Ablowal-I, bus coupler tripped however, 400/220KV 500 MVA ICT-3 & 220KV Bahadurgarh-I didn't trip.</p> <p>v)Further, 400/220KV 500 MVA ICT-3 tripped on over current earth fault protection operation and 220KV Bahadurgarh-I tripped from Bahadurgarh end only.</p> <p>vi)Further, at the same time, Nabha-II, Ablowal-II also tripped due to overloading.</p> <p>vii)At 18:50:33 hrs, 220 KV Bahadurgarh(PS)-Patiala(PG) (PSTCL) Ckt-2 tripped on another B-N fault. As reported, fault occurred due to conductor snapping at distance ~1.5km from Bahadurgarh end.</p> <p>viii)As per PMU at Patiala(PG), B-N phase to earth fault at 18:50:15 hrs & 18:50:33 hrs with fault clearance time of 2400 msec at 18:50:15 hrs and 120 msec at 18:50:33 hrs is observed.</p> <p>ix)As per SCADA, change in demand of approx. 245MW is observed in Punjab control area.</p> <p>x)As reported by POWERGRID(INR-2), CB operating mechanism problem of 220KV Nabha-I line has been rectified and reason of non-tripping of 400/220KV 500 MVA ICT-3 & 220KV Bahadurgarh-I at Patiala(PG) on LBB operation is under investigation.</p>	Status of replacement of bus bar relay
6	Multiple elements tripping event at Mandaula(PG), Bawana(DTL) & Maharani Bagh(PG)	28-Jul-24	18:24	<p>i)400 KV Mandaula(PG)-Maharani Bagh(PG) (DTL) D/C and 400 KV Bawana(DTL)-Maharani Bagh(PG) (DTL) D/C are on same towers.</p> <p>ii)During antecedent condition, incoming power at Maharani Bagh(PG) through 400 KV Mandaula(PG)-Maharani Bagh(PG) (DTL) D/C and 400 KV Bawana(DTL)-Maharani Bagh(PG) (DTL) Ckt-1 was approx. 295 MW and 292 MW respectively (as per SCADA).</p> <p>iii)As reported, at 18:24 hrs, 400 KV Bawana(DTL)-Maharani Bagh(PG) (DTL) Ckt-1 and 400 KV Mandaula(PG)-Maharani Bagh(PG) (DTL) Ckt-2 tripped on Y-B phase to phase fault and at the same time 400 KV Mandaula(PG)-Maharani Bagh(PG) (DTL) Ckt-1 also tripped from Mandaula(PG) end (reason of tripping is yet to be received).</p> <p>iv)During patrolling of Ckts, it was found that Y-B phase to phase fault occurred on 400 KV Bawana(DTL)-Maharani Bagh(PG) (DTL) Ckt-1 and 400 KV Mandaula(PG)-Maharani Bagh(PG) (DTL) Ckt-2 due to kite thread.</p> <p>v)As per PMU at Maharani Bagh(PG), Y-B followed by Y-B phase to phase fault with fault clearing time of 120msec & 120msec is observed.</p> <p>vi)As per DR of Bawana(DTL) end of 400 KV Bawana(DTL)-Maharani Bagh(PG) (DTL) Ckt-1, Y-B phase to phase fault (Iy=9.8kA & Ib=10.3kA) sensed in zone-2 with carrier signal received is observed. Fault distance was 39.58km from Bawana(DTL) end (as reported).</p> <p>vii)As per SCADA, change in demand of approx. 95 MW in Delhi control area.</p>	Reason of tripping of 400 KV Mandaula(PG)-Maharani Bagh(PG) (DTL) Ckt-1
7	Multiple elements tripping event at Nara(UP)	11-Aug-24	18:25	<p>i)220KV Nara(UP) has main and transfer bus scheme at 220KV level.</p> <p>ii)During antecedent condition, loading at Nara(UP) S/s was approx. 80 MW. Loading of 220/132KV 160 MVA ICT-1 & 220/132KV 200 MVA ICT-2 at Nara(UP) S/s were approx. 35 MW and 45 MW respectively.</p> <p>iii)As reported, at 18:25 hrs, 220 KV Meerut(PG)-Nara(UP) (PG) Ckt tripped from Meerut(PG) end on B-N phase to earth fault with fault distance of 10.5 km (33.02%) from Meerut(PG) end with fault current of Ib=14.05kA.</p> <p>iv)On this fault, B-phase pole of CB of 220 KV Meerut(PG)-Nara(UP) (PG) Ckt at Nara(UP) end got stuck and could not open properly. On this, LBB of Meerut bay at Nara(UP) S/s operated which led to tripping of 220KV line from Nara(UP) to Roorkee(UK), 200/132KV 160 MVA ICT-1 and 200 MVA ICT-2 at Nara(UP) S/s.</p> <p>v)As reported, during inspection (at Nara(UP) S/s) it was found that tripping command was issued to both 220KV Muzaffarnagar and 220KV Jansath bay also but their breakers were not tripped (cable found broken) hence both these lines were tripped from other end in zone -3.</p> <p>vi)As per PMU at Muzaffarnagar(UP), B-N phase to earth fault with delayed fault clearance time of 1240msec is observed.</p> <p>vii)As per DR of Meerut end of 220 KV Meerut(PG)-Nara(UP) (PG) Ckt, B-N phase to earth fault with fault current of Ib=12.3kA with unsuccessful A/R operation is observed. Zone-1 distance protection operated from Meerut(PG) end.</p> <p>viii) Due to LBB operation at Nara(UP) S/s and tripping of 220 KV Nara-Jansath (UP) Ckt & 220 KV Nara-Muzaffarnagar (UP) Ckt from remote ends, Nara(UP) S/s lost its connectivity from Grid which led to blackout at 220KV Nara(UP) S/s.</p> <p>ix) As reported, no fault record found at Nara(UP) S/s. During inspection, it was found that DC main fuse of relay panel was blown off.</p> <p>x) As per SCADA, change in demand of approx. 70 MW & 40 MW in UP and Uttarakhand control area respectively. However, SLDC-UP has reported load loss of approx. 80 MW at Nara(UP) S/s.</p>	Status of work related to relay communication cables replacement of Muzaffarnagar & Jansath Ckt bay at Nara(UP) S/s.

8	Multiple elements tripping event at Vishnuprayag HPS	25-Aug-24	<p>04:25</p> <p>i) During antecedent condition, 400 kV Muzaffarnagar(UP)-Vishnuprayag(UP) (UP) Ckt, 110 MW Unit-1 & 4 at Vishnuprayag(UP) were connected to 400kV Bus-1 at Vishnuprayag(UP) and 400 kV Alaknanda(UP)-Vishnuprayag(UP) (UP) Ckt, 110 MW Unit-2 & 3 at Vishnuprayag(UP) were connected to 400kV Bus-2 at Vishnuprayag(UP). 400 kV Vishnuprayag (UP)- Muzaffarnagar(UP) (UP) Ckt, 400kV Alaknanda-Muzaffarnagar ckt and 400kV Vishnuprayag-Alaknanda ckt were carrying ~343 MW, ~462 MW & 86 MW respectively.</p> <p>ii) As reported, at 04:25 hrs, 400 kV Muzaffarnagar(UP)-Vishnuprayag(UP) (UP) Ckt tripped on Y-B phase to phase fault. Fault occurred due to tree falling on the line between tower location no. 102 & 103, tower base at location no. 102 also got damaged due to land slide. Fault distance was ~225km (~79%) from Muzaffarnagar end.</p> <p>iii) Further after ~50msec, 400kV bus coupler at Vishnuprayag HEP tripped on over current stage-2 (DT) protection operation.</p> <p>iv) With the tripping of 400kV Bus coupler at Vishnuprayag HEP, 110 MW Unit-1 & 4 at Vishnuprayag HEP also tripped due to loss evacuation path.</p> <p>v) As per PMU at Muzaffarnagar(UP) and line DR files, Y-B phase to phase which cleared within 80msec is observed. Fault was in Z-1 from Vishnuprayag end.</p> <p>vi) As per SCADA, generation loss of ~220MW occurred at 110 MW Unit-1 & 4 at Vishnuprayag HEP due to tripping of 110 MW Unit-1 & 4.</p> <p>vii) As tower base at location no. 102 of 400 kV Muzaffarnagar(UP)-Vishnuprayag(UP) (UP) Ckt damaged during the event, line was taken under emergency shutdown after the event. Unit-1&4 were revived by 06:00 hrs and taken into service through 400kV Bus-2. Generation evacuated through 400kV Vishnuprayag-Alaknanda ckt & 400kV Alaknanda-Muzaffarnagar ckt path.</p> <p>viii) 400 kV Muzaffarnagar(UP)-Vishnuprayag(UP) (UP) Ckt was revived at 17:33 hrs on 27.08.024. 400kV Bus-1 was also taken into service with the revival of 400 kV Muzaffarnagar(UP)-Vishnuprayag(UP) (UP) Ckt.</p>	Status of remedial action taken for issue of O/C protection applied on bus coupler at Vishnuprayag.
9	Multiple elements tripping event at Bawana(DV), Mundka (DV) & Maharani Bagh(PG)	31-Aug-24	<p>16:40</p> <p>i) 400kV Bawana(DTL) 5/s has one and half breaker bus arrangement at 400kV level.</p> <p>ii) During antecedent condition, incoming power at Bawana(DTL) through 400 KV Bawana-Mundka (DV) Ckt-1 & 2 were approx. 514MW & 503MW respectively and outgoing power from Bawana(DTL) to Maharani Bagh(PG) through 400 KV Bawana(DV)-Maharani Bagh(PG) (DTL) Ckt-1 & 2 were approx. 294 MW & 294 MW.</p> <p>iii) As reported, at 16:40 hrs, 400 KV Bawana(DV)-Maharani Bagh(PG) (DTL) Ckt-1 tripped on R-Y phase to phase fault with fault distance of 4.71km and with fault current of $I_r=31.38kA$ & $I_y=29.27kA$ from Bawana end (Reason of fault is yet to be received). 400 KV Bawana(DV)-Maharani Bagh(PG) (DTL) Ckt-1 tripped on zone-1 distance protection from Bawana(DTL) end.</p> <p>iv) As per DR of Bawana(DTL) end of 400 KV Bawana(DV)-Maharani Bagh(PG) (DTL) Ckt-1, R-Y phase to phase fault is observed with fault current of $I_r=31.3kA$, $I_y=29.3kA$ and line tripped on zone-1 distance protection.</p> <p>v) As reported, the same fault sensed in zone-1 from Mundka(DTL) end and 400 KV Bawana-Mundka (DV) Ckt-1 & 2 tripped on zone-1 distance protection from Mundka(DTL) end.</p> <p>vi) As per PMU at Maharani Bagh(PG), R-Y phase to phase fault with fault clearing time of 120msec is observed.</p> <p>vii) As per SCADA, change in demand of approx. 105MW is observed in Delhi control area.</p> <p>viii) As reported by SLDC Delhi, the case of over reach of GE D60 relays at Mundka(DTL) 5/s is already forwarded to GE company for analysis and necessary corrective recommendations.</p>	Status of remedial action taken for issue of over reaching of distance relays at Mundka(DTL) end.

Tripping events to be discussed in 52nd PSC Meeting

S.No.	Category of Grid Disturbance (GD-1 to GD-V)	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage		Event (As reported)	Loss of generation / loss of load during the Grid Disturbance		Fault Clearance time (in ms)
					Date	Time		Generation Loss(MW)	Load Loss (MW)	
1	GD-1	1)220 KV Chinhath-Satrikh Road (UP) Ckt 2)220 KV Chinhath-Gomtinagar (UP) Ckt 3)220 KV Chinhath-Kursi Road (UP) Ckt 4)220 KV Chinhath(UP)-Lucknow_1(PG) (UP) Ckt	Uttar Pradesh	PGCIL, UPPTCL	1-Jul-24	00:15	i)220kv Chinhath(UP) has main and transfer bus scheme at 220kv level. ii)During antecedent condition, incoming power at Chinhath(UP) was through 220kv Satrikh ckt (~100MW), Kursi Road ckt (~30MW) and Lucknow(PG) ckt (~80MW) and outgoing power was through 220kv Gomatinagar ckt (~90MW) and load at Chinhath(UP) S/s (~90MW). All 220kv lines and ICTs connected to 220kv main bus at Chinhath(UP) S/s. 220kv Chinhath-LMRS D/C is radial line from Chinhath(UP) S/s. iii)As reported, at 00:15 hrs, LA of 220 KV Chinhath-Satrikh Road (UP) Ckt bay burst at Chinhath(UP) S/s which caused R-N phase to earth fault. iv)On this fault 220kv lines from Chinhath(UP) to Satrikh Road (UP), Gomtinagar (UP), Kursi Road (UP) & Lucknow_1(PG) tripped (Reason of tripping and type of protection operated for all elements yet to receive). v)Due to these trippings at Chinhath(UP) S/s, 220kv Chinhath-LMRS D/C, 220/132kv ICT-1 & 2 became dead and blackout occurred at 220kv Chinhath(UP) S/s. vi)As per PMU at Lucknow(PG), R-N phase to earth fault with delayed fault clearance of 440msec is observed (reason for delayed fault clearance yet to receive). vii)As per SCADA, change in demand of approx. 195 MW in UP control area.	0	195	440
2	GI-1	1)220 KV Akal-Akal(Suzlon) (RS) Ckt-2 2)220 KV Akal-Akal(Suzlon) (RS) Ckt-1 3)220 KV Akal-Mulana (RS) Ckt	Rajasthan	RVPNL, Mulana, Suzlon	6-Jul-24	05:26	i)400/220kv Akal(RS) has one and half breaker scheme at 400kv level and double main and transfer bus scheme at 220kv level. ii)During antecedent condition, incoming power at Akal(RS) S/s through 220 KV Akal-Akal(Suzlon) (RS) D/C and 220 KV Akal-Mulana (RS) Ckt were approx. 235 MW and 125 MW respectively. iii)As reported, at 05:26 hrs, R-phase conductor of 220 KV Akal-Akal(Suzlon) (RS) ckt-2 broke at a distance of approx. 160m from Akal(RS) S/s which caused R-N phase to earth fault and subsequently 220 KV Akal-Akal(Suzlon) (RS) ckt-2 tripped on zone-1 distance protection from Akal(RS) end. iv)As per PMU at ASP51(IP), R-Y phase to phase fault followed by R-N phase to earth fault with fault clearance time of 80msec and 80msec respectively are observed. v)At the same time, 220 KV Akal-Akal(Suzlon) (RS) Ckt-1 and 220 KV Akal-Mulana (RS) Ckt also tripped from Akal(RS) end (Reason of tripping yet to be received). vi)During this event, dip in Rajasthan wind generation of approx. 1800 MW is observed out of which approx. 1150 MW recovered within 10 minutes. (As per SCADA). vii)As per SCADA, no change in demand is observed in Rajasthan control area. viii)As per SCADA, change in Rajasthan wind generation of approx. 168MW is observed.	650	0	80
3	GI-2	1)400 KV Azamgarh-Mau (UP) Ckt 2)400 KV Mau(UP)-Baliala(PG) (PG) Ckt 3)400/132 kv 200 MVA ICT 3 at Mau(UP)	Uttar Pradesh	PGCIL, UPPTCL	7-Jul-24	11:44	i)220kv Mau(UP) has double main and transfer bus scheme at 400kv level. ii)During antecedent condition, 400 KV Azamgarh-Mau (UP) Ckt, 400 KV Mau(UP)-Baliala(PG) (PG) Ckt & 400/132 kv 200 MVA ICT-3 connected to 400kv bus-1 and 400kv Mau-Rasra (UP) ckt, 400/132/33kv 200MVA ICT-1 & 2 connected to 400kv bus-2. 400 KV Anpara_B(UPUN)-Mau(UP) Ckt was not in service during the event. iii)As reported, at 11:44 hrs, B-phase CT of 400 KV Azamgarh-Mau (UP) Ckt burst which caused bus fault on 400kv bus-1 which led to bus bar protection operation on 400kv bus-1 at Mau(UP) S/s (Reason for delayed operation of bus bar protection yet to be received). iv)As per PMU at Azamgarh(UP), B-N phase to earth fault converted into Y-B phase to phase fault with delayed fault clearance time of 560ms is observed (Reason for delayed fault clearance is yet to receive). v)Due to bus bar protection operation, all elements connected to 400kv bus-1 (400kv Azamgarh(UP) ckt, Baliala(PG) ckt and 400/132 kv 200 MVA ICT-3) tripped at 400kv Mau(UP) S/s. vi)As per SCADA, change in demand of approx. 60 MW in UP control area.	0	60	560
4	GI-2	1)400 KV Varanasi(PG)-Sahapuri(UP) (PG) Ckt-1 2)400 KV Varanasi(PG)-Sahapuri(UP) (PG) Ckt-2 3)400 KV Sahapuri(UP)-Biharsharif(PG) (PG) Ckt-1 4)400 KV Sahapuri(UP)-Biharsharif(PG) (PG) Ckt-2 5)400/220 kv 500 MVA ICT 2 at Sahapuri(UP) 6)132 KV Sahapuri(UP)-Karamnasa(BS) (UP) Ckt-1	Uttar Pradesh	PGCIL, UPPTCL	10-Jul-24	15:54	i)400/220kv Sahapuri(UP) has double main double scheme at 400kv and 220kv level. ii)During antecedent condition at 15:52 hrs, 400 KV Varanasi(PG)-Sahapuri(UP) (PG) Ckt-2, 400 KV Sahapuri(UP)-Biharsharif(PG) (PG) Ckt-1 and 400/220 kv 500 MVA ICT-2 were connected to 400kv bus-1 and 400 KV Varanasi(PG)-Sahapuri(UP) (PG) Ckt-1 and 400 KV Sahapuri(UP)-Biharsharif(PG) (PG) Ckt-2 were connected to 400kv bus-2 at 400kv Sahapuri(UP) S/s. 400/220 kv 500 MVA ICT-1 at Sahapuri(UP) is under installation (commissioning) process. iii)As reported, at 15:54 hrs, Y-N phase to earth fault occurred in GIS compartment at 400kv Sahapuri(UP) (exact location of fault is yet to be received). It is suspected that fault location was in the bay of 400 KV Varanasi(PG)-Sahapuri(UP) (PG) Ckt-2 in GIS compartment at 400kv Sahapuri(UP). iv)On this fault, 400 KV Sahapuri(UP)-Biharsharif(PG) (PG) Ckt-1 & 2 (fault current I _{ph} =1.11kA from Sahapuri end) tripped only from Sahapuri(UP) end on zone-4 distance protection. 400 KV Varanasi(PG)-Sahapuri(UP) (PG) Ckt-1 & 2 (fault current I _{ph} =3.3kA from Varanasi end, I _{ph} =3.6kA from Sahapuri end) tripped only from Varanasi(PG) end on zone-2 distance protection and fault sensed in zone-4 from Sahapuri(UP) end. 400/220 kv 500 MVA ICT 2 at Sahapuri(UP) and also tripped (details of protection operation is yet to receive). v)As reported, from 15:27 hrs to 17:49 hrs, multiple 220 & 132kv line also tripped at 220kv Sahapuri S/s i.e. 220kv Sahapuri-Churk ckt, 220kv Sahapuri-Raja Talab ckt, 220kv Sahapuri(400kv)-Sahapuri(200kv) Interconnector, 132kv Sahapuri-Aliapur ckt, 132kv Sahapuri-Karamnasha ckt, 132kv Sahapuri-Chandaula ckt, 132kv Sahapuri-Sadat ckt and 132kv Sahapuri-Dhanapur ckt. Reason of tripping of these lines are yet to be received. vi)As per PMU at Varanasi(PG), at 15:54 hrs, Y-N phase to earth fault with delayed fault clearance time of 400msec is observed (Reason for delayed fault clearance is yet to receive). vii)As per SCADA, at 15:54 hrs, change in demand of approx. 100 MW in UP control area. viii)By 18:29 hrs, 400 KV Sahapuri(UP)-Biharsharif(PG) (PG) D/C and 400/220 kv 500 MVA ICT-2 were changed.	0	100	400
5	GI-2	1)400/220 kv 500 MVA ICT 1 at Lucknow(UP) 2)400/220 kv 500 MVA ICT 2 at Lucknow(UP) 3)220kv Lucknow-Hardoi Road (UP) ckt 4)220kv Lucknow-Unnao (UP) ckt 5)220/132 kv 200 MVA ICT 1 at Lucknow(UP) 6)220/132 kv 200 MVA ICT 2 at Lucknow(UP)	Uttar Pradesh	UPPTCL	14-Jul-24	15:53	i)220kv Lucknow(UP) has double main and transfer bus scheme at 220kv level. ii)During antecedent condition, 400/220kv 500 MVA ICT-1 & 2, 220/132kv 200 MVA ICT-1 & 2, 220kv Lucknow-Hardoi Road (UP) ckt & 220kv Lucknow-Unnao (UP) ckt were connected to 220kv bus-1 and 220kv lines from Lucknow(UP) to Bachrawan, Gomatinagar, Kanpur Road & 220/132kv 200MVA ICT-1 & 2 connected to 220kv bus-2 at 220kv Lucknow(UP) S/s. 220kv Lucknow-Kanpur Road (UP) ckt was not in service during the event. iii)As reported, at 15:53 hrs, R-N phase to earth fault occurred on 220kv bus-1 which led to tripping of all elements connected to 220kv bus-1 at 220kv Lucknow(UP). Bus bar protection failed to operate and 400/220 kv 500 MVA ICT-1 & 2 tripped on LBB protection (Type of protection operated in tripping of other elements is yet to receive). iv)As per PMU at Lucknow(PG), R-N phase to earth fault with delayed fault clearance time of 880ms is observed (Reason for delayed fault clearance is yet to receive). v)As per SCADA, change in demand of approx. 280 MW in UP control area. However, approx. 250 MW load loss in UP control area as per SLDC-UP.	0	250	880
6	GD-1	1) 220 KV Samaypur (BB)-Palli (HV) (HVPNL) Ckt-1 2) 220 KV Samaypur (BB)-Palli (HV) (HVPNL) Ckt-2 3) 220 KV Badshahpur (HV)-Palli (HV) (HVPNL) Ckt-1 4) 220 KV Badshahpur (HV)-Palli (HV) (HVPNL) Ckt-2 5) 220 KV Palli (HV) (Sec-46) -Palli (HV) (HVPNL) Ckt-1 6) 220 KV Palli (HV) (Sec-46) -Palli (HV) (HVPNL) Ckt-2 7) 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-1 8) 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-2	Haryana and Delhi	BBMB, HVPNL	16-Jul-24	22:10	i)During antecedent condition, 220 kv Palli S/s importing load from 220 KV Samaypur (BB)-Palli (HV) (HVPNL) Ckt-1 & Ckt-2, 220 KV Badshahpur (HV)-Palli (HV) (HVPNL) Ckt-1 & ckt-2 and 220 KV Sector-56 (Gurgaon) -Palli (HV) (HVPNL) Ckt-1 & Ckt-2 and feeding that load to 220 KV Palli (HV) (Sec-46) & 220 KV Palli (2*100MVA+1*160MVA) S/s. ii)As reported, to manage the line loading on sector-72 Gurgaon ckt, 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-1 was opened at 22:10 hrs on the instruction of SLDC-Haryana. This led to sparking on the 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-2 at Palli S/s end. iii)At the same time, busbar protection operated at 220kv Palli(HV) due to which all the elements connected to 220kv Bus-1 and 2 at Palli(HV) tripped and complete blackout occurred at Palli(HV) S/s. iv)As per PMU, R-Y phase to phase fault with delayed fault clearing time of 880 ms was observed. v)As per SCADA, change in demand of approx. 600 MW and 980 MW in Delhi and Haryana control area respectively were observed. However, as reported, approx. 400 MW load loss occurred at Palli & Sec-46 (Faridabad). Rest of the change in demand is suspected due to stalling of induction motor.	0	1580	880
7	GD-1	1) 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-1 2) 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-2 3) 220 KV Khodri(UK)-Sarsawan(UP) (UP) Ckt 4) 220 KV Khodri(UK)-Saharanpur(UP) (UP) Ckt 5) 220 KV Khodri-Chhibro (UK) Ckt-1 6) 220 KV Khodri-Chhibro (UK) Ckt-2 7) 30 MW Khodri Unit-1, 2, 3 & 4 8) 60 MW Chhibro Unit-1, 2, 3 & 4	Uttarakhand	PTCL, HPPTCL, UPPTCL	19-Jul-24	21:31	i)During antecedent condition, all the four 30MW units of Khodri and 60 MW units of Chhibro were running and total active power generation of Khodri and Chhibro was approx. 89 MW and 196 MW (as per SCADA). Total generation of Chhibro was evacuating through 220 KV Khodri-Chhibro (UK) Ckt-1 & 2. ii)As reported, at 21:31 hrs, while taking out 30MW Khodri Unit-2, B-phase pole of CB of Unit-2 did not open. This led to LBB protection operation which further resulted in tripping of all the elements connected to both the buses at 220kv Khodri(UK) and complete blackout occurred at 220kv Khodri(UK) S/s. iii)Due to tripping of 220 KV Khodri-Chhibro (UK) Ckt-1 & 2, 60 MW Chhibro Unit-1, 2, 3 & 4 also tripped due to loss of evacuation path and complete blackout occurred at 220kv Chhibro(UK) S/s. iv)As per PMU, no fault was observed in the system. v)As per SCADA, change in demand and generation of approx. 30 MW and 300 MW respectively in Uttarakhand control area were observed. vi)As remedial action taken, over hauling & testing of generator CB has been performed and found satisfactory.	300	30	NA

S.No.	Category of Grid Disturbance (GD-I to GD-V)	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage		Event (As reported)	Loss of generation / loss of load during the Grid Disturbance		Fault Clearance time (in ms)
					Date	Time		Generation Loss(MW)	Load Loss (MW)	
8	GI-1	1) 220kV Bhadla(RS)-Saurya Urja Ckt-2 2) 220 kV Bus sectionalizer-1 (Bay no. 09) 3) 220 kV Bus Coupler-1 (Bay no. 13) 4) 220kV Bhadla(RS)-RSDCL I Ckt-2	Rajasthan	RVPNL	30-Jul-24	11:38	i)400/220kV Bhadla(RS) has double main and transfer bus arrangement at 220kV side. ii)During antecedent condition, 220 kV Bhadla(RS)-Saurya Urja-2 and 220kV Bhadla(RS)-RSDCL I Ckt-2 were carrying approx. 242 MW & 128 MW respectively (reported data). iii)As reported, at 11:38hrs, B-ph jumper of 220kV Bhadla(RS)-Saurya Urja Ckt-2 snapped from Main Bus at Bhadla(RS) which led to tripping of 220kV Bhadla(RS)-Saurya Urja Ckt-2. iv)During the same time, 220 kV Bus sectionalizer-1 (Bay no. 09) and 220 kV Bus Coupler-1 (Bay no. 13) at Bhadla(RS) also tripped due to B-N phase to ground fault (As per PMU, Y-N fault; phase sequence issue is observed). v)Further as reported, 220kV Bhadla(RS)-RSDCL I Ckt-2 also tripped from RSDCL I end only due to LBB operation at the same time (exact reason of LBB operation yet to be shared). vi)As per PMU at Bhadla(PG), Y-N phase to ground fault is observed with delayed fault clearing time of 160 ms. vii) As per SCADA, change in solar generation of approx. 905MW is observed in Rajasthan control area. viii)As reported by SLDC Rajasthan, approx. 370 MW of solar generation loss occurred in Rajasthan control area and there is total approx. 730 MW reduction in solar generation by RE plants connected at Bhadla(RS).	370	0	160
9	GI-1	1)220/132kV 160MVA ICT-1 at Barn (JK) 2)220/132kV 160MVA ICT-2 at Barn (JK) 3)220/132kV 160MVA ICT-3 at Barn (JK) 4)132kV Barn-Canal (JK) Ckt-1 5)132kV Barn-Canal (JK) Ckt-2	Jammu and Kashmir	JK PDD	2-Aug-24	15:03	i)As reported, at 15:03hrs, 220/132kV 160MVA ICT-1, 132kV Barn-Canal (JK) D/C tripped at Barn(JK) S/s on Y-B phase to phase fault which occurred on 132kV Barn-Canal (JK) D/C (exact reason, location of fault and type of protection operated is yet to be received). ii)As reported, due to tripping of ICT-1, the complete load shifted on 220/132kV 160MVA ICT-2 & 3 which led to tripping of 220/132kV 160MVA ICT-2 & 3 on overloading at Barn(JK) S/s. iii)As per PMU at Kishenpur(PG), Y-B phase to phase fault with fault clearing time of 120ms is observed. iv)As per SCADA, load loss of approx. 345MW occurred in J&K control area.	0	345	120
10	GI-2	1)400/220 kv 315 MVA ICT 1 at Muzaffarnagar(UP) 2)400/220 kv 315 MVA ICT 2 at Muzaffarnagar(UP) 3)400/220 kv 315 MVA ICT 3 at Muzaffarnagar(UP) 4)400/220 kv 500 MVA ICT 4 at Muzaffarnagar(UP) 5)220kV Muzaffarnagar-Charla (UP) Ckt 6)220kV Muzaffarnagar-Jansath (UP) Ckt 7)220kV Muzaffarnagar-Shamli (UP) Ckt 8)220kV Muzaffarnagar-Khatauli (UP) Ckt	Uttar Pradesh	UPPTCL	21-Aug-24	09:02	i)During antecedent condition, 400/220kV 315 MVA ICT-1, 400/220kV 500 MVA ICT-4, 220kV Muzaffarnagar-Shamli (UP) Ckt, 220kV Muzaffarnagar-Khatauli (UP) Ckt, 220kV Muzaffarnagar-Badhni kalan (UP) Ckt & 220/132kV 160MVA ICT-4 were connected to 220kV bus-1 and 400/220 kv 315 MVA ICT-2, 400/220 kv 315 MVA ICT-3, 220kV Muzaffarnagar-Charla (UP) Ckt, 220kV Muzaffarnagar-Jansath (UP) Ckt & 220/132kV 160MVA ICT-5 were connected to 220kV bus-2 at Muzaffarnagar(UP) S/s. Bus coupler of 220kV bus-1 and 220kV bus-2 was in ON condition and 220kV Muzaffarnagar-Nara (UP) Ckt was not in service (under shutdown) during the tripping event. ii)As reported, at 09:02 hrs, R-N phase to earth fault occurred on 220kV Muzaffarnagar-Badhni kalan (UP) Ckt with fault distance of 3.8km from Muzaffarnagar(UP) end and 20.4km from Badhni kalan(UP) end. Fault was sensed in zone-1 from both ends. iii)On this fault 220kV Muzaffarnagar-Badhni kalan (UP) Ckt tripped from Badhni kalan end on zone-1 distance protection on R-N fault. During fault clearing process at Muzaffarnagar(UP) end, R-phase CB interrupting chamber got damaged which resulted into continuation of sparking between R phase male contact and R phase dropper wire of breaker. The circuit breaker operated mechanically (auxiliary contacts operated properly) and thus breaker status reflected as OPEN. iv)As breaker didn't open completely (sparking between R phase male contact and R phase dropper wire of breaker was still there), fault was not cleared yet. Due to continuous fault feeding 400/220kV 315MVA ICT-1 & 2 and 400/220kV 500 MVA ICT-4 tripped on directional earth fault protection and 400/220kV 315 MVA ICT-3 tripped on back up impedance protection. 220 kV Charla line, 220 kv Jansath line and 220 kv shamli line tripped from remote ends on zone-3 distance protection (It is confirmed from respective DRS also). v)Ideally, this fault would have been cleared by LBB protection of Badhni kalan bay, but as CB status changed from ON to OFF due to proper operation of breaker auxiliary contacts, LBB initiation got reset. vi)Further, as reported, bus bar protection of 220kV bus-1 at Muzaffarnagar(UP) also operated after 1 second of fault starting time due to persisting differential current. vii)As per DR of bus bar protection at Muzaffarnagar(UP), busbar protection operated on 220kV bus-1 after 1.05 second of fault starting time. On this, all remaining elements also tripped which were connected to 220kV bus-1 i.e. 220kV Muzaffarnagar-Khatauli (UP) Ckt, 220/132kV 160MVA ICT-4 and bus coupler of 220kV bus-1 and bus-2. viii) As per PMU at Meerut(PG), R-N phase to earth fault with delayed fault clearing time of 1080 msec is observed. ix)As per SCADA, load loss of approx. 290 MW in UP control area. However, SLDC-UP reported load loss of 127 MW in UP control area.	0	127	1080
11	GD-1	1)220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-1 2)220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-2 3)220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1 4)220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-2 5)220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-1 6)220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-2 7)220 KV Shahbad-Durla(HV)(HVPNL) Ckt-1 8)220 KV Shahbad-Durla(HV)(HVPNL) Ckt-2 9)220 KV Shahbad-Joria(HV)(HVPNL) Ckt-1 10)220 KV Shahbad-Joria(HV)(HVPNL) Ckt-2	Haryana	PGCIL, HVPNL	26-Aug-24	22:58	i)220kV Rajokheri(HV) & 220kV Shahbad(HV) S/s have double main bus arrangement at 220kV side. ii)During antecedent condition, incoming power at Rajokheri(HV) S/s through 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) D/C was approx. 115 MW and outgoing power from Rajokheri(HV) through 220 KV Shahbad-Rajokheri(HV)(HVPNL) D/C was approx. 90 MW. Loading of 220 KV Shahbad-Joria(HV)(HVPNL) D/C and 220 KV Shahbad-Durla(HV)(HVPNL) D/C were approx. 100 MW and 75 MW feeding to Shahbad(HV) and Durla(HV) respectively. iii)As reported, at 22:58 hrs, due to inclement weather conditions, Y-B phase to phase occurred on 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1 & 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-1. iv)As reported, 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) D/C tripped only from Abdullapur(PG) end not from Rajokheri(HV) end. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1 tripped on zone-1 distance protection on Y-B-G double phase to ground fault with fault distance of 29km and fault current of I _{ph} =5.79kA & I _{bn} =5.39kA from Rajokheri(HV) end. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-2 & 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-2 tripped on direction earth fault from Rajokheri(HV) end. 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-1 tripped on zone-3 distance protection on Y-B phase to phase fault from Rajokheri(HV) end (details regarding trippings at Shahbad(HV) S/s is yet to be received). v)As per PMU at Abdullapur(PG), Y-B phase to phase fault converted into R-Y-B three phase fault with delayed fault clearing time of 2040msec is observed. vi)Due to tripping of all 220kV lines at Rajokheri(HV) & Shahbad(HV), both sub-stations lost their connectivity from Grid which led to blackout of 220kV Rajokheri(HV) S/s & 220kV Shahbad(HV) S/s. vii)As per SCADA, change in demand of approx. 350 MW in Haryana control area.	0	350	2040

Utilities are requested to prepare detailed analysis report and present the event details during 52nd PSC meeting. Events involving more than one utility may be jointly prepared and presented.

**Multiple elements tripping at
400/220kV Akal(RS)
06th July 2024**


Brief of event:

- i. 400/220kV Akal(RS) has one and half breaker scheme at 400kV level and double main and transfer bus scheme at 220kV level.
- ii. During antecedent condition, incoming power at Akal(RS) S/s through 220 KV Akal-Akal(Suzlon) (RS) D/C and 220 KV Akal-Mulana (RS) Ckt were approx. 235 MW and 125 MW respectively.
- iii. As reported, at 05:26 hrs, R-phase conductor of 220 KV Akal-Akal(Suzlon) (RS) ckt-2 broke at a distance of approx. 160m from Akal(RS) S/s which caused R-N phase to earth fault and subsequently 220 KV Akal-Akal(Suzlon) (RS) ckt-2 tripped on zone-1 distance protection from Akal(RS) end.
- iv. As per PMU at ASP51(IP), R-Y phase to phase fault followed by R-N phase to earth fault with fault clearance time of 80msec and 80msec respectively are observed.
- v. At the same time, 220 KV Akal-Akal(Suzlon) (RS) Ckt-1 and 220 KV Akal-Mulana (RS) Ckt also tripped from Akal(RS) end (Reason of tripping yet to be received).
- vi. During this event, dip in Rajasthan wind generation of approx. 1800 MW is observed out of which approx. 1150 MW recovered within 10 minutes. (As per SCADA).
- vii. As per SCADA, no change in demand is observed in Rajasthan control area.
- viii. As per SCADA, change in Rajasthan wind generation of approx. 168MW is observed.


Elements tripped:

- i. 220 KV Akal-Akal(Suzlon) (RS) Ckt-2
- ii. 220 KV Akal-Akal(Suzlon) (RS) Ckt-1
- iii. 220 KV Akal-Mulana (RS) Ckt

Network Diagram



SLD of 400/220kV Akal(RS) before the event



SLD of 400/220kV Akal(RS) before the event

AKAL


400/220KV GSI AKAL RAJMER

Real Exp | Gen Run | Compare




Sat July 6 2024 05:24:00


SLD of 400/220kV Akal(RS) after the event



SLD of 400/220kV Akal(RS) after the event



Rajasthan Demand during the event




Jul 5 Fri 2024

Rajasthan Wind Generation during the event

Wind Generation of Rajasthan

Dip in wind generation of approx. 1800 MW is observed out of which approx. 1150 MW recovered within 10 minutes. (As per SCADA)



Jul 6 Sat 2024

PMU Plot of frequency at ASPS1(IP)

05:26 hrs/06-July-24



PMU Plot of phase voltage magnitude at ASPS1(IP)

05:26 hrs/06-July-24



Point of discussion

- i) Reason for tripping of 220 KV Akal-Akal(Suzlon) (RS) Ckt-1 and 220 KV Akal-Mulana (RS) Ckt need to be shared.
- ii) SCADA data was freeze during the event. Availability and healthiness of SCADA data need to be ensured.
- iii) DR/EL (.dat/.cfg file) of all tripped elements along with detailed tripping report and remedial action taken report need to be shared.
- iv) Trippings at Akal(RS) S/s are not recorded in SCADA SOE. Availability of SCADA SOE data needs to be ensured.

**Multiple elements tripping at
400/220kV Bhadla(RS)
30th July 2024**

Brief of event:

- i. 400/220kV Bhadla(RS) has double main and transfer bus arrangement at 220kV side.
- ii. During antecedent condition, 220 kV Bhadla(RS)-Saurya Urja-2 and 220kV Bhadla(RS)-RSDCL I Ckt-2 were carrying approx. 242 MW & 128 MW respectively (reported data).
- iii. As reported, at 11:38hrs, B-ph jumper of 220kV Bhadla(RS)-Saurya Urja Ckt-2 snapped from Main Bus at Bhadla(RS) which led to tripping of 220kV Bhadla(RS)-Saurya Urja Ckt-2.
- iv. During the same time, 220 kV Bus sectionalizer-I (Bay no. 09) and 220 kV Bus Coupler-I (Bay no. 13) at Bhadla(RS) also tripped due to B-N phase to ground fault (As per PMU, Y-N fault; phase sequence issue is observed).
- v. Further as reported, 220kV Bhadla(RS)-RSDCL I Ckt-2 also tripped from RSDCL I end only due to LBB operation at the same time (exact reason of LBB operation yet to be shared).
- vi. As per PMU at Bhadla(PG), Y-N phase to ground fault is observed with delayed fault clearing time of 160 ms.
- vii. As per SCADA, change in solar generation of approx. 905MW is observed in Rajasthan control area.
- viii. As reported by SLDC Rajasthan, approx. 370 MW of solar generation loss occurred in Rajasthan control area and there is total approx. 730 MW reduction in solar generation by RE plants connected at Bhadla(RS).

Elements tripped:

- i. 220kV Bhadla(RS)-Saurya Urja Ckt-2
- ii. 220 kV Bus sectionalizer-I (Bay no. 09)
- iii. 220 kV Bus Coupler-I (Bay no. 13)
- iv. 220kV Bhadla(RS)-RSDCL I Ckt-2

SLD of 400/220/132kV Bhadla(RS) before the event




Tue July 30 2024 11:36:00

SLD of 400/220/132kV Bhadla(RS) after the event




Rajasthan Solar Generation during the event

ICOMPANIES!RRVPNLIREPET_RSISOLARINET_SLR!P.MvMoment




Reduction in solar generation of approx. 905 MW in Rajasthan control area (as per SCADA)

MW generation of RE Plants connected at Bhadla(RS)




MVAR generation of RE Plants connected at Bhadla(RS)




PMU Plot of frequency at Bassi(PG)

11:38 hrs/30-July-24



PMU Plot of Phase Voltage Magnitude at Bhadla(PG)

11:38 hrs/30-July-24



— VBM	— VRM	— VYM
SubstationId: BHDLA_PG	SubstationId: BHDLA_PG	SubstationId: BHDLA_PG
DeviceId: 4008HDL2BHDLA1	DeviceId: 4008HDL2BHDLA1	DeviceId: 4008HDL2BHDLA1

Point of discussion

- i) Exact reason of LBB operation at RSDCL need to be shared.
- ii) Phase sequence issue need to be resolved at the earliest.
- iii) Tripping is not recorded in SCADA SOE. Availability of SCADA SOE data needs to be ensured.
- iv) DR/EL (.dat/.cfg file) along with tripping report need to be shared for each element from both the ends.
- v) Remedial action taken report to be shared.



220KV SUB –STATION CHINHAT LUCKNOW, UPPTCL

**01.07.2024, 00:15 HRS
TRIPPING OF 220 KV LINE KURSI ROAD,
220 KV LINE PGCIL LKO & 220 KV LINE GOMTINAGAR
DUE TO FAULT ON 220KV CHINHAT-SATRIKH ROAD
LINE**

AT 220 KV CHINHAT :TRIPPING OF 220 KV KURSI ROAD LINE,220 KV PGCIL LKO LINE & 220 KV GOMTI NAGAR LINE DUE TO FAULT ON 220 KV SATRIKH ROAD LINE ON DT. 01.07.2024, TIME - 00:15 HRS


- **Date & Time of event:** 01.07.2024 at 00:15 hrs
- **Sub-Station affected:** 220 KV CHINHAT ,LKO
- **Date & Time of restoration:**220 KV LINE KURSHI ROAD AT 00:28 HRS, 220KV LINE PGCIL LKO AT 03:55 HRS, 220 KV LINE GOMTINAGAR AT 04:11 HRS & 220 KV LINE SATRIKH ROAD LKO AT 05:12 HRS On SAME DAY.

Antecedents condition

- 220 KV SUBSTATION CHINHAT HAS SINGLE MAIN AND TRANSFER BUS SCHEME.
- DURING ANTECEDENT CONDITION, **INCOMING POWER** AT CHINHAT WAS THROUGH 220KV SATRIKH ROAD LINE(~100MW),220 KV KURSI ROADLINE(~30 MW) AND 220 KV PGCIL LKO(~80 MW) & **OUTGOING POWER** WAS THROUGH 220 KV GOMTINAGAR LINE(~30 MW) AND LOAD AT CHINHAT SUB STATION(~90 MW).
- ALL 220 KV LINES AND ICTS CONNECTED TO 220 KV MAIN BUS AT CHINHAT S/S.220 KV LMRC D/C IS RADIAL LINE FROM CHINHAT S/S.

SLD

220 KV BUS AT CHINHAT SUB-STATION



Report


ELECTRICITY TEST AND COMMISSIONING DIVISION LUCKNOW

FALUT ANALYSIS SATATEMENT OF PROTECTION GEARS FOR THE MONTH OF JULY 2024

Sl. No.	Closing Date/Time	Name of Sub station	CB No.with Direction (Code)	Type of Relay Scheme	Flags and Observation Observed	F/L,DIR, SIR,AIR, C/L	Analysis
4	01/07/2024 05:12 Hrs	220 kv Chinhat	CB No. 83, 220 kv Satrikh-chinhat	ABB(REL 650),GE(D6 0)	21M1-IL1=14.62KA,IL2=0.51KA,IL3=0.045KA,IN=14.12KA ,21M2-VT FUSE FAIL,FAULT TYPE AG,PSP	Dist-6.3KM	1. On dated 01.07.2024 at 00:15 hrs, Fault occurred at 220kv Chinhat Substation due to 220 Kv Chinhat-Satrikh line, R Phase LA was damaged at Chinhat end and its relay picked up with flags- 21M1- IL1= 14.62KA,IL2=0.51 KA,IL3=0.045KA,IN-14.12KA ,21M2-VT FUSE FAIL, FAULT TYPE AG, PSB. As per DR , fault didn't reflect in relay due to weak earthing(earthing at switch yard and neutral point of relay panel). Due to this secondary voltage increased and relay didn't issue tripping command at Chinhat end and CB didn't trip. At other end, 220kv Bus coupler tripped with delay time 120ms at Satrikh road end hence satrikh end CB didn't trip .
5	01/07/2024 00:28 Hrs		CB No. 84,220kv Kurshi road-chinhat	Siemens 7SA611,Siemens 7SJ8031	R phase,Z2,Dist=15.6 km IL1=4.39KA,IL2=0.30KA,IL3=0.58KA,86-1,86-2	Dist=15.6 km	220kv Chinhat- Kursi road line tripped from Kursi road end in zone 2 with fault current- 4.39KA, Distance 15.6 km.
6	01/07/2024 04:11 Hrs		CB NO. 82 220kv chinhat Gomtinagar	Siemens 7SA611,Siemens 7SJ8031	Gen Trip,E/F trip,86A,86B		1. 220kv Chinhat- Gomtinagar line tripped on E/F IA-3.68KA, IB-0.393KA, IC-1.19KA IN-3.34KA with delay time 432 ms (AS PER DR) at Chinhat End. Relay Settings checked whether it is Non-Directional but current setting is found directional Earth Fault with PS=0.2 and TMS =0.2, its operation and star point re-checked. During testing of B/U relay through injection kit, it is also working in directional mode.Hence, it indicates that the back-up relay mal-operated during the fault, it should not have operated for reverse current but it operated .The setting and event record file has been shared
7	01/07/2024 03:55 Hrs		CB NO. 81,220kv PGCIL Lko-chinhat	ABB(REL 650),GE(D6 0)	Gen Trip,IL1=4.2KA,IL2=0.533KA ,IL3=1.07KA,IN=2.68KA,86-1,86-2,Z4 Pick up,Fault type AG other end flag :21M1-R phase F/I 4.68 KA,F/C=28.1km 21M2-Z2,F/L=27.96km,F/C 4.3KA	Dist= -2.1km	1. 220 kv Chinhat-PG Line tripped from PG end in zone 2 with fault curent-4.3KA, Dist.-27.96KM.At 00:15 hrs flags at Chinhat End, IL1- 4.2KA, I L20.533KA IL3-1.07KA, In 2.68KA, Z4 PU distt :- -2.1 KM,CB at chinhat end did not trip as CB of PG end tripped in Zone -2, after 850 ms of the occurrence of the fault as per DR- due to fault at PG end B Phase breaker pole got stuck (Also reported by operation wing) at PG end there appeared fault current in B phase. Fault gradually increased till 1900 ms then relay operated at earth-fault protection and the said fault was finally isolated from UPPTCL end.

220 KV LINE SATRIKH ROAD

DR1.DAT - 01/07/2024 - 00:08:12.703 - Primary - (Peak Type)




CH	Title	RMS	IntPeak	Phase	IntVal	RefVal	MaxPeak	MinPeak	Units
1	LINE_IL1	14903.077	25239.099	103.437°	3410.918	11450.273	25239.099	-21043.391	A 96
2	LINE_IL2	497.653	-802.754	266.388°	-100.258	-60.561	703.412	-802.754	A 96
3	LINE_IL3	126.950	-191.444	361.401°	-87.430	-110.119	372.331	-369.877	A 96
4	LINE_IN	14072.446	24283.493	103.388°	-3586.762	11279.481	24283.493	-21041.539	A 96
5	BUS_UL1	159531.705	278658.235	135.149°	-116618.561	226323.179	278658.235	-361683.784	V 2
6	BUS_UL2	236634.314	348418.160	95.108°	-17291.367	110382.678	366757.811	-366145.851	V 2
7	BUS_UL3	59735.756	100430.274	213.038°	-9306.668	94467.582	182426.897	-182421.330	V 2
8	BUS_IN	389897.705	651067.688	113.117°	-143851.612	431163.413	678074.630	-667037.468	V 2




A	DRPRDR NEMUSD	A	A			000
N	START_Z1	N	N	00:08:12.767949	00:08:13.107949	002
A	START_Z3	N	N	00:08:12.712949	00:08:13.227949	002
A	PHS-STFWL1	N	N	00:08:12.707949	00:08:14.602949	020
A	PHS-STFWPE	N	N	00:08:12.707949	00:08:14.602949	020
A	PLC SW D1 IN	A	A			000
A	MT AR SW IN	A	A			000
A	PLC SW D2 IN	A	A			000
A	FDPSPDIS_STAR	N	N	00:08:12.697949	00:08:14.602949	004
N	TEF-START	N	N	00:08:12.729949	00:08:14.602949	006
A	TEF-STRV	N	N	00:08:12.709949	00:08:14.625949	006
A	AR BLOCK	N	N	00:08:12.709949	00:08:14.606949	008

Sample: 511
Page Duration: 450 (file/s)


DR of PG line at Chinhat End. Snap-1




DR of PG line when current increase at Chinhat End. Snap-2



DR PG line after current reaches to zero at Chinhat End. Snap-3



dr.dat - 01/07/2024 - 00:15:10.464 - Primary - (Peak Type)




220 KV GOMTINAGAR LINE

File Data Channel View Values Window Help

Ext System Back Files

09/18/2024 02:52:04 PM

Data



Events Description

- On dated 01.07.2024 at **00:15 hrs** at **220 kv CHINHAT Substation**, R Ph LA was damaged at chinhat end of 220 Kv Chinhat-Satrikh line. During fault, CB didn't open from Chinhat end and 220kv Bus coupler tripped at other (Satrikh road) end.
- At same time 220kv Chinhat-PG Line tripped from both end, 220kv Chinhat- kursi Road line tripped from kursi Road end only and 220kv Chinhat-Gomtinagar line tripped from Chinhat end only.
- 220kv Chinhat- LMRC 1st & 2nd line didn't trip as it operates in radial mode at LMRC end.

Analysis Report :-

- On dated 01.07.2024 at 00:15 hrs, Fault occurred at 220kv Chinhat Substation on 220 Kv Chinhat-Satrikh line, R Phase LA was damaged at Chinhat end and its relay picked up with flags- 21M1- IL1= 14.62KA,IL2=0.51 KA,IL3=0.045KA,IN- 14.12KA ,21M2-VT FUSE FAIL, FAULT TYPE AG, PSB. As per DR , fault didn't reflect in relay due to weak earthing (earthing at switch yard and neutral point of relay panel). Due to this secondary voltage increased and relay didn't issue tripping command at Chinhat end and CB didn't trip. At other end, 220kv Bus coupler tripped with delay time 120ms at Satrikh road end hence satrikh end CB didn't trip .
- 220 kv Chinhat-PG Line tripped from PG end in zone 2 with fault current-4.3KA, Dist.-27.96KM. At 00:15 hrs flags at Chinhat End, IL1- 4.2KA, I L2-0.533KA, IL3- 1.07KA, In- 2.68KA, Z4 PU, dist :- -2.1 KM, CB at Chinhat end did not trip as CB of PG end tripped in Zone -2, After 850 ms of the occurrence of the fault as per DR. Due to fault at PG end B Phase breaker pole got stuck (Also reported by operation wing) at PG end there appeared fault current in B phase. Fault gradually increased till 1900 ms then relay operated at earth-fault protection and the said fault was finally isolated from UPPTCL end.

- 220kv Chinhat- Kursi road line tripped from Kursi road end in zone 2 with fault current- 4.39KA, Distance 15.60 KM.
- 220kv Chinhat- Gomtinagar line tripped on E/F IA-3.68KA, IB-0.393KA, IC-1.19KA IN-3.34KA with delay time 432 ms (AS PER DR) at Chinhat End. (Relay Settings checked whether it is Non-Directional but current setting is found directional Earth Fault with PS=0.2 and TMS =0.2, its operation and star point re-checked. During testing of B/U relay through injection kit, it is also working in directional mode.) Hence, it indicates that the back-up relay mal-operated during the fault, it should not have operated for reverse current but it operated .

Remedial Measures Taken.

- On dated 01.07.2024, 220 kV Chinhat-Satrikh line protection testing was performed at 220 kV Chinhat Substation and it was found that distance protection relay tripped on given fault with 86 relay and CB were operating properly. Earthing was done in field junction box but as per approved drawing there was earthing in panel also. Due to double earthing the above mentioned problem occurred. During shutdown, problem pertaining to neutral earthing has been rectified at 220kv Satrikh line relay panel.

THANK YOU.

**Multiple elements tripping at
400/132kV Mau(UP)
07th July 2024**


Brief of event:

- i. 220kV Mau(UP) has double main and transfer bus scheme at 400kV level.
- ii. During antecedent condition, 400 KV Azamgarh-Mau (UP) Ckt, 400 KV Mau(UP)-Balialia(PG) (PG) Ckt & 400/132 kV 200 MVA ICT-3 connected to 400kV bus-1 and 400kV Mau-Rasra (UP) ckt, 400/132/33kV 200MVA ICT-1 & 2 connected to 400kV bus-2. 400 KV Anpara_B(UPUN)-Mau(UP) (UP) Ckt was not in service during the event.
- iii. As reported, at 11:44 hrs, B-phase CT of 400 KV Azamgarh-Mau (UP) Ckt burst which caused bus fault on 400kV bus-1 which led to bus bar protection operation on 400kV bus-1 at Mau(UP) S/s (Reason for delayed operation of bus bar protection yet to be received).
- iv. As per PMU at Azamgarh(UP), B-N phase to earth fault converted into Y-B phase to phase fault with delayed fault clearance time of 560ms is observed (Reason for delayed fault clearance is yet to receive).
- v. Due to bus bar protection operation, all elements connected to 400kV bus-1 (400kV Azamgarh(UP) ckt, Balialia(PG) ckt and 400/132 kV 200 MVA ICT-3) tripped at 400kV Mau(UP) S/s.
- vi. As per SCADA, change in demand of approx. 60 MW in UP control area.


Elements tripped:

- i. 400 KV Azamgarh-Mau (UP) Ckt
- ii. 400 KV Mau(UP)-Balialia(PG) (PG) Ckt
- iii. 400/132 kV 200 MVA ICT 3 at Mau(UP)


Network Diagram




SLD of 400KV Mau(UP) before the event



SLD of 400KV Mau(UP) after the event



Uttar Pradesh Demand during the event



PMU Plot of frequency at Azamgarh(UP)

11:44 hrs/07-July-24



PMU Plot of phase voltage magnitude at Azamgarh(UP)

11:44 hrs/07-July-24



SCADA SOE

Time	Station Name	Voltage	Element Name	Element Type	Element Status	Remarks
11:44:30,568	MAU__UP	400kV	03TBC	Circuit Breaker	Open	Transfer bus coupler at Mau(UP) end of 400kVbus-1,2 &transfer bus opened
11:44:30,571	MAU__UP	400kV	06AZAMI	Circuit Breaker	Open	Line CBat Mau(UP) end of 400 kVMau-Azamgarh (UP) Ckt opened
11:44:30,571	MAU__UP	400kV	02T3	Circuit Breaker	Open	CBat Mau(UP) end of 400/132/33kV200MVAICT-3 opened
11:44:30,575	MAU__UP	400kV	08BALIAI	Circuit Breaker	Open	Line CBat Mau(UP) end of 400 KVMau(UP)-Balial(PG) (PG) Ckt opened
11:44:30,584	RASDA_UP	400kV	01MAU	Circuit Breaker	disturbe	
11:44:31,190	MAU__UP	400kV	06AZAMI	Circuit Breaker	Close	Line CBat Mau(UP) end of 400 kVMau-Azamgarh (UP) Ckt closed
11:44:31,239	MAU__UP	400kV	06AZAMI	Circuit Breaker	Open	Line CBat Mau(UP) end of 400 kVMau-Azamgarh (UP) Ckt opened
11:45:02,341	AZAMI_UP	400kV	10MAU	Circuit Breaker	Open	Tie CBat Azamgarh(UP) end of 400 kVMau-Azamgarh (UP) Ckt opened
11:45:06,123	AZAMI_UP	400kV	9MAU	Circuit Breaker	Open	Tie CBat Azamgarh(UP) end of 400 kVMau-Azamgarh (UP) Ckt opened

Point of discussion

- i) Nature of fault and reason for delayed fault clearance need to be shared.
- ii) Reason for delayed operation of bus bar protection and protection settings at Mau(UP) S/s need to be shared.
- iii) DR/EL (.dat/.cfg file) of all the tripped elements along with detailed tripping report need to be shared.
- iv) Remedial action taken report to be shared.



400 KV Sub-Station MAU, UPPTCL

07.07.2024, 11:44 Hrs

**TRIPPING OF BUS BAR AND ELEMENTS CONNECTED ON
BUS 1 (200 MVA ICT-3 & 400 KV MAU – BALLIA
(PGCIL)LINE DUE TO THE FAULT ON 400 KV MAU –
AZAMGARH LINE**

400 KV MAU :TRIPPING OF BUS BAR AND ELEMENTS
CONNECTED ON BUS-1 (200 MVA ICT-3,400 KV MAU-
BALLIA PGCIL LINE) DUE TO FAULT ON 400 KV MAU –
AZAMGARH LINE DATED-07.07.2024

- **Date & Time of event:** 07.07.2024 at 11:44 hrs
- **Sub-Station affected:** 400 KV Substation MAU
- **Date & Time of restoration:** 400 KV MAU-BALLIA PGCIL LINE, 200 MVA ICT-3 AT 14:01Hrs &14:02 Hrs RESPECTIVELY ON 07.07.2024. AND 400 KV MAU – AZAMGARH LINE AT 17:29 Hrs ON 09.07.2024.

Antecedents condition

- IN ANTECEDENTS CONDITION 400 /132KV 200 MVA ICT-3 & 400 KV MAU-AZAMGARH LINE , 400 KV MAU – BALLIA (PGCIL) LINE WERE CARRYING 66 MW,275MW & 509MW RESPECTIVELY.
- IN ANTECEDENTS CONDITION ELEMENTS CONNECTED ON BUS -2 : 400 /132KV 200 MVA ICT-1, ICT-2 & 400 KV MAU-RASRA LINE WERE CARRYING 63 MW,61MW & 47 MW RESPECTIVELY. 400 KV MAU-ANPARA LINE WAS IN SHUTDOWN.

Report 400 KV SS MAU

DETAILED ANALYSIS REPORT	
INTRODUCTION	
TIME AND DATE OF EVENT	11:44, 07.07.2024
SUBSTATION AFFECTED ALONG WITH VOLTAGE LEVEL	400kV S/S Mau
BRIEF SUMMARY	Brief Analysis: <ol style="list-style-type: none">1. B-phase CT of 400KV Mau- Azamgarh line got damaged.2. Busbar differential protection optd.3. B pole of CB lagged in opening causes LBB prot operation.
ANTECEDENT CONDITIONS	
WEATHER INFORMATION	Rainy
ADDITIONAL RELEVANT INFORMATION VIZ POWER FLOW AND SHUTDOWN	During antecedent condition 200 MVA ICT-3 and 400 kV lines to Azamgarh, Ballia (PGCIL), were carrying 66MW, 275MW.-509MW respectively.
EVENT DATA	
CHANGE IN FREQUENCY	
GENERATION LOSS	NIL
LOAD LOSS	60 MW (as per SCADA data)
ENERGY LOSS IN MU	
SINGLE LINE DIAGRAM(Detailing Bus arrangement and Tripped elements)	Attached
DR / EL	Attached

NAME AND TIME OF THE TRIPPED ELEMENT IN TIME CHRONOLOGY ALONG WITH RESTORATION TIME AND FLAG				
NAME OF ELEMENT	RESTORATION DATE	RESTORATION TIME	FLAGS END 1	FLAGS END 2
400kV Mau-Azamgarh line	09.07.2024	17:29	Control panel flag- Dist trip,carrier send, CB pole discrepancy, DT receive, GR B dc fail. M-1(REL670)- ZONE-1, B-PHASE, IL3=2.74KA, DIST=0KM, Rxme-18 B phase, GR-A trip . M-2(SIPROTEC)- B-PHASE PICKUP Flag on Other panel- RAICA prot optd	M1(SIPROTEC)- Y, B Phase pickup,zone-2, A/R optd, fault current-6.58KA, dist-46.1km. M2(ABB)- Y, B Phase pickup, zone-2, fault current-6.59KA, dist-45.4km
200MVA ICT-3	07.07.2024	14:02	BUSBAR OPERATION RELAY(SEL487B)- TRIP, 87 DIFF. ZONE-1, LBB Optd,BKR Fail,96 OPTD.	--
400kv Mau-Ballia(PG) line	07.07.2024	14:01	-Do-	--

EVENT DESCRIPTION/ANALYSIS OF THE EVENT

- On dated 07.07.2024 at 11:44Hrs, B phase CT of 400kv Mau- Azamgarh line got damaged As per the DR/EL zone-1 prot of main-1 relay and Busbar Differential protection operated (operating current 6pu) and elements connected through BUS-1 got tripped in 60ms(ict-3, pgcil) but due to delay/non opening of B pole CB of Mau- Azamgarh line as per DR at Mau end causes LBB Protection also (ABB Make RAICA static Relay) to operate in approx 500ms. CB of Mau- Azamgarh line opened on Pole discrepancy prot. As per DR of Main -2 relay of Mau- Azamgarh line, At the time of fault B phase current of core-2 (used for main-2 and LBB protection as per scheme) is negligible and B phase current of core-1 (used for main-1 protection) is about 30KA. After 280ms Y phase fault (6KA) created and LBB prot optd in (280ms+200ms)=480ms.

DR 400 KV MAU-AZAMGARH LINE



Disturbance Short Report

Disturbance Recordings Information

Device Information

Recorder ID	1
IED type	REL670
IED version	1.2.3.18
Station name	UPPTCL KASARA MAU
Object name	AZAMGARH LINE-M1
IED name	REL670 1.2.3

Fault Information

Trig date and time	07-07-2024 11:44:30.511
Trigger signal name	PHS-STFWL3
Recording number	735
Total recording time	3009 ms
Pre-trig recording time	500 ms
Post trig recording time	2499 ms
Max. recording time	3000 ms

General Recordings Information


Disturbance recorder	Installed
Event recorder	Installed
System frequency	50 Hz
Sampling frequency	1 kHz
Active setting group during recording	1

Fault Location Information

Fault loop type	L3-N
Fault location	0.0 (0.0 %)
Status of fault calculation	OK
Fault direction	Not valid


Analog Time Diagram


Trig Date Time: 07-07-2024 11:44:30.511



Binary Time Diagram

Trig Date Time: 07-07-2024 11:44:30.511







Vector Diagrams

Calculation Time Period : 1 ms to 20 ms

Currents



Voltages



No.	Name	RMS	Angle
1	LINE_A_IL1	580.329(A)	178.9°
2	LINE_A_IL2	650.396(A)	151.7°
3	LINE_A_IL3	15650.207(A)	200.7°
4	LINE_A_IN	16101.972(A)	197.2°

No.	Name	RMS	Angle
1	LINE_UL1	241021.469 (V)	148.1°
2	LINE_UL2	250097.719 (V)	39.8°
3	LINE_UL3	5120.696(V)	194.4°


Events List


Channel Number	Name	Status	Time
19	PHS-STFWL3	On	07-07-2024 11:44:30.511
20	PHS-STFWPE	On	07-07-2024 11:44:30.511
1	MAINC_B_GEN_TR	On	07-07-2024 11:44:30.517
4	MAINC_B_TR L3	On	07-07-2024 11:44:30.517
5	ZM01-TRIP	On	07-07-2024 11:44:30.517
6	ZM01-START	On	07-07-2024 11:44:30.517
8	ZM02-START	On	07-07-2024 11:44:30.517
10	ZM03-START	On	07-07-2024 11:44:30.517
22	ZCOM_CS	On	07-07-2024 11:44:30.517

ABB


63	AR-START	On	07-07-2024	11:44:30.517
81	TRIP_TRIP	On	07-07-2024	11:44:30.517
19	PHS-STFWL3	Off	07-07-2024	11:44:30.520
20	PHS-STFWPE	Off	07-07-2024	11:44:30.520
84	FLT_LOOP_Bph	On	07-07-2024	11:44:30.520
19	PHS-STFWL3	On	07-07-2024	11:44:30.523
20	PHS-STFWPE	On	07-07-2024	11:44:30.523
19	PHS-STFWL3	Off	07-07-2024	11:44:30.547
20	PHS-STFWPE	Off	07-07-2024	11:44:30.547
5	ZM01-TRIP	Off	07-07-2024	11:44:30.562
6	ZM01-START	Off	07-07-2024	11:44:30.562
8	ZM02-START	Off	07-07-2024	11:44:30.562
10	ZM03-START	Off	07-07-2024	11:44:30.562
63	AR-START	Off	07-07-2024	11:44:30.562
12	ZM04-START	On	07-07-2024	11:44:30.577
35	TOV1_START	On	07-07-2024	11:44:30.588
22	ZCOM_CS	Off	07-07-2024	11:44:30.619
1	MAINCB_GEN_TR	Off	07-07-2024	11:44:30.670
4	MAINCB_TR L3	Off	07-07-2024	11:44:30.670
81	TRIP_TRIP	Off	07-07-2024	11:44:30.670
84	FLT_LOOP_Bph	Off	07-07-2024	11:44:30.673
19	PHS-STFWL3	On	07-07-2024	11:44:30.739
20	PHS-STFWPE	On	07-07-2024	11:44:30.739
12	ZM04-START	Off	07-07-2024	11:44:30.742
19	PHS-STFWL3	Off	07-07-2024	11:44:30.742
20	PHS-STFWPE	Off	07-07-2024	11:44:30.742
1	MAINCB_GEN_TR	On	07-07-2024	11:44:30.760
4	MAINCB_TR L3	On	07-07-2024	11:44:30.760
5	ZM01-TRIP	On	07-07-2024	11:44:30.760
6	ZM01-START	On	07-07-2024	11:44:30.760
8	ZM02-START	On	07-07-2024	11:44:30.760
10	ZM03-START	On	07-07-2024	11:44:30.760
19	PHS-STFWL3	On	07-07-2024	11:44:30.760
20	PHS-STFWPE	On	07-07-2024	11:44:30.760
22	ZCOM_CS	On	07-07-2024	11:44:30.760
63	AR-START	On	07-07-2024	11:44:30.760
81	TRIP_TRIP	On	07-07-2024	11:44:30.760
84	FLT_LOOP_Bph	On	07-07-2024	11:44:30.763
32	TEF1_START	On	07-07-2024	11:44:30.773
32	TEF1_START	Off	07-07-2024	11:44:30.780
19	PHS-STFWL3	Off	07-07-2024	11:44:30.781
20	PHS-STFWPE	Off	07-07-2024	11:44:30.781
5	ZM01-TRIP	Off	07-07-2024	11:44:30.799
5	ZM01-START	Off	07-07-2024	11:44:30.799
8	ZM02-START	Off	07-07-2024	11:44:30.799
10	ZM03-START	Off	07-07-2024	11:44:30.799
63	AR-START	Off	07-07-2024	11:44:30.799
12	ZM04-START	On	07-07-2024	11:44:30.811
22	ZCOM_CS	Off	07-07-2024	11:44:30.862
1	MAINCB_GEN_TR	Off	07-07-2024	11:44:30.910
4	MAINCB_TR L3	Off	07-07-2024	11:44:30.910
81	TRIP_TRIP	Off	07-07-2024	11:44:30.910
84	FLT_LOOP_Bph	Off	07-07-2024	11:44:30.913
35	TOV1_START	Off	07-07-2024	11:44:31.092
12	ZM04-START	Off	07-07-2024	11:44:31.094

DR 400 KV BUS BAR MAU






Time	Value
I01(A)	27.168
I02(A)	7441.365
I03(A)	37.168
I04(A)	0.706
I05(A)	0.707
I06(A)	35.893
I07(A)	0.034
I08(A)	19.027
I09(A)	0.500
I10(A)	91.904
I11(A)	0.000
I12(A)	0.500
I13(A)	0.707
I14(A)	0.000
I15(A)	0.500
I16(A)	0.000
I17(A)	0.000
I18(A)	0.000
I19(A)	0.500
I20(A)	0.000
I21(A)	0.000
V01(kV)	0.000
V02(kV)	0.000
V03(kV)	0.000
IOP1	5.244



A	Z1_TEMP	N	N	11:44:30.643921	11:44:31.078921	002
N	FBF02	N	N	11:44:31.088921	11:44:31.108921	002
A	PLT01	N	A	11:44:30.548921		001
A	OUT104	N	A	11:44:30.548921		001
N	OUT107	N	N	11:44:31.088921	11:44:31.108921	002
A	Z15	N	N	11:44:30.643921	11:44:31.078921	002
N	Z25	N	N	11:44:30.698921	11:44:31.078921	002
A	Z39	N	N	11:44:30.643921	11:44:31.078921	002
A	B701	N	N	11:44:30.698921	11:44:31.088921	002
N	B752	N	N	11:44:30.678921	11:44:30.698921	002
N	B7R1	N	N	11:44:30.643921	11:44:31.078921	002
A	P82R1	N	N	11:44:30.698921	11:44:31.078921	009
A	B7C1	N	N	11:44:30.698921	11:44:31.078921	002
A	FAULT1	N	N	11:44:30.638921	11:44:31.093921	002
N	COB1	N	N	11:44:30.608921	11:44:30.643921	009
A	FDIF1	N	N	11:44:30.538921	11:44:31.093921	002

SLD 400 KV SS MAU

PROPOSED SINGLE LINE DIAGRAM OF 400/132/33 KV S/S KASARA, MAU




REPORT 400 KV AZAMGARH-MAU LINE

Electricity Test & Commissioning Circle, Gorakhpur
Division: Electricity Test & Commissioning Division, Azamgarh
Tripping Statement of 400 KV S/S Azamgarh

Jul-24

Sr. No.	Tripping Date/Time	Closing Date/Time	T/F/Feeder C.B. No.	Name of Sub-Station	Type of Protection	Flags Observed		Analysis	Remarks
						This End	Other End		
1	07/07/2024 11:44Hrs	09/07/2024 17:29Hrs	400 KV Azamgarh-Mau Line	400 KV S/S Azamgarh	Distance Protection - I Distance Protection - II	SIPROTEC Relay: Gen Trip ,Y Phasepickup ,B phase pick up, Z-2 ,A/Roptd ,IL2= 6.58 Ka ,IL36.37kA Distance - 46.1 km ,%d = 95.3% RXME ,R, Y, B interconnection SIPROTEC Relay: Gen Trip ,Y phase pickup, B phase pick up Z-2 ,IL2= 6.59 kA ,IL3 = 6.40 kA Distance - 45.4 km ,%d = 93.8%	REL 670 B phase Trip ,Z1 trip,IL3= 2742 A DT Receive, CB Pole Discrepancy , Dis -0Km Flag On Bus Bar Pane I- 87 Differential Optd,Zone-1,LLB	B Phase C T damage at Mau end.	

Fault on 400KV Azamgarh -Mau Line



DR 400 KV AZMGARH – MAU LINE

400KVMAU 400 AMH 7SA611 V4.7 Var 10

- 1 -

07-07-2024 / 11:44:48.558

400KVMAU 400 AMH 7SA611 V4.7 Var 10


File path: C:\USERS\ADMIN\DESKTOP\MAU07072024\M1 MAU 07072024.CFG



Start time: 07-07-2024 11:44:48.309


Sample rate: 1000 Hz

Value representation:secondary

Record type: COMTRADE







Events Description

ANALYSIS OF TRIPPING OF 400 KV MAU-AZAMGARH LINE OCCURRED ON 07.07.2024 AT 11:44 Hrs

- ➡ 400 KV Mau-Azamgarh Line tripped on 07.07.2024 at 11:44 Hrs, B-Ph CT of 400 Mau - Azamgarh Line got damaged at Mau end. As per the DR / EL zone -1 Prot. Of Main - 1 relay and Busbar Differential protection operated and elements connected through Bus - 1 got tripped in 60 ms (200 MVA ICT-3, 400 KV Mau-Ballia PGCIL Line) but DT was not sent to Azamgarh End because of the damage DT Cable. (DT Cable replaced and tested later). That is why at 400 KV Azamgarh Relay waited for 500 ms for Zone-2 and after 500 ms Line tripped in Zone-2 at Azamgarh end. Fault was cleared in 560 ms.
- ➡ Permissive Carrier not received at Azamgarh end due to defective LMU at Mau End (LMU replacement work is under process).
- ➡ C.B Status was not changed after Busbar operation of 400 KV Mau - Azamgarh Line at Mau end causes LBB operation due to defective CB status cable.(CB status cable has been changed)

THANK YOU.

**Multiple elements tripping at
400/220kV Lucknow2(HR)
14th August 2024**


Brief of event:

- i. 220kV Lucknow(UP) has double main and transfer bus scheme at 220kV level.
- ii. During antecedent condition, 400/220kV 500 MVA ICT-1 & 2, 220/132kV 200 MVA ICT-1 & 2, 220kV Lucknow-Hardoi Road (UP) ckt & 220kV Lucknow-Unnao (UP) ckt were connected to 220kV bus-1 and 220kV lines from Lucknow(UP) to Bachrawan, Gomatinagar, Kanpur Road & 220/132kV 200MVA ICT-1 & 2 connected to 220kV bus-2 at 220kV Lucknow(UP) S/s. 220kV Lucknow-Kanpur Road (UP) ckt was not in service during the event.
- iii. As reported, at 15:53 hrs, R-N phase to earth fault occurred on 220kV bus-1 which led to tripping of all elements connected to 220kV bus-1 at 220kV Lucknow(UP). Bus bar protection failed to operate and 400/220 kV 500 MVA ICT-1 & 2 tripped on LBB protection (Type of protection operated in tripping of other elements is yet to received)
- iv. As per PMU at Lucknow(PG), R-N phase to earth fault with delayed fault clearance time of 880ms is observed (Reason for delayed fault clearance is yet to receive).
- v. As per SCADA, change in demand of approx. 280 MW in UP control area. However, approx. 250 MW load loss in UP control area as per SLDC-UP.

Elements tripped:

- i. 400/220 kV 500 MVA ICT 1 at Lucknow(UP)
- ii. 400/220 kV 500 MVA ICT 2 at Lucknow(UP)
- iii. 220kV Lucknow-Hardoi Road (UP) ckt
- iv. 220kV Lucknow-Unnao (UP) ckt
- v. 220/132 kV 200 MVA ICT 1 at Lucknow(UP)
- vi. 220/132 kV 200 MVA ICT 2 at Lucknow(UP)

Network Diagram



SLD of 400/220KV Lucknow(UP) before the event

LUCKNOW_UP

Stat Expl

GenSum

Company

P sum 400 Kv =
Q sum 400 Kv =

LKNOW-1

SINGR-1

MOHANLAL GANI

BRELY-1




URTDSDM DATA

Stat	MW	MVAR	VOLTGAE	ANGLE
LUCK-LNNO	WWW	WWW	WWW	WWW
LUCK-SINGR	WWW	WWW	WWW	WWW
LUCK-BRELY	WWW	WWW	WWW	WWW
LUCK-LNO-PG	WWW	WWW	WWW	WWW
BB1	WWW	WWW	WWW	WWW

500MVA
FEB-T1
400/220/33 KV

500MVA
FEB-T2
400/220/33 KV



LUCKNOW-2

SLD of 400/220KV Lucknow(UP) after the event

LUCKNOW_UP

Stat Expl

GenSum

Company

P sum 400 Kv =
Q sum 400 Kv =

LKNOW-1

SINGR-1

MOHANLAL GANI

BRELY-1




UKTDSM DATA

	MW	MVAR	VOLTAGE	ANGLE
LUCK-UNNAO	WWW	WWW	WWW	WWW
LUCK-SINGR	WWW	WWW	WWW	WWW
LUCK-BRELY	WWW	WWW	WWW	WWW
LUCK-LKO-PG	WWW	WWW	WWW	WWW
BE 1	WWW	WWW	WWW	WWW

80MVAR BR

500MVA
FEB-T1
400/220/33 KV


500MVA
FEB-T2
400/220/33 KV




0.00 HZ
0 KV

LUCKNOW-2


SLD of 220/132KV Lucknow(UP) before the event



SLD of 220/132KV Lucknow(UP) after the event



Uttar Pradesh Demand during the event




PMU Plot of frequency at Lucknow(PG)

15:53 hrs/14-July-24



PMU Plot of phase voltage magnitude at Lucknow(PG)


15:53 hrs/14-July-24



SCADA SOE


Time	Station Name	Voltage	Element Name	Element Type	Element Status	Remarks
15:53:08,114	HRDOI_UP	220kV	01LUCK2	Circuit Breaker	Open	Line CB at Hardoi Road(UP) end, 220kVHardoi-Lucknow (UP) ckt opened
15:53:08,496	LUCK2_UP	132kV	02T2	Circuit Breaker	Open	CB at Lucknow(UP) end of 220/132kV160MVAICT-2 opened from 132kV side
15:53:08,498	LUCK1_UP	400kV	08T2	Circuit Breaker	Open	CB at Lucknow(UP) end of 400/220kV500MVAICT-2 opened from 400kV side
15:53:08,501	LUCK2_UP	220kV	02T2	Circuit Breaker	Open	CB at Lucknow(UP) end of 220/132kV160MVAICT-2 opened from 220kV side
15:53:08,510	LUCK1_UP	220kV	02T2	Circuit Breaker	Open	CB at Lucknow(UP) end of 400/220kV500MVAICT-2 opened from 220kV side
15:53:08,523	LUCK2_UP	132kV	81T1	Circuit Breaker	Open	CB at Lucknow(UP) end of 220/132kV160MVAICT-1 opened from 132kV side
15:53:08,528	LUCK2_UP	220kV	01T1	Circuit Breaker	Open	CB at Lucknow(UP) end of 220/132kV160MVAICT-1 opened from 220kV side
15:53:08,736	LUCK1_UP	400kV	07T1	Circuit Breaker	Open	CB at Lucknow(UP) end of 400/220kV500MVAICT-1 opened from 400kV side

DR of 400/220kV 500MVA ICT-2 at Lucknow2(UP)



O/C E/F operated, DR time is not synced

DR of 220/132kV 200MVA ICT-2 at Lucknow2(UP)



001111 51011HV 280.2 230424 / 90.521HV 753602 V/ Ser - 14/07/2024 15:13:42.190 Dela R 713.375 ms (35459 op; @ 50.1 Hz) 880/41 H.A.S./Units Dela V/ No file

O/C E/F operated, DR time is not synced

Point of discussion

- i) Reason of fault and reason for delayed fault clearance at 220kV Lucknow(UP) S/s need to be shared.
- ii) Reason for failed operation of bus bar protection at 220kV Lucknow(UP) S/s need to be shared.
- iii) Relay flag details and type of protection operated for all tripped elements need to be shared.
- iv) DR/EL (.dat/.cfg file) of all the tripped elements along with detailed tripping report need to be shared.
- v) Remedial action taken report to be shared.



400kV & 220kV Sarojini Nagar Sub-Station, UPPTCL, Lucknow

14.07.2024, 15:53

**Tripping of 200MVA ICT-I, 200MVA
ICT-II, 220kV Hardoi Road line, 220kV
Dahi Chauki(Unnao) line, 500MVA ICT-I,
500MVA ICT-II, *due to fault on 220kV
Bus-A at 220/132kV S/s Sarojini Nagar***


On 14.07.2024 at 15:53 hrs following elements trip at 400kV & 220kV S/s Sarojini Nagar

NAME OF ELEMENT	RESTORATION DATE	RESTORATION TIME	FLAGS END 1 (INCLUDING A/R)	FLAGS END 2 (INCLUDING A/R)
220/132kV 200MVA ICT-I	14.07.2024	16:08	<i>CP</i> : HV E/f, <i>RP</i> : HV Dir O/c & E/f, E/f trip relay, 86A, 86B	-
220/132kV 200MVA ICT-II	14.07.2024	16:08	<i>CP</i> : HV E/f, <i>RP</i> : HV O/c & E/f protection, General trip, R&B phase, E/f trip, 86A, 86B, 86LV, O/c & E/f protection relay	
220kV Sarojini Nagar (Lucknow)-Hardoi Road line	14.07.2024	16:27	No flag	Z-2, R-phase, 86 optd
220kV Sarojini Nagar (Lucknow)-Dahi Chauki(Unnao) line	14.07.2024	16:30	No flag	Z-2, R-phase, 86A, 86B
400/220kV 500MVA ICT-II	14.07.2024	19:30	<i>CP</i> : LBB optd, HV side O/C & E/f Relay: Trip, 51, A-N, HV-286, LV-286 HV side LBB Relay: Trip, 51, Breaker Failure	
400/220kV 500MVA ICT-I	14.07.2024	17:27	No flag	


Antecedents condition

- 220kV Bus Coupler was open.
- On 220kV Bus-A, the following elements were connected :-
 - 220/132kV 200MVA ICT-I
 - 220/132kV 200MVA ICT-II
 - 220kV Sarojini Nagar(Lucknow)-Hardoi Road line
 - 220kV Sarojini Nagar(Lucknow)-Dahi Chauki(Unnao) line
 - 400/220kV 500MVA ICT-II
- On 220kV Bus-B, the following elements were connected :-
 - 220/132kV 200MVA ICT-III
 - 220kV Sarojini Nagar(Lucknow)-Bachhrawan line
 - 220kV Sarojini Nagar(Lucknow)-Gomti Nagar line
 - 400/220kV 500MVA ICT-I
- 220kV Sarojini Nagar(Lucknow)- Kanpur Road line was not in service.

SINGLE LINE DIAGRAM OF 220 KV S/S Sarojini Nagar



SLD of 400kV Sanjini Nagar S/S



Events Description

- On 14.07.2024 at 15:54hrs, 220/132kV S/s Sarojini Nagar, a fault occurred on 220kV Bus-A, due to a bird carrying string (wire) dropped near jumper at R-phase gantry of 220kV Bus Coupler Bay.
- 220kV Bus Coupler was already open before the occurrence of fault.
- 220kV Busbar protection not operated because of CT Fail alarm and mentioned elements tripped with following flags-
 - 200MVA ICT-1, *CP*: HV E/f, *RP*: HV Dir O/c & E/f, E/f trip relay, 86A, 86B.
 - 200MVA ICT-2, *CP*: HV E/f, *RP*: HV O/c & E/f protection, General trip, R&B phase, E/f trip, 86A, 86B, 86LV, O/c & E/f protection relay.

Events Description

- 220kV Sarojini Nagar(Lucknow)-Dahi Chauki(Unnao) line, tripped from other end (Z-2, R-phase, 86 optd).
- 220kV Sarojini Nagar(Lucknow)-Hardoi Road line, tripped from other end (Z-2, R-phase, 86A, 86B).
- 500MVA ICT-2, *CP*: LBB optd,
HV side O/C & E/f Relay: Trip, 51, A-N, HV-286, LV-286
HV side LBB Relay: Trip, 51, Breaker Failure
- 400 side Bus Coupler/Busbar panel: Busbar protection DC Fail, 80T DC No Volt Relay (B/B protection trip ckt).
- 500MVA ICT-1, *RP*: 86ITA, 86ITB, 86ITC, 86ITD, 86TX, 86AX, 86BX


Analysis Report

- At 220kV Sarojini Nagar S/s, on 14.07.2024 at 15:54hrs, a bird dropped a string near R-phase gantry of 220kV Bus causing bus-A fault. 220kV Busbar protection failed to operate because of CT Fail alarm which blocked busbar protection causing tripping of 200MVA ICT-1&2, 220kV Sarojini Nagar(Lucknow)-Hardoi Road line, 220kV Sarojini Nagar(Lucknow)-Dahi Chauki(Unnao) line and 500MVA ICT-2.
- On further analysis it was found that CT fail alarm was appearing in 220kV Busbar relay due to mismatch between connected CT ratio and CT ratio fed in the relay in two no bays (200MVA ICT I and II)

Analysis Report

- At 400kV Sarojini Nagar S/s, 500MVA ICT-2 tripped on R-phase IDMT O/C & E/f protection. As per DR, HV LBB relay got initiation from respective Master Trip relay and after approx 200msec of initiation HV side LBB relay generated trip command.
- After Master trip relay operation current in ICT-2 became zero in all phases before LBB trip command generation, thus indicating false command generation. At the same time in Busbar panel “80T DC No Volt Relay (B/B protection trip ckt)” operated which means 400kV Busbar tripping circuit DC failed with fluctuations, and for this reason other elements on 400kV Bus-A may not have tripped.
- As per DR, after tripping of 500MVA ICT-2, approx 240msec later 500MVA ICT-1 tripped without any flags on protective relays installed on this ICT. Only trip relays operated. Cause of this tripping is yet to be analysed.

CEV_U_from_cev.dat - 14/07/2024 - 15:41:56.103 - Secondary - (Peak Type)



63	A 51N3P	A	A	000
64	A 51BR	A	A	000
67	A 51G1R	A	A	000
70	A 51G2R	A	A	000
93	N BKMON	N	A	15:41:56.293000
95	N BR	N	N	15:41:56.303000
104	N FAULT	N	A	15:41:56.303000
113	N TRIP	N	A	15:41:56.293000
114	N OUT101	N	N	15:41:56.293000
115	N OUT102	N	N	15:41:56.293000
117	N OUT301	N	N	15:41:56.293000
118	N OUT302	N	N	15:41:56.293000
119	N OUT303	N	N	15:41:56.293000
120	N OUT304	N	N	15:41:56.293000
129	A IN101	N	A	15:41:56.093000
214	A SIGNAL	A	A	000

IN101 : Initiation from Master
 Trip relay,
 After Master Trip relay
 operation Current in all three
 phases became Zero
 LBB Relay generated false
 tripping command. (all
 output - High after 200 msec
 of LBB initiation.)

Analysis Report

Because of non-operation of 220kV Busbar protection each element were tripped timely at own protection settings. For example, 500MVA ICT-2 setting are as-

O/C (IDMT) = 0.80, TMS = 0.30

O/C (Highset) = 4.5 Amp, Time = 0.06

E/f (IDMT) = 0.20, TMS = 0.30


E/f (Highset) = 4.5 Amp, Time = 0.06

As seen in DR, Current in R-Phase & Neutral are below Highset value.

Current in Neutral = 2.854 Amp (approx. 14.27 times of setting (0.2))

Therefore, the calculated time for tripping (according to IEC Standard Inv. Curve) = 771msec

DR Of B/U Relay (500MVA ICT-2)



FID=5EL-351A-R516-V0-Z106105-020150202 220KV Sun - 14/07/2024 15:44:26.603 Delta X: 269.948 ms [33.497 cyc @ 50.0 fs: 6410.256 Hz] AS: Units Delta Y: No Bars

Remedial Actions

- At 220kV Sarojini Nagar S/s, CT Fail Alarm problem was resolved by correcting the connected CT ratio.
- At 400kV Sarojini Nagar S/s, a new Busbar protection is being retrofitted since 17.09.2024.

THANK YOU.

**Multiple elements tripping at
400/220kV Muzaffarnagar(UP)
21st August 2024**

Brief of event:

- i. During antecedent condition, 400/220kV 315 MVA ICT-1, 400/220kV 500 MVA ICT-4, 220kV Muzaffarnagar-Shamli (UP) Ckt, 220kV Muzaffarnagar-Khatauli (UP) Ckt, 220kV Muzaffarnagar-Badhnikalan (UP) Ckt & 220/132kV 160MVA ICT-4 were connected to 220kV bus-1 and 400/220 kV 315 MVA ICT-2, 400/220 kV 315 MVA ICT-3, 220kV Muzaffarnagar-Charla (UP) Ckt, 220kV Muzaffarnagar-Jansath (UP) Ckt & 220/132kV 160MVA ICT-5 were connected to 220kV bus-2 at Muzaffarnagar(UP) S/s. Bus coupler of 220kV bus-1 and 220kV bus-2 was in ON condition and 220kV Muzaffarnagar-Nara (UP) Ckt was not in service (under shutdown) during the tripping event.
- ii. As reported, at 09:02 hrs, **R-N phase to earth fault occurred on 220kV Muzaffarnagar-Badhni kalan (UP) Ckt with fault distance of 3.8km from Muzaffarnagar(UP) end and 20.4km from Badhni kalan(UP) end.** Fault was sensed in zone-1 from both ends.
- iii. On this fault 220kV Muzaffarnagar-Badhni kalan (UP) Ckt tripped from Badhni kalan end on zone-1 distance protection on R-N fault. During fault clearing process at Muzaffarnagar(UP) end, R-phase CB interrupting chamber got damaged which resulted into continuation of sparking between R phase male contact and R phase dropper wire of breaker. The circuit breaker operated mechanically (auxiliary contacts operated properly) and thus breaker status reflected as OPEN.
- iv. As breaker didn't open completely, fault was not cleared yet. Due to continuous fault feeding 400/220kV 315MVA ICT-1 & 2 and 400/220kV 500 MVA ICT-4 tripped on directional earth fault protection and 400/220kV 315 MVA ICT-3 tripped on back up impedance protection. 220 kV Charla line, 220 kV Jansath line and 220 kV shamli line tripped from remote ends on zone-3 distance protection (it is confirmed from respective DRs also).


Brief of event:

- v. Ideally, this fault would have been cleared by LBB protection of Badhni kalan bay, but as CB status changed from ON to OFF due to proper operation of breaker auxiliary contacts, LBB initiation got reset.
- vi. Further, as reported, bus bar protection of 220kV bus-1 at Muzaffarnagar(UP) also operated after 1 second of fault starting time due to persisting differential current.
- vii. As per DR of bus bar protection at Muzaffarnagar(UP), busbar protection operated on 220kV bus-1 after 1.05 second of fault starting time. On this, all remaining elements also tripped which were connected to 220kV bus-1 i.e. 220kV Muzaffarnagar-Khatauli (UP) Ckt, 220/132kV 160MVA ICT-4 and bus coupler of 220kV bus-1 and bus-2.
- viii. As per PMU at Meerut(PG), R-N phase to earth fault with delayed fault clearing time of 1080 msec is observed.
- ix. As per SCADA, load loss of approx. 290 MW in UP control area. However, SLDC-UP reported load loss of 127 MW in UP control area.


Elements tripped:

- i. 1) 400/220 kV 315 MVA ICT 1 at Muzaffarnagar(UP)
- ii. 2) 400/220 kV 315 MVA ICT 2 at Muzaffarnagar(UP)
- iii. 3) 400/220 kV 315 MVA ICT 3 at Muzaffarnagar(UP)
- iv. 4) 400/220 kV 500 MVA ICT 4 at Muzaffarnagar(UP)
- v. 5) 220kV Muzaffarnagar-Charla (UP) Ckt
- vi. 6) 220kV Muzaffarnagar-Jansath (UP) Ckt
- vii. 7) 220kV Muzaffarnagar-Shamli (UP) Ckt
- viii. 8) 220kV Muzaffarnagar-Khatauli (UP) Ckt


Network Diagram




SLD of 400/220 KV Muzaffarnagar(UP) before the event



SLD of 400/220 KV Muzaffarnagar(UP) after the event




SLD of 400/220 KV Muzaffarnagar(UP) during the event (Bus wise arrangement)



Uttar Pradesh Demand during the event

Uttar Pradesh Demand



Aug 20 Tue 2024


PMU Plot of frequency at Meerut(PG)

09:02 hrs/21-Aug-24




PMU Plot of phase voltage magnitude at Meerut(PG)

09:02 hrs/21-Aug-24




DR of 220kV Muzaffarnagar-Shamli(end) (UP) ckt



✓ R-N fault, Z-3, trip time: ~560msec


DR of 400/220kV 315 MVA ICT-1 at Muzaffarnagar(UP)



400MVA_07M_07-1 Wed - 21/03/2024 09:02:47.732 Delta X: 345.968 ms 17.298 circ @ 50.00 Hz 1200.273 H AS: ++ Data T: No Sim


✓ DEF operated, $I_r \approx 1350A$, $I_n \approx 750A$

DR of 400/220kV 315 MVA ICT-2 at Muzaffarnagar(UP)




✓ DEF operated, $I_r \approx 1440A$, $I_n \approx 860A$

DR of 400/220kV 315 MVA ICT-3 at Muzaffarnagar(UP)




✓ Back up impedance protection operated, Z-3 operated; trip time: ~1.05 sec

DR of 400/220kV 500 MVA ICT-4 at Muzaffarnagar(UP)



✓ DEF operated

DR of bus bar protection at Muzaffarnagar(UP)



✓ Bus bar zone-1 operated after 1.05sec of fault starting time

SCADA SOE

Time	Station Name	Voltage	Element Name	Element Type	Element Status	Remarks
09:02:07,391	SHMLI_UP	220kV	08MUZA1	Circuit Breaker	Open	Line CB at Shamli end of 220kV Muzaffarnagar-Shamli ckt opened
09:02:07,890	MUZA1_UP	400kV	982T2	Circuit Breaker	Open	CB at 400kV side of 400/220kV 315 MVA ICT-2 at Muzaffarnagar opened
09:02:07,898	MUZA1_UP	220kV	882T2	Circuit Breaker	Open	CB at 220kV side of 400/220kV 315 MVA ICT-2 at Muzaffarnagar opened
09:02:07,917	MUZA1_UP	400kV	987T4	Circuit Breaker	Open	CB at 400kV side of 400/220kV 500 MVA ICT-4 at Muzaffarnagar opened
09:02:07,937	MUZA1_UP	220kV	887T4	Circuit Breaker	Open	CB at 220kV side of 400/220kV 500 MVA ICT-4 at Muzaffarnagar opened
09:02:07,937	MUZA1_UP	400kV	981T1	Circuit Breaker	Open	CB at 400kV side of 400/220kV 315 MVA ICT-1 at Muzaffarnagar opened
09:02:07,944	MUZA1_UP	220kV	881T1	Circuit Breaker	Open	CB at 220kV side of 400/220kV 315 MVA ICT-1 at Muzaffarnagar opened
09:02:07,955	MUZA1_UP	220kV	85MBC	Circuit Breaker	Open	Bus coupler breaker of 400kV side opened
09:02:07,977	MUZA1_UP	220kV	81BADHA	Circuit Breaker	Open	Line CB at Muzaffarnagar end of 220kV Muzaffarnagar-Badhaikalan ckt opened

Point of discussion

- i) Logic of identification of breaker ON & OFF status may be reviewed if needed.
- ii) Reason for bus bar protection operation need to be shared.
- iii) Remedial action taken report to be shared.



400KV MUZAFFARNAGAR SUB-STATION, UPPTCL

**Multiple tripping event on 21.08.2024 at
09:02hrs. alongwith 220kV Busbar operation.**


Antecedent Conditions:



- **Weather conditions :** - Clear at Muzaffarnagar
- **Date & Time of event:** 21.08.2024 at 09:02 hrs.
- **Sub-Station affected:** 220kV Bus at 400kV S/s Muzaffarnagar.
- **Load conditions on 400/220kV ICT's:** - 315MVA ICT-I, 315MVA ICT- II, 315MVA ICT-III and 500MVA ICT-IV were carrying 90MW, 96MW, 90MW and 146MW respectively.

	Elements tripped	Time of restoration	Bay No. (Busbar relay)
1.	315MVA ICT-I	09:55 hrs.	07
2.	315MVA ICT-II	10:00 hrs.	02
3.	315MVA ICT-III	12:13 hrs.	12
4.	500MVA ICT-IV	12:27 hrs.	14
5.	220kV Muzaffarnagar-Badhaikalan Line	18:22 hrs.	11
6.	220kV Muzaffarnagar-Shamli Line	14:23 hrs.	10
7.	220kV Muzaffarnagar-Khatauli Line	11:32 hrs.	05
8.	220kV Muzaffarnagar-Charla Line	19:28 hrs.	04
9.	220kV Muzaffarnagar-Jansath Line	10:54 hrs.	08
10.	220kV Bus Coupler	15:26 hrs.	06
11.	160MVA T/F-I	09:56 hrs.	01

NAME OF ELEMENT	RESTORATION DATE	RESTORATION TIME	FLAGS END 1 (Muzaffarnagar end)	FLAGS END 2 (Remote end) (INCLUDING A/R)
			(INCLUDING A/R)	(INCLUDING A/R)
CB-81 220 KV MUZAFFARNAGR-BADHAIKALAN LINE	21/08/2024	18:22 HRS	C/P: DIST.TRIP R/P: R PH,Z-1,C/S, K86R,86B IR-12.18KA DISTANCE-3.839KM (13.71%)	C/P: DIST. TRIP R/P: R PHASE, Z1,86A,86B, IR- 2.724KA. Dist: 20.399KM (72.85%)
220 kV BUS BAR (BUS A)	21/08/2024	15:26 HRS	CP= BUS BAR ZONE 1 RP=R PHASE BUS BAR DIFFERENTIAL TRIP, 96(315 MVA ICT-I,96(500 MVA ICT IV,96(220 KV KHATAULI LINE, 96(220 KV BUSCOUPLER ,96(220 KV SHAMALI LINE),96(160 MVA T/F-1)	
CB-84 220 KV MUZAFFARNAGA R-KHATAULI LINE	21/08/2024	11:32 HRS	R.P.: 96 TRIP,	Line radially fed from Muzaffarnagar end.
CB-86, 220 kV MUZAFFARNAGA R-SHAMLI LINE	21/08/2024	14:23 HRS	R.P.: 96 TRIP	C.P.- DPO, DPS,A/R LOCKOUT RP- R,N,Z4 , DIST:96.11KM IA- 1.497KA
CB-884/784 160 MVA T/F-I	21/08/2024	09:56 HRS	R.P.: 96 TRIP	
CB-85,220 KV BUS COUPLER	21/08/2024	15:26 HRS	R.P.: 96 TRIP	
CB-981/881,315 MVA ICT-I	21/08/2024	09:55 HRS	220 BUS BAR R/P: 96 TRIP ICT C/P: DIRECTIONAL E/F TRIP ICT R/P: DIR.E/F TRIP,86 GB IA-1.228KA,IB- 126A,IC- 329A ,IN-835A	
CB-987/887,500 MVA ICT-IV	21/08/2024	12:27 HRS	220 BUS BAR R/P: 96 TRIP ICT C/P: DIRECTIONAL E/F TRIP ICT R/P: DIR.E/F TRIP, 86 A,86B IA-2.339KA,IB- 0.378KA, IC- 0.596KA ,IN-1.328KA	
CB-982/882,315 MVA ICT-II	21/08/2024	10:00 HRS	C/P: DIRECTIONAL E/F TRIP R/P: DIR.E/F TRIP,86 GB IA-1.339KA,IB- 138.6A, IC- 385A , IN-926.9A	
CB-983/883,315 MVA ICT-III	21/08/2024	12:13 HRS	C/P: HV BACKUP IMPEDENCE TRIP R/P: R PH,Z-3, DISTANCE: 211.9KM, 86 HV,86LV IA-1.254KA,IB- 118A, IC- 318A ,IN-835A	
CB-87, 220 kV MUZAFFARNAGA R-JANSATH LINE	21/08/2024	10:54 HRS	Not Tripped	C.P.- DPO RP-M1- R,N,Z3, DIST: 51.2 KM IA-1.70KA,IB- 0.37KA,IC-0.27KA
CB-83, 220 kV MUZAFFARNAGA R-CHARLA LINE	21/08/2024	19:28 HRS	Not Tripped	C.P.-DPO,DPS, RP-R,N,Z-3,DIST: 83.68KM, IA-2.149KA,IB-

400kV S/S Muzaffarnagar Single line diagram on 21.08.2024



Legends:- CB tripped 
 CB closed 

Sequence of Events:

- 21.08.2024, 09:02 hrs. : R-N fault occurred on 220 kV Muzaffarnagar-Badhaikalan line having distance of 3.839Km, It's distance relay operated at Muzaffarnagar end in zone-1. This line tripped from remote end also on R phase fault in Z-1 with distance of 20.399 km. During fault clearing process at Muzaffarnagar end, R phase CB interrupting chamber got damage. Which resulted into continuous sparking between R phase male contact and R phase dropper wire of breaker. However it is to make clear that no phase to earth fault developed in the switchyard. The circuit breaker operated mechanically (auxiliary contacts operated properly), thereby reporting the status of breaker as open in the busbar relay. LBB didn't operate in this event.
- Hence, this fault was fed by upstream network thereby resulting into tripping of 315MVA ICT-1, 315MVA ICT-II, 500MVA ICT-IV on directional E/F protection, 315 MVA ICT-III on back up impedance protection. 220 kV Charla line, 220 kV Jansath line and 220 kV Shamli line tripped from remote end.

Sequence of Events (contd.):

- After fault incident, during patrolling of 220 kV Muzaffarnagar-Badhaikalan line OPGW wire found broken between tower no.-161 &162. On switchyard inspection R phase breaker pole of 220 kV Badhaikalan line found damaged. Also, R phase isolator arms' support insulators of 220 kV Shamli line got damaged due to impact of shattered pieces of Badhaikalan line CB pole interrupting chamber. Since no marks of electrical sparking were found either on isolator structure or at the ground near isolator, it is evident that the fault was already cleared by the time isolator arm fell from the post insulator.

Reason of Non operation of LBB:

- After detailed examination of disturbance records obtained from busbar and line protection we arrive at following conclusion.
- Ideally, This fault should have been cleared by LBB protection. However, In the busbar DR, at 09:02:06:925hrs, breaker failure initiation of 220 kV Badhaikalan line can be seen as asserted. After approx 50ms, at 09:02:06:965 hrs circuit breaker open status of Badhaikalan line also can be seen as asserted.
- As soon as CB status of BadhaiKalan line changed from ON to OFF, Badhai Kalan line vanished from zone 1 of busbar i.e. its assignment to zone 1 of the busbar protection ceased to exist. As zone-1assignment logic for any bay is boolean AND of isolator A(89A) and breaker auxiliary contact (52a) status. Because of changing of CB status of Badhaikalan from ON to OFF, Badhaikalan bay de-assigned from zone-1 . Due to these facts, LBB couldn't operate.

Reason of Busbar differential operation:

- When Badhaikalan line breaker status(52a) changed from ON to OFF, this line got vanished from zone 1 of busbar i.e. its assignment to zone 1 of the busbar protection ceased to exist. Now, because of non-accounting of BadhaiKalan line fault current (approximately 8 kA), in spite of having no actual busbar fault, the busbar relay started to show approximately 8 kA of differential current as well as the same amount of restraining current.
- Also, there is a provision in busbar relay to increase the stability of busbar relay by increasing the slope once a through fault is detected. This condition is represented by appearance of CON1 signal in DR. Once the through fault was detected, the bus bar relay increased its slope to a higher value (from normal slope of 60% to 80% in this case) for next 50 cycles i.e. 1s. This increased slope prevented busbar relay operation for next 1 second.
- Owing to these facts, the busbar relay operated on bus differential fault after one second of occurrence of through fault on BadhaiKalan line.
- Even when the busbar relay operated on differential fault it issued trip commands to all the bays connected to bus Zone 1 except bay 11 which is BadhaiKalan line. This confirms that BadhaiKalan line was totally eliminated from busbar protection scheme once its CB mechanically tripped.

220kV BADHAIKALAN LINE DR

WAVEWIN ABB H.G.24


Files Data Channels View Values Window Help

Exit System Back Files

08-27-2024 02:00:18 PM

Data: [Icons]


Wednesday 21 August 2024 09:02:06.000.DAT - 21/08/2024 - 09:02:06.912 - Primary - (Peak Type)




Samp#: 7030
Page Duration: 421 Mils(s) - 640 Mics(s)

1	A Anv Start	N	N	09:02:06.912320	09:02:08.124120	004
2	A Anv Trip	N	N	09:02:06.913980	09:02:07.988000	002
3	A DIST Trip A	N	N	09:02:06.913980	09:02:07.914960	002
4	N DIST Trip B	N	N	09:02:07.908320	09:02:07.914960	002
5	N DIST Trip C	N	N	09:02:07.908320	09:02:07.914960	002
6	A DIST Fwd	N	N	09:02:06.913980	09:02:07.914960	002
7	N DIST Rev	N	N	09:02:08.087600	09:02:08.124120	002
8	A Z1	N	N	09:02:06.913980	09:02:07.914960	002
11	N Z4	N	N	09:02:08.090920	09:02:08.124120	002
17	A L1-M CB R PH OP	N	A	09:02:06.977060		001
18	N L2-M CB Y PH OP	N	A	09:02:07.978040		001
19	N L3-M CB B PH OP	N	A	09:02:07.983020		001
25	A L9-R PH INI	N	N	09:02:06.925600	09:02:07.926580	002
26	N L10-Y PH INI	N	N	09:02:07.919940	09:02:07.926580	002
27	N L11-B PH INI	N	N	09:02:07.919940	09:02:07.926580	002
28	A L12-A/R IN	A	A			000

Busbar DR





FD-SEL-4678-1-R104-V1-ZR11005-D20151 Wed - 21/08/2024 19:02:07.095 Delta X: 120.400 ms (6.000 crl @ 50.00 Hz) (45-ON) Delta Y: 271.997 A



Trip command issued to these elements





Sample 120
 Page Duration: 2 Sec(s) (-100 MHz)

Breaker fail
 Indication



A 84	A	N	05:02:07.958475	0.0
A 85	A	N	05:02:07.958475	0.0
A 86	A	N	05:02:07.958475	0.0
A 87	A	N	05:02:07.958475	0.0
A 88	A	N	05:02:07.958475	0.0
A 89	A	N	05:02:07.958475	0.0
A 90	A	N	05:02:07.958475	0.0
A 91	M	N	05:02:07.958475	0.0
A 92	M	N	05:02:07.958475	0.0
A 93	M	N	05:02:07.958475	0.0
A 94	M	N	05:02:07.958475	0.0
A 95	M	N	05:02:07.958475	0.0
A 96	M	N	05:02:07.958475	0.0
A 97	M	N	05:02:07.958475	0.0
A 98	M	N	05:02:07.958475	0.0
A 99	M	N	05:02:07.958475	0.0
A 100	M	N	05:02:07.958475	0.0
A 101	M	N	05:02:07.958475	0.0
A 102	M	N	05:02:07.958475	0.0
A 103	M	N	05:02:07.958475	0.0
A 104	M	N	05:02:07.958475	0.0
A 105	M	N	05:02:07.958475	0.0
A 106	M	N	05:02:07.958475	0.0
A 107	M	N	05:02:07.958475	0.0
A 108	M	N	05:02:07.958475	0.0
A 109	M	N	05:02:07.958475	0.0
A 110	M	N	05:02:07.958475	0.0
A 111	M	N	05:02:07.958475	0.0
A 112	M	N	05:02:07.958475	0.0
A 113	M	N	05:02:07.958475	0.0
A 114	M	N	05:02:07.958475	0.0
A 115	M	N	05:02:07.958475	0.0
A 116	M	N	05:02:07.958475	0.0
A 117	M	N	05:02:07.958475	0.0
A 118	M	N	05:02:07.958475	0.0
A 119	M	N	05:02:07.958475	0.0
A 120	M	N	05:02:07.958475	0.0
A 121	M	N	05:02:07.958475	0.0
A 122	M	N	05:02:07.958475	0.0
A 123	M	N	05:02:07.958475	0.0
A 124	M	N	05:02:07.958475	0.0
A 125	M	N	05:02:07.958475	0.0
A 126	M	N	05:02:07.958475	0.0
A 127	M	N	05:02:07.958475	0.0
A 128	M	N	05:02:07.958475	0.0
A 129	M	N	05:02:07.958475	0.0
A 130	M	N	05:02:07.958475	0.0
A 131	M	N	05:02:07.958475	0.0
A 132	M	N	05:02:07.958475	0.0
A 133	M	N	05:02:07.958475	0.0
A 134	M	N	05:02:07.958475	0.0
A 135	M	N	05:02:07.958475	0.0
A 136	M	N	05:02:07.958475	0.0
A 137	M	N	05:02:07.958475	0.0
A 138	M	N	05:02:07.958475	0.0
A 139	M	N	05:02:07.958475	0.0
A 140	M	N	05:02:07.958475	0.0
N 882	BF1	M	05:02:07.958475	0.0

External Fault Detection Logic

In general, operating and restraint currents increase simultaneously for internal faults; for external faults, only the restraint current increases if there is no CT saturation. By comparing the change in operating current ($\Delta IOP1R$) to the change in restraint current ($\Delta IRT1R$), the relay detects external fault conditions. Because CTs can saturate during external faults, the relay asserts the external fault condition (Relay Word bit CON1) for 60 cycles after detecting an external fault.

Figure 5.9 shows the logic for detecting external fault conditions.

5.8 | Protection Functions Busbar Protection Elements




Figure 5.9 External Fault Detection Logic

Asserting CON1 for 60 cycles can slow relay operation for evolving faults (where the fault starts as an external fault and then develops into an internal fault). To prevent delayed tripping, CON1 resets when either the directional element (DE1F) detects an evolving fault or the internal fault detection logic (IFAULT1) confirms an internal fault condition.

Relay Word bit CON1 controls the operating mode of the relay by asserting when

Filtered Differential Element

The following discussion refers to the Filtered Differential Element 1, (with only Terminals O1 and O2 connected to the element) but applies equally well to the remaining five filtered differential elements. Using the output quantities from the digital band-pass filter (cosine filter), the filtered differential element calculates a restraint quantity, IRT1, and an operating quantity, IOP1, according to Equation 5.3 and Equation 5.4:

$$IRT1 = |I01CF| + |I02CF| \quad \text{Equation 5.3}$$

and

$$IOP1 = |I01CF + I02CF| \quad \text{Equation 5.4}$$

where:

I01CF and I02CF = Filtered per unit current values from Terminals I01 and I02

Figure 5.2 shows a block diagram of the elements necessary for obtaining the differential and restraint quantities used in the filtered differential elements. Relay Word bit FDIF1 is the output from the differential calculation. Relay Word bit 87O1 asserts when the differential current exceeds the O87P threshold. Together these two Relay Word bits form the filtered differential element characteristic.




Figure 5.2 Filtered Differential Element 1

Figure 5.3 shows the characteristic of the differential element as a straight line through the origin of the form:

$$IOP1(IRT1) = SLP1 \cdot IRT1 \quad \text{Equation 5.5}$$




Figure 5.3 Filtered Differential Element Characteristic

For operating quantities (IOP1) exceeding the threshold level O87P and falling in the operate region of *Figure 5.3*, the filtered differential element issues an output. There are two slope settings. Slope 1 (SLP1) is effective for internal faults, and Slope 2 (SLP2) is effective for external faults. To change the slope values, first enable the advanced settings by setting EADVS := Y in Group Settings and then proceed to change the slope values. When the fault detection logic detects an external fault condition, Relay Word bit CON1 asserts. CON1 switches the slope of the differential characteristic from Slope 1 to Slope 2 to add security to the filtered differential element (see *Fault Detection Logic* on page 5.7).

Directional Element

The relay includes directional elements that supervise the filtered differential elements. In particular, the directional elements provide additional security to the filtered differential elements during external faults with heavy CT saturation conditions. Each of the six busbar protection elements has a directional element specific to that differential element.


The directional element compares the direction of current at the reference termi-

File Home Insert Page Layout Formulas Data Review View


Clipboard Font Alignment Number Styles Cells Editing

Font: Arial, 11pt, Bold, Italic, Underline, Color, Background Color, Paragraph: Bullets, Numbering, Indentation, Alignment: Left, Center, Right, Justify, Merge & Center, Orientation: Horizontal, Vertical, Text Wrapping: Wrap Text, Number: Decimal places: 2, Percentage: 0%, Thousands separator: On, Conditional Formatting: As Table, Styles: Normal, Bad, Good, Neutral, Calculation, Thick Cell, Cells: Insert, Delete, Format, Editing: AutoSum, Filter, Sort & Filter, Find & Select

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
E7267			NOT B1_35A AND NOT B1_35B AND NOT B1_35C AND B1_52A													
13614	Z1	T2020V	Valid range = The legal operators AND OR NOT R_TRIG_F_TRIG	NA	NA	False	Terminal to Bus Connection Logic		True							
13615	Z1	CT1082N	Select: F, N	N	N	False	Connect Terminal 10 to Bus-Joint 6		False							
13616	Z1	T20210	Range = Maximum of 1 Digital or Analog Elements	E10		True	Terminal E10		True							
13617	Z1	T20960	Range = Maximum of 1 Digital or Analog Elements	B06		True	Bus-Joint B06		True							
13618	Z1	T20960	Select: F, N	P	P	False	Polarity E10-B06		True							
13619	Z1	T2020V	Valid range = The legal operators AND OR NOT R_TRIG_F_TRIG	NA	NA	False	Terminal to Bus Connection Logic		True							
13620	Z1	CT11821	Select: F, N	N	Y	True	Connect Terminal 11 to Bus-Joint 1		False							
13621	Z1	T20261	Range = Maximum of 1 Digital or Analog Elements	E11	VALID_B1	True	Terminal E11		False							
13622	Z1	T20961	Range = Maximum of 1 Digital or Analog Elements	B21	B21	False	Bus-Joint B21		False							
13623	Z1	T20961	Select: F, N	P	P	False	Polarity E11-B21		False							
13624	Z1	T1821V	Valid range = The legal operators AND OR NOT R_TRIG_F_TRIG	NA	B1_30A AND B1_52A	True	Terminal to Bus Connection Logic		False							
13625	Z1	CT11821	Select: F, N	N	Y	True	Connect Terminal 11 to Bus-Joint 2		False							
13626	Z1	T20262	Range = Maximum of 1 Digital or Analog Elements	E11	VALID_B1	True	Terminal E11		False							
13627	Z1	T20962	Range = Maximum of 1 Digital or Analog Elements	B22	B22	False	Bus-Joint B22		False							
13628	Z1	T20962	Select: F, N	P	P	False	Polarity E11-B22		False							
13629	Z1	T1822V	Valid range = The legal operators AND OR NOT R_TRIG_F_TRIG	NA	B1_30B AND B1_52A	True	Terminal to Bus Connection Logic		False							
13630	Z1	CT11821	Select: F, N	N	Y	True	Connect Terminal 11 to Bus-Joint 3		False							
13631	Z1	T20263	Range = Maximum of 1 Digital or Analog Elements	E11	VALID_B1	True	Terminal E11		False							
13632	Z1	T20963	Range = Maximum of 1 Digital or Analog Elements	B23	B23	False	Bus-Joint B23		False							
13633	Z1	T20963	Select: F, N	P	P	False	Polarity E11-B23		False							
13634	Z1	T1823V	Valid range = The legal operators AND OR NOT R_TRIG_F_TRIG	NA	B1_30C AND B0_52A AND B0_39C	True	Terminal to Bus Connection Logic		False							
13635	Z1	CT11821	Select: F, N	N	N	False	Connect Terminal 11 to Bus-Joint 4		False							
13636	Z1	T20264	Range = Maximum of 1 Digital or Analog Elements	E11		True	Terminal E11		True							
13637	Z1	T20964	Range = Maximum of 1 Digital or Analog Elements	B24		True	Bus-Joint B24		True							



Damaged CB of
Badhaikalan line



← Rph Dropper wire
of Badhaikalan line



Damaged isolator of Shamli line


Remedial Measures Taken:

- 220kV Badhaikalan line CB R phase Pole replacement work is under progress. Line is being fed by TBC.
- Broken earthwire of Badhaikalan line was repaired before charging of the line.
- 220kV Shamli line Isolator arm's post insulator was replaced on the same day of event.

CONCLUSION

- **To avoid such type of incidence in future we arrive on conclusion that in SEL487B busbar relay, zone-1assignment logic for any bay which is at present boolean AND of isolator A(89A) and breaker auxiliary contact (52a) status, needs to be revised.**

“Thank You”



**Multiple elements tripping at
400/220kV Sahupuri(UP)
10th July 2024**

Brief of event:

- i. 400/220kV Sahupuri(UP) has double main double scheme at 400kV and 220kV level.
- ii. During antecedent condition at 15:52 hrs, 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2, 400 KV Sahupuri(UP)-Biharshariff(PG) (PG) Ckt-1 and 400/220 kV 500 MVA ICT-2 were connected to 400kV bus-1 and 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-1 and 400 KV Sahupuri(UP)-Biharshariff(PG) (PG) Ckt-2 were connected to 400kV bus-2 at 400kV Sahupuri(UP) S/s. 400/220 kV 500 MVA ICT-1 at Sahupuri(UP) is under installation (commissioning) process.
- iii. As reported, at 15:54 hrs, Y-N phase to earth fault occurred in GIS compartment at 400kV Sahupuri(UP) (exact location of fault is yet to be received). It is suspected that fault location was in the bay of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2 in GIS compartment at 400kV Sahupuri(UP).
- iv. On this fault, 400 KV Sahupuri(UP)-Biharshariff(PG) (PG) Ckt-1 & 2 (fault current $I_y \sim 1.1\text{kA}$ from Sahupuri end) tripped only from Sahupuri(UP) end on zone-4 distance protection. 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-1 & 2 (fault current $I_y \sim 3.3\text{kA}$ from Varanasi end, $I_y \sim 3.6\text{kA}$ from Sahupuri end) tripped only from Varanasi(PG) end on zone-2 distance protection and fault sensed in zone-4 from Sahupuri(UP) end. 400/220 kV 500 MVA ICT 2 at Sahupuri(UP) and also tripped (details of protection operation is yet to receive).
- v. As reported, from 15:27 hrs to 17:49 hrs, multiple 220 & 132kV line also tripped at 220kV Sahupuri S/s i.e. 220kV Sahupuri-Churk ckt, 220kV Sahupuri-Raja Talab ckt, 220kV Sahupuri(400kV)-Sahupuri(200kV) interconnector, 132kV Sahupuri-Aliapur ckt, 132kV Sahupuri-Karamnasha ckt, 132kV Sahupuri-Chandauli ckt, 132kV Sahupuri-Sadat ckt and 132kV Sahupuri-Dhanapur ckt. Reason of tripping of these lines are yet to be received.


Brief of event:

- vi. As per PMU at Varanasi(PG), at 15:54 hrs, Y-N phase to earth fault with delayed fault clearance time of 400msec is observed (Reason for delayed fault clearance is yet to receive).
- vii. As per SCADA, at 15:54 hrs, change in demand of approx. 100 MW in UP control area.
- viii. By 18:29 hrs, 400 KV Sahupuri(UP)-Biharshariff(PG) (PG) D/C and 400/220 kV 500 MVA ICT-2 were charged.

Elements tripped:

- i. 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-1
- ii. 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2
- iii. 400 KV Sahupuri(UP)-Biharshariff(PG) (PG) Ckt-1
- iv. 400 KV Sahupuri(UP)-Biharshariff(PG) (PG) Ckt-2
- v. 400/220 kV 500 MVA ICT 2 at Sahupuri(UP)
- vi. 132 KV Sahupuri(UP)-Karamnasa(BS) (UP) Ckt-1


Network Diagram



SLD of 400/220 KV Sahupuri(UP) @ 15:52 hrs

SAHUPURI-400KV UP

Stat Expl GenSum Company



SLD of 765/400KV Varanasi(PG) @ 15:52 hrs

CONTACT DETAILS	
EMAIL	varanasi765kv@powergrid.co.in
MOBILE	635749336
HOTLINE	20112472


size(500 kv) - 1.000
size(400 kv) - 4.00

VARANASI (GIS)


Stat Expl GenSum Company

size(500 kv) - 0.00
size(400 kv) - 12.00

10.7 15:51:59




SLD of 765/400KV Varanasi(PG) @ 15:52 hrs



SLD of 400/220 KV Sahupuri(UP) @ 15:56 hrs

SAHUPURI-400KV UP

Stat Expl GenSum Company



SLD of 400/220 KV Sahupuri(UP) @ 15:58 hrs

SAHUPURI-400KV UP

Stat Expl GenSum Company




SLD of 765/400KV Varanasi(PG) @ 15:58 hrs

CONTACT DETAILS	
EMAIL	varanasi765kv@powergrid.co.in
MOBILE	635746336
HOTLINE	20812472

220(50 kv) - 1.810
220(500 kv) - 1.820

VARANASI (GIS)


Stat Expl GenSum Company
10.7 15:57:59



SLD of 400/220 KV Sahupuri(UP) @ 18:35 hrs

SAHUPURI-400KV UP


Stat Expl GenSum Company



SLD of 400/220 KV Sahupuri(UP) @ 18:39 hrs


SAHUPURI-400KV UP

Stat Expl GenSum Company




SLD of 400/220 KV Sahupuri(UP) @ 19:24 hrs

SAHUPURI-400KV UP
Stat Expl GenSum Company




SLD of 765/400KV Varanasi(PG) @ 19:24 hrs




SLD of 400/220 KV Sahupuri(UP) @ 19:28 hrs


SAHUPURI-400KV_UP
Stat Expl GenSum Company



SLD of 765/400KV Varanasi(PG) @ 19:28 hrs




Uttar Pradesh Demand during the event (@ 15:54 hrs)




Uttar Pradesh Demand during the event (@ 18:37 hrs)

Uttar Pradesh Demand



Uttar Pradesh Demand during the event (@ 19:25 hrs)



PMU Plot of frequency at Varanasi(PG)

15:54 hrs/10-July-24



PMU Plot of frequency at Varanasi(PG)

18:37 hrs/10-July-24



PMU Plot of frequency at Varanasi(PG)

19:25 hrs/10-July-24



PMU Plot of phase voltage magnitude at Varanasi(PG)

15:54 hrs/10-July-24




PMU Plot of phase voltage magnitude at Varanasi(PG)

18:37 hrs/10-July-24




PMU Plot of phase voltage magnitude at Varanasi(PG)

19:25 hrs/10-July-24




— YB	— YR	— YG
SubstationId: VRNST_PG	SubstationId: VRNST_PG	SubstationId: VRNST_PG
DeviceId: 400BUS1_____	DeviceId: 400BUS1_____	DeviceId: 400BUS1_____

DR of 400 KV Varanasi(PG)(end)-Sahupuri(UP) (PG) Ckt-1 (15:54 hrs)




- ✓ Y-N phase to earth fault. $I_y \approx 3.3\text{kA}$.
- ✓ Zone-2 distance protection operated.

DR of 400 KV Varanasi(PG)(end)-Sahupuri(UP) (PG) Ckt-2 (15:54 hrs)




- ✓ Y-N phase to earth fault. $I_y \approx 3.6\text{kA}$.
- ✓ Zone-2 distance protection operated.

DR of 400 KV Sahupuri(UP)(end)-Biharshariff(PG) (PG) Ckt-1 (15:54 hrs)




- ✓ Y-N phase to earth fault. $I_y \sim 1.1 \text{ kA}$.
- ✓ Zone-4 distance protection operated.

DR of 400 KV Sahupuri(UP)(end)-Biharshariff(PG) (PG) Ckt-2 (15:54 hrs)




- ✓ Y-N phase to earth fault. $I_y \sim 1.1\text{kA}$.
- ✓ Zone-4 distance protection operated.

DR of 400 KV Sahupuri(UP)(end)-Biharshariff(PG) (PG) Ckt-1 (18:37 hrs)



- ✓ Y-N phase to earth fault. $I_y \sim 1.3 \text{ kA}$.
- ✓ Zone-4 distance protection operated.

DR of 400 KV Sahupuri(UP)(end)-Biharshariff(PG) (PG) Ckt-2 (18:37 hrs)



- ✓ Y-N phase to earth fault. $I_y \sim 1.3\text{kA}$.
- ✓ Zone-4 distance protection operated.

SCADA SOE


Time	Station Name	Voltage	Element Name	Element Type	Element Status	Remarks
15:54:36,503	VRNS1_PG	400kV	2BHRTIE	Circuit Breaker	Open	Tie CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2 opened
15:54:36,503	VRNS1_PG	400kV	5ALBDBHR	Circuit Breaker	Open	Tie CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-1 opened
15:54:36,503	VRNS1_PG	400kV	3SAHU2	Circuit Breaker	Open	Main CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2 opened
15:54:36,504	VRNS1_PG	400kV	4SAHU1	Circuit Breaker	Open	Main CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-1 opened
15:57:26,280	BHLPR_UP	33kV	04BHLPR	Circuit Breaker	Open	Line CB at Bhelupur(UP) end of 33kV Bhelupur-Bhelupur (UP) ckt opened

SCADA SOE

Time	Station Name	Voltage	Element Name	Element Type	Element Status	Remarks
19:24:24,814	VRNS1_PG	400kV	3SAHU2	Circuit Breaker	Close	Main CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2 closed
19:25:33,550	VRNS1_PG	400kV	5ALBDBHR	Circuit Breaker	Open	Tie CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2 opened
19:25:33,550	VRNS1_PG	400kV	4SAHU1	Circuit Breaker	Open	Main CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-1 opened
19:26:06,556	VRNS1_PG	400kV	3SAHU2	Circuit Breaker	Open	Main CB at Varanasi(PG) end of 400 KV Varanasi(PG)-Sahupuri(UP) (PG) Ckt-2 opened

Point of discussion

- i) Reason for delayed fault clearance in all tripping events need to be shared.
- ii) Reason and type of protection operated for tripping of multiple elements at 220kV Sahupuri(UP) S/s is yet to be received.
- iii) Exact location of fault need to be shared.
- iv) Type of protection operated in tripping of 400/220 kV 500 MVA ICT-2 at Sahupuri(UP) need to be shared.
- v) DR/EL (.dat/.cfg file) of 400/220 kV 500 MVA ICT-2 at 400kV Sahupuri(UP) and multiple elements tripped at 220kV Sahupuri(UP) along with detailed tripping report need to be shared.
- vi) Remedial action taken report to be shared.
- vii) SCADA data of 400kV Sahupuri(UP) S/s was freeze and some trippings were not recorded in SCADA SOE during the event. Healthiness of SCADA data at 400kV Sahupuri(UP) S/s and 220kV Sahupuri(UP) S/s need to be ensured.



**Tripping Analysis Report of
multiple element Tripping
event on 10.07.2024 at 400 kV
GIS Sub-Station Sahupuri-
Chandauli**

Details of Tripping


On dated 10.07.2024 at 15:54 hrs multiple tripping occurred at 400 kV GIS Sub-Station Sahupuri (Chandauli) due to fault persist in GIS Module between Breaker & Bus Isolator at 400 kV Sahupuri- Varanasi (PG)- II Line,

Both 400 kV Sahupuri-Biharsharif-I & II line Tripped in zone-4 from Sahupuri End and 400 KV Sahupuri - Varanasi (PG)- I & II Line Tripped in Zone-2 from other end. Also, 500 MVA ICT-II Tripped on E/F Highset Flag.

400 kV Biharsharif Circuit-II charged at 17:35 hrs and 400 kV Biharsharif Circuit-I charged at 17:53 Tripped but both lines tripped again at 18:37 hrs in zone-4, 400 / 220 kV 500 MVA ICT-II again tripped at 18:37 Hrs along with these two lines & finally charged at 22:59 Hrs.

400 kV Varanasi (PG)- I Line is charged at 18:54 Hrs & taken on Load. After that, 400 kV Varanasi (PG)- II Line was tried to charged at 19:26 Hrs but tripped instantaneously from Varanasi (PG) End along with Varanasi (PG)-I Line on Zone- 2.

SLD OF TRIP EVENTS OCCURED AT 15:54 hrs



Single Line Diagram of 400 kV GIS Sahupuri (Chandauli)

1). Exact Reason of Trippings:-

- ❖ Flashover occurred between Bus Isolator & Circuit Breaker Section of GIS Module of Bay 407, 400 kV Sahupuri - Varanasi - II (PG) Line.

2). Nature & location of Faults

- ❖ Fault is of flashover type & location is between Bus Isolator & Circuit Breaker Section of GIS Module of Bay 407, 400 kV Sahupuri - Varanasi - II (PG) Line.

3). Sequence of tripping events

At 15:54 Hrs, following elements were tripped:-


- 400 kV Sahupuri - Biharsharif - I Line
- 400 kV Sahupuri - Biharsharif - II Line
- 400 kV Sahupuri - Varanasi- I (PG) Line
- 400 kV Sahupuri - Varanasi- II (PG) Line
- 500 MVA ICT-II

After trippings at 15:54 Hrs, except Varanasi - I & II (PG) Line, Biharsharif Ckt-I & II, 500 MVA ICT-II were charged at 17:53, 17:35 & 17:59 Hrs respectively from Bus-I.


At 18:37 Hrs, following elements once again tripped:-

- 400 kV Sahupuri - Biharsharif - I Line
- 400 kV Sahupuri - Biharsharif - II Line
- 500 MVA ICT-II


At 18:54 Hrs, Varanasi - I (PG) Line was charged from both ends. Varnasi -II (PG) line was tried to charge at 19:26 Hrs but tripped instantaneously from Varanasi (PG) End along with Varanasi-I Line on Zone- 2.




Fault Initiation, Bay 409- 400 kV SHP – Bihar Sharif-I (PG) Line at 15:54 Hrs




Tripping Command, Bay 409-400 kV SHP – Bihar Sharif-I (PG) Line at 15:54 Hrs




Fault Initiation, Bay 409- 400 kV SHP – Bihar Sharif-I (PG) Line at 18:37 Hrs




Tripping Command Bay 409- 400 kV SHP – Bihar Sharif-I (PG) Line at 18:37 Hrs




Fault Initiation Bay 410- 400 kV SHP – Bihar Sharif-II (PG) Line at 15:54 Hrs




Tripping Command Bay 410- 400 kV SHP – Bihar Sharif-II (PG) Line at 15:54 Hrs




Fault Initiation Bay 410- 400 kV SHP – Bihar Sharif-II (PG) Line at 18:37 Hrs




Tripping Command Bay 410- 400 kV SHP – Bihar Sharif-II (PG) Line at 18:37 Hrs




Fault Initiation & Tripping Command 500 MVA ICT-II at 15:54 Hrs




Fault Initiation & Tripping Command 500 MVA ICT-II at 18:37 Hrs




Fault Initiation Bay 404- 400 kV SHP – Varanasi-I (PG) Line at 15:54 Hrs



Fault End Point Bay 404- 400 kV SHP – Varanasi-I (PG) Line at 15:54 Hrs



Fault Initiation Bay 404- 400 kV SHP – Varanasi-I (PG) Line at 19:25 Hrs



Fault End Point Bay 404- 400 kV SHP – Varanasi-I (PG) Line at 19:25 Hrs

4). Details of Protection Operation & Relay Flags:-

- A). 400 kV Sahupuri - Biharsharif -I Line - Y-Ph Optd, GND PU, Zone-4 Trip, 86 Trip Relay Optd
- B). 400 kV Sahupuri - Biharsharif -II Line - Y-Ph Optd, GND PU, Zone-4 Trip, 86 Trip Relay Optd,
- C). 400 kV Sahupuri - Varanasi (PG)- I (PG) Line - Tripped from Varanasi (PG) End on Zone - 2
- D). 400 kV Sahupuri - Varanasi (PG)- II (PG) Line - Tripped from Varanasi (PG) End on Zone - 2
- E). 400/220 kV 500 MVA ICT-II - E/F Highset Trip, 86 Trip Relay Optd

Note:- Above elements tripped again at 18:37 Hrs & 19:26 Hrs on almost same flags.

5). DR (.dat / .cfg) file w.r.t. protection operation

Enclosed

6). Reason for delayed fault clearance:-

400 kV Sahupuri - Biharsharif -I & II Line tripped on Zone-4 with a time delay of 450 ms as Bus Bar protection was kept out of circuit (due to some bay integration issue in busbar).

7). Details of load loss in UP Control Area / Substation

131 MW (Load on 500 MVA ICT-II at 15:30 Hrs)

8). Remedial Action taken to avoid such events in future

Bus Bar protection system is now in circuit & Replacement of GIS Module is under progress.

**Multiple elements tripping at
220kV Palli(HR)
16th August 2024**


Brief of event:

- i. During antecedent condition, 220 kV Palli S/S importing load from 220 KV Samaypur (BB)-Palli (HV) (HVPNL) Ckt-1 & Ckt-2, 220 KV Badshahpur (HV)-Palli (HV) (HVPNL) Ckt-1 & ckt-2 and 220 KV Sector-56 (Gurgaon) -Palli (HV) (HVPNL) Ckt-1 & Ckt-2 and feeding that load to 220 KV Palla (HV) (Sec-46) & 220 KV Palli (2*100MVA+1*160MVA) S/S.
- ii. As reported, to manage the line loading on sector-72 Gurgaon ckt, 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-1 was opened at 22:10 hrs on the instruction of SLDC-Haryana. This led to sparking on the 220 KV Sector 52 (HV) (Sec-56 Gurgaon)-Palli (HV) (HVPNL) Ckt-2 at Palli S/S end.
- iii. At the same time, busbar protection operated at 220kV Palli(HV) due to which all the elements connected to 220kV Bus-1 and 2 at Palli(HV) tripped and complete blackout occurred at Palli(HV) S/s.
- iv. As per PMU, R-Y phase to phase fault with delayed fault clearing time of 880 ms was observed.
- v. As per SCADA, change in demand of approx. 600 MW and 980 MW in Delhi and Haryana control area respectively were observed. However, as reported, approx. 400 MW load loss occurred at Palli & Sec-46 (Faridabad). Rest of the change in demand is suspected due to stalling of induction motor.

Elements tripped:

- i. 220 KV Samaypur (BB)-Palli (HV) (HVPNL) Ckt-1
- ii. 220 KV Samaypur (BB)-Palli (HV) (HVPNL) Ckt-2
- iii. 220 KV Badshahpur (HV)-Palli (HV) (HVPNL) Ckt-1
- iv. 220 KV Badshahpur (HV)-Palli (HV) (HVPNL) Ckt-2
- v. 220 KV Palla (HV) (Sec-46) -Palli (HV) (HVPNL) Ckt-1
- vi. 220 KV Palla (HV) (Sec-46) -Palli (HV) (HVPNL) Ckt-2
- vii. 220 KV Sector 52 (HV) (Sec-56 Gurgoan)-Palli (HV) (HVPNL) Ckt-1
- viii. 220 KV Sector 52 (HV) (Sec-56 Gurgoan)-Palli (HV) (HVPNL) Ckt-2


Network Diagram



SLD of 220/66kV Palli(HV) before the event

PALLI


Red Logo Logo Company




SLD of 220/66kV Palli(HV) after the event

PALLI


Line Expl. GenCircs Company



SLD of 220kV Samaypur(BB) before the event



SLD of 220kV Samaypur(BB) after the event




Haryana demand during the event

Haryana Demand Met




Delhi demand during the event

Delhi Demand Met




PMU Plot of frequency at Bassi(PG)

22:10 hrs/16-July-24



PMU Plot of Phase Voltage Magnitude at Ballabgarh(PG)

22:10 hrs/16-July-24



SCADA SOE

Time	Station Name	Voltage Level	Element Name	Element Type	Element Status	Remarks
22:10:48,296	SMYUR_BB	220kV	12PALLI2	Circuit Breaker	Open	Line CB at Samaypur(BBMB) end of 220 KV Samaypur(BB)-Palli(HV) (HVPNL) Ckt-2 opened

DR summary file of 220kV Samaypur(end)-Palli ckt-2

Disturbance Short Report

Disturbance Recordings Information

Device Information

Station name PALI-2 MCOM M-2
Object name 1

Fault Information


Trig date and time 16-07-2024 22:08:48.487

General Recordings Information

System frequency 50 Hz

Analog Time Diagram

Trig Date Time: 16-07-2024 22:08:48.487



Binary Time Diagram

Trig Date Time: 16-07-2024 22:08:48.487



R-N fault, Z-2, FD:13.45km

Point of discussion

- i) Exact reason, location and nature of fault need to be shared.
- ii) Reason of delayed clearance of fault need to be shared.
- iii) Reason of tripping of multiple elements.
- iv) Feeder-wise load loss details need to be shared.
- v) SCADA data issue was observed at 220/66kV Palli(HV) during the event. Availability and healthiness of SCADA data need to be ensured.
- vi) DR/EL (.dat/.cfg file) of all tripped elements need to be shared.
- vii) Remedial action taken report need to be shared.

**Multiple elements tripping at
220kV Khodri HEP
19th July 2024**


Brief of event:

- i. During antecedent condition, all the four 30MW units of Khodri and 60 MW units of Chhibro were running and total active power generation of Khodri and Chhibro was approx. 89 MW and 196 MW (as per SCADA). Total generation of Chhibro was evacuating through 220 KV Khodri-Chhibro (UK) Ckt-1 & 2.
- ii. As reported, at 21:31 hrs, while taking out 30MW Khodri Unit-2, B-phase pole of CB of Unit-2 did not open. This led to LBB protection operation which further resulted in tripping of all the elements connected to both the buses at 220kV Khodri(UK) and complete blackout occurred at 220kV Khodri(UK) S/s.
- iii. Due to tripping of 220 KV Khodri-Chhibro (UK) Ckt-1 & 2, 60 MW Chhibro Unit-1, 2, 3 & 4 also tripped due to loss of evacuation path and complete blackout occurred at 220kV Chhibro(UK) S/s.
- iv. As per PMU, no fault was observed in the system.
- v. As per SCADA, change in demand and generation of approx. 30 MW and 300 MW respectively in Uttarakhand control area were observed.
- vi. As remedial action taken, over hauling & testing of generator CB has been performed and found satisfactory.


Elements tripped:

- i. 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-1
- ii. 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-2
- iii. 220 KV Khodri(UK)-Sarsawan(UP) (UP) Ckt
- iv. 220 KV Khodri(UK)-Saharanpur(UP) (UP) Ckt
- v. 220 KV Khodri-Chhibro (UK) Ckt-1
- vi. 220 KV Khodri-Chhibro (UK) Ckt-2
- vii. 30 MW Khodri Unit-1, 2, 3 & 4
- viii. 60 MW Chhibro Unit-1, 2, 3 & 4


Network Diagram



SLD of 220kV Khodri(UK) before the event



SLD of 220kV Khodri(UK) after the event



SLD of 220kV Chhibro(UK) before the event

CHHIBRO

Wrong CB status

Stat Expl

GenSum

Company

19.7 . 21:29:0

GEN-1


GEN-2

GEN-3

GEN-4

Khodr2

Khodr1



SLD of 220kV Chhibro(UK) after the event

CHHIBRO


Stat Expl

GenSum

Company


220kV Chhibro(UK)
S/s blackout

19.7 . 21:33:0




Uttarakhand demand during the event

Uttarakhand Demand Met



Uttarakhand generation during the event


■ UTTARAKHAND GENERATION



Jul 19 Fri 2024

Khodri and Chhibro generation during the event

Khodri and Chhibro Generation during the event



PMU Plot of frequency at Saharanpur(PG)

21:31 hrs/19-July-24



PMU Plot of Phase Voltage Magnitude at Saharanpur(PG)

21:31 hrs/19-July-24



SCADA SOE

Time	Station Name	Voltage Level	Element Name	Element Type	Element Status	Remarks
21:31:06,690	KHODR_UK	220kV	F3CHBRO1	Circuit Breaker	disturbe	
21:31:06,690	KHODR_UK	220kV	SRNPR2	Circuit	Open	Line CB at Khodri(UK) end of 220 kVSaharanpur (UP)-Khodri(UK) (UP) Ckt opened
21:31:15,904	CHBRO_UK	220kV	G3G3	Circuit	disturbe	
21:31:45,752	CHBRO_UK	220kV	G4G4	Circuit	disturbe	
21:31:45,752	CHBRO_UK	220kV	G2G2	Circuit	disturbe	
21:31:45,752	CHBRO_UK	220kV	G1G1	Circuit	disturbe	
21:32:16,208	KHODR_UK	220kV	F1JHJRA	Circuit	disturbe	
21:32:16,208	KHODR_UK	220kV	88MAJRI2	Circuit	disturbe	

Details received from Khodri(Utt)

Mechanical failure of Unit # 02 on 19.07.2024 at 4 x 30 MW Khodri Power Station.

S.No	Brief description of deficiency	Please tick appropriate type of deficiencies		Action plan to rectify deficiencies in protection system indicating intermediate milestone with date	Date on which complete rectification of deficiency is expected	Compliance w.r.t. Time schedule indicated and constraints, if any in compliance thereof	Remark
		Category - A (Where no procurement is involve)	Category - B (Where procurement is involve)				
1	Mechanical failure of 220 kV GCB of Unit # 02's B phase pole trip/open mechanism on 19.07.2024 at 21:31 hrs.	-	-	The trip/open mechanism of the 220 kV GCB repaired after replacement of control valve assembly & tripping coil and overhauling done. Thereafter Open close timing noted and CRM testing performed. [Copy attached].	At 19:30 hrs on 20.07.2024 the GCB was energised.		The Breaker failure/LBB protection operated resulting in opening of all 220 kV Circuit breakers i.e., 04 Generation units + Feeder no. 81, 82, 83, 84, 86, 87, 88, 85 (Bus coupler) and 885 (Auto transformer) alongwith 01 no. 132 k V (785) feeder.

Testing report

Date: - 20/07/2024

Technical report

CGL make 220KV Circuit breaker # 2 installed at Khodri switchyard Power Station

In reference to offer No : SS/CR/BPO/ CG/ 0024/2024-2025, following work of replacement of defective Control valve Assembly, gasket and trip coil with new ones was carried out (Control valve Assembly, Gasket and Trip coil was provided by the UJVN Limited and following works as mentioned below were also carried out.

1. Dismantling of control valve Assembly from the Mechanism housing.
2. Dismantling of control valve sheet, bend pipe O ring & trip coil from the Mechanism housing.
3. Fixing of new control valve Assembly into the Mechanism housing.
4. Fixing of new control valve sheet, bend pipe O ring & trip coil into the Mechanism housing
5. After replacement of spares, filled air pressure up to 15 Kg/Sq. cm
6. Electrical & manually (Close, Open, Pole Discrepancy and Anti pumping) operation checked found working satisfactorily
7. Whole breaker tested (CRM and Time interval) as per following report satisfactorily.

Timing in milli – Second(ms)	Unit #2 882 Breaker			
	C	O (TC-I)	O (TC-II)	CRM ($\mu\Omega$)
R	85.0	20.0	20.0	49.2
Y	85.0	20.0	20.0	47.4
B	87.0	20.0	20.0	46.9

Work of CGL make 220KV SF6 breakers was carried out by service team of M/s Shrihar Switchgears & Services Pvt Ltd. This will ensure you, the smooth and safety operation. Now the breaker is ready for operations.

Point of discussion

- i) Due to LBB operation, only the elements connected to the same bus as Unit-2 should have tripped. Exact reason of ripping of the elements connected to the other bus at Khodri need to be shared.
- ii) Wrong status of CB at Khodri and Chhibro was observed during the event. Availability and healthiness of SCADA data need to be ensured.
- iii) DR/EL (.dat/.cfg file) of all tripped elements need to be shared.

**Multiple elements tripping at
220kV Shahbad(HR) & Rajokheri(HR)
26th August 2024**

Brief of event:

- i. 220kV Rajokheri(HV) & 220kV Shahbad(HV) S/s have double main bus arrangement at 220kV side.
- ii. During antecedent condition, incoming power at Rajokheri(HV) S/s through 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) D/C was approx. 115 MW and outgoing power from Rajokheri(HV) through 220 KV Shahbad-Rajokheri(HV)(HVPNL) D/C was approx. 90 MW. Loading of 220 KV Shahbad-Joria(HV)(HVPNL) D/C and 220 KV Shahbad Durla(HV)(HVPNL) D/C were approx. 100 MW and 75 MW feeding to Shahbad(HV) and Durla(HV) respectively.
- iii. As reported, at 22:58 hrs, due to inclement weather conditions, **Y-B phase to phase occurred on 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1 & 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-1.**
- iv. As reported, 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) D/C tripped only from Abdullapur(PG) end not from Rajokheri(HV) end. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1 tripped on zone-1 distance protection on Y-B-G double phase to ground fault with fault distance of 29km and fault current of $I_y \sim 5.79\text{kA}$ & $I_b \sim 5.39\text{kA}$ from Rajokheri(HV) end. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-2 & 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-2 tripped on direction earth fault from Rajokheri(HV) end. 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-1 tripped on zone-3 distance protection on Y-B phase to phase fault from Rajokheri(HV) end (details regarding trippings at Shahbad(HV) S/s is yet to be received).
- v. As per PMU at Abdullapur(PG), Y-B phase to phase fault converted into R-Y-B three phase fault with delayed fault clearing time of 2040msec is observed.


Brief of event:

- vi. Due to tripping of all 220kV lines at Rajokheri(HV) & Shahbad(HV), both sub-stations lost their connectivity from Grid which led to blackout of 220kV Rajokheri(HV) S/s & 220kV Shahbad(HV) S/s.
- vii. As per SCADA, change in demand of approx. 350 MW in Haryana control area.


Elements tripped:

- i. 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-1
- ii. 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-2
- iii. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-1
- iv. 220 KV Shahbad-Rajokheri(HV)(HVPNL) Ckt-2
- v. 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-1
- vi. 220 KV Tepla-Rajokheri(HV)(HVPNL) Ckt-2
- vii. 220 KV Shahbad-Durla(HV)(HVPNL) Ckt-1
- viii. 220 KV Shahbad-Durla(HV)(HVPNL) Ckt-2
- ix. 220 KV Shahbad-Joria(HV)(HVPNL) Ckt-1
- x. 220 KV Shahbad-Joria(HV)(HVPNL) Ckt-2

Network Diagram



SLD of 220kV Rajokheri(HV) before the event




SLD of 220kV Rajokheri(HV) after the event


RAJOKHERI

BarGraph BusColor LineColor


26.8 22:59:39



SLD of 220kV Shahbad(HV) before the event




SLD of 220kV Shahbad(HV) after the event




Haryana Demand during the event

Haryana Demand Met



PMU Plot of frequency at Abdullapur(PG)

22:58 hrs/26-August-24



PMU Plot of Phase voltage magnitude at Abdullapur(PG)


22:58 hrs/26-August-24



SCADA SOE


Time	Station Name	Voltage	Element Name	Element Type	Element Status	Remarks
22:58:19,921	ABDUL_PG	220kV	15RJKHR1	Circuit Breaker	Open	Line CB at Abdullapur(PG) end of 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-1 opened
22:58:21,008	RJKRI_HS	220kV	03TEPLA1	Circuit Breaker	Open	Line CB at Rajokheri(HV) end of 220 KV Tepla-Rajokheri (HVPNL) Ckt-1 opened
22:58:21,955	SHBAD_HS	220kV	09T2	Circuit Breaker	Open	CB at Shahbad(HV) end of 220/66kVICT-2 opened from 220kV side
22:58:21,968	SHBAD_HS	220kV	03TEPLA1	Circuit Breaker	Open	Line CB at Shahbad(HV) end of 220 KV Tepla-Shahbad (HVPNL) Ckt-1 opened
22:58:21,973	RJKRI_HS	220kV	04TEPLA2	Circuit Breaker	Open	Line CB at Rajokheri(HV) end of 220 KV Tepla-Rajokheri (HVPNL) Ckt-2 opened
22:58:21,975	RJKRI_HS	220kV	08MBC	Circuit Breaker	Open	Main bus coupler at Rajokheri(HV) end of 220kV bus-1 & bus-2 opened
22:58:21,986	ABDUL_PG	220kV	16RJKHR2	Circuit Breaker	Open	Line CB at Abdullapur(PG) end of 220 KV Abdullapur(PG)-Rajokheri (HV) (HVPNL) Ckt-2 opened
22:58:21,998	SHBAD_HS	220kV	05JORIA1	Circuit Breaker	Open	Line CB at Shahbad(HV) end of 220 KV Joria-Shahbad (HVPNL) Ckt-1 opened
22:58:21,999	SHBAD_HS	220kV	08MBC	Circuit Breaker	Open	Main bus coupler at Shahbad(HV) end of 220kV bus-1 & bus-2 opened
22:58:22,005	SHBAD_HS	220kV	04TEPLA2	Circuit Breaker	Open	Line CB at Shahbad(HV) end of 220 KV Tepla-Shahbad (HVPNL) Ckt-2 opened
22:58:22,007	SHBAD_HS	220kV	02DURLA1	Circuit Breaker	Open	Line CB at Shahbad(HV) end of 220 KV Durla-Shahbad (HVPNL) Ckt-1 opened
22:58:22,009	SHBAD_HS	220kV	06JORIA2	Circuit Breaker	Open	Line CB at Shahbad(HV) end of 220 KV Joria-Shahbad (HVPNL) Ckt-2 opened
22:58:22,017	RJKRI_HS	220kV	02SHBAD2	Circuit Breaker	Open	Line CB at Rajokheri(HV) end of 220 KV Shahbad-Rajokheri (HVPNL) Ckt-2 opened
22:58:22,039	RJKRI_HS	220kV	01SHBAD1	Circuit Breaker	Open	Line CB at Rajokheri(HV) end of 220 KV Shahbad-Rajokheri (HVPNL) Ckt-1 opened
22:58:22,781	SHBAD_HS	220kV	01DURLA2	Circuit Breaker	Open	Line CB at Shahbad(HV) end of 220 KV Durla-Shahbad (HVPNL) Ckt-2 opened

DR of 220kV Abdullapur(end)-Rajokheri ckt-1



Y-B fault, Z-1, 3-ph trip (As reported, FD:1.3km)

DR of 220kV Abdullapur(end)-Rajokheri ckt-2



R-Y-B fault, Z-2, 3-ph trip (As reported, FD:23.41km)

Protection operation at 220kV Shahbad(HR) (details submitted by HVPNL)

9	220kV Shahbad XEN TS Ambala	220kV Shahbad - Durala Ckt.-1	(26.08.24) 22:57	(26.08.24) 23:35	00:38	Bus Bar Protection operated	Not tripped	Bus Bar Protection operated alongwith 220kV Rajokheri - Shahbad Ckt.-1		Nil	<p>protection was operated.</p> <ol style="list-style-type: none"> The 220 KV Bus bar protection was operated showing check zone differential current with the tripping of 220 KV Rajokheri ckt-1 from 220 KV Shahbad. During checking it was found that the open/close status of 220 KV isolators on Bus -1 and Bus-2 are not coming properly in the bus bar differential relays (R,Y & B phase). Due to this bus bar differential scheme was not able to sense the proper CT selection circuit and creates the difference in the check zone however there was no fault current recorded in the Zone-1 and Zone-2 in the Bus bar protection relay. Further the control cables in the Bus Bar Protection panel were found short circuited during set right the proper status of isolators. SSE is advised to monitor the proper selection of Isolators on Bus-1 and Bus-2 and Open and close status of Breakers in the 220 KV Bus Bar protection relays.
10		220kV Shahbad - Durala Ckt.-2	(26.08.24) 22:57	(26.08.24) 23:40	00:43						
11		220kV Shahbad - Jorian Ckt.-1	(26.08.24) 22:57	(26.08.24) 23:20	00:23						
12		220kV Shahbad - Jorian Ckt.-2	(26.08.24) 22:57	(26.08.24) 23:23	00:26						
13		220kV Bus Coupler	(26.08.24) 22:57	(26.08.24) 23:25	00:28						
14		220/66kV 100 MVA T/F T-1	(26.08.24) 22:57	(26.08.24) 23:26	00:31						
15		220/66kV 100 MVA T/F T-2	(26.08.24) 22:57	(26.08.24) 23:30	00:33						
16	220/66kV 100 MVA T/F T-6	(26.08.24) 22:57	(26.08.24) 23:33	00:36							

Yes
(220kV S/Bad
upto 23:28
hrs.)

Yes
(220kV S/Bad
upto 23:28
hrs (73 Nos.
11kV
Feeders)

Point of discussion

- Exact location of fault seen by distance protection relay at Rajokheri end at 22:58:19:800 hrs ?
- Protection operation at 22:58:19:800 hrs at Rajokheri end on Y-B fault? Delayed clearance of fault is observed.
- DR/EL of all the tripped lines at Rajokheri end not received. Same need to be submitted.
- As reported, Bus bar differential relay maloperated at 220kV Shahbad(HR) due to issue in isolator status. Exact details of issues need to be shared.
- DR of bus bar relay need to be shared.
- Remedial action taken report to be shared.

**Multiple elements tripping at
220kV Barn (J&K)
02nd August 2024**


Brief of event:

- i. As reported, at 15:03hrs, 220/132kV 160MVA ICT-1, 132kV Barn-Canal (JK) D/C tripped at Barn(JK) S/s on Y-B phase to phase fault which occurred on 132kV Barn-Canal (JK) D/C (exact reason, location of fault and type of protection operated is yet to be received).
- ii. As reported, due to tripping of ICT-1, the complete load shifted on 220/132kV 160MVA ICT-2 & 3 which led to tripping of 220/132kV 160MVA ICT-2 & 3 on overloading at Barn(JK) S/s.
- iii. As per PMU at Kishenpur(PG), Y-B phase to phase fault with fault clearing time of 120ms is observed.
- iv. As per SCADA, load loss of approx. 345MW occurred in J&K control area.


Elements tripped:

- i. 220/132kV 160MVA ICT-1 at Barn (JK)
- ii. 220/132kV 160MVA ICT-2 at Barn (JK)
- iii. 220/132kV 160MVA ICT-3 at Barn (JK)
- iv. 132kV Barn-Canal (JK) Ckt-1
- v. 132kV Barn-Canal (JK) Ckt-2

Network Diagram




J&K (UT)-Valley Network Diagram before the event




J&K (UT)-Valley Network Diagram after the event

JAMMU & KASHMIR (UT) - VALLEY



J&K demand during the event



Aug 2 Fri 2024


PMU Plot of frequency at Kishenpur(PG)

15:03hrs/02-Aug-24



PMU Plot of phase voltage magnitude at Kishenpur(PG)

15:03hrs/02-Aug-24



Point of discussion

- i) Exact reason and location of fault need to be shared.
- ii) Details of protection operated during the tripping event need to be shared.
- iii) Loading of all three ICTs just before the tripping event need to be shared.
- iv) Overloading protection settings of all three ICTs at Barn(JK) need to be shared.
- v) DR/EL (.dat/.cfg file) of all the tripped elements along with tripping report of the event need to be shared.
- vi) SLD of 220/132kV Barn(JK) S/s need to be shared.
- vii) Remedial action taken report to be shared.

Annexure-XIX

RE: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

Thu 8/29/2024 7:29 PM

To:NRLDC SO 2 <nrlcdso2@grid-india.in>; CPCC1 <rtamc.nr1@powergrid.in>;

Cc:seo-nrpc <seo-nrpc@nic.in>; Somara Lakra (सोमारा लाकरा) <somara.lakra@grid-india.in>; Mahavir Prasad Singh (महावीर प्रसाद सिंह) <mahavir@grid-india.in>; Arunkumar P <Arunkumar.P@adani.com>; Sugata Bhattacharya (सुगाता भट्टाचार्या) <sugata@grid-india.in>; Deepak Kumar <deepak.kr@grid-india.in>; AMIT SHARMA <amsharma@grid-india.in>; Bikas Kumar Jha (बिकास कुमार झा) <bikaskjha@grid-india.in>; Manas Ranjan Chand (मानस रंजन चंद) <manas@grid-india.in>; Aman Gautam (अमन गौतम) <amangautam@grid-india.in>; Gnanaguru . <Gnanaguru.1@adani.com>; Sumeet Sharma <Sumeet.Sharma@adani.com>; Naman Vyas <Namany.Vyas@adani.com>; Milan Popat <Milan.Popat@adani.com>; Nihar Raj <nihar.raj@adani.com>; Abhishek Kukreja <Abhishek.Kukreja@adani.com>;

5 attachments (9 MB)

Counter (2).jpg; Counter.jpg; TPS (2).jpg; TPS.jpg; 220KV Alwar ss.jpg;

****Warning****

This email has not originated from Grid-India. Do not click on attachment or links unless sender is reliable.
Malware/ Viruses can be easily transmitted via email.

Dear Sir,

Please find the attached Photos. on 28-08-2024, a representative from M/s. Commtel Networks visited the Mahendragarh site and confirmed the healthiness of the SDH and TPS, along with their associated cards.

All SPS System equipment are functioning properly. The 15 TPS installed in the remote substation.

The details and status of TPS and Counter at Mahendragarh End.

S.No	TPS	TPS Status	Counter	Counter Status
1	PG Hissar	ON	17	OKAY
2	Bhiwani	ON	17	OKAY
3	Dadari	ON	17	OKAY
4	Alwar	ON	-	OFF
5	Bhilwara	ON	12	OKAY
6	Merta	ON	14	OKAY
7	Ratangarh	ON	-	OFF
8	Gobinugarg	ON	-	OFF
9	Malerkotla	ON	-	OFF
10	Laton Kalan	ON	6	OKAY
11	Mandula	ON	12	OKAY
12	Bamnauli	ON	-	OFF
13	Shamli	ON	-	OFF
14	Bahadurgarh	ON	10	OKAY

15	Dhanonda	ON	-	OFF
----	----------	----	---	-----

There alarms on the system are due to the following reasons.

1. Equipment Failure/ card failure/ power failure at Remote Sites.
2. Cable connectivity break between the remote System and cable coming from Field.
3. E1 connectivity outage at remote Sites.

Our team, with support from Commtel Networks, visited the nearest TPS installed at the 220/132 kV Alwar Substation to check its healthiness. However, during the inspection, the panel was found to be de-energized, necessitating an end-to-end test. (Photo Attached) Similarly, each substation needs to be ensured the healthiness of the TPS by respective Substation owner.

We request you to please confirm the healthiness of the Sr no 1 and 2 .

Thanks and Regards,

Kalicharan Sahu

(O&M) HVDC & EHV Substations,

Adani Energy Solutions Limited

| ±500kV HVDC Mahendragarh Terminal Sub Station I

Village-Kheri- Aghiyar, Taluka- Kanina, Mahendragarh 123 029, Haryana, India

Mob +91 9764006167| Off +91 1285 277326

adani

Growth
with
Goodness

Our Values: Courage | Trust | Commitment

f t i+ /AdaniOnline

From: NRLDC SO 2 <nrlcdcso2@grid-india.in>

Sent: Tuesday, August 27, 2024 10:07 AM

To: SLDC Punjab <se-sldcprojects@pstcl.org>; PC PSTCL SLDC PUNJAB <pcpstcl@gmail.com>; Haryana <sldcharyanacr@gmail.com>; Delhi <sldcmintoroad@gmail.com>; UP <sera@upslcd.org>; Rajasthan <SE.LDRVPNL@RVPN.CO.IN>; ce.ld@rvpn.co.in; CPCC1 <rtamc.nr1@powergrid.in>; neerajk@powergrid.in; setncmrt@upptcl.org; bharatlalgujar@gmail.com; akashdeep3433786@gmail.com; xenemtcbhpp2@bbmb.nic.in; PC Control Room <pccont@bbmb.nic.in>; se.prot.engg@rvpn.co.in; Arunkumar P <Arunkumar.P@adani.com>; Kali Charan Sahu <Kalicharan.Sahu@adani.com>; rajbir-walia79@yahoo.com; ase-sldcop@pstcl.org; sesldcop@hvpn.org.in; cepso@upslcd.org; se-sldcop <se-sldcop@pstcl.org>; SICHVDC Controlroom <SICHVDC.Controlroom@adani.com>

Cc: seo-nrpc <seo-nrpc@nic.in>; somara.lakra <somara.lakra@grid-india.in>; Mahavir Prasad Singh (महावीर प्रसाद सिंह) <mahavir@grid-india.in>; Sugata Bhattacharya (सुगता भट्टाचार्या) <sugata@grid-india.in>; deepak.kr <deepak.kr@grid-india.in>; AMIT SHARMA <amsharma@grid-india.in>; bikaskjha <bikaskjha@grid-india.in>; Manas Ranjan Chand (मानस रंजन चंद) <manas@grid-india.in>; Aman Gautam (अमन गौतम) <amangautam@grid-india.in>

Subject: Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link


***CAUTION:** This mail has originated from outside Adani. Please exercise caution with links and attachments.*

Sir,

In reference of the trailing mail, it is to be mentioned that inputs have received from Rajasthan only. Members agreed to shared the details by 22nd August 2024, however no further details received from Haryana, Punjab, Delhi, UP & ADANI.

Kindly share the details as discussed during the meeting held on 20th August 2024, so that further remedial actions can be initiated on the basis of those details.

सादर धन्यवाद/ Thanks & Regards
 प्रणाली संचालन-II/ System Operation-II
 उ०क्षे०भा०प्रे०के०/ NRLDC
 ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड/ Grid Controller of India Limited
 Formerly known as
 पोसोको / POSOCO



From: NRLDC SO 2

Sent: Tuesday, August 20, 2024 12:49:55 PM

To: SLDC Punjab; PC PSTCL SLDC PUNJAB; Haryana; Delhi; UP; Rajasthan; ce.ld@rvpn.co.in; CPCC1; neerajk@powergrid.in; setncmrt@upptcl.org; bharatlalgujar@gmail.com; akashdeep3433786@gmail.com; xenemtcbhpp2@bbmb.nic.in; PC Control Room; se.prot.engg@rvpn.co.in; Arunkumar.P@adani.com; Kalicharan.Sahu@adani.com; rajbir-walia79@yahoo.com; ase-sldcop@pstcl.org; sesldcop@hvpn.org.in

Cc: seo-nrpc; Somara Lakra (सोमारा लाकरा); Mahavir Prasad Singh (महावीर प्रसाद सिंह); Sugata Bhattacharya (सुगाता भट्टाचार्या); Deepak Kumar; AMIT SHARMA; Bikas Kumar Jha (बिकास कुमार झा); Manas Ranjan Chand (मानस रंजन चंद); Aman Gautam (अमन गौतम)

Subject: Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

Sir,

Please find attached presentation w.r.t. review of SPS of HVDC Mundra-Mahindergarh link.

As discussed during online meeting held today from 10:30hrs onward with SLDCs, ADANI and POWERGRID, following action plan has been decided:

1. SLDCs shall share the revised updated feeder details (radial) along with expected average/peak load

- relief through respective feeders.
2. SLDCs in coordination with their transmission and protection team shall share the status and healthiness of existing SPS system along with details of availability of communication path for incorporation of proposed revised/additional feeders.
 3. Mahindergarh(ADANI) shall coordinate with the POWERGRID and share the action plan to make the SPS system healthy and operational at Mahindergarh(ADAIN), Bhiwani(PG) & Bhiwani(BBMB).
 4. POWERGRID & ADANI shall review the healthiness of SPS system at different load centers and communication path between them in coordination with the SLDCs.

Kindly take necessary actions w.r.t. your control area and share the inputs by afternoon of 22nd August 2024.

सादर धन्यवाद/ Thanks & Regards

प्रणाली संचालन-II/ System Operation-II

उ०क्षे०भा०प्रे०के०/ NRLDC

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड/ Grid Controller of India Limited

Formerly known as

पोसोको / POSOCO



ग्रिड-इंडिया
GRID-INDIA



भारत 2023 इंडिया

एकुत्तम वृत्तुत्तम

ONE EARTH - ONE FAMILY - ONE FUTURE



From: NRLDC SO 2

Sent: Friday, August 16, 2024 5:36:26 PM

To: SLDC Punjab; PC PSTCL SLDC PUNJAB; Haryana; Delhi; UP; Rajasthan; ce.ld@rvpn.co.in; CPCC1; neerajk@powergrid.in; setncmrt@upptcl.org; bharatlalgujar@gmail.com; akashdeep3433786@gmail.com; xenemtcbhpp2@bbmb.nic.in; PC Control Room; se.prot.engg@rvpn.co.in; Arunkumar.P@adani.com; Kalicharan.Sahu@adani.com; rajbir-walia79@yahoo.com; ase-sldcop@pstcl.org

Cc: seo-nrpc; Somara Lakra (सोमारा लाकरा); Mahavir Prasad Singh (महावीर प्रसाद सिंह); Sugata Bhattacharya (सुगाता भट्टाचार्या); Deepak Kumar; AMIT SHARMA; Bikas Kumar Jha (बिकास कुमार झा); Manas Ranjan Chand (मानस रंजन चंद); Aman Gautam (अमन गौतम)

Subject: Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

Sir,

Kindly refer trailing mail.

ADANI has shared the identified issues in communication link of SPS and load related details have been received from UP only. Other members are also requested to share the details w.r.t. their control area. POWERGRID and ADANI are requested to review the status of healthiness of communication links to load centers.

In this regard an online meeting has been scheduled on 20th August 2024 (Tuesday). Kindly ensure that concerned members shall connect in the meeting.

Online meeting to review the healthiness of SPS of 500kV HVDC Mundra-Mahindergarh link
Hosted by NRLDCSO Grid_India

<https://nrlcd.webex.com/nrlcd/j.php?MTID=m8a6b11dfbb5341cc4b8de3e5403b9ff6>

Tuesday, August 20, 2024 10:30 AM | 5 hours | (UTC+05:30) Chennai, Kolkata, Mumbai, New Delhi

Meeting number: 2514 426 7076

Password: rgEcnsPB934

सादर धन्यवाद/ Thanks & Regards

प्रणाली संचालन-II/ System Operation-II

उ०क्षे०भा०प्रे०के०/ NRLDC

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड/ Grid Controller of India Limited

Formerly known as

पोसोको / POSOCO



ग्रिड-इंडिया
GRID-INDIA



भारत 2023 INDIA

एक परिवार, एक भविष्य

ONE EARTH • ONE FAMILY • ONE FUTURE



आज़ादी का
अमृत महोत्सव

From: NRLDC SO 2

Sent: Tuesday, August 13, 2024 4:32 PM

To: SLDC Punjab; PC PSTCL SLDC PUNJAB; Haryana; Delhi; UP; Rajasthan; ce.ld@rvpn.co.in; CPCC1; neerajk@powergrid.in; setncmrt@upptcl.org; bharatlagujar@gmail.com; akashdeep3433786@gmail.com; xenemtcbhpp2@bbmb.nic.in; PC Control Room; se.prot.engg@rvpn.co.in; Arunkumar.P@adani.com; Kalicharan.Sahu@adani.com; rajbir-walia79@yahoo.com; ase-sldcop@pstcl.org

Cc: seo-nrpc; Somara Lakra (सोमारा लाकरा); Mahavir Prasad Singh (महावीर प्रसाद सिंह); Sugata Bhattacharya (सुगाता भट्टाचार्या); Deepak Kumar; AMIT SHARMA; Bikas Kumar Jha (बिकास कुमार झा)

Subject: Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

Sir,

Non operation of SPS of 500kV HVDC Mundra-Mahindergarh inter regional link on 17th May 2024 on outage of both pole (carrying total ~1500MW) was discussed during 51st PSC meeting. ADANI was requested to share the details w.r.t. SPS operation during the meeting.

As per details received from ADANI, there are two links for SPS signal communication to load centers. One is directly to 220kV Dhanonda(HR) and communication to rest of load centers is through Bhiwani & Hissar S/s of POWERGRID. Other stations are also involved in further communication to all the load centers. SPS communication network (received from ADANI) is attached herewith the mail.

During 17th May incident, SPS operated at Dhanonda S/s however, operation didn't occur at load centers on second path. During investigation by ADANI team, it was identified that communication link between Bhiwani and Hissar is not healthy and there are chances that communication link between other stations may also be not healthy.

During online meeting conducted on 05th August 2023, states also highlighted the challenges regarding changes / unavailability in identified load feeders and load shedding in Punjab, Haryana, Delhi, UP and Rajasthan.

In view of above following actions are desired:

1. POWERGRID and concerned states are requested to identify the issue in communication links and take expeditious actions to make the all the communication link healthy.
2. States are requested to go through the details of load feeders mentioned in SPS document and share the changes / modifications as per present scenario and also share the inputs w.r.t. unavailability in identified load feeders and load shedding.

Details have received from UP only. POWERGRID and states are requested to share their inputs at the earliest. Necessary actions also need to be taken on priority.

सादर धन्यवाद/ Thanks & Regards

प्रणाली संचालन-II/ System Operation-II

उ०क्षे०भा०प्रे०के०/ NRLDC

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड/ Grid Controller of India Limited

Formerly known as

पोसोको / POSOCO



ग्रिड-इंडिया
GRID-INDIA



From: NRLDC SO 2

Sent: Thursday, August 8, 2024 12:22:45 PM

To: SLDC Punjab; PC PSTCL SLDC PUNJAB; Haryana; Delhi; UP; Arshad Jamal; Rajasthan; ce.ld@rvpn.co.in

Cc: seo-nrpc; N Roy (एन रॉय); S Usha (एस उषा); Somara Lakra (सोमारा लाकरा); Mahavir Prasad Singh (महावीर प्रसाद सिंह); Manas Ranjan Chand (मानस रंजन चंद); Rahul Shukla (राहुल शुक्ला); Aman Gautam (अमन गौतम); Minnakuri Venkateswara Rao (मिन्नाकुरी वेंकटेश्वर राव); Sugata Bhattacharya (सुगाता भट्टाचार्या); Deepak Kumar; AMIT SHARMA

Subject: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

Ma'am/Sir,

As you are well aware that an online meeting was scheduled on 05.08.2024 among NLDC, WRLDC, NRLDC, SLDC Gujarat, SLDC Delhi, SLDC UP, SLDC Haryana, SLDC Punjab and ATL team to discuss the mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link and some challenges were highlighted during the meeting regarding changes/unavailability in identified load feeders and load shedding in Punjab, Haryana, Delhi, UP and Rajasthan.

As per IEGC clause 16.1, *"SPS for identified system shall have redundancies in measurement of input signals and communication paths involved up to the last mile to ensure security and dependability."*

As per IEGC clause 16.2, *"For the operational SPS, RLDC or NLDC, as the case may be, in consultation with the concerned RPC(s) shall perform regular load flow and dynamic studies and mock testing for reviewing SPS parameters & functions, at least once in a year. RLDC or NLDC shall share the report of such studies and mock testing including any short comings to respective RPC(s). The data for such studies shall be provided by CTU to the concerned RPC, RLDC and NLDC."*

In view of the above, states may confirm the status of the identified load feeders (whether operational or not) and whether any changes done in the existing load details. SPS scheme of 500kV HVDC Mundra-Mahindergarh is attached herewith.

सादर धन्यवाद/ Thanks & Regards

सुगता भट्टाचार्य/ Sugata Bhattacharya

प्रणाली संचालन-II/ System Operation-II

उ०क्षे०भा०प्रे०के०/ NRLDC

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड/ Grid Controller of India Limited

Formerly known as

पोसोको / POSOCO

Fwd: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

Tue 8/27/2024 4:58 PM

Inbox

To: NRLDC SO 2 <nrlcdso2@grid-india.in>;

****Warning****

This email has not originated from Grid-India. Do not click on attachment or links unless sender is reliable.
Malware/ Viruses can be easily transmitted via email.

----- Forwarded message -----

From: SE T&C Meerut <setncmrt@upptcl.org>

Date: Tue, Aug 27, 2024 at 4:34 PM

Subject: Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

To: SE (R&A) <sera@upsldc.org>

As per telephonic conversation with EEEMTD, Meerut, it is to inform that Six pairs (12Nos) fiber are available between 220KV Substation, Shamli & 400KV Substation, Shamli. Further modalities regarding availability & sharing of these fiber can be discussed with EMTD & Transmission wing.

On Tue, 27 Aug, 2024, 16:24 SE (R&A), <sera@upsldc.org> wrote:

Sir,

As per trailing mail and in reference to the meeting held on 20.08.2024, kindly share the status of availability/status/healthiness of communication path between 220kV Shamli and 400kV Shamli, availability of communication path for incorporation of proposed revised/additional feeders along with the healthiness of existing communication path of SPS incorporated feeders at 220kV Shamli.

----- Forwarded message -----

From: NRLDC SO 2 <nrlcdso2@grid-india.in>

Date: Tue, Aug 27, 2024 at 10:07 AM

Subject: Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

To: SLDC Punjab <se-sldcprojects@pstcl.org>, PC PSTCL SLDC PUNJAB <pcpstcl@gmail.com>, Haryana <sldcharyanacr@gmail.com>, Delhi <sldcmintoroad@gmail.com>, UP <sera@upsldc.org>, Rajasthan <SE.LDRVNL@rvpn.co.in>, ce.ld@rvpn.co.in <ce.ld@rvpn.co.in>, CPCC1 <rtamc.nr1@powergrid.in>, neerajk@powergrid.in <neerajk@powergrid.in>, setncmrt@upptcl.org <setncmrt@upptcl.org>, bharatlalgujar@gmail.com <bharatlalgujar@gmail.com>, akashdeep3433786@gmail.com <akashdeep3433786@gmail.com>, xenemtcbhpp2@bbmb.nic.in <xenemtcbhpp2@bbmb.nic.in>, PC Control Room <pccont@bbmb.nic.in>, se.prot.engg@rvpn.co.in <se.prot.engg@rvpn.co.in>, Arunkumar.P@adani.com <Arunkumar.P@adani.com>, Kalicharan.Sahu@adani.com <Kalicharan.Sahu@adani.com>, rajbir-walia79@yahoo.com <rajbir-walia79@yahoo.com>, ase-sldcop@pstcl.org <ase-sldcop@pstcl.org>, sesldcop@hvpn.org.in <sesldcop@hvpn.org.in>, cepso@upsldc.org <cepso@upsldc.org>, se-sldcop <se-sldcop@pstcl.org>, sicHVDC.Controlroom@adani.com <sicHVDC.Controlroom@adani.com>

Cc: seo-nrpc <seo-nrpc@nic.in>, Somara Lakra (सोमारा लाकरा) <somara.lakra@grid-india.in>, Mahavir Prasad Singh (महावीर प्रसाद सिंह) <mahavir@grid-india.in>, Sugata Bhattacharya (सुगाता भट्टाचार्या) <sugata@grid-india.in>, Deepak Kumar <deepak.kr@grid-india.in>, AMIT SHARMA <amsharma@grid-india.in>, Bikas Kumar Jha (बिकास कुमार झा) <bikaskjha@grid-india.in>, Manas Ranjan Chand (मानस रंजन चंद) <manas@grid-india.in>, Aman Gautam (अमन गौतम) <amangautam@grid-india.in>

Sir,

In reference of the trailing mail, it is to be mentioned that inputs have received from Rajasthan only. Members agreed to shared the details by 22nd August 2024, however no further details received from Haryana, Punjab, Delhi, UP & ADANI. Kindly share the details as discussed during the meeting held on 20th August 2024, so that further remedial actions can be initiated on the basis of those details.

सादर धन्यवाद/ Thanks & Regards
प्रणाली संचालन-II/ System Operation-II
उ०क्षे०भा०प्रे०के०/ NRLDC
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड/ Grid Controller of India Limited
Formerly known as
पोसोको / POSOCO



ग्रिड-इंडिया
GRID-INDIA



एक परिवार एक राष्ट्र
ONE EARTH - ONE FAMILY - ONE FUTURE



From: NRLDC SO 2

Sent: Tuesday, August 20, 2024 12:49:55 PM

To: SLDC Punjab; PC PSTCL SLDC PUNJAB; Haryana; Delhi; UP; Rajasthan; ce.ld@rvpn.co.in; CPCC1; neerajk@powergrid.in; setncmrt@upptcl.org; bharatlalgujar@gmail.com; akashdeep3433786@gmail.com; xenemtcbhpp2@bbmb.nic.in; PC Control Room; se.prot.engg@rvpn.co.in; Arunkumar.P@adani.com; Kalicharan.Sahu@adani.com; rajbir-walia79@yahoo.com; ase-sldcop@pstcl.org; sesldcop@hvpn.org.in

Cc: seo-nrpc; Somara Lakra (सोमारा लाकरा); Mahavir Prasad Singh (महावीर प्रसाद सिंह); Sugata Bhattacharya (सुगाता भट्टाचार्या); Deepak Kumar; AMIT SHARMA; Bikas Kumar Jha (बिकास कुमार झा); Manas Ranjan Chand (मानस रंजन चंद); Aman Gautam (अमन गौतम)

Subject: Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

Sir,

Please find attached presentation w.r.t. review of SPS of HVDC Mundra-Mahindergarh link.

As discussed during online meeting held today from 10:30hrs onward with SLDCs, ADANI and POWERGRID, following action plan has been decided:

1. SLDCs shall share the revised updated feeder details (radial) along with expected average/peak load relief through respective feeders.
2. SLDCs in coordination with their transmission and protection team shall share the status and healthiness of existing SPS system along with details of availability of communication path for incorporation of proposed revised/additional feeders.

उत्तर प्रदेश राज्य भार प्रेषण केन्द्र लि०
यू०पी०एस०एल०डी०सी०परिसर, विभूति
खण्ड - II, गोमती नगर, लखनऊ-226010
ई मेल : sera@upsldc.org



U.P. State Load Despatch Centre Ltd.
UPSLDC Complex, Vibhuti Khand - II
Gomti Nagar, Lucknow- 226010
E-mail: sera@upsldc.org

No: - **2661** /SE(R&A)/EE-II/SPS

Dated:- **07/08/2024**

**General Manager, NRLDC18-A,
SJSS Marg, Katwaria Sarai,
New Delhi - 110016**

Subject- Regarding SPS of HVDC Mundra-Mahendargarh line

Kindly refer to SE (ETC) Muzaffarnagar letter no/062/E.T.C./MZN/400 kV S/S Shamli dated 05.05.2024. (copy enclosed) regarding feeder wise load of Shamli area. As per the letter, at present complete load relief (i.e. 300MW) may not be provided by 220 kV Shamli, so that alternatively feeder and load details of 400 kV Shamli has also been provided. Also it is informed that at present SPS system at 220 kV Shamli is not healthy which is being maintained by PGCIL.

It is therefore requested to kindly instruct the concerned to incorporate 132 kV feeders of 220 kV Shamli & 400 kV Shamli in SPS of HVDC Mundra-Mahendargarh line so that appropriated load relief may be provided from UP Control area and take necessary action regarding healthiness of SPS system

Sangeeta

(Sangeeta)

Superintending Engineer (R&A)

No: - /SE(R&A)/EE-II/SPS

Dated: - 2024

Copy forwarded to following via e-mail for kind information and necessary action:-

1. Director, UPSLDC, Vibhuti Khand - II, Gomti Nagar, Lucknow.
2. Director (Operation), UPPTCL, 11th Floor, Shakti Bhawan Extn., Lucknow.
3. Chief Engineer (PSO), Vibhuti Khand - II, Gomti Nagar, Lucknow.
4. Chief Engineer (Trans. West), Pareshan Bhawan, 130D, Hydrel Colony, Victoria Park, Meerut 250001.
5. SE (Operations), 18 - A SJSS Marg, Katwaria Sarai, New Delhi, 110016.

(Sangeeta)

Superintending Engineer (R&A)



कार्यालय
अधीक्षण अभियन्ता
विद्युत पारेषण मण्डल
उप्रोपावर ट्रांसमिशन कारपोरेशन लि०
132 के०वी० भोपारोड उपकेन्द्र
मुजफ्फरनगर-251001

OFFICE OF THE
SUPERINTENDING ENGINEER
Electricity Transmission Circle
U.P. Power Transmission Corporation Ltd.
132 KV Bhopa Road Sub-station
Muzaffarnagar-251001

दूरभाष : 0131-2608038

Ph. 0131-2608038

E-mail : seetcmzn@upptcl.org, seetcmzn@gmail.com

संख्या / No. 1062 /E.T.C./MZN/400 KV S/S Shamli

दिनांक / DATED 05/08/24

Subject: - Regarding SPS of HVDC Mundra-Mahendargarh.

Superintending Engineer (R & A)
U.P State Load Despatch Centre Ltd.
UPSLDC Complex, Vibhuti Khand-II
Gomti Nagar, Lucknow.
Email. sera@upslde.org

Please refer to your office letter no. 2187 dt. 01.07.2024, forwarded to this office by SE (T&C), Meerut vide endorsement no. 2237/CE(TW)/MT/SPS dt. 23.07.2024 vide which it has been requested to provide details of 132 KV feeders for planned relief to HVDC Mundra-Mahendargarh SPS.

In this reference, it is to apprise that following is the details of 132 KV feeders being fed from 220 KV Sub-Station Shamli.

S.No.	Name of feeder	Connected Load (MVA)	Maximum Load (MW)	Average Load (MW)
1	132 KV Lalukheri	63+63	72	47
2	132 KV Jinhjana	63+40+40	80	52
3	132 KV Kairana-I/II	63+63	41	27
4	132 KV Jasala	63+40	58	38
Total			251	164

1. Following Case wise Trippings of 132 KV Feeders at 220 KV Sub-Station, Shamli for tripping of HVDC Mundra-Mahendergarh Line may be used.

(A) In Maximum Load Condition:-

S. No.	State.L.S quantum	Name of feeding substation	Feeder/line/ equipment	MW	Case-1 50 MW	Case-2 100 MW	Case-3 200MW	Case-4 300 MW
1	Uttar Pradesh Case-1 =50 MW Case-2 =100 MW Case-3 =200 MW Case-4 =300 MW	220 KV Subsatation, Shamli	132 KV Jasala	58	1	1	1	1
2			132 KV Kairana-I	20.5		1		1
3			132 KV Kairana-II	20.5	-	1		1
4			132 KV Lalukheri	72	-	-	1	1
5			132 KV Jinhjana	80	-	-	1	1
Total Relief				251	58	99	210	251

(B) In Average Load Condition :-

S. No.	State.L.S quantum	Name of feeding substation	Feeder/line/ equipment	MW	Case-1 50 MW	Case-2 100 MW	Case-3 200MW	Case-4 300 MW
1	Uttar Pradesh Case-1 =50 MW Case-2 =100 MW Case-3 =200 MW Case-4 =300 MW	220 KV Subsatation, Shamli	132 KV Jasala	38	1		1	1
2			132 KV Kairana-I	13.5	1		1	1
3			132 KV Kairana-II	13.5	-		1	1
4			132 KV Lalukheri	47	-	1	1	1
5			132 KV Jinhjana	52	-	1	1	1
Total Relief				164	51.5	99	164	164

Alternatively HVDC Mundra-Mahendargarh SPS may be shifted to 400 KV Sub-Station Shamli, details of 132 KV feeders from 400 KV Sub-Station Shamli with its Maximum and Average load is as follows :

S.No.	Name of feeder	Connected Load (MVA)	Maximum Load (MW)	Average Load (MW)
1	132 KV Budhana	63+40	82	53
2	132 KV Kharad	63+40	78	51
3	132 KV Jalalpur	40+40	41	27
4	132 KV Thanabhawan	63+63+40	74	48
5	132 KV Kaniyan	40+40	35	23
Total			310	202

2. Following Case wise Trippings of 132 KV Feeders at 400 KV Sub-Station, Shamli for tripping of HVDC Mundra-Mahendargarh Line is hereby recommended


(A). In Maximum Load Condition :-

S. No.	State.L.S quantum	Name of feeding substation	Feeder/line/ equipment	MW	Case-1 50 MW	Case-2 100 MW	Case-3 200MW	Case-4 300 MW
1	Uttar Pradesh Case-1 =50 MW Case-2 =100 MW Case-3 =200 MW Case-4 =300 MW	400 KV Subsatatio n, Shamli	132 KV Budhana	82	-	-	1	1
2			132 KV Kharad	78	-	-	1	1
3			132 KV Jalalpur	41	1	-	1	1
4			132 KV Thanabhawan	74	-	1	-	1
5			132 KV Kaniyan	35	1	1	-	1
Total Relief				310	76	109	201	310

(B). In Average Load Condition :-

S. No.	State.L.S quantum	Name of feeding substation	Feeder/line/ equipment	MW	Case-1 50 MW	Case-2 100 MW	Case-3 200MW	Case-4 300 MW
1	Uttar Pradesh Case-1 =50 MW Case-2 =100 MW Case-3 =200 MW Case-4 =300 MW	400 KV Subsatatio n, Shamli	132 KV Budhana	53	-	1	1	1
2			132 KV Kharad	51	1	1	1	1
3			132 KV Jalalpur	27	-	-	1	1
4			132 KV Thanabhawan	48	-	-	1	1
5			132 KV Kaniyan	23	-	-	1	1
Total Relief				202	51	104	202	202

Submitted for information and necessary action


(Nikhil Kumar)
Superintending Engineer

संख्या / No.

/E.T.C./MZN/

दिनांक / DATED

Copy forwarded to the following for information and necessary action :

1. Chief Engineer (TW) UPPTCL Meerut.
2. Superintending Engineer, Electricity (T&C) Circle, UPPTCL Meerut.
3. Executive Engineer Electricity Transmission Division, Shamli

(Nikhil Kumar)
Superintending Engineer

कार्यालय
अधीक्षण अभियन्ता
विद्युत परीक्षण एवं परिचालन मण्डल
उपरो पावर ट्रांसमिशन कारपोरेशन लि०
प्रथम तल पारेषण भवन, 130-डी, विक्टोरिया पार्क
मेरठ- 250 003
मोबाइल: 9412749817



OFFICE OF THE
SUPERINTENDING ENGINEER
Electricity Test & Commissioning Circle
U.P. POWER TRANSMISSION CORPORATION LTD.
1st Floor Pareshan Bhawan, 130-D, Victoria Park,
Meerut 250 003
Mobile: 9412749817

No. 82... / ETCC-MT /

Dated- 30/05/24

Sub :- SPS related to HVDC Mundra-Mahendargarh.

Superintending Engineer (R&A)
UPSLDC Vibhuti Khand,
Gomti Nagar,
Lucknow.


(By e-mail)

In reference to the above cited subject, UPSLDC via email on 22.05.2024 informed that on 17.05.2024 at 16:20 hrs, Case-3 of SPS related to HVDC Mundra - Mahendargarh operated. As per action in case-3 operation of this line SPS, 200MW load relief at 220kV Shamli (UP) is desired. However, no load relief at 220kV Shamli was observed at given date and time. It is to bring in your notice that due to commissioning of 400kV Shamli S/s entire power flow scenario has been changed. Current situation is summarized as below.

At 220kV Shamli S/s feeders shown in the list	Planned load relief (MW)	Current situation
Thana Bhawan -1	25	The only line cateting Thana Bhawan has been made LILO at 132kV Jalalpur. Now Jalalpur is fed from 220kV Shamli S/s while load of Thana Bhawan is fed from 400kV Shamli S/s.
Thana Bhawan -2	25	
Jasala-1	25	Only one line exists.
Jasala-2	25	
Kharad-1	50	Only one line exists which is normally kept open at Kharad and load of Kharad is normally fed from 400kV Shamli S/s.
Kharad-2	50	
Baraut-1	150 (case-4)	No such line exist at 220kV Shamli S/s.
Baraut-2	150 (case-4)	

In view of the above facts, entire load relief strategy needs to be reviewed and redesigned for SPS. On 17.05.2024 at 16:20 hrs, no tripping observed at 220kV S/S Shamli as SPS system is unhealthy, which is being maintained by M/s PGCIL.

Hence it is requested to you to kindly coordinate with M/s PGCIL for modification of the scheme and rectification of the fault in SPS.



(Pramod Kumar Mishra)
Superintending Engineer

No. 82... / ETCC-MT /

Dated/- 30/05/24

Copy forwarded to the following for information & necessary action:-

1. Chief Engineer (TW), UPPTCL Victoria Park, Meerut.
2. Executive Engineer, Electricity Test & Commissioning Div., Muzaffarnagar.


(Pramod Kumar Mishra)
Superintending Engineer

Revised updated feeder details (radial) along with expected average Load Relief

S.No.	Name of Sub- Station	Feeder name as per existing detail	Revised name of Existing Feeder /Line/Equipment	Average Load relief (MW)	Remark
1	220 kV GSS Alwar	132 kV GSS Mundawar	132 kV GSS Pinan	25	
		132 kv GSS Bansoor	132 kV GSS Telco	45	
		132 kV GSS Ramgarh	132 kV GSS Ramgarh	65	
		132 kV GSS Malakhera	132 kV GSS Malakhera	50	
		132 kV Alwar (LOCAL)	132 kV GSS Alwar (LOCAL)	120	
2	220 kV GSS Ratangarh	132 kV Sardar Sher			Generally Feed from 220 kV Halasar
3	220 kV GSSV Bhilwara	132 kV GSS Gangapur	132 kv GSS Karoi	15	
		132 kV GSS Danta	132 kV GSS Danta	30	
		132 kV GSS Devgarh	132 kV GSS Bankali	18	
		132 kV GSS Kareda			
4	400 kV GSS Merta	132 kV GSS Kuchera	132 kV GSS Dhawa	25	
		132 kV GSS Lamba	132 kV GSS Lamba jatan	55	
		132 kV GSS Gotan			

Email**Control Room CONTROL ROOM SLDC****Re: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.****From :** Executive Engineer TS Rewari
<xentsrwr@hvpn.org.in>

Thu, Aug 29, 2024 01:20 PM

Subject : Re: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.**To :** Control Room CONTROL ROOM SLDC
<controlroomslcdc@hvpn.org.in>**Cc :** SE TS GGN <setsggn@hvpn.org.in>, Executive Engineer Executive Engineer
<xen400kvdhanoda@hvpn.org.in>, Substation Engineer <sse220kvlulaahir@hvpn.org.in>

In continuation of trailing email and discussion held today telephonically, it is gathered that desired load relief shall not get as load of 220 kV Lula Ahir shall be fed through 220 kV Dadri-Lula Ahir line being synchronized. Therefore, it is proposed that in the existing scheme SPS, the tripping of 220 kV D/C Lula Ahir line at 400 kV Dhanonda end may be removed and tripping of all incomers (2 no. 132 kV Incomers of 100 MVA 220/132 kV TFs and one no. 33 kV incomer of 100 MVA 220/33 kV TF) at 220 kV Lula Ahir substation may be added.

The maximum load (for FY 2023-24) on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 53.46 MVA, 86.26 MVA and 87.02 MVA

The average load on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 50 MVA, 70 MVA and 70 MVA

From: "Executive Engineer TS Rewari" <xentsrwr@hvpn.org.in>
To: "Control Room CONTROL ROOM SLDC" <controlroomslcdc@hvpn.org.in>
Cc: "SE TS GGN" <setsggn@hvpn.org.in>, "Executive Engineer Executive Engineer" <xen400kvdhanoda@hvpn.org.in>, "Substation Engineer" <sse220kvnarnaul@hvpn.org.in>
Sent: Wednesday, August 28, 2024 12:46:13 PM
Subject: Re: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.

In reference of trailing email it is submitted that 220 kV Lula Ahir is connected with 400 kV Dhanonda through 220kV D/C line and with 220 kV Dadri through 220kV S/C line and with 220 kV Rewari with 220kV S/C line.

In general circuits of 400 kV Dhanonda and 220 kV Dadri runs in synchronization. The maximum load (for FY 2023-24) on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 53.46 MVA, 86.26 MVA and 87.02 MVA. It is further added that in general 220 kV Dadri takes load from 220 kV Lula Ahir substation and thus act as sink.

In case of operation of SPS at 400 kV Dhanonda, the desired load relief as mentioned in trailing email (90+95 MW) can be achieved through existing scheme (by outage of three no. 100 MVA TFs and 220 kV Dadri (acting as sink)).

Regards
XEN/TS Division
HVPNL Rewari.

From: "Control Room CONTROL ROOM SLDC" <controlroomsldc@hvpn.org.in>
To: "Executive Engineer TS Rewari" <xentsrwr@hvpn.org.in>, "Executive Engineer TS Rohtak" <xentsrtk@hvpn.org.in>, "Executive Engineer Ts Bhiwani" <xentsbhw@hvpn.org.in>, "Executive Engineer Executive Engineer" <xen400kvdhanoda@hvpn.org.in>, xendhanonda@gmail.com
Cc: "Chief Engineer SO Commercial" <cesocomml@hvpn.org.in>, "Chief Engineer TS Panchkula" <cetspkl@hvpn.org.in>, "Chief Engineer TS Hisar" <cetshsr@hvpn.org.in>, "Superintending Engineer SLDC OP" <sesldcop@hvpn.org.in>, "SE TS Rohtak" <setsrtk@hvpn.org.in>, "SE TS GGN" <setsggn@hvpn.org.in>, "Superintending Engineer TS Hisar" <setshsr@hvpn.org.in>, "Superintending Engineer MP CC Dhulkote" <sempccdk@hvpn.org.in>, "Superintending Engineer MP CC Delhi" <sempccdelhi@hvpn.org.in>, "Executive Engineer MP Rohtak" <xenmpccrtk@hvpn.org.in>, "XEN MP Hisar" <xenmpcchsr@hvpn.org.in>, "XEN MP CC" <xenmpccggn@hvpn.org.in>
Sent: Wednesday, August 21, 2024 11:57:59 AM
Subject: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.

Sir,

Please see the attachments.

--

Regards,
SCE (पाली प्रभारी अभियंता)/SLDC Control room,
HVPNL Panipat
Contact No- 9053090722,9053090721,0180-2664095

**Every 8333.3 sheets of paper costs us a tree.
Please don't print this e-mail unless you really need to. Save Paper Save Trees**

Fwd: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.

Control Room CONTROL ROOM SLDC <controlroomsldc@hvpn.org.in>

Fri 8/30/2024 12:44 PM

To: NRLDC SO 2 <nrlcso2@grid-india.in>; NRLDC SO-II <nrlcso2@gmail.com>; Deepak Kumar <deepak.kr@grid-india.in>;

Cc: Superintending Engineer SLDC OP <sesldcop@hvpn.org.in>;

2 attachments (209 KB)

Email SPS Rewari.pdf; Regarding SPS Bhiwani.pdf;

****Warning****

This email has not originated from Grid-India. Do not click on attachment or links unless sender is reliable. Malware/ Viruses can be easily transmitted via email.

Sir,

In reference to the SPS installed for 500kV HVDC Munda - Mahindergarh link the information received from TS wing (copy attached) is as under:

1. At 400kV Dhanonda through Lula Ahir substation:- It is proposed that in the existing scheme SPS, the tripping of 220 kV D/C Lula Ahir line at 400 kV Dhanonda end may be removed and tripping of all incomers (2 no. 132 kV Incomers of 100 MVA 220/132 kV TFs and one no. 33 kV incomer of 100 MVA 220/33 kV TF) at 220 kV Lula Ahir substation may be added. The maximum load (for FY 2023-24) on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 53.46 MVA, 86.26 MVA and 87.02 MVA. The average load on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 50 MVA, 70 MVA and 70 MVA.

2. At 400/220kV Bhiwani BBMB: It is proposed that in the existing scheme SPS, the tripping of 220 kV Bapora (Bhiwani HVPNL) D/C line at Bhiwani BBMB end may be removed and tripping of all incomers (2 no. 132 kV Incomers of 100 MVA 220/132 kV T-1 & T-2 TFs) at 220 kV Bapora (Bhiwani HVPNL) substation may be added. The maximum load on two no. 100 MVA TFs installed at 220kV Bhiwani HVPNL is 80 MW and 85 MW respectively. The average load on two no. 100 MVA TFs installed at 220kV Bhiwani HVPNL is 70 MW and 70 MW respectively.

3. At 132kV Charkhi Dadri: It is proposed that in the existing scheme SPS, the tripping of 132kV Kalanaur line at Dadri BBMB end may be removed and tripping of 132kV Haluwas & 132kV Dadri old at Dadri BBMB may be added. The maximum load on 132kV Haluwas & 132kV Dadri old line is 45 MW and 50 MW respectively. The average load on 132kV Haluwas & 132kV Dadri old line is 40 MW and 40 MW respectively.

Rest information kept unchanged. It is also added here that the fiber connectivity is also available on all the above substations.

It is also pertinent to mention here that 700 MW load relief is expected from Haryana. Rest of the states have been allotted with a relative less amount of relief as compared to Haryana for 500kV HVDC Mundra - Mahendargarh link. The Haryana share from APL Mundra has also been reduced now. In view of the above, the expected load relief from the NR states is required to be reviewed accordingly. The same was also pointed out by this office during the online meeting held on dated 20.08.2024.

This is for information & further necessary action please.

From: "Executive Engineer TS Rewari" <xentsrwr@hvpn.org.in>

To: "Control Room CONTROL ROOM SLDC" <controlroomsldc@hvpn.org.in>

Cc: "SE TS GGN" <setsggn@hvpn.org.in>, "Executive Engineer Executive Engineer" <xen400kvdhanoda@hvpn.org.in>, "Substation Engineer" <sse220kvlulaahir@hvpn.org.in>

Sent: Thursday, August 29, 2024 1:20:08 PM

Subject: Re: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.

In continuation of trailing email and discussion held today telephonically, it is gathered that desired load relief shall not get as load of 220 kV Lula Ahir shall be fed through 220 kV Dadri-Lula Ahir line being synchronized. Therefore, it is proposed that in the existing scheme SPS, the tripping of 220 kV D/C Lula Ahir line at 400 kV Dhanonda end may be removed and tripping of all incomers (2 no. 132 kV Incomers of 100 MVA 220/132 kV TFs and one no. 33 kV incomer of 100 MVA 220/33 kV TF) at 220 kV Lula Ahir substation may be added.

The maximum load (for FY 2023-24) on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 53.46 MVA, 86.26 MVA and 87.02 MVA

The average load on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 50 MVA, 70 MVA and 70 MVA

From: "Executive Engineer TS Rewari" <xentsrwr@hvpn.org.in>
To: "Control Room CONTROL ROOM SLDC" <controlroomsldc@hvpn.org.in>
Cc: "SE TS GGN" <setsggn@hvpn.org.in>, "Executive Engineer Executive Engineer" <xen400kvdhanoda@hvpn.org.in>, "Substation Engineer" <sse220kvnamaul@hvpn.org.in>
Sent: Wednesday, August 28, 2024 12:46:13 PM
Subject: Re: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.

In reference of trailing email it is submitted that 220 kV Lula Ahir is connected with 400 kV Dhanonda through 220kV D/C line and with 220 kV Dadri through 220kV S/C line and with 220 kV Rewari with 220kV S/C line.

In general circuits of 400 kV Dhanonda and 220 kV Dadri runs in synchronization. The maximum load (for FY 2023-24) on three no. 100 MVA TFs installed at 220 kV Lula Ahir is 53.46 MVA, 86.26 MVA and 87.02 MVA. It is further added that in general 220 kV Dadri takes load from 220 kV Lula Ahir substation and thus act as sink.

In case of operation of SPS at 400 kV Dhanonda, the desired load relief as mentioned in trailing email (90+95 MW) can be achieved through existing scheme (by outage of three no. 100 MVA TFs and 220 kV Dadri (acting as sink)).

Regards
XEN/TS Division
HVPNL Rewari.

From: "Control Room CONTROL ROOM SLDC" <controlroomsldc@hvpn.org.in>
To: "Executive Engineer TS Rewari" <xentsrwr@hvpn.org.in>, "Executive Engineer TS Rohtak" <xentsrtk@hvpn.org.in>, "Executive Engineer Ts Bhiwani" <xentsbhw@hvpn.org.in>, "Executive Engineer Executive Engineer" <xen400kvdhanoda@hvpn.org.in>, xendhanonda@gmail.com <cetsshsr@hvpn.org.in>, "Superintending Engineer SLDC OP" <sesldcop@hvpn.org.in>, "SE TS Rohtak" <setsrtk@hvpn.org.in>, "SE TS GGN" <setsggn@hvpn.org.in>, "Superintending Engineer TS Hisar" <setshsr@hvpn.org.in>, "Superintending Engineer MP CC Dhulkote" <sempccdt@hvpn.org.in>, "Superintending Engineer MP CC Delhi" <sempccdelhi@hvpn.org.in>, "Executive Engineer MP Rohtak" <xenmpccrtk@hvpn.org.in>, "XEN MP Hisar" <xenmpccshr@hvpn.org.in>, "XEN MP CC" <xenmpccggn@hvpn.org.in>
Sent: Wednesday, August 21, 2024 11:57:59 AM
Subject: Review of SPS installed for 500kV HVDC Mundra - Mahindergarh.

Sir,

Please see the attachments.

--
Regards,
SCE (पाली प्रभारी अभियंता)/SLDC Control room,
HVPNL Panipat
Contact No- 9053090722,9053090721,0180-2664095

**Every 8333.3 sheets of paper costs us a tree.
Please don't print this e-mail unless you really need to. Save Paper Save Trees**

--
Regards,
SCE (पाली प्रभारी अभियंता)/SLDC Control room,
HVPNL Panipat
Contact No- 9053090722,9053090721,0180-2664095

**Every 8333.3 sheets of paper costs us a tree.
Please don't print this e-mail unless you really need to. Save Paper Save Trees**



HARYANA VIDYUT PRASARAN NIGAM LIMITED

Regd. Office: Shakti Bhawan, Plot No. C-4, Sector-6, Panchkula, 134109.

Corporate Identity Number: U40101HR1997SGC033683

Website: www.hvpn.org.in, E-mail - xentsbhw@hvpn.org.in

Phone No: 01664-242797(O)

To

The Executive Engineer,
LDPC, HVPNL,
Panipat.

Memo No.Ch-116/OMBE-7

Dated: 29.08.2024


Subject: SPS scheme at HVPNL substations for getting load relief due to tripping of 500Kv HVDC Mundra – Mahendargarh

Please refer to this O/Memo No. 108/OMBE-7 dated 27.08.2024 and O/Email dated 09.08.2024 on the subject cited matter.

In this continuation to above, the details of SPS under TS division, HVPNL, Bhiwani is as under:

S No.	Name of feeding S/Stn	Feeder/Line/Equipment	SPS Installed	Max. Load	Load Relief (Avg Load)	Remarks
1	220KV S/Stn Bhiwani	132KV IA Bhiwani Line	UFR	50MW	40 MW	SPS (UFR)Installed and healthy
2	220KV S/Stn Bhiwani	132KV Bhiwani Ckt 2	UFR	50MW	40 MW	SPS (UFR)Installed and healthy
3	220KV S/Stn Bhiwani	132KV Tosham	UFR	-	-	SPS (UFR) Installed and healthy but line is running on No load as 2 nd source to 132KV Tosham
4	220KV S/Stn Bhiwani	132KV Incomer of Transformer 100MVA Transformer T2	-	85MW	70 MW	SPS may be provided for load relief as mentioned on subject above.
5	220KV S/Stn Bhiwani	132KV Incomer of 100MVA Transformer T1	-	80MW	70 MW	SPS may be provided for load relief as mentioned on subject above.
6	132kv substation Dadri-2	132kv Dadri-kalanaur ckt	Yes		Nil	SPS Installed and healthy but line is running on No load as 2 nd source to 132KV Kalanaur
7	132kv substation Dadri-2	132kv Dadri-Makrani ckt	Yes		Nil	SPS Installed and healthy but line is running on No load as 2 nd source to 132KV Makrani
8	132kv substation Dadri-2	132kv Dadri-Haluwas ckt	-	45MW	40MW	SPS may be provided for load relief as mentioned on subject above.
9	132kv substation Dadri-2	132kv Dadri-Dadri old	-	50MW	40MW	SPS may be provided for load relief as mentioned on subject above.

This is for kind information and necessary action please.


Executive Engineer,
Transmission System Division,
HVPNL, Bhiwani

CC to:

1. SE/TS Circle, HVPNL, Hisar for kind information, please.

Re: Mock testing of SPS of 500kV HVDC Mundra-Mahindergarh link

SLDC, DELHI <sldcmintoroad@gmail.com>

Wed 8/28/2024 3:48 PM

To:NRLDC SO 2 <nrlcso2@grid-india.in>;

Cc:sinha.surendra <sinha.surendra@yahoo.com>; dgmsodelhisldc@gmail.com <dgmsodelhisldc@gmail.com>; Manager (T) SO <managersogd@gmail.com>;

****Warning****

This email has not originated from Grid-India. Do not click on attachment or links unless sender is reliable.
Malware/ Viruses can be easily transmitted via email.

In reference to trailing mail, the maximum load on 220kV feeders covered under SPS of 500kV HVDC Mundra-Mahindergarh link are as under:

S. No.	Name of the Element	MW
1	220 KV BAMNAULI-PAPANKALAN-I CKT.-I	120
2	220 KV BAMNAULI-PAPANKALAN-I CKT.-II	120
3	220 KV MANDAULA- GOPALPUR CKT.-I	212
4	220 KV MANDAULA- GOPALPUR CKT.-II	214

Regards,
SLDC Delhi

On Tue, Aug 27, 2024 at 10:07 AM NRLDC SO 2 <nrlcso2@grid-india.in> wrote:

Sir,

In reference of the trailing mail, it is to be mentioned that inputs have received from Rajasthan only. Members agreed to shared the details by 22nd August 2024, however no further details received from Haryana, Punjab, Delhi, UP & ADANI.

Kindly share the details as discussed during the meeting held on 20th August 2024, so that further remedial actions can be initiated on the basis of those details.

सादर धन्यवाद/ Thanks & Regards
प्रणाली संचालन-II/ System Operation-II
उ०क्षे०भा०प्रे०के०/ NRLDC
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड/ Grid Controller of India Limited
Formerly known as
पोसोको / POSOCO

Date	Time	Load throw-off quantum (State-wise)						Total Load throw-off quantum	Remarks
		Delhi	Punjab	Haryana	Rajasthan	UP	Uttarakhand		
5/25/2024	12:46	82	1375	0	140	172	0	1769	as reported by SLDCs
5/27/2024	14:36	280	0	540	0	140	100	1060	as per SCADA data at NRLDC, SLDCs have not confirmed yet
6/1/2024	13:26	0	440	0	0	100	0	540	as per SCADA data at NRLDC, SLDC-Punjab have confirmed
6/1/2024	13:44	270	580	120	0	220	0	1190	SLDC-Punjab & UP have confirmed
6/3/2024	5:28	0	300	0	0	0	0	300	as reported by SLDC-Punjab
6/4/2024	12:35	0	400	0	0	0	0	400	as per SCADA data at NRLDC, SLDC-Punjab have confirmed
6/9/2024	11:21	0	435	0	0	0	0	435	as per SCADA data at NRLDC, SLDC-Punjab have not confirmed yet
6/19/2024	12:42	0	723	0	107	220	0	1050	as reported by SLDCs
6/23/2024	9:11	0	880	0	0	0	0	0	as reported by SLDC-Punjab

51	11/01/23	Jul - 2024	400V Main Bay 408 of 400 KV HSD(MANNEKURU)LINE-4 at Shamoli(UPL)	UPPTCL	600KV	408	Main Bay	Shamoli(UPL)	UTTAR PRADESH	18-02-2023 -00:00, 8 29-10-2023-00:00, 15	26 Jul 2024 11-19, 23 Jul 2024 11-14	30 Jul 2024 11:07, 24 Jul 2024 11-11	14 Aug 2024 16:11, 03 Aug 2024 11-42	20 Aug 2024 10:10, 06 Aug 2024 15-50	23-Aug-2024	16.52
52	11/01/23	Jul - 2024	400V Main Bay 407 of HV SIDE OF 500 MVA CT 2 at Shamoli(UPL)	UPPTCL	400KV	407	Main Bay	Shamoli(UPL)	UTTAR PRADESH	19-02-2023 -00:00, 11 29-10-2023-00:00, 15	26 Jul 2024 11-19, 23 Jul 2024 11-14	30 Jul 2024 11:07, 24 Jul 2024 11-11	14 Aug 2024 16:11, 02 Aug 2024 11-43	20 Aug 2024 10:10, 06 Aug 2024 15-50	23-Aug-2024	16.55
53	11/01/23	Jul - 2024	220V Main Bay 208 of HV SIDE OF 500 MVA CT 4 at Shamoli(UPL)	UPPTCL	220KV	208	Main Bay	Shamoli(UPL)	UTTAR PRADESH	19-02-2023 -00:00, 11 29-10-2023-00:00, 15	26 Jul 2024 11-19, 23 Jul 2024 11-14	30 Jul 2024 11:07, 24 Jul 2024 11-11	14 Aug 2024 16:11, 06 Aug 2024 11-42	20 Aug 2024 10:10, 06 Aug 2024 15-50	23-Aug-2024	16.57
54	11/01/23	May -	400V Main Bay 405 of HV SIDE OF 500 MVA CT 4 at	UPPTCL	220KV	206	Main Bay	Jeebharpur_TPS(UPL)	UTTAR PRADESH	30-05-2024 -00:00, 38, 9, 9, 201, 7	23-May-2024 15-17	25-May-2024 12-32	18 Jul 2024 12:25, 08 Jul 2024 11-22	19 Jul 2024 16:15, 10 Jul 2024 09-38	24-Aug-2024	13.18
55	11/01/23	May -	400V Tie Bay 402 of 500 MVA CT 1 at	UPPTCL	400KV	402	Tie Bay	Jeebharpur_TPS(UPL)	UTTAR PRADESH	30-05-2024 -00:00, 38, 9, 9, 201, 7	22-May-2024 15-14	25-May-2024 12-23	18 Jul 2024 12:24, 08 Jul 2024 11-22	19 Jul 2024 16:15, 10 Jul 2024 09-38	24-Aug-2024	15.06
56	11/01/20	Aug - 2024	400V Main Bay 413 (C13) of 400KV THRE PHSP-KOTIOTI(WARPG) LINE(4) at Talsit(DIOL)	Talsi P&S	400KV	413 (C13)	Main Bay	Talsit(DIOL)	UTTARAKHAND	30-05-2020 -10:00, 279, 9, 0, 10 of 41	20 Aug 2024 10:54, 17 Aug 2024 09-23	21 Aug 2024 09:30, 19 Aug 2024 14-39	22 Aug 2024 10:35, 11 Aug 2024 11-17	27 Aug 2024 17:11, 22 Aug 2024 14-34	29-Aug-2024	13.51
57	11/01/24	Jun - 2024	400V Main Bay 417 of 400/230 KV 500 MVA CT 3 at Bikaner(PG)	POWERGR	400KV	417	Main Bay	Bikaner(PG)	RAJASTHAN	30-06-2022 -10:30, 8, 0, no 03, 23	15 Jun 2024 10-23	17 Jun 2024 15-51	29 Aug 2024 21:30, 28 Aug 2024 14-38	30 Aug 2024 10:01, 29 Aug 2024 21-00	30-Aug-2024	23.40
58	11/01/24	Jun - 2024	400V Tie Bay 416 of 400/230 KV 500 MVA CT 3 and Future at Bikaner(PG)	POWERGR	400KV	426	Tie Bay	Bikaner(PG)	RAJASTHAN	30-06-2022 -10:30, 8, 0, no 03, 23	15 Jun 2024 10-23	17 Jun 2024 15-51	29 Aug 2024 21:30, 28 Aug 2024 14-38	30 Aug 2024 10:01, 29 Aug 2024 21-00	30-Aug-2024	23.54
59	11/01/24	Jun - 2024	220V Main Bay 211 of 400/230 KV 500 MVA CT 3 at Bikaner(PG)	POWERGR	220KV	211	Main Bay	Bikaner(PG)	RAJASTHAN	30-06-2022 -10:30, 8, 0, no 03, 23	15 Jun 2024 10-23	17 Jun 2024 15-51	29 Aug 2024 21:30, 28 Aug 2024 14-38	30 Aug 2024 10:01, 29 Aug 2024 21-00	01-Sep-2024	03.06
60	11/01/22	Jul - 2024	220V Main Bay 202 of 230 KV Bikaner_3 same line at Bikaner_2 (PRTSL)	PRTSL	220KV	202	Main Bay	Bikaner_2 (PRTSL)	RAJASTHAN	29-09-2021 -10:30, 16, 4, 8, 9, 10 and No 21, 12	29 Aug 2024 22:26, 23 Jul 2024 16:15, 20 Jul 2024 15-00	30 Aug 2024 17:31, 23 Jul 2024 16:15, 20 Jul 2024 17-00	31 Aug 2024 11:10	01-Sep-2024 15-03	02-Sep-2024	17.25
61	11/01/23	Jul - 2024	400V Main Bay 416 of 400 KV Bikaner_2, 500V Line at Bikaner_2 (PRTSL)	PRTSL	400KV	416	Main Bay	Bikaner_2 (PRTSL)	RAJASTHAN	29-12-2021 -10:30, 2, 4, 10	30 Aug 2024 15:25, 27 Jul 2024 14-39	07 Sep 2024 11:51, 29 Sep 2024 08-55	03 Sep 2024 12:20, 02 Sep 2024 15-15	03 Sep 2024 17:07, 02 Sep 2024 17-10	08-Sep-2024	18.29
62	11/01/23	Jun - 2024	400V Tie Bay 726 of 765KV Fatehgarh-2 to Bhaola-2 circuit 3 (Karnam) and 765KV CT-6 at Fatehgarh_(PG)	POWERGR	765KV	726	Tie Bay	Fatehgarh_(PG)	RAJASTHAN	18-09-2019 -10:30, 5, 15 & 16, 7	09 Jun 2024 09-00	13 Jun 2024 11-03	08 Jul 2024 18:03, 03 Jul 2024 23-18	10 Jul 2024 16:31, 08 Jul 2024 17:07	05-Sep-2024	19.15
63	11/01/23	Jun - 2024	400V Main Bay 404 of 125 MVA BUS REACTOR at	UPPTCL	400KV	404	Main Bay	Jeebharpur_TPS(UPL)	UTTAR PRADESH	27-10-2022 -00:00, 24881/2022, 2-550, 7	19 Jul 2024 17:09	23 Jul 2024 10-32	03 Sep 2024 15:29, 10 Aug 2024 11-22, 28	04 Sep 2024 15:21, 02 Sep 2024 11-22, 28	05-Sep-2024	18.30
64	11/01/23	Jul - 2024	400V Main Bay 407 of 400 KV SPARE BAY at Jeebharpur_TPS(UPL)	UPPTCL	400KV	407	Main Bay	Jeebharpur_TPS(UPL)	UTTAR PRADESH	27-10-2022 -00:00, 24881/2022, 2-550, 7	19 Jul 2024 17:09	23 Jul 2024 10-32	03 Sep 2024 15:29, 10 Aug 2024 11-22, 28	04 Sep 2024 15:21, 02 Sep 2024 11-22, 28	05-Sep-2024	18.48
65	11/01/23	Jul - 2024	400V Tie Bay 408 of 125 MVA BUS REACTOR and SPARE BAY at Jeebharpur_TPS(UPL)	UPPTCL	400KV	408	Tie Bay	Jeebharpur_TPS(UPL)	UTTAR PRADESH	27-10-2022 -00:00, 24881/2022, 2-550, 7	19 Jul 2024 17:09	23 Jul 2024 10-32	03 Sep 2024 15:29, 10 Aug 2024 11-22, 28	04 Sep 2024 15:21, 02 Sep 2024 11-22, 28	05-Sep-2024	18.49
66	11/01/23	May -	765V Main Bay 608 of 132 MVA LINE REACTOR at Chhatrapur_TPS(UPL)	CS-PTCL	765KV	608	Main Bay	Chhatrapur_TPS(UPL)	UTTAR PRADESH	15-11-2018 -00:00, 2 & 37, 18 & 1, 2, 3, 250, 4, 8, 4	23-May-2024 10-18	28-May-2024 16-43	30 Aug 2024 15:14, 28 Aug 2024 12:21, 13	01-Sep-2024 15-13 Aug 2024 16-18	05-Sep-2024	21.13
67	11/01/24	Jun - 2024	765V Main Bay 724 of 765/500KV 1500 MVA CT 4 at Bhaola_2 (PG)	POWERGR	765KV	724	Main Bay	Bhaola_2 (PG)	RAJASTHAN	10-09-2019 -10:30, 6, Point no. 1 and 5	25 Jun 2024 09:20, 24 Jun 2024 12-15	28 Jun 2024 14:26, 29 Jul 2024 08-15	31 Aug 2024 11:36	01-Sep-2024 10-23	01-Sep-2024	01.04
68	11/01/23	Aug - 2024	400V Main Bay 403 of 400 KV AGE23L SL BHD2_PG Bhaola_2 (PG) 1 at AGE23L SL BHD2_PG	AGE23L	400KV	403	Main Bay	AGE23L SL BHD2_PG	RAJASTHAN	01-09-2020 -11:00, 2nd NWPCTP Meeting_AnnexV/Tablr 2/7_16	20 Aug 2024 12:18, 16 Aug 2024 13:27, 14	20 Aug 2024 15:54, 20 Aug 2024 10:50, 16	05 Sep 2024 12:30, 04 Sep 2024 17:01, 04 Sep 2024 16:51, 03 Sep	06 Sep 2024 17:40, 05 Sep 2024 12:19, 04 Sep 2024 14:37	07-Sep-2024	22.36
69	11/01/23	Aug - 2024	400V Tie Bay 403 of 400 KV AGE23L SL BHD2_PG Bhaola_2 (PG) 1 and CT 1 at AGE23L SL BHD2_PG	AGE23L	400KV	403	Tie Bay	AGE23L SL BHD2_PG	RAJASTHAN	01-09-2020 -11:00, 2nd NWPCTP Meeting_AnnexV/Tablr 2/7_16	20 Aug 2024 12:18, 16 Aug 2024 13:27, 14	20 Aug 2024 15:54, 20 Aug 2024 10:50, 16	05 Sep 2024 12:30, 04 Sep 2024 17:01, 04 Sep 2024 16:51, 03 Sep	06 Sep 2024 17:40, 05 Sep 2024 12:19, 04 Sep 2024 14:37	07-Sep-2024	23.24
70	11/01/23	Aug - 2024	400V Main Bay 401 of CT 1 at AGE23L SL BHD2_PG	AGE23L	400KV	401	Main Bay	AGE23L SL BHD2_PG	RAJASTHAN	01-09-2020 -11:00, 2nd NWPCTP Meeting_AnnexV/Tablr 2/7_16	20 Aug 2024 12:18, 16 Aug 2024 13:27, 14	20 Aug 2024 15:54, 20 Aug 2024 10:50, 16	05 Sep 2024 12:30, 04 Sep 2024 17:01, 04 Sep 2024 16:51, 03 Sep	06 Sep 2024 17:40, 05 Sep 2024 12:19, 04 Sep 2024 14:37	07-Sep-2024	23.47
71	11/01/23	Aug - 2024	400V Main Bay 004 of CT 2 at AGE23L SL BHD2_PG	AGE23L	400KV	404	Main Bay	AGE23L SL BHD2_PG	RAJASTHAN	01-09-2020 -11:00, 2nd NWPCTP Meeting_AnnexV/Tablr 2/7_16	20 Aug 2024 12:18, 16 Aug 2024 13:27, 14	20 Aug 2024 15:54, 20 Aug 2024 10:50, 16	05 Sep 2024 12:30, 04 Sep 2024 17:01, 04 Sep 2024 16:51, 03 Sep	06 Sep 2024 17:40, 05 Sep 2024 12:19, 04 Sep 2024 14:37	08-Sep-2024	00.16
72	11/01/23	Aug - 2024	400V Tie Bay 400 of Bus no 01 and CT 2 at AGE23L SL BHD2_PG	AGE23L	400KV	405	Tie Bay	AGE23L SL BHD2_PG	RAJASTHAN	01-09-2020 -11:00, 2nd NWPCTP Meeting_AnnexV/Tablr 2/7_16	20 Aug 2024 12:18, 16 Aug 2024 13:27, 14	20 Aug 2024 15:54, 20 Aug 2024 10:50, 16	05 Sep 2024 12:30, 04 Sep 2024 17:01, 04 Sep 2024 16:51, 03 Sep	06 Sep 2024 17:40, 05 Sep 2024 12:19, 04 Sep 2024 14:37	08-Sep-2024	00.34

BUS Report from 01-07-2024 to 10-09-2024

S.A. No.	CASE ID	Applicable in Month	Name of element	Owner	Voltage Level (kV)	Bus No.	Bus Type	Bus Scheme	Rack Level	Normal Current Capacity	Substation	State	Approved in 25MW/30MW Bus	Remark	Information request for changing of new element (element)		Acknowledgment sent by 25MW/30MW Bus		Request for start changing and start use (element)		Finalized Approval for Test Changing/Total element (element)		Actual date & time of changing		Request for Total Operation Certificate		Total Run Operation Certificate Details	
															Date	Time	Date	Time	Date	Time	Date	Time	Date	Time	Date	Time	Date	Time
1	1119530	Jun_2024	400W Main Bus 2 at Rosar(PSTCL)	PSTCL	400kV	2	Main Bus	One & half Breaker	NA	2456 A	Rosar(PSTCL)	PUNJAB	24-09-2019	10:30, 34, 35 & 36	05 Jul 2024 05:25, 06 Jul 2024 05:30, 07 Jun 2024 14:24, 27 Jun 2024 12:01	06 Jul 2024 03:37, 05 Jul 2024 11:02, 09 Jun 2024 10:22, 27 Jun 2024 14:38	03 Jul 2024 19:23, 06 Jul 2024 19:19	03 Jul 2024 19:23, 06 Jul 2024 19:19	03 Aug 2024	11:59								
2	1119531	Jun_2024	220W Main Bus 1 at Rosar(PSTCL)	PSTCL	220kV	1	Main Bus	Double Main & Transfer	80 kA	2500 A	Rosar(PSTCL)	PUNJAB	24-09-2019	10:30, 34, 35 & 36	05 Jul 2024 05:25, 06 Jul 2024 05:30, 07 Jun 2024 14:24, 27 Jun 2024 12:01	06 Jul 2024 03:37, 05 Jul 2024 11:02, 09 Jun 2024 10:22, 27 Jun 2024 14:38	03 Jul 2024 19:23, 06 Jul 2024 19:19	03 Jul 2024 19:23, 06 Jul 2024 19:19	03 Aug 2024 10:22	03 Aug 2024 11:56	03 Aug 2024	14:23						
3	1119531	Jun_2024	220W Main Bus 2 at Rosar(PSTCL)	PSTCL	220kV	2	Main Bus	Double Main & Transfer	80 kA	2500 A	Rosar(PSTCL)	PUNJAB	24-09-2019	10:30, 34, 35 & 36	05 Jul 2024 05:25, 06 Jul 2024 05:30, 07 Jun 2024 14:24, 27 Jun 2024 12:01	06 Jul 2024 03:37, 05 Jul 2024 11:02, 09 Jun 2024 10:22, 27 Jun 2024 14:38	03 Jul 2024 19:23, 06 Jul 2024 19:19	03 Jul 2024 19:23, 06 Jul 2024 19:19	03 Aug 2024 10:22	03 Aug 2024 11:56	03 Aug 2024	14:51						

Bus Coupler Report from 01-07-2024 to 10-09-2024

S.No	Case ID	Applicatio n Month	Name of element	Owner	Voltage Level (in kV)	Associated Transmission Element1	Associated Transmission Element2	Substation	State	Approved in SCMP/Status/Body	Remark	Intimation request for changing of new element (Format A)	Acknowledment sent by NREDC (Format B)	Request for test charging and trial run (Format C)	Provisional Approval for Test Charging/Trial operation (Format D)	Actual date & time of charging	Request for Trial Operation Certificate (Format E)	Trial Run Operation Certificate Details			
												Date	Date	Date	Date	Date	Date	Time	Date	Trial Run/Operation Period	Certificate No.
1	1119209	Aug-2024	400KV Bus Coupler Bay 405 of 400 KV BUS-I and 400 KV BUS-II at Shamli (UP)	UPPTCL	400KV	400 KV BUS-I	400 KV BUS-II	Shamli (UP)	UTTAR PRADESH	19-02-2024 -00-00, 3, 29-SIANNKURECE@7, 5		24 Aug 2024 15:43	28 Aug 2024 12:39	04 Sep 2024 11:09, 11 Aug 2024 11:47	05 Sep 2024 10:05, 02 Sep 2024 12:11	06-Sep-2024	17:22				

BUS REACTOR Report from 01-07-2024 to 10-09-2024

S/N	CASE ID	Applicatio n Month	Name of element	Owner	Voltage Level	MVA/Capacity	Substation	Make	Configuration	Serial No	State	Approved in SCADA/Operate Mode	Remarks	Bus Reactor Details	Old MVA/Capacity	Intention request for changing of new element (SCADA)		Request for test changing and trial run period	Provisional Approval for Trial Changing/Trial operation/Control BT		Request for Trial Operation Certificate Serial ID	Trial Run/Operation Certificate Details		
																Date	Date		Date	Date		Date	Time	Date
1	1118171	Jul_2024	600V LIS MVA Bus Reactor at Dharmapur	APTEL	60KV	120 MVA	DRBHILL	WEL	3 Phase	002708	CTMR, PRADESH	14-02-2024 00:00.3 14-02-2024 00:00.3		None			21 Jul 2024 11:10	21 Jul 2024 16:36	01 Aug 2024 00:26, 03 Aug 2024 01:08, 03 Aug 2024 01:46, 05 Aug 2024 02:00	04 Aug 2024 01:10, 03 Aug 2024 01:10, 03 Aug 2024 01:10, 03	03 Aug 2024	21:10		
2	1118170	Jul_2024	600V LIS MVA Bus Reactor at Jambhampur, TDSUR	APTEL	60KV	120 MVA	DRBHILL	WEL	3 Phase	17164051 & 31248	CTMR, PRADESH	17-10-2023 00:00 14-08-2022 2:55:2		None			18 Jul 2024 17:03	21 Jul 2024 10:32	01 Sep 2024 03:26, 30 Sep 2024 03:30, 28 Aug 2024 03:45	04 Sep 2024 03:26, 02 Sep 2024 03:30, 28 Aug 2024 03:45	06 Sep 2024	18:30		

AC Transmission line Shifting Report from 01-07-2024 to 10-09-2024

S.No	CASE ID	Applicatio n Month	Name of element	Owner	Voltage Level (kV)		Circuit No	Line Length	Conductor Type	Tower Configuration	State	Approved In	Remark	Information request for	Admission/ment sent	Request for test	Provisional Approval	Actual date & time of operation		Request for Trial	Trial Run Operation Certificate Details	
					SCH/Statutory Body	charging of new element (Formal A)						to NREDC (Formal B)		for Test Shifting and Trial run (Formal C)	for Test Shifting/Trial operation(Formal W)	Date	Date	Date	Date	Date	Date	Date
1	1110105	Jul - 2024	120KV Paridahan(NT) Samangay(20)	POWERGRID D.	220KV		1	17.545 KM	ZSBA	Double	MADHYANA to DANESANA	09-06-2024 - 11.03, MOEM of NREDC - 1. A1		Date	Date	19 Jul 2024 11:01:29	19 Jul 2024 15:25:29	20 Jul 2024 20:25	30 Jul 2024	17:30		

ADANI GREEN ENERGY TWENTY FIVE LIMITED (ADANI RENEWABLES)

400kV BADISID SUBSTATION LINE PROTECTION RELAY SETTING CALCULATION

400kV BADISID SUBSTATION


500 MW BADISID SOLAR POWER PROJECT

We reserve all rights in this document and in the information contained therein. Reproduction use or disclosure to third parties without express authority is strictly forbidden. Copyright © by Hitachi Energy India Limited.

"Disclaimer – Unauthorized access

The offered solution may be accessed through the customer network and therefore represents a danger which poses a potential threat of intrusion by unauthorized parties. Therefore, Hitachi Energy India Limited strongly recommends that the customer insures/implements necessary protection measures against the possibility of such unauthorized access.

Hitachi Energy India Limited disclaims any responsibility and shall under no circumstances be liable for damages or malfunctions caused by external intrusion of any kind whatsoever."

	Categories: <input type="checkbox"/> Cat-I Approved. Good for Manufacturing/Construction/Fabrication.
VISHRAM <small>Digitally signed by VISHRAM Date: 2024.09.02 17:14:28 +05'30'</small> Reviewer	<input checked="" type="checkbox"/> Cat-I* Approved with minor comments. No resubmission is required. To be incorporated in As-Built. Good for Manufacturing/ Construction/ Fabrication subject to incorporation of comments. <input type="checkbox"/> Cat-II Resubmission is required. Approved & Released for Manufacturing/ fabrication/ construction subjected to incorporation of comments.
Shaheed Patel <small>Digitally signed by Shaheed Patel Date: 2024.09.02 18:16:06 +05'30'</small> Approver	<input type="checkbox"/> Cat-III Not Approved. Revise & Resubmit for Approval <input type="checkbox"/> Cat-IV For Information & Records. <input type="checkbox"/> Cat-IV* Incorporate Comments & resubmit for Information & records. Note: "Approval of this document does not absolve the Contractor/ Supplier/Fabricator from fulfilling Contractual obligations in any way"


400kV BADISID SUBSTATION LINE PROTECTION RELAY SETTING CALCULATION

DOCUMENT	400kV BADISID SUBSTATION LINE PROTECTION RELAY SETTING CALCULATION
PROJECT	500 MW BADISID SOLAR POWER PROJECT
SUBSTATION	400kV BADISID SUBSTATION
CLIENT	ADANI GREEN ENERGY TWENTY FIVE LIMITED
SUPPLIER	HITACHI ENERGY INDIA LIMITED
PO / LOA No.	IDTO-VI/ Adani Green-400 kV at Badi Sid - Rajasthan /PGGA/CRP & SAS
HEIL SO REF.	3100139976, 1MNS500950-PAAA

Revisions:

Rev.	Prep. / Appr.	Description	Date
00	SS / PN	First Submission	02-Aug-24
01	SS / PN	Revised as per customer comments	19-Aug-24

CUSTOMER NEPAL ELECTRICITY AUTHORITY.	DEPT. PG-GAS	DOCUMENT ID. 1MNS500735-CGAA	REV. 01	LANG. En	PAGE 2/50
PROJECT 400kV BADISID SUBSTATION LINE PROTECTION RELAY SETTING CALCULATION			PREP. SS	APPR. PN	DATE 19-AUG-24

 Hitachi Energy PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

General Data of 400 KV LINE CONTROL AND RELAY PANEL (BAY-403)

Relay Details

Type = Micom P546

Bay Details

Local Station: = 400kV BADISID SUBSTATION

Bay Reference = BAY -403

Remote Station: = Bhadla

Network Details

Voltage = 400 kV

Frequency = 50 Hz

OHL length of this circuit = 12.00 km

CT Details (Local end):


CT Ratio = 2000-1000-500/1 A

Rated Primary current = 1000 A

Rated Secondary current = 1 A

Information

All the settings are in Secondary values

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

The Relay Bias characteristics is determined by four protection settings

- Is1 = The basic differential current setting which determines the minimum pick up of the relay
- Is2 = A bias threshold setting, above which the higher percentage bias k2 is used
The lower percentage bias setting used when the bias current is below IS2, This provides stability for small CT mismatches, whilst ensuring good sensitivity to resistive faults under heavy load conditions.
- K1 =
- K2 = The higher percentage bias setting used to improve relay stability under heavy through fault current conditions.

Basic Differential setting

This is basic differential current setting which determines the minimum pick up level of the relay. Where Capacitive Charging Current compensation is disabled, the setting of Is1 must be >2.5 times of total line charging current value.

The Charging current is calculated according to the following equation

$$I_{\text{charge}} = \frac{U}{\sqrt{3} * X_{c1}}$$

Where,

$$U = \text{System Line Voltage}$$

$$X_{c1} = \text{Positive Sequence Line Capacitance value}$$

$$I_{\text{charge}} = \text{Line charging current/kM due to Line Capacitance}$$

$$C1 = \frac{1}{2 * \pi * f * C1}$$

$$C1 = \text{Line Capacitance value/kM}$$

$$C1 = 0.0119 \text{ } \mu\text{F/kM}$$

$$X_{c1} = \frac{1}{2 * \pi * f * C1}$$

$$X_{c1} = \frac{1}{2 * 3.14 * 50 * 0.000000119}$$

$$X_{c1} = 267623 \text{ } \Omega$$

$$I_{\text{charge}} = \frac{U}{\sqrt{3} * X_{c1}}$$

$$I_{\text{charge}} = \frac{400}{\sqrt{3} * 267622.97}$$

$$I_{\text{charge}} = 0.86 \text{ A}$$


Primary Charging Current of line = 0.86*12

$$= 10.32 \text{ A}$$

Sec.Charging Current of line, Ic = Icharge / CTR

$$= 10.32/1000$$

$$= 0.01032 \text{ A}$$



The below mention setting recommended As per Main-1 relay

In_Nominal current (CT secondary)	=	1	A
Is1	=	0.25% of In	
	=	0.25	A
k1	=	30%	
Is2	=	2*In	
	=	2.0	A
K2	=	150%	


CT Ratio Correction

Local End CT Ratio	=	1000 / 1 A
Remote End CT Ratio	=	3000 / 1 A
CT Correction factor	=	CT Primary/Min Scheme CT Primary
	=	Min Scheme CT Primary ---> Lowest CT ratio

Local end CT Correction factor	=	1.0
Remote end CT Correction factor	=	3.0

Compenstation

Compenstation	=	Cap Charging
Susceptance (B)	=	ωC
	=	$I_{ch}/V * 10^{-3}$
	=	$(0.86 / (400 / 1.732)) * 10^{-3}$
	=	0.0037 mS

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION		Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)		Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE		Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546		Rev No.	1

Setting Calculation of Distance

General Data=

Total Line length is = 12.00 km

OHL data

Basic Line OHL parameters

Positive sequence imp. per km = 0.0266 +j 0.313 Ohm/km

Zero sequence imp. per km = 0.162 +j 1.187 Ohm/km

continuous current carrying capacity for each OHL - Icon

Considered as per Maximum power flow In the line (0 MVA) = 953 A

Line length = 12.00 Km

Line data= OHL

(Pos. seq. impedance of the line) = 0.319 +j 3.750 Ohm

R1A' + jX1A' = 3.764 L 85.13

(Zero seq. impedance of the line) = 1.940 +j 14.244 Ohm

R0A' + jX0A' = 14.376 L 82.24

CT Ratio (Adopted) = 1000 / 1 A

VT ratio = 400 / 0.11 kV

CT / VT Ratio conversion = CT ratio / VT ratio
= (1000/1)/(400/0.11)
= 0.275

Maximum load on line = 953 A

Zload' = (400*0.85*1000) / (952.7*1.732*1.5)

Zload' = 137.4 Ohm/ph

Referred to Secondary side = Maximum load on line * (CT/VT ratio)
= 137.37 x 0.275

Zload = 37.777 Ohm/ph

Cosφmin = 0.85 Minimum power factor

= 32 Deg

Set Load Angle = φmin + 5

(Load encroachment angle) = (32+5)

= 37 Deg

Arc Resistance Phase- Phase Rarc p-p' = 15 Ohm/ph


Referred to Secondary side Rarc p-p = 4.1 Ohm/ph

Arc Resistance Phase- Earth Rarc p-e' = 15 Ohm/ph

Referred to Secondary side Rarc p-e' = 4.1 Ohm/ph

Tower Foot Resistance Rtower' = 10 Ohm/ph

Referred to Secondary side Rtower' = 2.8 Ohm/ph

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION		Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)		Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE		Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546		Rev No.	1

General settings

Protected Line Impedance
Line Impedance secondary = 3.7636 * 0.275
= **1.03** Ohm/ph

Line Angle (Deg) = **85.1** Deg

Short Line Feeder Details at Remote Station

Name of the line = -

Length of the line = 30.45 Km

Positive sequence imp. per km = 0.015 +j 0.253 Ohm/Km
Zero sequence imp. per km = 0.249 +j 0.999 Ohm/Km

Positive sequence imp. for total line km = 0.448 +j 7.698 Ohm
Zero sequence imp. for total line km = 7.585 +j 30.420 Ohm

Longest Line Feeder Details at Remote Station

Name of the line = -

Length of the line = 52.00 Km

Positive sequence imp. per km = 0.036 +j 0.310 Ohm/Km
Zero sequence imp. per km = 0.256 +j 1.104 Ohm/Km

Positive sequence imp. for total line km = 1.872 +j 16.141 Ohm
Zero sequence imp. for total line km = 13.312 +j 57.408 Ohm

Distance Measuring zones settings

To find KN magnitude and KN angle for Zone 1

KZ1 Res Comp & KZ1 Angle = (Z0-Z1)/3Z1
= (14.376-3.764)/(3x3.764)
= 0.94 L -3.917

To find KN magnitude and KN angle for Zone 2, 3, 4


Positive sequence imp. for total line km = 0.409 +j 5.290 Ohm
= 5.305 L 85.58
Zero sequence imp. for total line km = 3.457 +j 20.328 Ohm
= 20.620 L 80.35
KZ2/3/4 Res Comp & KZ2/3/4 Angle = (Z0-Z1)/3Z1
= 0.96 L -7.036

Distance Zone 1 setting (Zone-1 Enabled only during communication failure)

Relay zone-1 reach shall be set to cover 80% forward direction considering the parallel line in operation

Operation direction

OperationDir = Forward **(*Fixed Direction mode as Forward for Zone-1)**

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

Positive sequence reactance reach

Zone 1 phase fault reach is set to **80%** of the total line reactance

Zone-1 reactance reach setting for phase faults, X1Z1'

$$\begin{aligned}
 &= 0.8 * jX1' \\
 &= 0.8 * 3.75 \\
 X1Z1' &= 3.00 \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
 &= X1Z1' * CT \text{ ratio} / VT \text{ ratio} \\
 X1Z1 &= \mathbf{0.83} \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

Positive sequence resistance for zone characteristics angle

$$\begin{aligned}
 &= 0.8 * R1' \\
 &= 0.8 * 0.32 \\
 R1Z1' &= 0.26 \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
 &= R1Z1' * CT \text{ ratio} / VT \text{ ratio} \\
 R1Z1 &= \mathbf{0.07} \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

Positive sequence Impedance reach

$$Z1' = 3.01$$

The secondary setting will thus be

$$\begin{aligned}
 &= Z1' * CT \text{ ratio} / VT \text{ ratio} \\
 Z1 &= \mathbf{0.83} \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

Set the resistive reach for phase faults to=

$$R1ph' = 30.00 \qquad \qquad \qquad \text{Ohm/l}$$

The secondary setting will thus be

$$\begin{aligned}
 &= R1ph' * CT \text{ ratio} / VT \text{ ratio} \\
 R1ph &= \mathbf{8.25} \qquad \qquad \qquad \text{Ohm/l}
 \end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Earth)

Set the resistive reach for earth faults to

$$R1G' = 25.00 \qquad \qquad \qquad \text{Ohm/l}$$


The secondary setting will thus be

$$\begin{aligned}
 &= R1G' * CT \text{ ratio} / VT \text{ ratio} \\
 R1G &= \mathbf{6.88} \qquad \qquad \qquad \text{Ohm/l}
 \end{aligned}$$

Time delay of trip

$$tZ1 = 0.00 \qquad \qquad \qquad \text{Sec}$$

Distance Zone 2 setting

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

Relay zone-2 reach shall be set to cover
100 % of protected line + 20 % of Remote end shortest line forward direction

Operation direction

OperationDir = Forward (*Fixed Direction mode as Forward for Zone-2)

Positive sequence reactance reach

Zone 2 phase fault reach is set to **100%** of the total line reactance
+ **20%** of Remote end shortest line forward direction

Zone-2 reactance reach setting for phase faults, X1Z2

$$\begin{aligned}
 &= (100\% \times 3.75) + (20\% \times 7.7) \\
 &= (1 \times 3.75) + (0.2 \times 7.7) \\
 X1Z2' &= 5.29 \qquad \qquad \qquad \text{Ohm/p}
 \end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
 &= X1Z2' \times \text{CT ratio} / \text{VT ratio} \\
 X1Z2 &= \mathbf{1.46} \qquad \qquad \qquad \text{Ohm/p}
 \end{aligned}$$

Positive sequence resistance for zone characteristics angle

$$\begin{aligned}
 &= (100\% \times 0.32) + (20\% \times 0.45) \\
 &= (1 \times 0.32) + (0.2 \times 0.45) \\
 R1Z2' &= 0.41 \qquad \qquad \qquad \text{Ohm/p}
 \end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
 &= R1Z2' \times \text{CT ratio} / \text{VT ratio} \\
 R1Z2 &= \mathbf{0.11} \qquad \qquad \qquad \text{Ohm/p}
 \end{aligned}$$

Positive sequence Impedance reach

$$Z2' = 5.31$$

The secondary setting will thus be

$$\begin{aligned}
 &= Z2' \times \text{CT ratio} / \text{VT ratio} \\
 Z2 &= \mathbf{1.46} \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

The resistive reach for phase to phase is set to cover a maximum expected fault resistance of 30 ohm

Considering a factor of 2 on the zone-1 resistive reach value to take care of in feed effect.

$$R2ph = 60$$

Set the resistive reach for phase faults to=

$$R2ph' = 60.00 \qquad \qquad \qquad \text{Ohm/l}$$

The secondary setting will thus be


$$\begin{aligned}
 &= R2ph' \times \text{CT ratio} / \text{VT ratio} \\
 R2ph &= \mathbf{16.50} \qquad \qquad \qquad \text{Ohm/l}
 \end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Earth)

Setting of the resistive reach for the underreaching zone 2 should follow the condition to minimize the risk for overreaching

Set the resistive reach for earth faults to

$$R2G' = 50.00 \qquad \qquad \qquad \text{Ohm/l}$$

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

The secondary setting will thus be

$$R2G = R2G' * CT \text{ ratio} / VT \text{ ratio} = 13.75 \text{ Ohm/l}$$

Time delay of trip Phase-Phase loops

Setting of Zone timers=

Normal values the needed time difference can be calculated

$$t2 = 40ms + 40ms + 40ms + 50ms = 170ms$$

Where,

the operation time of protection is 40 ms (Distance relay operation of other line at Remote End)

the breaker opening time is 40 ms

the resetting time of protection is 40 ms and

the additional margin is 50 ms

$$tZ2 = 0.35 \text{ Sec}$$

Distance Zone 3 setting

Relay zone-3 reach shall be set to cover

120 % of protected line + 100 % of Remote end longest line forward direction

Operation direction

$$\text{OperationDir} = \text{Forward}$$

Positive sequence reactance reach

Zone 3 phase fault reach is set to **120%** of the total line reactance
+ **100%** of Remote end longest line forward direction

Zone-3 reactance reach setting for phase faults, X1Z3

$$= (120\% \times 3.75) + (100\% \times 16.14)$$

$$= (1.2 \times 3.75) + (1 \times 16.14)$$

$$X1Z3' = 20.64 \text{ Ohm/p}$$

The secondary setting will thus be

$$X1Z3 = X1Z3' * CT \text{ ratio} / VT \text{ ratio} = 5.68 \text{ Ohm/p}$$

Positive sequence resistance for zone characteristics angle

$$(120\% \times 0.32) + (100\% \times 1.87)$$

$$(1.2 \times 0.32) + (1 \times 1.87)$$

$$R1Z3' = 2.26 \text{ Ohm/p}$$

The secondary setting will thus be

$$R1Z3 = R1Z3' * CT \text{ ratio} / VT \text{ ratio} = 0.62 \text{ Ohm/p}$$

Positive sequence Impedance reach


$$Z3' = 20.76$$

The secondary setting will thus be

$$Z3 = Z3' * CT \text{ ratio} / VT \text{ ratio} = 5.71 \text{ Ohm/P}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

Considering a factor of 2.5 on the zone-1 resistive reach value to take care of in feed effect.

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

Set the resistive reach for phase faults to

$$R_{3ph'} = 75.00 \quad \text{Ohm/l}$$

The secondary setting will thus be

$$= R_{3ph'} * CT \text{ ratio} / VT \text{ ratio}$$

$$R_{3ph} = 20.63 \quad \text{Ohm/l}$$

Fault resistance reach in Ohm/loop (Phase-Earth)

Setting of the resistive reach for the underreaching zone 3 should follow the condition to minimize the risk for overreaching

Set the resistive reach for earth faults to

$$R_{3G'} = 65.00 \quad \text{Ohm/l}$$

The secondary setting will thus be

$$= R_{3G'} * CT \text{ ratio} / VT \text{ ratio}$$

$$R_{3G} = 17.88 \quad \text{Ohm/l}$$

Time delay of trip

Setting of Zone timers=

Normal values the needed time difference can be calculated

$$t_3 = 350\text{ms} + 40\text{ms} + 40\text{ms} + 40\text{ms} + 50\text{ms} = 520\text{ms}$$

Where, Zone-2 operation is 350 ms (Distance relay operation of other line at Remote End)

the operation time of protection is 40 ms (Distance relay operation of other line at Remote End)

the breaker opening time is 100 ms

the resetting time of protection is 40 ms and

the additional margin is 50 ms

$$t_{Z3} = 1.00 \quad \text{Sec}$$

Distance Zone 4 setting

Relay zone-4 reach shall be set to cover 20 % of protected line + 0 % of Remote end longest line forward

direction

Operation direction

$$\text{OperationDir} = \text{Reverse}$$

Positive sequence reactance reach

Zone 4 phase fault reach is set to **20%** of the total line reactance
+ **0%** of Remote end longest line forward direction

Zone-4 reactance reach setting for phase faults, X1Z4

$$= (20\% \times 3.75) + (0\% \times 16.14)$$

$$= (0.2 \times 3.75) + (0 \times 16.14)$$

$$X_{1Z4'} = 0.75 \quad \text{Ohm/p}$$

The secondary setting will thus be


$$= X_{1Z4'} * CT \text{ ratio} / VT \text{ ratio}$$

$$X_{1Z4} = 0.21 \quad \text{Ohm/p}$$

Positive sequence resistance for zone characteristics angle

$$= (20\% \times 0.32) + (0\% \times 1.87)$$

$$= (0.2 \times 0.32) + (0 \times 1.87)$$

 Hitachi Energy PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

$$R1Z4' = 0.06 \text{ Ohm/p}$$

The secondary setting will thus be

$$= R1Z4' * CT \text{ ratio} / VT \text{ ratio}$$

$$R1Z4 = 0.02 \text{ Ohm/p}$$

Positive sequence Impedance reach

$$Z4' = 0.75$$

The secondary setting will thus be

$$= Z4' * CT \text{ ratio} / VT \text{ ratio}$$

$$Z4 = 0.21 \text{ Ohm/P}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

The faults on remote lines will have in-feed of fault current through the fault resistance from other remote feeders which will make an apparent increase of the value. The setting is selected to take care of above factors. Set the resistive reach for phase faults to=

Setting the RF/X factor giving the PhF resistive coverage

Set the resistive reach for phase faults to

$$R4ph' = 75.00 \text{ Ohm/l}$$

The secondary setting will thus be

$$= R4ph' * CT \text{ ratio} / VT \text{ ratio}$$

$$R4ph = 20.63 \text{ Ohm/l}$$

Fault resistance reach in Ohm/loop (Phase-Earth)

Setting of the resistive reach for the underreaching zone 4 should follow the condition to minimize the risk for overreaching

Set the resistive reach for earth faults to

$$R4G' = 65.00 \text{ Ohm/l}$$

The secondary setting will thus be

$$= R4G' * CT \text{ ratio} / VT \text{ ratio}$$

$$R4G = 17.88 \text{ Ohm/l}$$

Time delay of trip

Setting of Zone timers=

Normal values the needed time difference can be calculated

$$t4 = 40ms + 40ms + 40ms + 50ms = 170ms$$

Where,

the operation time of protection is 40 ms (Busbar Protection relay)

the breaker opening time is 40 ms

the resetting time of protection is 40 ms and

the additional margin is 50 ms


$$tZ4 = 0.35 \text{ Sec}$$

Load Blinders

$$Z < \text{Blinder Imp (90\% of LR)} = 34.0 \text{ Ohm}$$

$$\text{Load/B Angle} = 37.0 \text{ Deg}$$

POWER SWING BLOCK=

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

PSB Blocking zone = Zone-1, 2,3,4
PSB Unblock delay = 2.0 Sec

Slow Swing Setting

$R7 = R7' = 1.2 \times \text{Maximum Resistive reach (Zone 3)}$ = 1.2×17.875
21.45 Ω

$Z7 = Z7' = 1.2 \times \text{Maximum Zone reach (Zone 3)}$ = 1.2×5.71
6.85 Ω

$R8 = R8' = 1.1 \times R7$ = 1.1×21.45
23.60 Ω

$Z8 = Z8' = 1.1 \times Z7$ = 1.1×6.852
7.54 Ω

Alpha = 0 deg
PSB Timer = 50 mSec

SOTF=

SOTF Status = En Pdead + Pulse
SOTF Tripping = Zone-2
SOTF Delay = 110 sec
TOR Status = Enabled
TOR Tripping = Zone-2

VT SUPERVISION=

VTS Mode = Measured + MCB
VTS Status = Blocking
VTS Reset Mode = Auto
VTS Time Delay = 5 Sec
VTS I> Inhibit = 10 A
VTS I2> Inhibit = 50mA

OVERVOLTAGE PROTECTION=

V> Measur't Mode = V1> & V2 Ph- N
V> Operate Mode = V1> & V2 Any Ph
V>1 Function = DT
V>1 Set = 70 V
V>1 time delay = 5 sec
V>2 Set = 89 V
V>2 time delay = 0.1 sec


UNDERVOLTAGE PROTECTION (Only DR Trigger - No Tripping)

V< Measur't Mode = V1< & V2 Ph- N
V< Operate Mode = V1> & V2 Any Ph
V<1 Function = DT
V<1 Set = 57 V
V<1 time delay = 0 sec
V<1 Poledead Inh = Enabled

DIR. EARTH FAULT SETTINGS = 67N

Pickup current should be set above the continuous residual current under normal operation.

Max Load Current = 952.7
IN>1 Function = IEC S Inverse
IN>1 Directional = Directional Fwd

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY-403)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BHADLA LINE	Doc No.	1MNS500950-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

IN>1 Pickup current in A = 23 % of Maximum Load current of the Conductor
 $0.23 * 952.7 = 219.121A$

IN>1 Current Set (Is) = 0.22 A

The Earth fault function has to be graded with the Zone-3 Protection

Required time (Treq) = 1.13 Sec

The IDMT curve shall saturate if the fault current more than 20 times of pickup current. In this case fault current more than 20 times. Hence 20 times of set current considered for TMS calculation.

Fault Current = $20 * \text{Pickup} = 4382.42 \text{ A}$
IN>1 TMS = $(T_{req} * (I_f / I_s)^{0.02-1}) / 0.14$
= $(1.13 * (4382.42 / 219.121)^{0.02-1}) / 0.14$
= 0.50
Char Angle = -45 Deg

BROKEN CONDUCTOR: (Alarm Only)

I2/I1 Ratio = 0.2
time delay = 5

DISTURBANCE RECORDER:

Pre-Fault time = 0.5 Sec
Posr-Fault time = 2.5 Sec
Total time = 3 Sec

STUB PROTECTION: 50STUB

Max Load Current = 952.7
I>4 Function = IEC DT
I>4 Directional = Non Directional
I>4 Pickup current in A = 200 % of Maximum Load current of the Conductor
= $2 * 952.7 = 1905.4A$
I>4 Current Set (Is) = 1.91 A
I>4 operating time = 0.05 Sec

TELE PROTECTION

Scheme type = Permissive OR



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:34

- SYSTEM DATA
 - 00.01: Language: English
 - 00.02: Password: ****
 - 00.03: Sys Fn Links: 0
 - 00.04: Description: Bhadla line
 - 00.05: Plant Reference: Badisid
 - 00.06: Model Number: P546?1109?552?K
 - 00.08: Serial Number: 12345
 - 00.09: Frequency: 50 Hz
 - 00.0A: Comms Level: 2
 - 00.0B: Relay Address: 1
 - 00.0C: Plant Status: 0000001000000010
 - 00.0D: Control Status: 0000000000000000
 - 00.0E: Active Group: 1
 - 00.10: CB Trip/Close: No Operation
 - 00.11: Software Ref. 1: P546__4_520_A
 - 00.20: Opto I/P Status: 000000000000000000000000
 - 00.21: Relay O/P Status: 000000000000000000001000
 - 00.22: Alarm Status 1: 00000010000000000000000000000000
 - 00.50: Alarm Status 1: 00000010000000000000000000000000
 - 00.51: Alarm Status 2: 00000000000000000000000000000000
 - 00.52: Alarm Status 3: 00000000000000000000000000000000
 - 00.D0: Access Level: 2
 - 00.D1: Password Control: 2
 - 00.D2: Password Level 1: ****
 - 00.D3: Password Level 2: ****
- CB CONTROL
 - 07.01: CB Control by: Disabled
 - 07.11: CB Status Input: 52B 1 pole
- DATE AND TIME
 - 08.01: Date/Time: 2007-04-08 23:39:09.855
 - 08.06: Battery Status: Healthy
 - 08.07: Battery Alarm: Enabled
 - 08.20: LocalTime Enable: Flexible
 - 08.21: LocalTime Offset: 330.0 min
 - 08.22: DST Enable: Disabled
 - 08.30: RP1 Time Zone: Local
- CONFIGURATION
 - 09.01: Restore Defaults: No Operation
 - 09.02: Setting Group: Select via Menu
 - 09.03: Active Settings: Group 1
 - 09.04: Save Changes: No Operation
 - 09.05: Copy From: Group 1
 - 09.06: Copy To: No Operation
 - 09.07: Setting Group 1: Enabled
 - 09.08: Setting Group 2: Disabled
 - 09.09: Setting Group 3: Disabled
 - 09.0A: Setting Group 4: Disabled
 - 09.0B: Distance: Enabled
 - 09.0C: Directional E/F: Disabled
 - 09.0F: Phase Diff: Enabled
 - 09.10: Overcurrent: Enabled
 - 09.11: Neg Sequence O/C: Disabled
 - 09.12: Broken Conductor: Enabled
 - 09.13: Earth Fault: Enabled
 - 09.15: Sensitive E/F: Disabled
 - 09.16: Residual O/V NVD: Disabled
 - 09.17: Thermal Overload: Disabled
 - 09.18: PowerSwing Block: Enabled
 - 09.1D: Volt Protection: Enabled
 - 09.1E: Freq Protection: Disabled
 - 09.1F: df/dt Protection: Disabled
 - 09.20: CB Fail: Disabled
 - 09.21: Supervision: Enabled
 - 09.25: Input Labels: Visible
 - 09.26: Output Labels: Visible



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:35

- 09.28: CT & VT Ratios: Visible
- 09.29: Record Control: Visible
- 09.2A: Disturb Recorder: Visible
- 09.2B: Measure't Setup: Visible
- 09.2C: Comms Settings: Visible
- 09.2D: Commission Tests: Visible
- 09.2E: Setting Values: Secondary
- 09.2F: Control Inputs: Visible
- 09.35: Ctrl I/P Config: Visible
- 09.36: Ctrl I/P Labels: Visible
- 09.39: Direct Access: Enabled
- 09.50: Function Key: Visible
- 09.FF: LCD Contrast: 11

- CT AND VT RATIOS
- 0A.01: Main VT Primary: 400kV
- 0A.02: Main VT Sec'y: 110.0 V
- 0A.07: Phase CT Primary: 1000 A
- 0A.08: Phase CT Sec'y: 1.000 A
- 0A.0B: SEF CT Primary: 1000 A
- 0A.0C: SEF CT Secondary: 1.000 A
- 0A.0D: MComp CT Primary: 1000 A
- 0A.0E: MComp CT Sec'y: 1.000 A
- 0A.11: CT Polarity: Standard
- 0A.12: CT2 Polarity: Standard
- 0A.13: SEF CT Polarity: Standard
- 0A.14: M CT Polarity: Standard
- 0A.18: VT Connected: Yes

- RECORD CONTROL
- 0B.01: Clear Events: No
- 0B.02: Clear Faults: No
- 0B.03: Clear Maint: No
- 0B.04: Alarm Event: Enabled
- 0B.05: Relay O/P Event: Enabled
- 0B.06: Opto Input Event: Enabled
- 0B.07: General Event: Enabled
- 0B.08: Fault Rec Event: Enabled
- 0B.09: Maint Rec Event: Enabled
- 0B.0A: Protection Event: Enabled
- 0B.30: Clear Dist Recs: No
- 0B.40: DDB 31 - 0: 11111111111111111111111111111111
- 0B.41: DDB 63 - 32: 11111111111111111111111111111111
- 0B.42: DDB 95 - 64: 11111111111111111111111111111111
- 0B.43: DDB 127 - 96: 11111111111111111111111111111111
- 0B.44: DDB 159 - 128: 11111111111111111111111111111111
- 0B.45: DDB 191 - 160: 11111111111111111111111111111111
- 0B.46: DDB 223 - 192: 11111111111111111111111111111111
- 0B.47: DDB 255 - 224: 11111111111111111111111111111111
- 0B.48: DDB 287 - 256: 11111111111111111111111111111111
- 0B.49: DDB 319 - 288: 11111111111111111111111111111111
- 0B.4A: DDB 351 - 320: 11111111111111111111111111111111
- 0B.4B: DDB 383 - 352: 11111111111111111111111111111111
- 0B.4C: DDB 415 - 384: 11111111111111111111111111111111
- 0B.4D: DDB 447 - 416: 11111111111111111111111111111111
- 0B.4E: DDB 479 - 448: 11111111111111111111111111111111
- 0B.4F: DDB 511 - 480: 11111111111111111111111111111111
- 0B.50: DDB 543 - 512: 11111111111111111111111111111111
- 0B.51: DDB 575 - 544: 11111111111111111111111111111111
- 0B.52: DDB 607 - 576: 11111111111111111111111111111111
- 0B.53: DDB 639 - 608: 11111111111111111111111111111111
- 0B.54: DDB 671 - 640: 11111111111111111111111111111111
- 0B.55: DDB 703 - 672: 11111111111111111111111111111111
- 0B.56: DDB 735 - 704: 11111111111111111111111111111111
- 0B.57: DDB 767 - 736: 11111111111111111111111111111111
- 0B.58: DDB 799 - 768: 11111111111111111111111111111111
- 0B.59: DDB 831 - 800: 11111111111111111111111111111111
- 0B.5A: DDB 863 - 832: 11111111111111111111111111111111



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K


Printed on: 23/08/2024 17:17:35

```

..... 0B.5B: DDB 895 - 864: 11111111111111111111111111111111
..... 0B.5C: DDB 927 - 896: 11111111111111111111111111111111
..... 0B.5D: DDB 959 - 928: 11111111111111111111111111111111
..... 0B.5E: DDB 991 - 960: 11111111111111111111111111111111
..... 0B.5F: DDB 1023 - 992: 11111111111111111111111111111111
..... 0B.60: DDB 1055 - 1024: 11111111111111111111111111111111
..... 0B.61: DDB 1087 - 1056: 11111111111111111111111111111111
..... 0B.62: DDB 1119 - 1088: 11111111111111111111111111111111
..... 0B.63: DDB 1151 - 1120: 11111111111111111111111111111111
..... 0B.64: DDB 1183 - 1152: 11111111111111111111111111111111
..... 0B.65: DDB 1215 - 1184: 11111111111111111111111111111111
..... 0B.66: DDB 1247 - 1216: 11111111111111111111111111111111
..... 0B.67: DDB 1279 - 1248: 11111111111111111111111111111111
..... 0B.68: DDB 1311 - 1280: 11111111111111111111111111111111
..... 0B.69: DDB 1343 - 1312: 11111111111111111111111111111111
..... 0B.6A: DDB 1375 - 1344: 11111111111111111111111111111111
..... 0B.6B: DDB 1407 - 1376: 11111111111111111111111111111111

```

```

.....  DISTURB RECORDER
..... 0C.01: Duration: 3.000 s
..... 0C.02: Trigger Position: 16 %
..... 0C.03: Trigger Mode: Single
..... 0C.04: Analog Channel 1: VA
..... 0C.05: Analog Channel 2: VB
..... 0C.06: Analog Channel 3: VC
..... 0C.07: Analog Channel 4: IA
..... 0C.08: Analog Channel 5: IB
..... 0C.09: Analog Channel 6: IC
..... 0C.0A: Analog Channel 7: IN
..... 0C.0B: Analog Channel 8: IN Sensitive
..... 0C.0C: Digital Input 1: Relay 1
..... 0C.0D: Input 1 Trigger: No Trigger
..... 0C.0E: Digital Input 2: Relay 2
..... 0C.0F: Input 2 Trigger: No Trigger
..... 0C.10: Digital Input 3: Relay 3
..... 0C.11: Input 3 Trigger: Trigger L/H
..... 0C.12: Digital Input 4: Relay 4
..... 0C.13: Input 4 Trigger: No Trigger
..... 0C.14: Digital Input 5: Relay 5
..... 0C.15: Input 5 Trigger: No Trigger
..... 0C.16: Digital Input 6: Relay 6
..... 0C.17: Input 6 Trigger: No Trigger
..... 0C.18: Digital Input 7: Relay 7
..... 0C.19: Input 7 Trigger: No Trigger
..... 0C.1A: Digital Input 8: Relay 8
..... 0C.1B: Input 8 Trigger: No Trigger
..... 0C.1C: Digital Input 9: Relay 9
..... 0C.1D: Input 9 Trigger: No Trigger
..... 0C.1E: Digital Input 10: Relay 10
..... 0C.1F: Input 10 Trigger: No Trigger
..... 0C.20: Digital Input 11: Relay 11
..... 0C.21: Input 11 Trigger: No Trigger
..... 0C.22: Digital Input 12: Relay 12
..... 0C.23: Input 12 Trigger: No Trigger
..... 0C.24: Digital Input 13: Relay 13
..... 0C.25: Input 13 Trigger: No Trigger
..... 0C.26: Digital Input 14: Relay 14
..... 0C.27: Input 14 Trigger: No Trigger
..... 0C.28: Digital Input 15: Relay 15
..... 0C.29: Input 15 Trigger: No Trigger
..... 0C.2A: Digital Input 16: Relay 16
..... 0C.2B: Input 16 Trigger: No Trigger
..... 0C.2C: Digital Input 17: Opto 1
..... 0C.2D: Input 17 Trigger: No Trigger
..... 0C.2E: Digital Input 18: Opto 2
..... 0C.2F: Input 18 Trigger: No Trigger
..... 0C.30: Digital Input 19: Opto 3

```



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:35

```

..... 0C.31: Input 19 Trigger: No Trigger
..... 0C.32: Digital Input 20: Opto 4
..... 0C.33: Input 20 Trigger: No Trigger
..... 0C.34: Digital Input 21: Opto 5
..... 0C.35: Input 21 Trigger: No Trigger
..... 0C.36: Digital Input 22: Opto 6
..... 0C.37: Input 22 Trigger: No Trigger
..... 0C.38: Digital Input 23: Opto 7
..... 0C.39: Input 23 Trigger: No Trigger
..... 0C.3A: Digital Input 24: Opto 8
..... 0C.3B: Input 24 Trigger: No Trigger
..... 0C.3C: Digital Input 25: Opto 9
..... 0C.3D: Input 25 Trigger: No Trigger
..... 0C.3E: Digital Input 26: Opto 10
..... 0C.3F: Input 26 Trigger: No Trigger
..... 0C.40: Digital Input 27: Opto 11
..... 0C.41: Input 27 Trigger: No Trigger
..... 0C.42: Digital Input 28: Opto 12
..... 0C.43: Input 28 Trigger: No Trigger
..... 0C.44: Digital Input 29: Opto 13
..... 0C.45: Input 29 Trigger: No Trigger
..... 0C.46: Digital Input 30: Opto 14
..... 0C.47: Input 30 Trigger: No Trigger
..... 0C.48: Digital Input 31: Opto 15
..... 0C.49: Input 31 Trigger: No Trigger
..... 0C.4A: Digital Input 32: Opto 16
..... 0C.4B: Input 32 Trigger: No Trigger
..... 0C.50: Analog Channel 9: IM
..... 0C.51: Analog Channel10: IA2
..... 0C.52: Analog Channel11: IB2
..... 0C.53: Analog Channel12: IC2

```

```

..... MEASURET SETUP
..... 0D.01: Default Display: Description
..... 0D.02: Local Values: Primary
..... 0D.03: Remote Values: Primary
..... 0D.04: Measurement Ref: VA
..... 0D.05: Measurement Mode: 0
..... 0D.06: Fix Dem Period: 30.00 min
..... 0D.07: Roll Sub Period: 30.00 min
..... 0D.08: Num Sub Periods: 1
..... 0D.09: Distance Unit: Kilometres
..... 0D.0A: Fault Location: Distance

```

```

..... COMMISSION TESTS
..... 0F.01: Opto I/P Status: 000000000000000000000000
..... 0F.02: Relay O/P Status: 0000000000000000000001010
..... 0F.03: Test Port Status: 00001000
..... 0F.05: Monitor Bit 1: 1060
..... 0F.06: Monitor Bit 2: 1062
..... 0F.07: Monitor Bit 3: 1064
..... 0F.08: Monitor Bit 4: 1066
..... 0F.09: Monitor Bit 5: 1068
..... 0F.0A: Monitor Bit 6: 1070
..... 0F.0B: Monitor Bit 7: 1072
..... 0F.0C: Monitor Bit 8: 1074
..... 0F.0D: Test Mode: Disabled
..... 0F.0E: Test Pattern: 000000000000000000000000
..... 0F.0F: Contact Test: No Operation
..... 0F.10: Test LEDs: No Operation
..... 0F.12: Static Test: Disabled
..... 0F.13: Test Loopback: Disabled
..... 0F.14: IM64 TestPattern: 0000000000000000
..... 0F.15: IM64 Test Mode: Disabled
..... 0F.1A: Red LED Status: 0000000000000001000
..... 0F.1B: Green LED Status: 0000000000000001000
..... 0F.20: DDB 31 - 0: 000000000000000000000000000001010
..... 0F.21: DDB 63 - 32: 000000000000000000000000000000000

```




Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:35

```

..... D OF.22: DDB 95 - 64: 00000000000000000000000000000000
..... D OF.23: DDB 127 - 96: 00000000000000000000000000000000
..... D OF.24: DDB 159 - 128: 000000000000000000000000000001010
..... D OF.25: DDB 191 - 160: 000000000000000000000000000000000
..... D OF.26: DDB 223 - 192: 000000000000000000000000000000000
..... D OF.27: DDB 255 - 224: 000000000000000000000000000000000
..... D OF.28: DDB 287 - 256: 000000000000000000000000000000000
..... D OF.29: DDB 319 - 288: 000000101000000000000000000000000
..... D OF.2A: DDB 351 - 320: 000000000000000000000000000000000
..... D OF.2B: DDB 383 - 352: 000000000000000000000000000000000
..... D OF.2C: DDB 415 - 384: 000000000000000000000000000000000
..... D OF.2D: DDB 447 - 416: 000000000011000000000000000000000
..... D OF.2E: DDB 479 - 448: 000000000000000000000000000000000
..... D OF.2F: DDB 511 - 480: 000000000000000000000000000000000
..... D OF.30: DDB 543 - 512: 000000000010000000000000000000000
..... D OF.31: DDB 575 - 544: 000000000000000000000000000000000
..... D OF.32: DDB 607 - 576: 000000000000000000000000000000000
..... D OF.33: DDB 639 - 608: 000000000000000000000000000000000
..... D OF.34: DDB 671 - 640: 000000000000000000000000000000000
..... D OF.35: DDB 703 - 672: 000000000000000000000000000000000
..... D OF.36: DDB 735 - 704: 000000000000000000000000000000000
..... D OF.37: DDB 767 - 736: 000000000000000000000000000000000
..... D OF.38: DDB 799 - 768: 000000000000000000000000000000000
..... D OF.39: DDB 831 - 800: 111000000000000000000000000000000
..... D OF.3A: DDB 863 - 832: 000000000000000000000000000000000
..... D OF.3B: DDB 895 - 864: 01111100001001101010001111111111
..... D OF.3C: DDB 927 - 896: 00000000011100000111000000000100
..... D OF.3D: DDB 959 - 928: 000000000000000000000000000000000
..... D OF.3E: DDB 991 - 960: 000000000000000000000000000000000
..... D OF.3F: DDB 1023 - 992: 000000000000000000000000000000000
..... D OF.40: DDB 1055 - 1024: 00000000000000000000000011000000
..... D OF.41: DDB 1087 - 1056: 00000000000000000000000110000000000
..... D OF.42: DDB 1119 - 1088: 000000000000000000000000000000000
..... D OF.43: DDB 1151 - 1120: 000001000000000000000000000000001
..... D OF.44: DDB 1183 - 1152: 100010100000000000000000000000000
..... D OF.45: DDB 1215 - 1184: 000000000000000000000000000001000
..... D OF.46: DDB 1247 - 1216: 000000000000000000000000000000000
..... D OF.47: DDB 1279 - 1248: 000000000000000000000000000000000
..... D OF.48: DDB 1311 - 1280: 000000000000000000000000000000000
..... D OF.49: DDB 1343 - 1312: 000000010000000000000000000000000
..... D OF.4A: DDB 1375 - 1344: 000001000000000000000000000000000
..... D OF.4B: DDB 1407 - 1376: 000000000000000000000000000000000

```

OPTO CONFIG

```

..... D 11.01: Global Nominal V: 220/250V
..... D 11.60: Opto Filter Cntl: 1111111111101111111011
..... D 11.80: Characteristic: Standard 60%-80%

```

CONTROL INPUTS

```

..... D 12.01: Ctrl I/P Status: 00000000000000000000000000000000
..... D 12.02: Control Input 1: No Operation
..... D 12.03: Control Input 2: No Operation
..... D 12.04: Control Input 3: No Operation
..... D 12.05: Control Input 4: No Operation
..... D 12.06: Control Input 5: No Operation
..... D 12.07: Control Input 6: No Operation
..... D 12.08: Control Input 7: No Operation
..... D 12.09: Control Input 8: No Operation
..... D 12.0A: Control Input 9: No Operation
..... D 12.0B: Control Input 10: No Operation
..... D 12.0C: Control Input 11: No Operation
..... D 12.0D: Control Input 12: No Operation
..... D 12.0E: Control Input 13: No Operation
..... D 12.0F: Control Input 14: No Operation
..... D 12.10: Control Input 15: No Operation
..... D 12.11: Control Input 16: No Operation
..... D 12.12: Control Input 17: No Operation
..... D 12.13: Control Input 18: No Operation

```



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:35

- 12.14: Control Input 19: No Operation
- 12.15: Control Input 20: No Operation
- 12.16: Control Input 21: No Operation
- 12.17: Control Input 22: No Operation
- 12.18: Control Input 23: No Operation
- 12.19: Control Input 24: No Operation
- 12.1A: Control Input 25: No Operation
- 12.1B: Control Input 26: No Operation
- 12.1C: Control Input 27: No Operation
- 12.1D: Control Input 28: No Operation
- 12.1E: Control Input 29: No Operation
- 12.1F: Control Input 30: No Operation
- 12.20: Control Input 31: No Operation
- 12.21: Control Input 32: No Operation

..... CTRL I/P CONFIG

- 13.01: Hotkey Enabled: 11111111111111111111111111111111
- 13.10: Control Input 1: Latched
- 13.11: Ctrl Command 1: SET/RESET
- 13.14: Control Input 2: Latched
- 13.15: Ctrl Command 2: SET/RESET
- 13.18: Control Input 3: Latched
- 13.19: Ctrl Command 3: SET/RESET
- 13.1C: Control Input 4: Latched
- 13.1D: Ctrl Command 4: SET/RESET
- 13.20: Control Input 5: Latched
- 13.21: Ctrl Command 5: SET/RESET
- 13.24: Control Input 6: Latched
- 13.25: Ctrl Command 6: SET/RESET
- 13.28: Control Input 7: Latched
- 13.29: Ctrl Command 7: SET/RESET
- 13.2C: Control Input 8: Latched
- 13.2D: Ctrl Command 8: SET/RESET
- 13.30: Control Input 9: Latched
- 13.31: Ctrl Command 9: SET/RESET
- 13.34: Control Input 10: Latched
- 13.35: Ctrl Command 10: SET/RESET
- 13.38: Control Input 11: Latched
- 13.39: Ctrl Command 11: SET/RESET
- 13.3C: Control Input 12: Latched
- 13.3D: Ctrl Command 12: SET/RESET
- 13.40: Control Input 13: Latched
- 13.41: Ctrl Command 13: SET/RESET
- 13.44: Control Input 14: Latched
- 13.45: Ctrl Command 14: SET/RESET
- 13.48: Control Input 15: Latched
- 13.49: Ctrl Command 15: SET/RESET
- 13.4C: Control Input 16: Latched
- 13.4D: Ctrl Command 16: SET/RESET
- 13.50: Control Input 17: Latched
- 13.51: Ctrl Command 17: SET/RESET
- 13.54: Control Input 18: Latched
- 13.55: Ctrl Command 18: SET/RESET
- 13.58: Control Input 19: Latched
- 13.59: Ctrl Command 19: SET/RESET
- 13.5C: Control Input 20: Latched
- 13.5D: Ctrl Command 20: SET/RESET
- 13.60: Control Input 21: Latched
- 13.61: Ctrl Command 21: SET/RESET
- 13.64: Control Input 22: Latched
- 13.65: Ctrl Command 22: SET/RESET
- 13.68: Control Input 23: Latched
- 13.69: Ctrl Command 23: SET/RESET
- 13.6C: Control Input 24: Latched
- 13.6D: Ctrl Command 24: SET/RESET
- 13.70: Control Input 25: Latched
- 13.71: Ctrl Command 25: SET/RESET



Settings File Report

Substation:

File: p546.set

Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:35

- 13.74: Control Input 26: Latched
- 13.75: Ctrl Command 26: SET/RESET
- 13.78: Control Input 27: Latched
- 13.79: Ctrl Command 27: SET/RESET
- 13.7C: Control Input 28: Latched
- 13.7D: Ctrl Command 28: SET/RESET
- 13.80: Control Input 29: Latched
- 13.81: Ctrl Command 29: SET/RESET
- 13.84: Control Input 30: Latched
- 13.85: Ctrl Command 30: SET/RESET
- 13.88: Control Input 31: Latched
- 13.89: Ctrl Command 31: SET/RESET
- 13.8C: Control Input 32: Latched
- 13.8D: Ctrl Command 32: SET/RESET

FUNCTION KEYS

- 17.01: Fn Key Status: 0000000000
- 17.02: Fn Key 1: Unlocked
- 17.03: Fn Key 1 Mode: Normal
- 17.04: Fn Key 1 Label: Function Key 1
- 17.05: Fn Key 2: Unlocked
- 17.06: Fn Key 2 Mode: Normal
- 17.07: Fn Key 2 Label: Function Key 2
- 17.08: Fn Key 3: Unlocked
- 17.09: Fn Key 3 Mode: Normal
- 17.0A: Fn Key 3 Label: Function Key 3
- 17.0B: Fn Key 4: Unlocked
- 17.0C: Fn Key 4 Mode: Normal
- 17.0D: Fn Key 4 Label: Function Key 4
- 17.0E: Fn Key 5: Unlocked
- 17.0F: Fn Key 5 Mode: Normal
- 17.10: Fn Key 5 Label: Function Key 5
- 17.11: Fn Key 6: Unlocked
- 17.12: Fn Key 6 Mode: Normal
- 17.13: Fn Key 6 Label: Function Key 6
- 17.14: Fn Key 7: Unlocked
- 17.15: Fn Key 7 Mode: Normal
- 17.16: Fn Key 7 Label: Function Key 7
- 17.17: Fn Key 8: Unlocked
- 17.18: Fn Key 8 Mode: Normal
- 17.19: Fn Key 8 Label: Function Key 8
- 17.1A: Fn Key 9: Unlocked
- 17.1B: Fn Key 9 Mode: Normal
- 17.1C: Fn Key 9 Label: Function Key 9
- 17.1D: Fn Key 10: Unlocked
- 17.1E: Fn Key 10 Mode: Normal
- 17.1F: Fn Key 10 Label: Function Key 10

PROT COMMS/ IM64

- 20.01: Scheme Setup: 2 Terminal
- 20.03: Address: 0-0
- 20.10: Comms Mode: Standard
- 20.11: Baud Rate Ch1: 64kbits/s
- 20.13: Clock Source Ch1: Internal
- 20.17: Comm Delay Tol: 350.0 us
- 20.18: Comm Fail Timer: 10.00 s
- 20.1A: GPS Sync: Disabled
- 20.1B: Char Mod Time: 500.0 ms
- 20.1F: Alarm Level: 25.00 %
- 20.20: Prop Delay Stats: Enabled
- 20.21: MaxCh1 PropDelay: 15.00 ms
- 20.30: IM1 Cmd Type: Permissive
- 20.31: IM1 Fallbck Mode: Default
- 20.32: IM1 Default Val: 0
- 20.34: IM2 Cmd Type: Permissive
- 20.35: IM2 Fallbck Mode: Default
- 20.36: IM2 Default Val: 0
- 20.38: IM3 Cmd Type: Permissive



Settings File Report


Substation:

File: p546.set

Model Number: P546?1109?552?K


Printed on: 23/08/2024 17:17:36

- 20.39: IM3 Fallbck Mode: Default
- 20.3A: IM3 Default Val: 0
- 20.3C: IM4 Cmd Type: Permissive
- 20.3D: IM4 Fallbck Mode: Default
- 20.3E: IM4 Default Val: 0
- 20.40: IM5 Cmd Type: Permissive
- 20.41: IM5 Fallbck Mode: Default
- 20.42: IM5 Default Val: 0
- 20.44: IM6 Cmd Type: Permissive
- 20.45: IM6 Fallbck Mode: Default
- 20.46: IM6 Default Val: 0
- 20.48: IM7 Cmd Type: Permissive
- 20.49: IM7 Fallbck Mode: Default
- 20.4A: IM7 Default Val: 0
- 20.4C: IM8 Cmd Type: Permissive
- 20.4D: IM8 Fallbck Mode: Default
- 20.4E: IM8 Default Val: 0


 CTRL I/P LABELS


- 29.01: Control Input 1: Control Input 1
- 29.02: Control Input 2: Control Input 2
- 29.03: Control Input 3: Control Input 3
- 29.04: Control Input 4: Control Input 4
- 29.05: Control Input 5: Control Input 5
- 29.06: Control Input 6: Control Input 6
- 29.07: Control Input 7: Control Input 7
- 29.08: Control Input 8: Control Input 8
- 29.09: Control Input 9: Control Input 9
- 29.0A: Control Input 10: Control Input 10
- 29.0B: Control Input 11: Control Input 11
- 29.0C: Control Input 12: Control Input 12
- 29.0D: Control Input 13: Control Input 13
- 29.0E: Control Input 14: Control Input 14
- 29.0F: Control Input 15: Control Input 15
- 29.10: Control Input 16: Control Input 16
- 29.11: Control Input 17: Control Input 17
- 29.12: Control Input 18: Control Input 18
- 29.13: Control Input 19: Control Input 19
- 29.14: Control Input 20: Control Input 20
- 29.15: Control Input 21: Control Input 21
- 29.16: Control Input 22: Control Input 22
- 29.17: Control Input 23: Control Input 23
- 29.18: Control Input 24: Control Input 24
- 29.19: Control Input 25: Control Input 25
- 29.1A: Control Input 26: Control Input 26
- 29.1B: Control Input 27: Control Input 27
- 29.1C: Control Input 28: Control Input 28
- 29.1D: Control Input 29: Control Input 29
- 29.1E: Control Input 30: Control Input 30
- 29.1F: Control Input 31: Control Input 31
- 29.20: Control Input 32: Control Input 32

 Group 1

 GROUP 1 LINE PARAMETERS

- 30.01: Line Length: 12.00 km
- 30.03: Line Impedance: 1.030 Ohm
- 30.04: Line Angle: 85.00 deg
- 30.05: kZN Res Comp: 940.0e-3
- 30.06: kZN Res Angle: -4.000 deg
- 30.07: Mutual Comp: Disabled
- 30.0B: Phase Sequence: Standard ABC
- 30.0C: Tripping Mode: 1 Pole & 3 Pole






 GROUP 1 DISTANCE SETUP

- 31.0C: Setting Mode: Advanced
-  31.10: PHASE DISTANCE:
- 31.11: Phase Chars.: Quad
- 31.20: Zone 1 Ph Status: Enabled Ch Fail
- 31.30: Zone 2 Ph Status: Enabled



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:36

- 31.40: Zone 3 Ph Status: Enabled
- 31.42: Zone 3 Ph Offset: Enabled
- 31.50: Zone P Ph Status: Disabled
- 31.60: Zone 4 Ph Status: Enabled
-  31.70: GROUND DISTANCE:
- 31.71: Ground Chars.: Quad
- 31.80: Zone 1 Gnd Stat.: Enabled Ch Fail
- 31.90: Zone 2 Gnd Stat.: Enabled
- 31.A0: Zone 3 Gnd Stat.: Enabled
- 31.A2: Zone3 Gnd Offset: Enabled
- 31.B0: Zone P Gnd Stat.: Disabled
- 31.C0: Zone 4 Gnd Stat.: Enabled
- 31.D0: Digital Filter: Standard
- 31.D1: CVT Filters: Disabled
- 31.D3: Load Blinders: Enabled
- 31.D4: Z< Blinder Imp: 34.00 Ohm
- 31.D5: Load/B Angle: 37.00 deg
- 31.D6: Load Blinder V<: 15.01 V
- 31.D7: Dist. Polarizing: 1.000
-  31.E0: DELTADIRECTIONAL:
- 31.E1: Dir. Status: Disabled
-  GROUP 1 DIST. ELEMENTS
-  32.01: PHASE DISTANCE:
- 32.02: Z1 Ph. Reach: 830.0 mOhm
- 32.03: Z1 Ph. Angle: 85.00 deg
- 32.07: R1 Ph. Resistive: 8.250 Ohm
- 32.08: Z1 Tilt Top Line: 0 deg
- 32.09: Z1 Sensit. Iph>1: 50.00 mA
- 32.10: Z2 Ph. Reach: 1.460 Ohm
- 32.11: Z2 Ph. Angle: 85.00 deg
- 32.15: R2 Ph. Resistive: 16.50 Ohm
- 32.16: Z2 Tilt Top Line: 0 deg
- 32.17: Z2 Sensit. Iph>2: 50.00 mA
- 32.20: Z3 Ph. Reach: 5.710 Ohm
- 32.21: Z3 Ph. Angle: 85.00 deg
- 32.22: Z3' Ph Rev Reach: 5.710 Ohm
- 32.25: R3 Ph. Res. Fwd.: 20.63 Ohm
- 32.26: R3' Ph. Res. Rev: 20.63 Ohm
- 32.27: Z3 Tilt Top Line: 0 deg
- 32.28: Z3 Sensit. Iph>3: 50.00 mA
- 32.40: Z4 Ph. Reach: 210.0 mOhm
- 32.41: Z4 Ph. Angle: 85.00 deg
- 32.42: R4 Ph. Resistive: 20.63 Ohm
- 32.45: Z4 Tilt Top Line: -3.000 deg
- 32.46: Z4 Sensit. Iph>4: 50.00 mA
-  32.50: GROUND DISTANCE:
- 32.51: Z1 Gnd. Reach: 830.0 mOhm
- 32.52: Z1 Gnd. Angle: 85.00 deg
- 32.53: Z1 Dynamic Tilt: Disabled
- 32.54: Z1 Tilt Top Line: -3.000 deg
- 32.55: kZN1 Res. Comp.: 940.0e-3
- 32.56: kZN1 Res. Angle: -4.000 deg
- 32.59: R1 Gnd Resistive: 6.880 Ohm
- 32.5B: Z1 Sensit Ignd>1: 50.00 mA
- 32.60: Z2 Gnd. Reach: 1.460 Ohm
- 32.61: Z2 Gnd. Angle: 85.00 deg
- 32.63: Z2 Dynamic Tilt: Disabled
- 32.64: Z2 Tilt Top Line: -3.000 deg
- 32.65: kZN2 Res. Comp.: 940.0e-3
- 32.66: kZN2 Res. Angle: -4.000 deg
- 32.69: R2 Gnd Resistive: 13.75 Ohm
- 32.6B: Z2 Sensit Ignd>2: 50.00 mA
- 32.70: Z3 Gnd. Reach: 5.710 Ohm
- 32.71: Z3 Gnd. Angle: 85.00 deg
- 32.72: Z3' Gnd Rev Rch: 5.710 Ohm
- 32.73: Z3 Dynamic Tilt: Disabled



Settings File Report

Substation:

File: p546.set

Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:36

..... 32.74: Z3 Tilt Top Line: -3.000 deg
..... 32.75: kZN3 Res. Comp.: 940.0e-3
..... 32.76: kZN3 Res. Angle: -4.000 deg
..... 32.79: R3 Gnd. Res. Fwd: 17.88 Ohm
..... 32.7A: R3' Gnd Res. Rev: 1.000 Ohm
..... 32.7C: Z3 Sensit Ignd>3: 50.00 mA
..... 32.90: Z4 Gnd. Reach: 210.0 mOhm
..... 32.91: Z4 Gnd. Angle: 85.00 deg
..... 32.93: Z4 Dynamic Tilt: Disabled
..... 32.94: Z4 Tilt Top Line: -3.000 deg
..... 32.95: kZN4 Res. Comp.: 940.0e-3
..... 32.96: kZN4 Res. Angle: -4.000 deg
..... 32.99: R4 Gnd Resistive: 17.88 Ohm
..... 32.9B: Z4 Sensit Ignd>4: 50.00 mA

..... GROUP 1 PHASE DIFF
..... 33.01: Phase Diff: Enabled
..... 33.06: Phase Is1: 250.0 mA
..... 33.07: Phase Is2: 2.000 A
..... 33.08: Phase k1: 30.00 %
..... 33.09: Phase k2: 150.0 %
..... 33.0A: Phase Char: DT
..... 33.0B: Phase Time Delay: 0 s
..... 33.0E: PIT Time: 200.0 ms
..... 33.0F: Ph CT Corr'tion: 1.000
..... 33.10: Compensation: Cap Charging
..... 33.11: Susceptance: 3.700 uS
..... 33.17: PIT I selection: Remote

..... GROUP 1 SCHEME LOGIC
..... 34.01: BASIC SCHEME:
..... 34.08: Zone1 Tripping: Phase And Ground
..... 34.09: tZ1 Ph. Delay: 0 s
..... 34.0A: tZ1 Gnd. Delay: 0 s
..... 34.10: Zone2 Tripping: Phase And Ground
..... 34.11: tZ2 Ph. Delay: 350.0 ms
..... 34.12: tZ2 Gnd. Delay: 350.0 ms
..... 34.18: Zone3 Tripping: Phase And Ground
..... 34.19: tZ3 Ph. Delay: 1.000 s
..... 34.1A: tZ3 Gnd. Delay: 1.000 s
..... 34.20: ZoneP Tripping: Disabled
..... 34.28: Zone4 Tripping: Phase And Ground
..... 34.29: tZ4 Ph. Delay: 350.0 ms
..... 34.2A: tZ4 Gnd. Delay: 350.0 ms
..... 34.40: AIDED SCHEME 1:
..... 34.41: Aid. 1 Selection: POR
..... 34.42: Aid 1 Distance: Phase And Ground
..... 34.43: Aid.1 Dist. Dly: 0 s
..... 34.60: AIDED SCHEME 2:
..... 34.61: Aid. 2 Selection: Disabled
..... 34.80: Trip On Close:
..... 34.81: SOTF Status: Enabled PoleDead + Pulse
..... 34.82: SOTF Delay: 110.0 s
..... 34.83: SOTF Tripping: 000010 Zone1 and Zone2
..... 34.84: TOR Status: Enabled
..... 34.85: TOR Tripping: 000010
..... 34.86: TOC Reset Delay: 500.0 ms
..... 34.88: TOC Delay: 200.0 ms
..... 34.B0: Z1 Extension:
..... 34.B1: Z1 Ext Scheme: Disabled
..... 34.C0: Loss Of Load:
..... 34.C1: LOL Scheme: Disabled

..... GROUP 1 OVERCURRENT
..... 35.01: I>1 Status: Disabled
..... 35.0A: I>2 Status: Disabled
..... 35.13: I>3 Status: Disabled
..... 35.18: I>4 Status: Enabled
..... 35.19: I>4 Directional: Non-Directional



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:36

- 35.1A: I>4 Current Set: 1.910 A
- 35.1B: I>4 Time Delay: 50.00 ms
- 35.1C: I> Char Angle: 30.00 deg
- 35.1D: I> Blocking: 001111
- GROUP 1 BROKEN CONDUCTOR
- 37.01: Broken Conductor: Enabled
- 37.02: I2/I1 Setting: 200.0e-3
- 37.03: I2/I1 Time Delay: 5.000 s
- GROUP 1 EARTH FAULT
- 38.01: IN>1 Status: Enabled
- 38.25: IN>1 Function: IEC S Inverse
- 38.26: IN>1 Directional: Directional Fwd
- 38.29: IN>1 Current Set: 220.0 mA
- 38.2D: IN>1 TMS: 500.0e-3
- 38.33: IN>1 tRESET: 0 s
- 38.35: IN>2 Status: Disabled
- 38.46: IN>3 Status: Disabled
- 38.4D: IN>4 Status: Disabled
- 38.54: IN> Blocking: 001111
- 38.55: IN> DIRECTIONAL:
- 38.56: IN> Char Angle: -45.00 deg
- 38.57: IN> Polarisation: Zero Sequence
- 38.59: IN> VNpol Set: 1.000 V
- GROUP 1 POWER SWING BLK.
- 3D.01: PSB Status: Blocking
- 3D.03: Zone 1 Ph. PSB: Blocking
- 3D.05: Zone 2 Ph. PSB: Blocking
- 3D.07: Zone 3 Ph. PSB: Blocking
- 3D.09: Zone P Ph. PSB: Blocking
- 3D.0B: Zone 4 Ph. PSB: Blocking
- 3D.0D: Zone 1 Gnd. PSB: Blocking
- 3D.0F: Zone 2 Gnd. PSB: Blocking
- 3D.11: Zone 3 Gnd. PSB: Blocking
- 3D.13: Zone P Gnd. PSB: Blocking
- 3D.15: Zone 4 Gnd. PSB: Blocking
- 3D.20: PSB Unblocking: Enabled
- 3D.21: PSB Unblock dly: 2.000 s
- 3D.22: PSB Reset Delay: 200.0 ms
- 3D.23: OST Mode: OST Trip
- 3D.24: Z5: 6.850 Ohm
- 3D.25: Z6: 7.540 Ohm
- 3D.26: Z5': -6.850 Ohm
- 3D.27: Z6': -7.540 Ohm
- 3D.28: R5: 21.45 Ohm
- 3D.29: R6: 23.60 Ohm
- 3D.2A: R5': -21.45 Ohm
- 3D.2B: R6': -23.60 Ohm
- 3D.2C: Blinder Angle: 20.00 deg
- 3D.2D: delta T: 40.00 ms
- 3D.2E: Tost: 0 s
- GROUP 1 VOLT PROTECTION
- 42.01: UNDER VOLTAGE:
- 42.02: V< Measur't Mode: V<1 & V<2 Ph-N
- 42.03: V< Operate Mode: V<1 & V<2 Any Ph
- 42.04: V<1 Function: DT
- 42.05: V<1 Voltage Set: 57.00 V
- 42.06: V<1 Time Delay: 0 s
- 42.08: V<1 Poledead Inh: Disabled
- 42.09: V<2 Status: Disabled
- 42.0D: OVERVOLTAGE:
- 42.0E: V> Measur't Mode: V>1 & V>2 Ph-N
- 42.0F: V> Operate Mode: V>1 & V>2 Any Ph
- 42.10: V>1 Function: DT
- 42.11: V>1 Voltage Set: 70.01 V
- 42.12: V>1 Time Delay: 5.000 s
- 42.14: V>2 Status: Enabled

UNDER VOLATGE - ONLY DR TRIGGERING
NO CB TRIP



Settings File Report

Substation:

File: p546.set

Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:36


- 42.15: V>2 Voltage Set: 89.01 V
- 42.16: V>2 Time Delay: 100.0 ms
- GROUP 1 CB FAIL & P.DEAD
- 45.0A: UNDER CURRENT:
- 45.0B: I< Current Set: 50.00 mA
- 45.0D: ISEF< Current: 20.00 mA
- 45.0E: POLEDEAD VOLTAGE:
- 45.10: V<: 38.11 V
- GROUP 1 SUPERVISION
- 46.01: VTS Mode: Measured + MCB
- 46.02: VTS Status: Blocking
- 46.03: VTS Reset Mode: Auto
- 46.04: VTS Time Delay: 5.000 s
- 46.05: VTS I> Inhibit: 10.00 A
- 46.06: VTS I2> Inhibit: 50.00 mA
- 46.0E: INRUSH DETECTION:
- 46.0F: I>2nd Harmonic: 20.00 %
- 46.10: WEAK INFEEED BLK:
- 46.11: WI Inhibit: Disabled
- 46.12: I0/I2 Setting: 3.000
- 46.30: CT SUPERVISION:
- 46.31: CTS Mode: Disabled
- GROUP 1 INPUT LABELS
- 4A.01: Opto Input 1: Input L1
- 4A.02: Opto Input 2: Input L2
- 4A.03: Opto Input 3: Input L3
- 4A.04: Opto Input 4: Input L4
- 4A.05: Opto Input 5: Input L5
- 4A.06: Opto Input 6: Input L6
- 4A.07: Opto Input 7: Input L7
- 4A.08: Opto Input 8: Input L8
- 4A.09: Opto Input 9: Input L9
- 4A.0A: Opto Input 10: Input L10
- 4A.0B: Opto Input 11: Input L11
- 4A.0C: Opto Input 12: Input L12
- 4A.0D: Opto Input 13: Input L13
- 4A.0E: Opto Input 14: Input L14
- 4A.0F: Opto Input 15: Input L15
- 4A.10: Opto Input 16: Input L16
- 4A.11: Opto Input 17: Input L17
- 4A.12: Opto Input 18: Input L18
- 4A.13: Opto Input 19: Input L19
- 4A.14: Opto Input 20: Input L20
- 4A.15: Opto Input 21: Input L21
- 4A.16: Opto Input 22: Input L22
- 4A.17: Opto Input 23: Input L23
- 4A.18: Opto Input 24: Input L24
- GROUP 1 OUTPUT LABELS
- 4B.01: Relay 1: Output R1
- 4B.02: Relay 2: Output R2
- 4B.03: Relay 3: Output R3
- 4B.04: Relay 4: Output R4
- 4B.05: Relay 5: Output R5
- 4B.06: Relay 6: Output R6
- 4B.07: Relay 7: Output R7
- 4B.08: Relay 8: Output R8
- 4B.09: Relay 9: Output R9
- 4B.0A: Relay 10: Output R10
- 4B.0B: Relay 11: Output R11
- 4B.0C: Relay 12: Output R12
- 4B.0D: Relay 13: Output R13
- 4B.0E: Relay 14: Output R14
- 4B.0F: Relay 15: Output R15
- 4B.10: Relay 16: Output R16
- 4B.11: Relay 17: Output R17
- 4B.12: Relay 18: Output R18



Settings File Report
Substation:
File: p546.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 17:17:36

-
- 4B.13: Relay 19: Output R19
 - 4B.14: Relay 20: Output R20
 - 4B.15: Relay 21: Output R21
 - 4B.16: Relay 22: Output R22
 - 4B.17: Relay 23: Output R23
 - 4B.18: Relay 24: Output R24

		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

General Data

Network Details

Voltage	=	400		kV
Frequency	=	50		Hz
System X/R Ratio	=	40		
Fault Current	=	10500		A

Local End Bay Details

Station Name	=	400kV ADST SS		
Object Name	=	400 KV LINE CONTROL AND RELAY PANEL		
Object Number	=	B-403		

Relay Type	=	7SL87		
------------	---	-------	--	--

CT Primary current (Adopted)	=	1000		A
CT Secondary current	=	1		A

Protected Line details

Line details


Line length	=	12.00		km
Rated current capacity	=	953		A
Positive sequence imp. per km	=	0.0266	+j 0.313	Ohm/km
Zero sequence imp. per km	=	0.168	+j 1.187	Ohm/km

Short Line Feeder Details at Remote Station

Remote end station name	=	-		
Length of the line	=	30.45		Km
Positive sequence imp. per km	=	0.015	+j 0.253	Ohm/Km
Zero sequence imp. per km	=	0.249	+j 0.999	Ohm/Km

Longest Line Feeder Details at Remote Station

Remote end station name	=	-		
Length of the line	=	52.00		Km
Positive sequence imp. per km	=	0.036	+j 0.310	Ohm/Km
Zero sequence imp. per km	=	0.256	+j 1.104	Ohm/Km

 PGGA-2875		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

CALCULATION FOR DIFFERENTIAL FUNCTION :

If the charging current compensation is ON, the pickup value I-DIFF> can be set equal I_{charge} . Thus the residual error of the charging current compensation is considered. Without charging current compensation, this pickup value must be set to a value that is higher than the total steady-state charging current of the protected object

Charging Current Calculation:

The charging current is calculated according to the following equation,

Where,

$$I_{charge} : U / (\sqrt{3} * Xc1)$$

U : System Line Voltage
 $Xc1$: Positive Sequence Line Capacitive reactance value
 I_{charge} : Line charging current/kM due to Line Capacitance
 $Xc1$: $1 / (2 * \pi * f * C1)$
 $C1$: Line Capacitance value/kM
 $Xc1$: $1 / (2 * \pi * f * C1)$
 $Xc1$: $1 / (2 * 3.14 * 50 * 0.0000000119)$
: 267622.97 Ω

$$I_{charge} : U / (\sqrt{3} * Xc1)$$

$$I_{charge} : 400000 / (\sqrt{3} * 267622.97)$$

$$I_{charge} : 0.86 \text{ A}$$

Total Primary Charging Current : $0.86 * 12$
: 10.32 A

Total Sec.Charging Current, I_c : I_{charge} / CTR
: $10.32 / 1000$
: 0.01032 A

I-DIFF:Threshold:

Considering the variations of voltage and frequency, the set value should be at least 2 to 3 times higher than the calculated charging current or 20% of the rated current of the line whichever is greater.

$$3 \text{ times of } : 3 * I_c$$

$$: 0.03096 \text{ A}$$

I-DIFF:Threshold : 0.25 A

I-DIFF Switch-on:

A setting to three to four times the steady-state charging current usually ensures the stability of the protection during switch-on of the line.

$$I-DIFF:Threshold \text{ Switch On } : 0.30 \text{ A}$$

I-DIFF Fast :


As per the relay Recommendation, set the pickup value is 1.0 times to 2 times of Rated Current

$$\text{Rated current} : 952.66 \text{ A}$$

$$: 2 * 952.66$$

$$: 1905.32 \text{ A}$$

Therefore, as seen by the CT : 1.91 A

 Hitachi Energy PGG-2875		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

I-DIFF fast:Threshold : 2 A

I-DIFF fast Switch on :


I-DIFF fast SWITCHON should be 2 to 3 times the setting value of I-DIFF fast

I-DIFF fast:Threshold Switch : 2*1.91
: 3.82 A

The below mentioned setting recommended,


I-DIFF:Threshold : 0.25 A
 I-DIFF:Threshold Switch On : 0.30 A
 I-DIFF:Operate delay : 0.00 Sec
 Ic-compensat.:Mode : ON
 Ic-stabilization/Ic-rated : 1.00
 I-DIFF fast:Threshold : 2 A
 I-DIFF fast:Threshold Switch On : 3.82 A
 INRUSH REST. : On

CT ratio correction: 9001:101 Rated current to be same at both end of the line to compensate CT ratio



Reference: IEC 60255-27-1, 2011

Figure 6-13 Operate Curve of the Differential Protection

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

CALCULATION FOR DISTANCE FUNCTION : QUADRILATERAL

Zone Reach Details

Zone 1	:	80%	of the protected Line
Zone 2	:	100% 20%	of the protected Line + of the shortest adjacent Line)
Zone 3	:	120% 100%	of the protected Line + of Remote end Longest Line
Zone 4	:	20%	of the protected L (Reverse Zone)
Zone 1B	:	Setting same as Zone-2	
VT Ratio	:	400x1000 / 110 3636	
CT Ratio	:	1000 / 1 1000	

Transformation Ratio	N	:	CT Ratio / VT Ratio 1000/3636 0.275	
----------------------	---	---	---	--

Calculated Sec Impedance Z_{sec}		:	$N \times Z_{prim}$ in ohm	
	Z_{prim}	:	Primary Impedance in ohm	

Protected Line:


Line Length	:	12.00 km		
Line Total +VE Seq Impedance	:	$(R_1$	+j	$X_1)$
	:	0.319	+j	3.75
	:	3.764 L85.14		
Line Total Zero Seq Impedance	:	$(R_0$	+j	$X_0)$
	:	2.012	+j	14.244
	:	14.385 L81.96		


Adjacent Shortest Line: (Remote End)

Line Length	:	30.5 km		
Total +VE Sequence Impedance	:	$(R_1$	+j	$X_1)$
	:	0.448	+j	7.698
	:	7.711 L86.67		
Total Zero Sequence Impedance	:	$(R_0$	+j	$X_0)$
	:	7.585	+j	30.42
	:	31.351 L76		

Adjacent Longest Line: (Remote End)

Line Length	:	52.00 km		
Total +VE Sequence Impedance	:	$(R_1$	+j	$X_1)$
	:	1.872	+j	16.141
	:	16.249 L83.38		

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1
Total Zero Sequence Impedance : $(R_0 + jX_0)$: 13.312 +j 57.408 : 58.931 L76.94				
Zero Sequence Compensation Factor:				
Resistance Ratio K_r : $1/3((R_0/R_1)-1)$: 1.769				
Reactance Ratio K_x : $1/3((X_0/X_1)-1)$: 0.933				
Line Angle Setting				
Tan ϕ : X_L/R_L : X_1/R_1 ϕ : 85.14 deg				
Earth Impedance Compensation K_o Factor.				
K_o : Z_E / Z_L : $1/3 ((Z_0/Z_1)-1)$				
Z_1 : Positive sequence Impedance of the Line				
Z_0 : Zero sequence Impedance of the Line				
Z_0 / Z_1 : 3.822 L -3.18 : 3.816 +j -j0.212				
$1/3 ((Z_0/Z_1)-1)$: $1/3(3.82+j-0.212-1)$: 0.942 L-4.32				
K_o : 0.94				
ϕ_o : -4.32 deg				
Load Impedance and Load Angle Calculation:				
Rated Current : 952.66 A				
At worst case, the maximum load current of the transmission line has been considered slightly higher than nominal loading (120%) to cover emergency loading of the protected line in case of heavy load flow.				
Maximum Load Current (I_{max}) : 1429.00 A (1.5 times of Load current)				
Minimum Operating Voltage : 85% of rated voltage : $0.85 * 400000$: 340000 V				
Load Impedance R_{Load} : $U_{min} / \sqrt{3} \times I_{max}$: $340000 / \sqrt{3} \times 1429$				
R_{Load} Primary : 137.370 ohm				
R_{Load} Secondary : 137.37×0.275 : 37.78 ohm				
The largest angle of the load impedance is given by the worst, smallest power factor. Hence,				
Minimum Power Factor $\cos\phi_{min}$: 0.850 (Assumed)				
ϕ_{min} : 32 deg				
Set Load Angle : $\phi_{min} + 5$: 32 + 5 : 37 deg				
To avoid load encroachment for the phase-phase measuring elements, the set resistive reach of any distance protection				

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

zone should not exceed 60% of the R_{load} .

$$60.00\% \text{ of } R_{load} : 0.6 * 37.78 \\ 22.67 \quad \Omega$$

To avoid load encroachment for the phase-earth measuring elements, the set resistive reach of any distance protection zone should not exceed 80% of the R_{load} .

$$80.00\% \text{ of } R_{load} : 0.8 * 37.78 \\ 30.22 \quad \Omega$$

Arc Resistance :

$$\text{Arc Resistance for Ph-Ph fault (Pri)} : 5.000 \quad \Omega \quad (\text{Assumed})$$

$$\text{Arc Resistance for Ph-Ph fault (Sec)} : 5 * 0.275 \\ \text{Rarc (Ph-Ph)} : 0.740 \quad \Omega$$

$$\text{Arc Resistance for PH-E fault (Pri)} : 3.000 \quad \Omega \quad (\text{Assumed})$$

$$\text{Arc Resistance for PH-E fault (Sec)} : 3 * 0.275 \\ \text{Rarc (Ph-E)} : 0.479 \quad \Omega$$

$$\text{Tower Footing Resistance (Pri)} : 10.000 \quad \Omega \quad (\text{Assumed})$$

$$R_{TF} \text{ (Sec)} : 2.750 \quad \Omega$$

Zone 1 Reach Values:

$$\text{Reactance, X reach (Z1)} : 80\% \times X1 \times N \\ : 0.8 * 3.75 * 0.275 \\ : 0.825 \text{ ohm}$$

$$\text{Resistance Ph-Ph fault, R(Z1)} : 80\% \times R1 \times N + \text{Rarc (Ph-Ph)}/2 \\ : (0.8 * 0.319 * 0.275) + 0.74/2 \\ : 0.440 \text{ ohm}$$

Now, for Earth arc resistance shall include tower footing resistance

$$\text{Resistance Ph-E fault, RE(Z1)} : 80\% * R1 * N + \text{Rarc(ph-E)} + R_T \\ : (0.8 * 0.319 * 0.275) + (0.479 + 2.75) \\ : 3.299 \text{ ohm}$$


Zone 2 Reach Values

$$\text{Reactance, X reach (Z2)} : 100\% \text{ of } X1 \text{ Protection Line} + \\ 20\% \text{ of } X1 \text{ Remote end Shortest Line } \times N \\ : ((1 * 3.75) + (0.2 * 7.698)) * 0.275 \\ : 1.455 \text{ ohm}$$

$$\text{Resistance Ph-Ph fault, R(Z2)} : 100\% \text{ of } R1 \text{ Protected Line} + 20\% \text{ of } R1 \text{ of Remote end} \\ \text{shortest Line) } \times N + \text{Rarc (Ph-Ph)}/2 \\ : ((1 * 0.319) + (0.2 * 0.448)) * 0.275 + (0.74/2) \\ : 0.482 \text{ ohm}$$

Now, for Earth arc resistance shall include tower footing resistance

$$\text{Resistance Ph-E fault, RE(Z2)} : 100\% \text{ of } R1 \text{ Protected Line} + 20\% \text{ of } R1 \text{ of Remote end} \\ \text{Longest Line } \times N + \text{Rarc (Ph-E)} + R_T \\ : ((1 * 0.319) + (0.2 * 0.448)) * 0.275 + (0.479 + 2.75)$$

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

: 3.341 ohm

Zone 3 Reach Values

Reactance, X(Z3) : 120% of X1 Protection Line +
100% of X1 Remote end Longest Line x N
: $((1.2 \times 3.75) + (1 \times 16.141)) \times 0.275$
: 5.676 ohm

Resistance Ph-Ph fault, R(Z3) : 120% of R1 Protected Line + 100% of R1 of Remote end
Longest Line x N + Rarc (Ph-Ph)/2
: $((1.2 \times 0.319) + (1 \times 1.872)) \times 0.275 + (0.74/2)$
: 0.990 ohm

Now, for Earth arc resistance shall include tower footing resistance

Resistance Ph-E fault, RE(Z3) : 120% of R1 Protected Line + 100% of R1 of Remote end
Longest Line) x N + Rarc (Ph-E) + R_T
: $((1.2 \times 0.319) + (1 \times 1.872)) \times 0.275 + (0.479 + 2.75)$
: 3.849 ohm

Zone -4 Setting:(Reverse Reach)

Reactance, X(Z4) : 20% x X1 x N
: $0.2 \times 3.75 \times 0.275$
: 0.206 ohm

Resistance Ph-Ph fault, R(Z4) : 20% x R1 x N + Rarc (Ph-Ph)/2
: $(0.2 \times 0.319 \times 0.275) + 0.74/2$
: 0.388 ohm

Now, for Earth arc resistance shall include tower footing resistance

Resistance Ph-E fault, RE(Z4) : 20% * R1 * N + Rarc(ph-E) + R_T
: $(0.2 \times 0.319 \times 0.275) + (0.479 + 2.75)$
: 3.247 ohm

Zone-1B Setting:

Set Zone-1B settings equal to Zone-2 value

Zone Timer setting:


ZONE 1- t1 PP : 0.00 sec
ZONE 1- t1 PE : 0.00 sec
ZONE 2- t1 PP : 0.35 sec
ZONE 2- t1 PE : 0.35 sec
ZONE 3- t1 PP : 1.00 sec
ZONE 3- t1 PE : 1.00 sec
ZONE 4- t1 PP : 0.35 sec
ZONE 4- t1 PE : 0.35 sec
ZONE 1B-t1 PP : 0.00 sec
ZONE 1B-t1 PE : 0.00 sec

Load Cutout

Z< Blinder Imp (90% of LR) : 34.0 Ohm
Load/B Angle : 37.0 Deg

TELEPROTECTION FOR DISTANCE:

The relay shall work in Permissive Over Reach(POTT) mode with the following settings:

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

Send with : Distance prot. Z1
Operate with : Distance prot. Z2
Send prolongation : 0.05 Sec
Send delay : 0.00 Sec
1-pole operate allowed : Yes
Operate delay : 0.00 sec

POWER SWING:

Power swing operating mode : All zones block
Max.Blocking Time : 2 Sec

50HS INSTANTANEOUS SOTF:

SOTF to be enabled for Zone-2, Zone-3

Operate delay : 0 sec

STUB PROTECTION:

The threshold value must be higher than the maximum operational current to be expected, in order to avoid pickup without fault. Grading time above the base time of the main protection is usually sufficient.

Threshold : 1.9 A
Operate delay : 0.04 msec

FUSE FAIL MONITORING:

Asym.fail.DO on netw.ftt : no
Asym.fail.time delay : 5 sec
3ph fail-phs.curr.release : 0.1 A
3ph fail-phs.curr.jump : 0.1 A
3ph fail-VA,VB,VC < : 5 V
Switch-on 3ph.failure : on
SO 3ph.fail-time delay : 5 sec

DIR. EARTH FAULT SETTINGS :

The pickup characteristics should be more than the standing unbalance current as seen by the system and the CT's.


1Ph Fault Current : 10500 A
IN> Pickup current in A : 23% of rated current
: 0.23*1000=230A
IN> Current Set (Is) : 0.23 A
Minimum setting available in Relay : 0.23 A

The Earth fault function has to be graded with the Zone-3 Protection

Zone-3 operating time : 1.00 Sec
Grading margin : 0.13 Sec
Required time (Treq) : 1.13 Sec

Note: The IDMT curve shall saturate if the fault current more than 20 times of pickup current. 20 times of set current considered for TMS calculation.

Fault Current considered : 4600 A
51 Time Dial : (Treq*(IF/Is)^0.02-1)/0.14
: (1.13*(4600/230)^0.02-1)/0.14
: 0.5

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	10-11-2023
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	1

BROKEN CONDUCTOR

A broken wire of the protected line or in the current transformer secondary circuit can be detected, if the minimum current PoleOpenCurrent flows via the feeder. If the minimum phase current is below this limit while the other phase currents are above this limit, an interruption of this conductor may be assumed. If current asymmetry is also detected (see margin heading "Current Symmetry"), the device issues the message Fail Conductor (No. 195).

OVERVOLTAGE PROTECTION: 59

Measuring value	:	phase-neutral	
Definite-T 1:Threshold	:	70 V	110% of Rated voltage
Definite-T 1:Operate delay	:	5 sec	
Definite-T 2:Threshold	:	89 V	140% of Rated voltage
Definite-T 2:Operate delay	:	0.1 sec	

UNDERVOLTAGE PROTECTION:27 (Alarm Only)

Measuring quantities by Uphase-phase			
Uph-ph< pickup	:	57 V	90% of Rated Voltage
T Uph-ph< time delay	:	0 sec	

Power system

General

Number	Settings	Value
11.2311.101	Phase sequence	All: ABC

Meas.point I-3ph 1

CT 3-phase \General

Number	Settings	Value
11.931.8881.115	CT connection	All: 3-phase
11.931.8881.127	Tracking	All: active
11.931.8881.130	Measuring-point ID	All: 1

CT 3-phase \CT phases

Number	Settings	Value
11.931.8881.101	Rated primary current	All: 1000 A
11.931.8881.102	Rated secondary current	All: 1 A
11.931.8881.117	Current range	All: 100 x IR
11.931.8881.118	Internal CT type	All: CT protection
11.931.8881.116	Neutr.point in dir.of ref.obj	All: yes
11.931.8881.114	Inverted phases	All: none
11.931.8881.107	CT error changeover	All: 1.5
11.931.8881.108	CT error A	All: 5 %
11.931.8881.109	CT error B	All: 15 %

CT 3-phase \MP disconnection

Number	Settings	Value
11.931.8881.173	Current check	All: active
11.931.8881.112	I< threshold	All: 0.10 A

CT 1

Number	Settings	Value
11.931.3841.103	Magnitude correction	All: 1
11.931.3841.117	Phase	All: I A

CT 2

Number	Settings	Value
11.931.3842.103	Magnitude correction	All: 1
11.931.3842.117	Phase	All: I B

CT 3

Number	Settings	Value
11.931.3843.103	Magnitude correction	All: 1
11.931.3843.117	Phase	All: I C

Brk.wire det.

Number	Settings	Value
11.931.5581.1	Mode	All: off
11.931.5581.101	Mode of blocking	All: blocking

Supv. balan. I

Number	Settings	Value
11.931.2491.1	Mode	Settings group 1: on
11.931.2491.101	Release threshold	Settings group 1: 0.50 A
11.931.2491.102	Threshold min/max	Settings group 1: 0.5
11.931.2491.6	Delay failure indication	Settings group 1: 5 s

Supv. ph.seq.I

Number	Settings	Value
11.931.2551.1	Mode	Settings group 1: on
11.931.2551.6	Delay failure indication	Settings group 1: 5 s
11.931.2551.102	Release threshold	Settings group 1: 0.50 A

Saturat. det.

Number	Settings	Value
11.931.17731.101	CT saturation threshold	Settings group 1: 8.00 A

Meas.point V-3ph 1

VT 3-phase		
Number	Settings	Value
11.941.8911.101	Rated primary voltage	All: 400.000 kV
11.941.8911.102	Rated secondary voltage	All: 110 V
11.941.8911.104	VT connection	All: 3 ph-to-gnd voltages
11.941.8911.106	Inverted phases	All: none
11.941.8911.111	Tracking	All: active
11.941.8911.130	Measuring-point ID	All: 2
11.941.8911.136	Internal VT type	All: Voltage transformer

VT 1		
Number	Settings	Value
11.941.3811.103	Magnitude correction	All: 1
11.941.3811.108	Phase	All: V A

VT 2		
Number	Settings	Value
11.941.3812.103	Magnitude correction	All: 1
11.941.3812.108	Phase	All: V B

VT 3		
Number	Settings	Value
11.941.3813.103	Magnitude correction	All: 1
11.941.3813.108	Phase	All: V C

Supv. balan. V		
Number	Settings	Value
11.941.2521.1	Mode	Settings group 1: on
11.941.2521.101	Release threshold	Settings group 1: 55.0 V
11.941.2521.102	Threshold min/max	Settings group 1: 0.75
11.941.2521.6	Delay failure indication	Settings group 1: 5 s

Supv. ph.seq.V		
Number	Settings	Value
11.941.2581.1	Mode	Settings group 1: on
11.941.2581.6	Delay failure indication	Settings group 1: 5 s

Supv. sum V		
Number	Settings	Value
11.941.2461.1	Mode	Settings group 1: off
11.941.2461.3	Threshold	Settings group 1: 27.5 V
11.941.2461.6	Delay failure indication	Settings group 1: 5 s

VT miniatureCB		
Number	Settings	Value
11.941.2641.101	Response time	Settings group 1: 0 s

Meas.point I-1ph 1

General		
Number	Settings	Value
11.951.2311.101	Rated primary current	All: 1000 A
11.951.2311.102	Rated secondary current	All: 1 A
11.951.2311.103	Current range	All: 100 x IR
11.951.2311.104	Internal CT type	All: CT protection
11.951.2311.116	Term. 1,3,5,7 in dir. of obj.	All: yes
11.951.2311.105	Tracking	All: inactive
11.951.2311.130	Measuring-point ID	All: 3

CT 1		
Number	Settings	Value
11.951.3841.103	Magnitude correction	All: 1
11.951.3841.117	Phase	All: Ix

Meas.point V-1ph 1

General		
Number	Settings	Value
11.961.2311.101	Rated primary voltage	All: 400 kV
11.961.2311.102	Rated secondary voltage	All: 100 V
11.961.2311.103	Tracking	All: inactive

Number	Settings	Value
11.961.2311.130	Measuring-point ID	All: 4

VT 1

Number	Settings	Value
11.961.3811.103	Magnitude correction	All: 1
11.961.3811.108	Phase	All: V B

VT miniatureCB

Number	Settings	Value
11.961.2641.101	Response time	Settings group 1: 0 s

*Setting marked as favorite setting

sp Setting marked as specific setting

Table of contents

Line 1

3 - 1

Line 1

General \Rated values

Number	Settings	Value
21.9001.101	Rated current	All: 3000 A 952A
21.9001.102	Rated voltage	All: 400.00 kV
21.9001.103	Rated apparent power	All: 693.0 MVA

General \Line data

Number	Settings	Value
21.9001.149	Neutral point	Settings group 1: grounded
21.9001.112	C1 per length unit	Settings group 1: 0.011900 $\mu\text{F}/\text{km}$
21.9001.148	C0 per length unit	Settings group 1: 0.011900 $\mu\text{F}/\text{km}$
21.9001.113	X per length unit	Settings group 1: 0.313000 Ω/km
21.9001.114	Line length	Settings group 1: 12 km
21.9001.108	Line angle	Settings group 1: 85.14 °
21.9001.104	Kr	Settings group 1: 1.77
21.9001.105	Kx	Settings group 1: 0.93
21.9001.106	KmR	Settings group 1: 0
21.9001.107	KmX	Settings group 1: 0
21.9001.109	Gnd.curr.ratio(MutComp)	Settings group 1: 95 %
21.9001.119	CT saturation detection	All: no
21.9001.111	Series compensation	Settings group 1: no
21.9001.110	Series capacit. reactance	Settings group 1: 0 Ω

General \Measurements

Number	Settings	Value
21.9001.158	P, Q sign	Settings group 1: not reversed

Process monitor

Closure detec.

Number	Settings	Value
21.1131.4681.101	Operating mode	Settings group 1: Manual close only
21.1131.4681.102	Action time after closure	Settings group 1: 0.5 s
21.1131.4681.103	Min. time feeder open	Settings group 1: 0.3 s

1pol.open det.

Number	Settings	Value
21.1131.4711.101	Operating mode	Settings group 1: with measurement

Volt.criterion

Number	Settings	Value
21.1131.4801.101	Threshold U open	Settings group 1: 18.15 V

Fault locator

Number	Settings	Value
21.8671.1	Mode	Settings group 1: on
21.8671.101	Start	Settings group 1: with going pickup
21.8671.102	Parallel-line compensat.	Settings group 1: no
21.8671.103	Load compensation	All: no

Mes.v.fail.det

Number	Settings	Value
21.2671.1	Mode	Settings group 1: on
21.2671.115	Asym.fail.-DO on netw.flt.	Settings group 1: yes
21.2671.113	Asym.fail. - time delay	Settings group 1: 5 s
21.2671.102	3ph.fail. - phs.curr.release	Settings group 1: 0.064 A
21.2671.103	3ph.fail. - phs.curr. jump	Settings group 1: 0.064 A
21.2671.101	3ph.fail. - VA,VB,VC <	Settings group 1: 3.025 V
21.2671.107	Switch-on 3ph. failure	All: on
21.2671.106	SO 3ph.fail. - time delay	Settings group 1: 0.5 s

50/51 OC-3ph-A1

General

Number	Settings	Value
21.201.2311.101	Emergency mode	Settings group 1: no

Definite-T 1 \General

Number	Settings	Value
21.201.661.1	Mode	Settings group 1: off

Totally Integrated Automation Portal		
--------------------------------------	--	--

Number	Settings	Value
21.201.661.2	Operate & flt.rec. blocked	Settings group 1: no
21.201.661.11	1-pole operate allowed	Settings group 1: no
21.201.661.26	Dynamic settings	All: no
21.201.661.8	Method of measurement	Settings group 1: fundamental comp.
21.201.661.3	Threshold	Settings group 1: 3.20 A
21.201.661.4	Dropout ratio	Settings group 1: 0.95
21.201.661.102	Pickup delay	Settings group 1: 0 s
21.201.661.101	Dropout delay	Settings group 1: 0 s
21.201.661.6	Operate delay	Settings group 1: 0.3 s
21.201.661.7	Operate delay mode	Settings group 1: Running dur. DO-delay

Definite-T 2 \General		
Number	Settings	Value
21.201.662.1	Mode	Settings group 1: off
21.201.662.2	Operate & flt.rec. blocked	Settings group 1: no
21.201.662.11	1-pole operate allowed	Settings group 1: yes
21.201.662.26	Dynamic settings	All: no
21.201.662.8	Method of measurement	Settings group 1: fundamental comp.
21.201.662.3	Threshold	Settings group 1: 2.00 A
21.201.662.4	Dropout ratio	Settings group 1: 0.95
21.201.662.102	Pickup delay	Settings group 1: 0 s
21.201.662.101	Dropout delay	Settings group 1: 0 s
21.201.662.6	Operate delay	Settings group 1: 0.1 s
21.201.662.7	Operate delay mode	Settings group 1: Running dur. DO-delay

50N/51N OC-gnd-A1

General		
Number	Settings	Value
21.211.2311.101	Emergency mode	Settings group 1: caused by main prot.
21.211.2311.9	Measured value	All: 3I0 calculated

Definite-T 1 \General		
Number	Settings	Value
21.211.751.1	Mode	Settings group 1: off
21.211.751.2	Operate & flt.rec. blocked	Settings group 1: no
21.211.751.26	Dynamic settings	All: no
21.211.751.102	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.211.751.8	Method of measurement	Settings group 1: fundamental comp.
21.211.751.3	Threshold	Settings group 1: 2.133 A
21.211.751.4	Dropout ratio	Settings group 1: 0.95
21.211.751.101	Dropout delay	Settings group 1: 0 s
21.211.751.6	Operate delay	Settings group 1: 0.3 s
21.211.751.7	Operate delay mode	Settings group 1: Running dur. DO-delay

Definite-T 2 \General		
Number	Settings	Value
21.211.752.1	Mode	Settings group 1: off
21.211.752.2	Operate & flt.rec. blocked	Settings group 1: no
21.211.752.26	Dynamic settings	All: no
21.211.752.102	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.211.752.8	Method of measurement	Settings group 1: fundamental comp.
21.211.752.3	Threshold	Settings group 1: 1.20 A
21.211.752.4	Dropout ratio	Settings group 1: 0.95
21.211.752.101	Dropout delay	Settings group 1: 0 s
21.211.752.6	Operate delay	Settings group 1: 0.3 s
21.211.752.7	Operate delay mode	Settings group 1: Running dur. DO-delay

67N GFP gnd.sys.1

General		
Number	Settings	Value
21.1111.2311.114	Direct. determination with	All: V0 + IY (neutral pt.)
21.1111.2311.101	Angle forward α	Settings group 1: 315 °
21.1111.2311.102	Angle forward β	Settings group 1: 135 °
21.1111.2311.103	Min. zero-seq. voltage V0	Settings group 1: 0.919 V
21.1111.2311.115	Dir.reslt=forw.at V0<min	Settings group 1: no
21.1111.2311.104	Min.3I0 f.increas.dir.sens.	Settings group 1: 0.064 A
21.1111.2311.116	Dir.corr.at ser.comp.lines	Settings group 1: no

Definite-T 1 \Blocking by		
Number	Settings	Value
21.1111.4861.140	21 Distance prot. 1.Z 1	true
21.1111.4861.140	21 Distance prot. 1.Z 2	true
21.1111.4861.140	21 Distance prot. 1.Z 3	true
21.1111.4861.140	21 Distance prot. 1.Z 4	false
21.1111.4861.140	87 Line diff. prot..Group indicat.	false

Totally Integrated Automation Portal		
Number	Settings	Value
21.1111.4861.140	87 Stub diff. prot. 1.Group indicat.	false
Definite-T 1 \General		
Number	Settings	Value
21.1111.4861.1	Mode	Settings group 1: off
21.1111.4861.2	Operate & flt.rec. blocked	Settings group 1: no
21.1111.4861.114	Directional mode	Settings group 1: forward
21.1111.4861.11	1-pole operate allowed	Settings group 1: no
21.1111.4861.8	Method of measurement	Settings group 1: 1-cycle filter
21.1111.4861.131	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.1111.4861.130	Blocking by prot. pickup	Settings group 1: every pickup
21.1111.4861.129	Op.mode at 1p dead time	Settings group 1: blocked
21.1111.4861.112	Hold mode 1p dead time	Settings group 1: 0.04 s
21.1111.4861.115	Dynamic settings	All: no
21.1111.4861.111	Stabiliz. w. phase current	Settings group 1: 10 %
21.1111.4861.3	Threshold	Settings group 1: 0.32 A
21.1111.4861.6	Operate delay	Settings group 1: 1 s
Definite-T 2 \Blocking by		
Number	Settings	Value
21.1111.4862.140	21 Distance prot. 1.Z 1	true
21.1111.4862.140	21 Distance prot. 1.Z 2	true
21.1111.4862.140	21 Distance prot. 1.Z 3	true
21.1111.4862.140	21 Distance prot. 1.Z 4	true
21.1111.4862.140	87 Line diff. prot..Group indicat.	false
21.1111.4862.140	87 Stub diff. prot. 1.Group indicat.	false
Definite-T 2 \General		
Number	Settings	Value
21.1111.4862.1	Mode	Settings group 1: off
21.1111.4862.2	Operate & flt.rec. blocked	Settings group 1: no
21.1111.4862.114	Directional mode	Settings group 1: forward
21.1111.4862.11	1-pole operate allowed	Settings group 1: no
21.1111.4862.8	Method of measurement	Settings group 1: 1-cycle filter
21.1111.4862.131	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.1111.4862.130	Blocking by prot. pickup	Settings group 1: every pickup
21.1111.4862.129	Op.mode at 1p dead time	Settings group 1: blocked
21.1111.4862.112	Hold mode 1p dead time	Settings group 1: 1.5 s
21.1111.4862.115	Dynamic settings	All: no
21.1111.4862.111	Stabiliz. w. phase current	Settings group 1: 10 %
21.1111.4862.3	Threshold	Settings group 1: 0.32 A
21.1111.4862.6	Operate delay	Settings group 1: 1 s
Inverse-T 1 \Blocking by		
Number	Settings	Value
21.1111.4891.140	21 Distance prot. 1.Z 1	true
21.1111.4891.140	21 Distance prot. 1.Z 2	true
21.1111.4891.140	21 Distance prot. 1.Z 3	true
21.1111.4891.140	21 Distance prot. 1.Z 4	true
21.1111.4891.140	87 Line diff. prot..Group indicat.	false
21.1111.4891.140	87 Stub diff. prot. 1.Group indicat.	false
Inverse-T 1 \General		
Number	Settings	Value
21.1111.4891.1	Mode	Settings group 1: on
21.1111.4891.2	Operate & flt.rec. blocked	Settings group 1: no
21.1111.4891.115	Directional mode	Settings group 1: forward
21.1111.4891.11	1-pole operate allowed	Settings group 1: no
21.1111.4891.8	Method of measurement	Settings group 1: 1-cycle filter
21.1111.4891.135	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.1111.4891.131	Blocking by prot. pickup	Settings group 1: every pickup
21.1111.4891.130	Op.mode at 1p dead time	Settings group 1: non-directional
21.1111.4891.113	Hold mode 1p dead time	Settings group 1: 0.04 s
21.1111.4891.116	Dynamic settings	All: no
21.1111.4891.112	Stabiliz. w. phase current	Settings group 1: 10 %
21.1111.4891.3	Threshold	Settings group 1: 0.23 A
21.1111.4891.133	Type of character. curve	Settings group 1: IEC normal inverse
21.1111.4891.106	Time dial	Settings group 1: 0.5
21.1111.4891.132	Additional time delay	Settings group 1: 0 s
21.1111.4891.134	Reset	Settings group 1: instantaneous
67 Dir.OC-3ph-A1		
General		
Number	Settings	Value
21.1461.2311.101	Emergency mode	Settings group 1: no
21.1461.2311.102	Rotation angle of ref. volt.	Settings group 1: 45 °

Definite-T 1 \General

Number	Settings	Value
21.1461.8131.1	Mode	Settings group 1: off
21.1461.8131.2	Operate & flt.rec. blocked	Settings group 1: no
21.1461.8131.105	Directional mode	Settings group 1: forward
21.1461.8131.8	Method of measurement	Settings group 1: fundamental comp.
21.1461.8131.107	Non-directional pickup	Settings group 1: no
21.1461.8131.104	Directional comparison	Settings group 1: yes
21.1461.8131.106	Release via input signal	Settings group 1: no
21.1461.8131.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.1461.8131.26	Dynamic settings	All: no
21.1461.8131.3	Threshold	Settings group 1: 1.92 A
21.1461.8131.4	Dropout ratio	Settings group 1: 0.95
21.1461.8131.101	Dropout delay	Settings group 1: 0 s
21.1461.8131.6	Operate delay	Settings group 1: 0.3 s

Definite-T 2 \General

Number	Settings	Value
21.1461.8132.1	Mode	Settings group 1: off
21.1461.8132.2	Operate & flt.rec. blocked	Settings group 1: no
21.1461.8132.105	Directional mode	Settings group 1: forward
21.1461.8132.8	Method of measurement	Settings group 1: fundamental comp.
21.1461.8132.107	Non-directional pickup	Settings group 1: at volt. < & mem.empty
21.1461.8132.104	Directional comparison	Settings group 1: no
21.1461.8132.106	Release via input signal	Settings group 1: no
21.1461.8132.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.1461.8132.26	Dynamic settings	All: no
21.1461.8132.3	Threshold	Settings group 1: 2.00 A
21.1461.8132.4	Dropout ratio	Settings group 1: 0.95
21.1461.8132.101	Dropout delay	Settings group 1: 0 s
21.1461.8132.6	Operate delay	Settings group 1: 0.1 s

Inverse-T 1 \General

Number	Settings	Value
21.1461.8161.1	Mode	Settings group 1: off
21.1461.8161.2	Operate & flt.rec. blocked	Settings group 1: no
21.1461.8161.111	Directional mode	Settings group 1: forward
21.1461.8161.8	Method of measurement	Settings group 1: fundamental comp.
21.1461.8161.113	Non-directional pickup	Settings group 1: no
21.1461.8161.110	Directional comparison	Settings group 1: yes
21.1461.8161.112	Release via input signal	Settings group 1: no
21.1461.8161.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.1461.8161.26	Dynamic settings	All: no
21.1461.8161.3	Threshold	Settings group 1: 1.92 A
21.1461.8161.130	Type of character. curve	Settings group 1: IEC normal inverse
21.1461.8161.114	Min. time of the curve	Settings group 1: 0 s
21.1461.8161.131	Reset	Settings group 1: disk emulation
21.1461.8161.101	Time dial	Settings group 1: 1
21.1461.8161.115	Additional time delay	Settings group 1: 0 s

46 I2 1

General

Number	Settings	Value
21.321.2311.106	Reference value	Settings group 1: rated current
21.321.2311.107	Current limitation I _{max}	All: no
21.321.2311.104	Release current	Settings group 1: 0.05 A

Definite-T 1

Number	Settings	Value
21.321.1981.1	Mode	Settings group 1: on
21.321.1981.2	Operate & flt.rec. blocked	Settings group 1: no
21.321.1981.3	Threshold	Settings group 1: 10 %
21.321.1981.4	Dropout ratio	All: 0.95
21.321.1981.101	Dropout delay	Settings group 1: 0 s
21.321.1981.6	Operate delay	Settings group 1: 5 s

Definite-T 2

Number	Settings	Value
21.321.1982.1	Mode	Settings group 1: off
21.321.1982.2	Operate & flt.rec. blocked	Settings group 1: no
21.321.1982.3	Threshold	Settings group 1: 65 %
21.321.1982.4	Dropout ratio	All: 0.95
21.321.1982.101	Dropout delay	Settings group 1: 0 s
21.321.1982.6	Operate delay	Settings group 1: 0.5 s

27 Undervolt.-3ph 1 UNDER VOLATGE - ONLY DR TRIGGERING NO CB TRIP

General

Number	Settings	Value
21.131.2311.104	Current-flow criterion	Settings group 1: on
21.131.2311.101	Threshold I>	Settings group 1: 0.05 A
21.131.2311.103	Stabilization counter	Settings group 1: 0

Definite-T 1

Number	Settings	Value
21.131.421.1	Mode	Settings group 1: on
21.131.421.2	Operate & flt.rec. blocked	Settings group 1: no
21.131.421.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.131.421.9	Measured value	Settings group 1: phase-to-ground
21.131.421.8	Method of measurement	Settings group 1: fundamental comp.
21.131.421.101	Pickup mode	Settings group 1: 1 out of 3
21.131.421.102	Pickup delay	Settings group 1: no
21.131.421.3	Threshold	Settings group 1: 57.000 V
21.131.421.4	Dropout ratio	Settings group 1: 1.05
21.131.421.6	Operate delay	Settings group 1: 0 s

Definite-T 2

Number	Settings	Value
21.131.422.1	Mode	Settings group 1: off
21.131.422.2	Operate & flt.rec. blocked	Settings group 1: no
21.131.422.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.131.422.9	Measured value	Settings group 1: phase-to-phase
21.131.422.8	Method of measurement	Settings group 1: fundamental comp.
21.131.422.101	Pickup mode	Settings group 1: 1 out of 3
21.131.422.102	Pickup delay	Settings group 1: no
21.131.422.3	Threshold	Settings group 1: 71.5 V
21.131.422.4	Dropout ratio	Settings group 1: 1.05
21.131.422.6	Operate delay	Settings group 1: 0.5 s

59 Overvolt.-3ph 1

General

Number	Settings	Value
21.51.2311.101	Stabilization counter	Settings group 1: 0

Definite-T 1

Number	Settings	Value
21.51.181.1	Mode	Settings group 1: on
21.51.181.2	Operate & flt.rec. blocked	Settings group 1: no
21.51.181.9	Measured value	Settings group 1: phase-to-ground
21.51.181.8	Method of measurement	Settings group 1: fundamental comp.
21.51.181.101	Pickup mode	Settings group 1: 1 out of 3
21.51.181.3	Threshold	Settings group 1: 70.000 V
21.51.181.4	Dropout ratio	Settings group 1: 0.95
21.51.181.6	Operate delay	Settings group 1: 0 s

Definite-T 2

Number	Settings	Value
21.51.182.1	Mode	Settings group 1: on
21.51.182.2	Operate & flt.rec. blocked	Settings group 1: no
21.51.182.9	Measured value	Settings group 1: phase-to-ground
21.51.182.8	Method of measurement	Settings group 1: fundamental comp.
21.51.182.101	Pickup mode	Settings group 1: 1 out of 3
21.51.182.3	Threshold	Settings group 1: 89.000 V
21.51.182.4	Dropout ratio	Settings group 1: 0.95
21.51.182.6	Operate delay	Settings group 1: 0.1 s

21 Distance prot. 1

General

Number	Settings	Value
21.901.2311.110	Zone timer start	Settings group 1: on dist. pickup
21.901.2311.107	Dist. characteristic angle	Settings group 1: 86.3 °
21.901.2311.105	Ground-fault detection	Settings group 1: 3I0 or V0
21.901.2311.103	3I0> threshold value	Settings group 1: 0.064 A
21.901.2311.102	V0> threshold value	Settings group 1: 1.008 V
21.901.2311.104	3I0 pickup stabilization	Settings group 1: 0.1
21.901.2311.108	Loop select. with ph-ph-g	Settings group 1: block leading phase
21.901.2311.106	Parallel-line compensat.	Settings group 1: no

Pickup Z<		
Number	Settings	Value
21.901.3661.101	Min. phase-current thresh	Settings group 1: 0.107 A
21.901.3661.102	Use ph-g load cutout	All: Yes
21.901.3661.105	Use ph-ph load cutout	All: Yes

Z 1		
Number	Settings	Value
21.901.3571.1	Mode	Settings group 1: on
21.901.3571.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3571.121	Blocked if diff.prot.active	Settings group 1: Yes
21.901.3571.11	1-pole operate allowed	Settings group 1: yes
21.901.3571.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3571.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3571.109	Directional mode	Settings group 1: forward
21.901.3571.102	X reach	Settings group 1: 0.825 Ω
21.901.3571.103	R (ph-g)	Settings group 1: 3.299 Ω
21.901.3571.104	R (ph-ph)	Settings group 1: 0.44 Ω
21.901.3571.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3571.110	Operate delay (1-phase)	Settings group 1: 0 s
21.901.3571.112	Operate delay (multi-ph.)	Settings group 1: 0 s

Z 2		
Number	Settings	Value
21.901.3572.1	Mode	Settings group 1: on
21.901.3572.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3572.121	Blocked if diff.prot.active	Settings group 1: no
21.901.3572.11	1-pole operate allowed	Settings group 1: no
21.901.3572.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3572.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3572.109	Directional mode	Settings group 1: forward
21.901.3572.102	X reach	Settings group 1: 1.455 Ω
21.901.3572.103	R (ph-g)	Settings group 1: 3.341 Ω
21.901.3572.104	R (ph-ph)	Settings group 1: 0.482 Ω
21.901.3572.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3572.110	Operate delay (1-phase)	Settings group 1: 0.35 s
21.901.3572.112	Operate delay (multi-ph.)	Settings group 1: 0.35 s

Z 3		
Number	Settings	Value
21.901.3573.1	Mode	Settings group 1: on
21.901.3573.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3573.121	Blocked if diff.prot.active	Settings group 1: no
21.901.3573.11	1-pole operate allowed	Settings group 1: no
21.901.3573.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3573.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3573.109	Directional mode	Settings group 1: forward
21.901.3573.102	X reach	Settings group 1: 5.676 Ω
21.901.3573.103	R (ph-g)	Settings group 1: 3.849 Ω
21.901.3573.104	R (ph-ph)	Settings group 1: 0.99 Ω
21.901.3573.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3573.110	Operate delay (1-phase)	Settings group 1: 1 s
21.901.3573.112	Operate delay (multi-ph.)	Settings group 1: 1 s

Z 4		
Number	Settings	Value
21.901.3574.1	Mode	Settings group 1: on
21.901.3574.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3574.121	Blocked if diff.prot.active	Settings group 1: no
21.901.3574.11	1-pole operate allowed	Settings group 1: no
21.901.3574.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3574.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3574.109	Directional mode	Settings group 1: reverse
21.901.3574.102	X reach	Settings group 1: 0.206 Ω
21.901.3574.103	R (ph-g)	Settings group 1: 3.247 Ω
21.901.3574.104	R (ph-ph)	Settings group 1: 0.388 Ω
21.901.3574.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3574.110	Operate delay (1-phase)	Settings group 1: 0.35 s
21.901.3574.112	Operate delay (multi-ph.)	Settings group 1: 0.35 s

87 Line diff. prot.

General		
Number	Settings	Value
21.831.2311.1	Mode	Settings group 1: on
21.831.2311.11	1-pole operate allowed	Settings group 1: yes
21.831.2311.102	Min. current for release	Settings group 1: 0 A
21.831.2311.104	Supervision Idiff	All: yes: reporting only
21.831.2311.108	Action on Behavior = test	Settings group 1: Test loc. device autom.

Remote trip. \General

Number	Settings	Value
21.831.5551.100	Transmitting	Settings group 1: yes
21.831.5551.101	Receiving	Settings group 1: yes

Remote trip. \Intertrip

Number	Settings	Value
21.831.5551.103	Send delay	Settings group 1: 0.02 s
21.831.5551.104	Send prolongation	Settings group 1: 0 s

I-DIFF

Number	Settings	Value
21.831.3451.1	Mode	Settings group 1: on
21.831.3451.2	Operate & flt.rec. blocked	Settings group 1: no
21.831.3451.3	Threshold	Settings group 1: 0.25 A
21.831.3451.101	Threshold switch on	Settings group 1: 0.30 A
21.831.3451.102	Delay 1-phase pickup	Settings group 1: 0 s
21.831.3451.6	Operate delay	Settings group 1: 0 s

I-DIFF fast 2

Number	Settings	Value
21.831.18211.1	Mode	Settings group 1: on
21.831.18211.2	Operate & flt.rec. blocked	Settings group 1: no
21.831.18211.3	Threshold	Settings group 1: 2.00 A
21.831.18211.101	Threshold switch on	Settings group 1: 3.82 A
21.831.18211.6	Operate delay	Settings group 1: 0 s
21.831.18211.106	Delay 1-phase pickup	Settings group 1: 0 s

Transformer

Number	Settings	Value
21.831.3541.101	Rated apparent power	Settings group 1: 693 MVA
21.831.3541.103	Voltage vector group nb.	Settings group 1: 0
21.831.3541.104	Current vector group nb.	Settings group 1: 0
21.831.3541.105	Residual curr. elimination	Settings group 1: yes

87 Stub diff. prot. 1

General

Number	Settings	Value
21.1431.2311.1	Mode	Settings group 1: off

S-DIFF

Number	Settings	Value
21.1431.8401.1	Mode	Settings group 1: off
21.1431.8401.2	Operate & flt.rec. blocked	Settings group 1: no
21.1431.8401.3	Threshold	Settings group 1: 0.480 A
21.1431.8401.6	Operate delay	Settings group 1: 0 s

S-DIFF fast 2

Number	Settings	Value
21.1431.18241.1	Mode	Settings group 1: off
21.1431.18241.2	Operate & flt.rec. blocked	Settings group 1: no
21.1431.18241.3	Threshold	Settings group 1: 1.600 A

68 P.swing blk \Zones to be blocked

Number	Settings	Value
21.5311.102	21 Distance prot. 1.Z 1	true
21.5311.102	21 Distance prot. 1.Z 2	true
21.5311.102	21 Distance prot. 1.Z 3	true
21.5311.102	21 Distance prot. 1.Z 4	true

68 P.swing blk

Number	Settings	Value
21.5311.1	Mode	Settings group 1: on
21.5311.103	Max. blocking time	Settings group 1: 2 s

85-21Perm. Permissive Overreach

85-21Perm.unde \Send with

Number	Settings	Value
21.1281.5671.140	21 Distance prot. 1.Z 1	true

Number	Settings	Value
21.1281.5671.140	21 Distance prot. 1.Z 2	false
21.1281.5671.140	21 Distance prot. 1.Z 3	false
21.1281.5671.140	21 Distance prot. 1.Z 4	false

85-21Perm.unde \Operate with		
Number	Settings	Value
21.1281.5671.141	21 Distance prot. 1.pickup general	false
21.1281.5671.141	21 Distance prot. 1.Z 1	false
21.1281.5671.141	21 Distance prot. 1.Z 2	true
21.1281.5671.141	21 Distance prot. 1.Z 3	false
21.1281.5671.141	21 Distance prot. 1.Z 4	false
21.1281.5671.141	receive (direct trip)	false

85-21Perm.unde Permissive Overreach		
Number	Settings	Value
21.1281.5671.1	Mode	Settings group 1: on
21.1281.5671.101	Send prolongation	Settings group 1: 0.05 s
21.1281.5671.11	1-pole operate allowed	Settings group 1: yes
21.1281.5671.102	Operate delay (1-phase)	Settings group 1: 0 s
21.1281.5671.103	Operate delay (multi-ph.)	Settings group 1: 0 s

Switch onto fault 1

Stage 1 \Configuration		
Number	Settings	Value
21.1341.5941.102	50/51 OC-3ph-A1.Definite-T 1	false
21.1341.5941.102	50/51 OC-3ph-A1.Definite-T 2	false
21.1341.5941.102	50N/51N OC-gnd-A1.Definite-T 1	false
21.1341.5941.102	50N/51N OC-gnd-A1.Definite-T 2	false
21.1341.5941.102	67N GFP gnd.sys.1.Definite-T 1	false
21.1341.5941.102	67N GFP gnd.sys.1.Definite-T 2	false
21.1341.5941.102	67N GFP gnd.sys.1.Inverse-T 1	false
21.1341.5941.102	67 Dir.OC-3ph-A1.Definite-T 1	false
21.1341.5941.102	67 Dir.OC-3ph-A1.Definite-T 2	false
21.1341.5941.102	67 Dir.OC-3ph-A1.Inverse-T 1	false
21.1341.5941.102	21 Distance prot. 1.Z 1	true
21.1341.5941.102	21 Distance prot. 1.Z 2	true
21.1341.5941.102	21 Distance prot. 1.Z 3	false
21.1341.5941.102	21 Distance prot. 1.Z 4	false
21.1341.5941.102	50 OC high-speed 1.Standard 1	false

Stage 1		
Number	Settings	Value
21.1341.5941.1	Mode	Settings group 1: on
21.1341.5941.2	Operate & flt.rec. blocked	Settings group 1: no
21.1341.5941.6	Operate delay	Settings group 1: 0 s

2.hrm.det. gnd		
Number	Settings	Value
21.22051.1	Mode	All: off
21.22051.102	2nd harmonic content	Settings group 1: 15 %

50 OC high-speed 1 / STUB PROTECTION

Standard 1		
Number	Settings	Value
21.971.3901.1	Mode	Settings group 1: on
21.971.3901.101	Activation	Settings group 1: only with binary signal
21.971.3901.3	Threshold	Settings group 1: 2.00 A
21.971.3901.4	Dropout ratio	Settings group 1: 0.9

Line 1\Circuit-breaker interaction

Protection group	Circuit-breaker group(s)
Line 1\ 50/51 OC-3ph-A1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50/51 OC-3ph-A1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50N/51N OC-gnd-A1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50N/51N OC-gnd-A1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67N GFP gnd.sys.1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67N GFP gnd.sys.1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67N GFP gnd.sys.1\ Inverse-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67 Dir.OC-3ph-A1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67 Dir.OC-3ph-A1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67 Dir.OC-3ph-A1\ Inverse-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 46 I2 1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 46 I2 1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip

Protection group	Circuit-breaker group(s)
Line 1\ 27 Undervolt.-3ph 1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 27 Undervolt.-3ph 1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 59 Overvolt.-3ph 1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 59 Overvolt.-3ph 1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 3	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 4	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 87 Line diff. prot.\ General	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 85-21Perm.underr.\ 85-21Perm.unde	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ Switch onto fault 1\ Stage 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 87 Stub diff. prot. 1\ General	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50 OC high-speed 1\ Standard 1	Circuit breaker 1:Circuit breaker 1:Trip

*Setting marked as favorite setting

sp Setting marked as specific setting

ADANI GREEN ENERGY TWENTY FIVE LIMITED (ADANI RENEWABLES) 400kV BADISID SUBSTATION REMOTE END LINE PROTECTION RELAY SETTING CALCULATION

400kV BHADLA SUBSTATION


500 MW BADISID SOLAR POWER PROJECT

We reserve all rights in this document and in the information contained therein. Reproduction use or disclosure to third parties without express authority is strictly forbidden. Copyright © by Hitachi Energy India Limited.

"Disclaimer – Unauthorized access

The offered solution may be accessed through the customer network and therefore represents a danger which poses a potential threat of intrusion by unauthorized parties. Therefore, Hitachi Energy India Limited strongly recommends that the customer insures/implements necessary protection measures against the possibility of such unauthorized access.

Hitachi Energy India Limited disclaims any responsibility and shall under no circumstances be liable for damages or malfunctions caused by external intrusion of any kind whatsoever."

	<p>Categories:</p> <p><input type="checkbox"/> Cat-I Approved. Good for Manufacturing/Construction/Fabrication.</p>
<p>VISHRAM Digitally signed by VISHRAM Date: 2024.09.02 17:13:33 +05'30' Reviewer</p>	<p><input checked="" type="checkbox"/> Cat-I* Approved with minor comments. No resubmission is required. To be incorporated in As-Built. Good for Manufacturing/ Construction/ Fabrication subject to incorporation of comments.</p> <p><input type="checkbox"/> Cat-II Resubmission is required. Approved & Released for Manufacturing/ fabrication/ construction subjected to incorporation of comments.</p>
<p>Shaheed Patel Digitally signed by Shaheed Patel Date: 2024.09.02 18:15:46 +05'30' Approver</p>	<p><input type="checkbox"/> Cat-III Not Approved. Revise & Resubmit for Approval</p> <p><input type="checkbox"/> Cat-IV For Information & Records.</p> <p><input type="checkbox"/> Cat-IV* Incorporate Comments & resubmit for Information & records.</p> <p><i>Note: "Approval of this document does not absolve the Contractor/ Supplier/Fabricator from fulfilling Contractual obligations in any way"</i></p>


400kV BADISID SUBSTATION REMOTE END LINE PROTECTION RELAY SETTING CALCULATION

DOCUMENT	400kV BADISID SUBSTATION REMOTE END LINE PROTECTION RELAY SETTING CALCULATION
PROJECT	500 MW BADISID SOLAR POWER PROJECT
SUBSTATION	400kV BHADLA SUBSTATION
CLIENT	ADANI GREEN ENERGY TWENTY FIVE LIMITED
SUPPLIER	HITACHI ENERGY INDIA LIMITED
PO / LOA No.	IDTO-VI/ Adani Green-400 kV at Badi Sid - Rajasthan /PGGA/CRP & SAS
HEIL SO REF.	3100139976, 1MNS500950-PAAA

Revisions:

Rev.	Prep. / Appr.	Description	Date
00	SS / PN	First Submission	02-Aug-24
01	SS / PN	Revised as per the customer comments	19-Aug-24

CUSTOMER NEPAL ELECTRICITY AUTHORITY.	DEPT. PG-GAS	DOCUMENT ID. 1MNS500735-CGAA	REV. 01	LANG. En	PAGE 2/47
PROJECT 400kV BADISID SUBSTATION REMOTE END LINE PROTECTION RELAY SETTING CALCULATION			PREP. SS	APPR. PN	DATE 19-AUG-24

 Hitachi Energy PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

General Data of 400 KV LINE CONTROL AND RELAY PANEL (BAY-X)

Relay Details

Type = Micom P546

Bay Details

Local Station: = RELAY SETTING REPORT FOR BADISID LINE

Bay Reference = BAY -

Remote Station: = Badisid

Network Details

Voltage = 400 kV

Frequency = 50 Hz

OHL length of this circuit = 12.00 km

CT Details (Local end):


CT Ratio = 3000/1 A

Rated Primary current = 3000 A

Rated Secondary current = 1 A

Information

All the settings are in Secondary values

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION		Contract No.	3100140325, IN-56424026	
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)		Date	19-Aug-24	
Prepared:	SS	RELAY SETTING REPORT FOR BADISID LINE		Doc No.	1MNS500960-PAAA
Checked:	PN	MAIN-1 LINE PROTECTION RELAY, Micom P546		Rev No.	1

The Relay Bias characteristics is determined by four protection settings

- Is1 = The basic differential current setting which determines the minimum pick up of the relay
- Is2 = A bias threshold setting, above which the higher percentage bias k2 is used
The lower percentage bias setting used when the bias current is below IS2, This provides stability for small CT mismatches, whilst ensuring good sensitivity to resistive faults under heavy load conditions.
- K1 =
- K2 = The higher percentage bias setting used to improve relay stability under heavy through fault current conditions.

Basic Differential setting

This is basic differential current setting which determines the minimum pick up level of the relay. Where Capacitive Charging Current compensation is disabled, the setting of Is1 must be >2.5 times of total line charging current value.

The Charging current is calculated according to the following equation

$$I_{charge} = \frac{U}{\sqrt{3} * X_{c1}}$$

Where,

$$U = \text{System Line Voltage}$$

$$X_{c1} = \text{Positive Sequence Line Capacitance value}$$

$$I_{charge} = \text{Line charging current/kM due to Line Capacitance}$$

$$X_{c1} = \frac{1}{(2 * \pi * f * C1)}$$

$$C1 = \text{Line Capacitance value/kM}$$

$$= 0.0119 \mu\text{F/kM (Assumed)}$$

$$X_{c1} = \frac{1}{(2 * \pi * 50 * 0.000000119)}$$

$$X_{c1} = 267623 \Omega$$


$$I_{charge} = \frac{U}{\sqrt{3} * X_{c1}}$$

$$I_{charge} = \frac{400}{(\sqrt{3} * 267622.97)}$$

$$= 0.86 \text{ A}$$

Primary Charging Current of line = 0.86*12 = 10.32 A

Sec.Charging Current of line, Ic = Icharge / CTR = 10.32/3000 = 0.00344 A



The below mention setting recommended As per Main-1 relay


In_Nominal current (CT secondary)	=	1	A
Is1	=	25% of In	
	=	0.25	A
k1	=	30%	
Is2	=	2*In	
	=	2.0	A
K2	=	150%	

CT Ratio Correction

Local End CT Ratio	=	3000 / 1 A
Remote End CT Ratio	=	1000 / 1 A
CT Correction factor	=	CT Primary/Min Scheme CT Primary
	=	Min Scheme CT Primary ---> Lowest CT ratio
Local end CT Correction factor	=	3.0
Remote end CT Correction factor	=	1.0

Compenstation

Compenstation	=	Cap Charging
Susceptance (B)	=	ωC
	=	$I_{ch}/V * 10^{-3}$
	=	$(0.86 / (400 / 1.732)) * 10^{-3}$
	=	0.0037 mS

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION		Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)		Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE		Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546		Rev No.	1

Setting Calculation of Distance

General Data=

Total Line length is = **12.00** **km**

OHL data

Basic Line OHL parameters

Positive sequence imp. per km = 0.0266 +j 0.313 Ohm/km

Zero sequence imp. per km = 0.162 +j 1.187 Ohm/km

continuous current carrying capacity for each OHL - Icon

Considered as per Maximum power flow In the line (0 MVA) = 953 A

Line length = 12.00 Km

Line data= OHL

(Pos. seq. impedance of the line) = 0.319 +j 3.750 Ohm

R1A' + jX1A' = 3.764 L 85.13

(Zero seq. impedance of the line) = 1.940 +j 14.244 Ohm

R0A' + jX0A' = 14.376 L 82.24

CT Ratio (Adopted) = 3000 / 1 A

VT ratio = 400 / 0.11 kV

CT / VT Ratio conversion = CT ratio / VT ratio
= (3000/1)/(400/0.11)
= 0.83

Maximum load on line = 953 A

Zload' = (400*0.85*1000) / (952.7*1.732*1.5)

Zload' = 137.4 Ohm/ph

Referred to Secondary side = Maximum load on line * (CT/VT ratio)
= 137.37 x 0.83

Zload = 113.33 Ohm/ph

Cosφmin = 0.85 Minimum power factor

= 32 Deg

Set Load Angle = φmin + 5

(Load encroachment angle) = (32+5)

= 37 Deg

Arc Resistance Phase- Phase Rarc p-p' = 15 Ohm/ph


Referred to Secondary side Rarc p-p = 12.5 Ohm/ph

Arc Resistance Phase- Earth Rarc p-e' = 15 Ohm/ph

Referred to Secondary side Rarc p-e' = 12.5 Ohm/ph

Tower Foot Resistance Rtower' = 10 Ohm/ph

Referred to Secondary side Rtower' = 8.3 Ohm/ph

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

General settings

Protected Line Impedance

$$\begin{aligned} \text{Line Impedance secondary} &= 3.7636 * 0.83 \\ &= \mathbf{3.12} && \text{Ohm/ph} \end{aligned}$$

$$\text{Line Angle (Deg)} = \mathbf{85.1} \quad \text{Deg}$$

Short Line Feeder Details at Remote Station

Name of the line = -

Length of the line = 0 Km

Positive sequence imp. per km = 0.000 +j 0.000 Ohm/Km

Zero sequence imp. per km = 0.000 +j 0.000 Ohm/Km

Positive sequence imp. for total line km = 0.000 +j 0.000 Ohm

Zero sequence imp. for total line km = 0.000 +j 0.000 Ohm

Longest Line Feeder Details at Remote Station

Name of the line = -

Length of the line = 0.00 Km

Positive sequence imp. per km = 0.000 +j 0.000 Ohm/Km

Zero sequence imp. per km = 0.000 +j 0.000 Ohm/Km

Positive sequence imp. for total line km = 0.000 +j 0.000 Ohm

To find KN magnitude and KN angle for Zone 1

$$\begin{aligned} \text{KZ1 Res Comp \& KZ1 Angle} &= (Z0-Z1)/3Z1 \\ &= (14.376-3.764)/(3*3.764) \\ &= 0.94 \quad \angle -3.917 \end{aligned}$$

To find KN magnitude and KN angle for Zone 2, 3, 4

Positive sequence imp. for total line km = 0.383 +j 4.500 Ohm

$$= 4.516 \quad \angle 85.14$$

Zero sequence imp. for total line km = 2.328 +j 17.093 Ohm

$$= 17.251 \quad \angle 82.24$$

$$\text{KZ2/3/4 Res Comp \& KZ2/3/4 Angle} = (Z0-Z1)/3Z1$$

$$= 0.94 \quad \angle -3.915$$

Distance Zone 1 setting (Zone-1 Enabled only during communication failure)

Relay zone-1 reach shall be set to cover 80% forward direction considering the parallel line in operation


Operation direction

OperationDir = Forward **(*Fixed Direction mode as Forward for Zone-1)**

Positive sequence reactance reach

Zone 1 phase fault reach is set to **80%** of the total line reactance

Zone-1 reactance reach setting for phase faults, X1Z1'

 Hitachi Energy PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

$$\begin{aligned}
 &= 0.8 * jX1' \\
 &= 0.8 * 3.75 \\
 X1Z1' &= 3.00 \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
 &= X1Z1' * CT \text{ ratio} / VT \text{ ratio} \\
 X1Z1 &= \mathbf{2.49} \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

Positive sequence resistance for zone characteristics angle

$$\begin{aligned}
 &= 0.8 * R1' \\
 &= 0.8 * 0.32 \\
 R1Z1' &= 0.26 \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
 &= R1Z1' * CT \text{ ratio} / VT \text{ ratio} \\
 R1Z1 &= \mathbf{0.21} \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

Positive sequence Impedance reach

$$\begin{aligned}
 Z1' &= 3.01 \\
 \text{The secondary setting will thus be} & \\
 &= Z1' * CT \text{ ratio} / VT \text{ ratio} \\
 Z1 &= \mathbf{2.50} \qquad \qquad \qquad \text{Ohm/P}
 \end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

Set the resistive reach for phase faults to=

$$R1ph' = 30.00 \qquad \qquad \qquad \text{Ohm/I}$$

The secondary setting will thus be

$$\begin{aligned}
 &= R1ph' * CT \text{ ratio} / VT \text{ ratio} \\
 R1ph &= \mathbf{24.90} \qquad \qquad \qquad \text{Ohm/I}
 \end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Earth)

Set the resistive reach for earth faults to

$$R1G' = 25.00 \qquad \qquad \qquad \text{Ohm/I}$$

The secondary setting will thus be


$$\begin{aligned}
 &= R1G' * CT \text{ ratio} / VT \text{ ratio} \\
 R1G &= \mathbf{20.75} \qquad \qquad \qquad \text{Ohm/I}
 \end{aligned}$$

Time delay of trip

$$tZ1 = 0.00 \qquad \qquad \qquad \text{Sec}$$

Distance Zone 2 setting

Relay zone-2 reach shall be set to cover
 120 % of protected line + 0 % of Remote end shortest line forward direction

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

Operation direction

OperationDir = Forward **(*Fixed Direction mode as Forward for Zone-2)**

Positive sequence reactance reach

Zone 2 phase fault reach is set to **120%** of the total line reactance
+ **0%** of Remote end shortest line forward direction

Zone-2 reactance reach setting for phase faults, X1Z2

$$\begin{aligned}
&= (120\% \times 3.75) + (0\% \times 0) \\
&= (1.2 \times 3.75) + (0 \times 0) \\
X1Z2' &= 4.50 \qquad \qquad \qquad \text{Ohm/p}
\end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
&= X1Z2' \times \text{CT ratio} / \text{VT ratio} \\
X1Z2 &= \mathbf{3.74} \qquad \qquad \qquad \text{Ohm/p}
\end{aligned}$$

Positive sequence resistance for zone characteristics angle

$$\begin{aligned}
&= (120\% \times 0.32) + (0\% \times 0) \\
&= (1.2 \times 0.32) + (0 \times 0) \\
R1Z2' &= 0.38 \qquad \qquad \qquad \text{Ohm/p}
\end{aligned}$$

The secondary setting will thus be

$$\begin{aligned}
&= R1Z2' \times \text{CT ratio} / \text{VT ratio} \\
R1Z2 &= \mathbf{0.32} \qquad \qquad \qquad \text{Ohm/p}
\end{aligned}$$

Positive sequence Impedance reach

$$\begin{aligned}
Z2' &= 4.52 \\
\text{The secondary setting will thus be} \\
Z2 &= Z2' \times \text{CT ratio} / \text{VT ratio} \\
&= \mathbf{3.75} \qquad \qquad \qquad \text{Ohm/P}
\end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

The resistive reach for phase to phase is set to cover a maximum expected fault resistance of 30 ohm
Considering a factor of 2 on the zone-1 resistive reach value to take care of in feed effect.

$$R2ph = 60$$

Set the resistive reach for phase faults to=

$$R2ph' = 60.00 \qquad \qquad \qquad \text{Ohm/l}$$

The secondary setting will thus be

$$\begin{aligned}
&= R2ph' \times \text{CT ratio} / \text{VT ratio} \\
R2ph &= \mathbf{49.80} \qquad \qquad \qquad \text{Ohm/l}
\end{aligned}$$

Fault resistance reach in Ohm/loop (Phase-Earth)


Setting of the resistive reach for the underreaching zone 2 should follow the condition to minimize the risk for overreaching

Set the resistive reach for earth faults to

$$R2G' = 50.00 \qquad \qquad \qquad \text{Ohm/l}$$

The secondary setting will thus be

$$= R2G' \times \text{CT ratio} / \text{VT ratio}$$

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

$$R2G = 41.50 \text{ Ohm/l}$$

Time delay of trip Phase-Phase loops

Setting of Zone timers=

Normal values the needed time difference can be calculated

$$t2 = 40\text{ms} + 40\text{ms} + 40\text{ms} + 50\text{ms} = 170\text{ms}$$

Where,

the operation time of protection is 40 ms (Distance relay operation of other line at Remote End)

the breaker opening time is 40 ms

the resetting time of protection is 40 ms and

the additional margin is 50 ms

$$tZ2 = 0.35 \text{ Sec}$$

Distance Zone 3 setting

Relay zone-3 reach shall be set to cover

200 % of protected line + 0 % of Remote end longest line forward direction

Operation direction

$$\text{OperationDir} = \text{Forward}$$

Positive sequence reactance reach

Zone 3 phase fault reach is set to **120%** of the total line reactance
+ **100%** of Remote end longest line forward direction

Zone-3 reactance reach setting for phase faults, X1Z3

$$= (200\% \times 3.75) + (0\% \times 0)$$

$$= (2 \times 3.75) + (0 \times 0)$$

$$X1Z3' = 7.50 \text{ Ohm/p}$$

The secondary setting will thus be

$$= X1Z3' \times \text{CT ratio} / \text{VT ratio}$$

$$X1Z3 = 6.23 \text{ Ohm/p}$$

Positive sequence resistance for zone characteristics angle

$$(200\% \times 0.32) + (0\% \times 0)$$

$$(2 \times 0.32) + (0 \times 0)$$

$$R1Z3' = 0.64 \text{ Ohm/p}$$

The secondary setting will thus be

$$= R1Z3' \times \text{CT ratio} / \text{VT ratio}$$

$$R1Z3 = 0.53 \text{ Ohm/p}$$

Positive sequence Impedance reach

$$Z3' = 7.53$$


The secondary setting will thus be

$$= Z3' \times \text{CT ratio} / \text{VT ratio}$$

$$Z3 = 6.25 \text{ Ohm/P}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

Considering a factor of 2.5 on the zone-1 resistive reach value to take care of in feed effect.

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

Set the resistive reach for phase faults to

$$R_{3ph'} = 75.00 \quad \text{Ohm/l}$$

The secondary setting will thus be

$$= R_{3ph'} * CT \text{ ratio} / VT \text{ ratio}$$

$$R_{3ph} = 62.25 \quad \text{Ohm/l}$$

Fault resistance reach in Ohm/loop (Phase-Earth)

Setting of the resistive reach for the underreaching zone 3 should follow the condition to minimize the risk for overreaching

Set the resistive reach for earth faults to

$$R_{3G'} = 65.00 \quad \text{Ohm/l}$$

The secondary setting will thus be

$$= R_{3G'} * CT \text{ ratio} / VT \text{ ratio}$$

$$R_{3G} = 53.95 \quad \text{Ohm/l}$$

Time delay of trip

Setting of Zone timers=

Normal values the needed time difference can be calculated

$$t_3 = 350ms + 40ms + 40ms + 40ms + 50ms = 520ms$$

Where, Zone-2 operation is 350 ms (Distance relay operation of other line at Remote End)

the operation time of protection is 40 ms (Distance relay operation of other line at Remote End)

the breaker opening time is 100 ms

the resetting time of protection is 40 ms and

the additional margin is 50 ms

$$t_{Z3} = 1.00 \quad \text{Sec}$$

Distance Zone 4 setting

Relay zone-4 reach shall be set to cover 20 % of protected line + 0 % of Remote end longest line forward

direction

Operation direction

$$\text{OperationDir} = \text{Reverse}$$

Positive sequence reactance reach

Zone 4 phase fault reach is set to **20%** of the total line reactance
+ **0%** of Remote end longest line forward direction

Zone-4 reactance reach setting for phase faults, X1Z4

$$= (20\% \times 3.75) + (0\% \times 0)$$

$$= (0.2 \times 3.75) + (0 \times 0)$$

$$X_{1Z4'} = 0.75 \quad \text{Ohm/p}$$

The secondary setting will thus be

$$= X_{1Z4'} * CT \text{ ratio} / VT \text{ ratio}$$


$$X_{1Z4} = 0.62 \quad \text{Ohm/p}$$

0.6

Positive sequence resistance for zone characteristics angle

$$= (20\% \times 0.32) + (0\% \times 0)$$

$$= (0.2 \times 0.32) + (0 \times 0)$$

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

$$R1Z4' = 0.06 \text{ Ohm/p}$$

The secondary setting will thus be

$$R1Z4 = R1Z4' * CT \text{ ratio} / VT \text{ ratio} = \mathbf{0.05 \text{ Ohm/p}}$$

Positive sequence Impedance reach

$$Z4' = 0.75$$

The secondary setting will thus be

$$Z4 = Z4' * CT \text{ ratio} / VT \text{ ratio} = \mathbf{0.63 \text{ Ohm/P}}$$

Fault resistance reach in Ohm/loop (Phase-Phase)

The faults on remote lines will have in-feed of fault current through the fault resistance from other remote feeders which will make an apparent increase of the value. The setting is selected to take care of above factors. Set the resistive reach for phase faults to=

Setting the RF/X factor giving the PhF resistive coverage

Set the resistive reach for phase faults to

$$R4ph' = 75.00 \text{ Ohm/l}$$

The secondary setting will thus be

$$R4ph = R4ph' * CT \text{ ratio} / VT \text{ ratio} = \mathbf{62.25 \text{ Ohm/l}}$$

Fault resistance reach in Ohm/loop (Phase-Earth)

Setting of the resistive reach for the underreaching zone 4 should follow the condition to minimize the risk for overreaching

Set the resistive reach for earth faults to

$$R4G' = 65.00 \text{ Ohm/l}$$

The secondary setting will thus be

$$R4G = R4G' * CT \text{ ratio} / VT \text{ ratio} = \mathbf{53.95 \text{ Ohm/l}}$$

Time delay of trip

Setting of Zone timers=

Normal values the needed time difference can be calculated

$$t4 = 40ms + 40ms + 40ms + 50ms = 170ms$$

Where,

the operation time of protection is 40 ms (Busbar Protection relay)

the breaker opening time is 40 ms

the resetting time of protection is 40 ms and

the additional margin is 50 ms


$$tZ4 = 0.35 \text{ Sec}$$

Load Blinders

$$Z < \text{Blinder Imp (90\% of LR)} = \mathbf{102.0 \text{ Ohm}}$$

$$\text{Load/B Angle} = \mathbf{37.0 \text{ Deg}}$$

POWER SWING BLOCK=

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

PSB Blocking zone = Zone- 1, 2,3,4
PSB Unblock delay = 2.0 Sec

Slow Swing Setting

R7=R7=1.2 x Maximum Resistive reach = 1.2*53.95
(Zone 3) 64.74 Ω

Z7=Z7=1.2 x Maximum Zone reach = 1.2*6.247
(Zone 3) 7.50 Ω

R8=R8'=>1.1*R7 = 1.1*64.74
71.21 Ω

Z8=Z8'=>1.1*Z7 = 1.1*7.4964
8.25 Ω

Alpha = 0 deg
PSB Timer = 50 mSec

SOTF=

SOTF Status = Enabled
SOTF Tripping = Zone-2
SOTF Delay = 110 sec
TOR Status = Enabled
TOR Tripping = Zone-2

VT SUPERVISION=

VTS Mode = Measured + MCB
VTS Status = Blocking
VTS Reset Mode = Auto
VTS Time Delay = 5 Sec
VTS I> Inhibit = 10 A
VTS I2> Inhibit = 50mA

OVERVOLTAGE PROTECTION=

V> Measur't Mode = V1> & V>2 Ph- N
V> Operate Mode = V1> & V>2 Any Ph
V>1 Function = DT
V>1 Set = 70 V
V>1 time delay = 5 sec
V>2 Set = 89 V
V>2 time delay = 0.1 sec


UNDERVOLTAGE PROTECTION (Only DR Trigger - No Tripping)

V< Measur't Mode = V1< & V<2 Ph- N
V< Operate Mode = V1> & V>2 Any Ph
V<1 Function = DT
V<1 Set = 57 V
V<1 time delay = 0 sec
V<1 Poledead Inh = Enabled

DIR. EARTH FAULT SETTINGS = 67N

Pickup current should be set above the continuous residual current under normal operation.

Max Load Current = 952.7
IN>1 Function = IEC S Inverse
IN>1 Directional = Directional Fwd
IN>1 Pickup current in A = 23 % of Maximum Load current of the Conductor

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100140325, IN-56424026
	400 KV LINE CONTROL AND RELAY PANEL (BAY-X)	Date	19-Aug-24
Prepared: SS	RELAY SETTING REPORT FOR BADISID LINE	Doc No.	1MNS500960-PAAA
Checked: PN	MAIN-1 LINE PROTECTION RELAY, Micom P546	Rev No.	1

$$0.23 * 952.7 = 219.121A$$

$$IN > 1 \text{ Current Set (Is)} = 0.07 \text{ A}$$

The Earth fault function has to be graded with the Zone-3 Protection

$$\text{Required time (Treq)} = 1.13 \text{ Sec}$$

The IDMT curve shall saturate if the fault current more than 20 times of pickup current. In this case fault current more than 20 times. Hence 20 times of set current considered for TMS calculation.

$$\text{Fault Current} = 20 * \text{Pickup} = 4382.42 \text{ A}$$

$$IN > 1 \text{ TMS} = (\text{Treq} * (\text{IF/Is})^{0.02-1}) / 0.14$$

$$= (1.13 * (4382.42 / 219.121)^{0.02-1}) / 0.14 = 0.50$$

$$\text{Char Angle} = -45 \text{ Deg}$$

BROKEN CONDUCTOR: (Alarm Only)

$$I2/I1 \text{ Ratio} = 0.2$$

$$\text{time delay} = 5$$

DISTURBANCE RECORDER:

$$\text{Pre-Fault time} = 0.5 \text{ Sec}$$

$$\text{Posr-Fault time} = 2.5 \text{ Sec}$$

$$\text{Total time} = 3 \text{ Sec}$$

STUB PROTECTION: 50STUB

$$\text{Max Load Current} = 952.7$$

$$I > 4 \text{ Function} = \text{IEC DT}$$

$$I > 4 \text{ Directional} = \text{Non Directional}$$

$$I > 4 \text{ Pickup current in A} = 200 \% \text{ of Maximum Load current of the Conductor}$$

$$= 2 * 952.7 = 1905.4A$$

$$I > 4 \text{ Current Set (Is)} = 0.64 \text{ A}$$

$$I > 4 \text{ operating time} = 0.05 \text{ Sec}$$

TELE PROTECTION

$$\text{Scheme type} = \text{Permissive OR}$$



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:39

- SYSTEM DATA
 - 00.01: Language: English
 - 00.02: Password: ****
 - 00.03: Sys Fn Links: 0
 - 00.04: Description: Badisid line
 - 00.05: Plant Reference: Bhadla SS
 - 00.06: Model Number: P546?1109?552?K
 - 00.08: Serial Number: 12345
 - 00.09: Frequency: 50 Hz
 - 00.0A: Comms Level: 2
 - 00.0B: Relay Address: 1
 - 00.0C: Plant Status: 0000001000000010
 - 00.0D: Control Status: 0000000000000000
 - 00.0E: Active Group: 1
 - 00.10: CB Trip/Close: No Operation
 - 00.11: Software Ref. 1: P546__4_520_A
 - 00.20: Opto I/P Status: 000000000000000000000000
 - 00.21: Relay O/P Status: 000000000000000000001000
 - 00.22: Alarm Status 1: 00000010000000000000000000000000
 - 00.50: Alarm Status 1: 00000010000000000000000000000000
 - 00.51: Alarm Status 2: 00000000000000000000000000000000
 - 00.52: Alarm Status 3: 00000000000000000000000000000000
 - 00.D0: Access Level: 2
 - 00.D1: Password Control: 2
 - 00.D2: Password Level 1: ****
 - 00.D3: Password Level 2: ****
- CB CONTROL
 - 07.01: CB Control by: Disabled
 - 07.11: CB Status Input: 52B 1 pole
- DATE AND TIME
 - 08.01: Date/Time: 2007-04-08 23:39:09.855
 - 08.06: Battery Status: Healthy
 - 08.07: Battery Alarm: Enabled
 - 08.20: LocalTime Enable: Flexible
 - 08.21: LocalTime Offset: 330.0 min
 - 08.22: DST Enable: Disabled
 - 08.30: RP1 Time Zone: Local
- CONFIGURATION
 - 09.01: Restore Defaults: No Operation
 - 09.02: Setting Group: Select via Menu
 - 09.03: Active Settings: Group 1
 - 09.04: Save Changes: No Operation
 - 09.05: Copy From: Group 1
 - 09.06: Copy To: No Operation
 - 09.07: Setting Group 1: Enabled
 - 09.08: Setting Group 2: Disabled
 - 09.09: Setting Group 3: Disabled
 - 09.0A: Setting Group 4: Disabled
 - 09.0B: Distance: Enabled
 - 09.0C: Directional E/F: Disabled
 - 09.0F: Phase Diff: Enabled
 - 09.10: Overcurrent: Enabled
 - 09.11: Neg Sequence O/C: Disabled
 - 09.12: Broken Conductor: Enabled
 - 09.13: Earth Fault: Enabled
 - 09.15: Sensitive E/F: Disabled
 - 09.16: Residual O/V NVD: Disabled
 - 09.17: Thermal Overload: Disabled
 - 09.18: PowerSwing Block: Enabled
 - 09.1D: Volt Protection: Enabled
 - 09.1E: Freq Protection: Disabled
 - 09.1F: df/dt Protection: Disabled
 - 09.20: CB Fail: Disabled
 - 09.21: Supervision: Enabled
 - 09.25: Input Labels: Visible
 - 09.26: Output Labels: Visible



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:39

- 09.28: CT & VT Ratios: Visible
- 09.29: Record Control: Visible
- 09.2A: Disturb Recorder: Visible
- 09.2B: Measure't Setup: Visible
- 09.2C: Comms Settings: Visible
- 09.2D: Commission Tests: Visible
- 09.2E: Setting Values: Secondary
- 09.2F: Control Inputs: Visible
- 09.35: Ctrl I/P Config: Visible
- 09.36: Ctrl I/P Labels: Visible
- 09.39: Direct Access: Enabled
- 09.50: Function Key: Visible
- 09.FF: LCD Contrast: 11

CT AND VT RATIOS

- 0A.01: Main VT Primary: 400kV
- 0A.02: Main VT Sec'y: 110.0 V
- 0A.07: Phase CT Primary: 3000 A
- 0A.08: Phase CT Sec'y: 1.000 A
- 0A.0B: SEF CT Primary: 3000 A
- 0A.0C: SEF CT Secondary: 1.000 A
- 0A.0D: MComp CT Primary: 3000 A
- 0A.0E: MComp CT Sec'y: 1.000 A
- 0A.11: CT Polarity: Standard
- 0A.12: CT2 Polarity: Standard
- 0A.13: SEF CT Polarity: Standard
- 0A.14: M CT Polarity: Standard
- 0A.18: VT Connected: Yes

RECORD CONTROL

- 0B.01: Clear Events: No
- 0B.02: Clear Faults: No
- 0B.03: Clear Maint: No
- 0B.04: Alarm Event: Enabled
- 0B.05: Relay O/P Event: Enabled
- 0B.06: Opto Input Event: Enabled
- 0B.07: General Event: Enabled
- 0B.08: Fault Rec Event: Enabled
- 0B.09: Maint Rec Event: Enabled
- 0B.0A: Protection Event: Enabled
- 0B.30: Clear Dist Recs: No
- 0B.40: DDB 31 - 0: 11111111111111111111111111111111
- 0B.41: DDB 63 - 32: 11111111111111111111111111111111
- 0B.42: DDB 95 - 64: 11111111111111111111111111111111
- 0B.43: DDB 127 - 96: 11111111111111111111111111111111
- 0B.44: DDB 159 - 128: 11111111111111111111111111111111
- 0B.45: DDB 191 - 160: 11111111111111111111111111111111
- 0B.46: DDB 223 - 192: 11111111111111111111111111111111
- 0B.47: DDB 255 - 224: 11111111111111111111111111111111
- 0B.48: DDB 287 - 256: 11111111111111111111111111111111
- 0B.49: DDB 319 - 288: 11111111111111111111111111111111
- 0B.4A: DDB 351 - 320: 11111111111111111111111111111111
- 0B.4B: DDB 383 - 352: 11111111111111111111111111111111
- 0B.4C: DDB 415 - 384: 11111111111111111111111111111111
- 0B.4D: DDB 447 - 416: 11111111111111111111111111111111
- 0B.4E: DDB 479 - 448: 11111111111111111111111111111111
- 0B.4F: DDB 511 - 480: 11111111111111111111111111111111
- 0B.50: DDB 543 - 512: 11111111111111111111111111111111
- 0B.51: DDB 575 - 544: 11111111111111111111111111111111
- 0B.52: DDB 607 - 576: 11111111111111111111111111111111
- 0B.53: DDB 639 - 608: 11111111111111111111111111111111
- 0B.54: DDB 671 - 640: 11111111111111111111111111111111
- 0B.55: DDB 703 - 672: 11111111111111111111111111111111
- 0B.56: DDB 735 - 704: 11111111111111111111111111111111
- 0B.57: DDB 767 - 736: 11111111111111111111111111111111
- 0B.58: DDB 799 - 768: 11111111111111111111111111111111
- 0B.59: DDB 831 - 800: 11111111111111111111111111111111
- 0B.5A: DDB 863 - 832: 11111111111111111111111111111111



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:39

```

..... 0B.5B: DDB 895 - 864: 11111111111111111111111111111111
..... 0B.5C: DDB 927 - 896: 11111111111111111111111111111111
..... 0B.5D: DDB 959 - 928: 11111111111111111111111111111111
..... 0B.5E: DDB 991 - 960: 11111111111111111111111111111111
..... 0B.5F: DDB 1023 - 992: 11111111111111111111111111111111
..... 0B.60: DDB 1055 - 1024: 11111111111111111111111111111111
..... 0B.61: DDB 1087 - 1056: 11111111111111111111111111111111
..... 0B.62: DDB 1119 - 1088: 11111111111111111111111111111111
..... 0B.63: DDB 1151 - 1120: 11111111111111111111111111111111
..... 0B.64: DDB 1183 - 1152: 11111111111111111111111111111111
..... 0B.65: DDB 1215 - 1184: 11111111111111111111111111111111
..... 0B.66: DDB 1247 - 1216: 11111111111111111111111111111111
..... 0B.67: DDB 1279 - 1248: 11111111111111111111111111111111
..... 0B.68: DDB 1311 - 1280: 11111111111111111111111111111111
..... 0B.69: DDB 1343 - 1312: 11111111111111111111111111111111
..... 0B.6A: DDB 1375 - 1344: 11111111111111111111111111111111
..... 0B.6B: DDB 1407 - 1376: 11111111111111111111111111111111

```

 DISTURB RECORDER

```

..... 0C.01: Duration: 3.000 s
..... 0C.02: Trigger Position: 16.00 %
..... 0C.03: Trigger Mode: Extended
..... 0C.04: Analog Channel 1: VA
..... 0C.05: Analog Channel 2: VB
..... 0C.06: Analog Channel 3: VC
..... 0C.07: Analog Channel 4: IA
..... 0C.08: Analog Channel 5: IB
..... 0C.09: Analog Channel 6: IC
..... 0C.0A: Analog Channel 7: IN
..... 0C.0B: Analog Channel 8: IN Sensitive
..... 0C.0C: Digital Input 1: Relay 1
..... 0C.0D: Input 1 Trigger: No Trigger
..... 0C.0E: Digital Input 2: Relay 2
..... 0C.0F: Input 2 Trigger: No Trigger
..... 0C.10: Digital Input 3: Relay 3
..... 0C.11: Input 3 Trigger: Trigger L/H
..... 0C.12: Digital Input 4: Relay 4
..... 0C.13: Input 4 Trigger: No Trigger
..... 0C.14: Digital Input 5: Relay 5
..... 0C.15: Input 5 Trigger: No Trigger
..... 0C.16: Digital Input 6: Relay 6
..... 0C.17: Input 6 Trigger: No Trigger
..... 0C.18: Digital Input 7: Relay 7
..... 0C.19: Input 7 Trigger: No Trigger
..... 0C.1A: Digital Input 8: Relay 8
..... 0C.1B: Input 8 Trigger: No Trigger
..... 0C.1C: Digital Input 9: Relay 9
..... 0C.1D: Input 9 Trigger: No Trigger
..... 0C.1E: Digital Input 10: Relay 10
..... 0C.1F: Input 10 Trigger: No Trigger
..... 0C.20: Digital Input 11: Relay 11
..... 0C.21: Input 11 Trigger: No Trigger
..... 0C.22: Digital Input 12: Relay 12
..... 0C.23: Input 12 Trigger: No Trigger
..... 0C.24: Digital Input 13: Relay 13
..... 0C.25: Input 13 Trigger: No Trigger
..... 0C.26: Digital Input 14: Relay 14
..... 0C.27: Input 14 Trigger: No Trigger
..... 0C.28: Digital Input 15: Relay 15
..... 0C.29: Input 15 Trigger: No Trigger
..... 0C.2A: Digital Input 16: Relay 16
..... 0C.2B: Input 16 Trigger: No Trigger
..... 0C.2C: Digital Input 17: Opto 1
..... 0C.2D: Input 17 Trigger: No Trigger
..... 0C.2E: Digital Input 18: Opto 2
..... 0C.2F: Input 18 Trigger: No Trigger
..... 0C.30: Digital Input 19: Opto 3

```




Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:39

```

..... 0C.31: Input 19 Trigger: No Trigger
..... 0C.32: Digital Input 20: Opto 4
..... 0C.33: Input 20 Trigger: No Trigger
..... 0C.34: Digital Input 21: Opto 5
..... 0C.35: Input 21 Trigger: No Trigger
..... 0C.36: Digital Input 22: Opto 6
..... 0C.37: Input 22 Trigger: No Trigger
..... 0C.38: Digital Input 23: Opto 7
..... 0C.39: Input 23 Trigger: No Trigger
..... 0C.3A: Digital Input 24: Opto 8
..... 0C.3B: Input 24 Trigger: No Trigger
..... 0C.3C: Digital Input 25: Opto 9
..... 0C.3D: Input 25 Trigger: No Trigger
..... 0C.3E: Digital Input 26: Opto 10
..... 0C.3F: Input 26 Trigger: No Trigger
..... 0C.40: Digital Input 27: Opto 11
..... 0C.41: Input 27 Trigger: No Trigger
..... 0C.42: Digital Input 28: Opto 12
..... 0C.43: Input 28 Trigger: No Trigger
..... 0C.44: Digital Input 29: Opto 13
..... 0C.45: Input 29 Trigger: No Trigger
..... 0C.46: Digital Input 30: Opto 14
..... 0C.47: Input 30 Trigger: No Trigger
..... 0C.48: Digital Input 31: Opto 15
..... 0C.49: Input 31 Trigger: No Trigger
..... 0C.4A: Digital Input 32: Opto 16
..... 0C.4B: Input 32 Trigger: No Trigger
..... 0C.50: Analog Channel 9: IM
..... 0C.51: Analog Channel10: IA2
..... 0C.52: Analog Channel11: IB2
..... 0C.53: Analog Channel12: IC2

```

MEASUREMENT SETUP

```

..... 0D.01: Default Display: Description
..... 0D.02: Local Values: Primary
..... 0D.03: Remote Values: Primary
..... 0D.04: Measurement Ref: VA
..... 0D.05: Measurement Mode: 0
..... 0D.06: Fix Dem Period: 30.00 min
..... 0D.07: Roll Sub Period: 30.00 min
..... 0D.08: Num Sub Periods: 1
..... 0D.09: Distance Unit: Kilometres
..... 0D.0A: Fault Location: Distance

```

COMMISSION TESTS

```

..... 0F.01: Opto I/P Status: 000000000000000000000000
..... 0F.02: Relay O/P Status: 0000000000000000000001010
..... 0F.03: Test Port Status: 00001000
..... 0F.05: Monitor Bit 1: 1060
..... 0F.06: Monitor Bit 2: 1062
..... 0F.07: Monitor Bit 3: 1064
..... 0F.08: Monitor Bit 4: 1066
..... 0F.09: Monitor Bit 5: 1068
..... 0F.0A: Monitor Bit 6: 1070
..... 0F.0B: Monitor Bit 7: 1072
..... 0F.0C: Monitor Bit 8: 1074
..... 0F.0D: Test Mode: Disabled
..... 0F.0E: Test Pattern: 000000000000000000000000
..... 0F.0F: Contact Test: No Operation
..... 0F.10: Test LEDs: No Operation
..... 0F.12: Static Test: Disabled
..... 0F.13: Test Loopback: Disabled
..... 0F.14: IM64 TestPattern: 0000000000000000
..... 0F.15: IM64 Test Mode: Disabled
..... 0F.1A: Red LED Status: 0000000000000001000
..... 0F.1B: Green LED Status: 0000000000000001000
..... 0F.20: DDB 31 - 0: 000000000000000000000000000001010
..... 0F.21: DDB 63 - 32: 000000000000000000000000000000000

```



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:39

```

..... D 0F.22: DDB 95 - 64: 00000000000000000000000000000000
..... D 0F.23: DDB 127 - 96: 00000000000000000000000000000000
..... D 0F.24: DDB 159 - 128: 000000000000000000000000000001010
..... D 0F.25: DDB 191 - 160: 00000000000000000000000000000000
..... D 0F.26: DDB 223 - 192: 00000000000000000000000000000000
..... D 0F.27: DDB 255 - 224: 00000000000000000000000000000000
..... D 0F.28: DDB 287 - 256: 00000000000000000000000000000000
..... D 0F.29: DDB 319 - 288: 00000101000000000000000000000000
..... D 0F.2A: DDB 351 - 320: 00000000000000000000000000000000
..... D 0F.2B: DDB 383 - 352: 00000000000000000000000000000000
..... D 0F.2C: DDB 415 - 384: 00000000000000000000000000000000
..... D 0F.2D: DDB 447 - 416: 00000000011000000000000000000000
..... D 0F.2E: DDB 479 - 448: 00000000000000000000000000000000
..... D 0F.2F: DDB 511 - 480: 00000000000000000000000000000000
..... D 0F.30: DDB 543 - 512: 00000000010000000000000000000000
..... D 0F.31: DDB 575 - 544: 00000000000000000000000000000000
..... D 0F.32: DDB 607 - 576: 00000000000000000000000000000000
..... D 0F.33: DDB 639 - 608: 00000000000000000000000000000000
..... D 0F.34: DDB 671 - 640: 00000000000000000000000000000000
..... D 0F.35: DDB 703 - 672: 00000000000000000000000000000000
..... D 0F.36: DDB 735 - 704: 00000000000000000000000000000000
..... D 0F.37: DDB 767 - 736: 00000000000000000000000000000000
..... D 0F.38: DDB 799 - 768: 00000000000000000000000000000000
..... D 0F.39: DDB 831 - 800: 11100000000000000000000000000000
..... D 0F.3A: DDB 863 - 832: 00000000000000000000000000000000
..... D 0F.3B: DDB 895 - 864: 01111100001001101010001111111111
..... D 0F.3C: DDB 927 - 896: 00000000011100000111000000000100
..... D 0F.3D: DDB 959 - 928: 00000000000000000000000000000000
..... D 0F.3E: DDB 991 - 960: 00000000000000000000000000000000
..... D 0F.3F: DDB 1023 - 992: 00000000000000000000000000000000
..... D 0F.40: DDB 1055 - 1024: 0000000000000000000000011000000
..... D 0F.41: DDB 1087 - 1056: 0000000000000000000000011000000000
..... D 0F.42: DDB 1119 - 1088: 00000000000000000000000000000000
..... D 0F.43: DDB 1151 - 1120: 00001000000000000000000000000001
..... D 0F.44: DDB 1183 - 1152: 10001010000000000000000000000000
..... D 0F.45: DDB 1215 - 1184: 00000000000000000000000000001000
..... D 0F.46: DDB 1247 - 1216: 00000000000000000000000000000000
..... D 0F.47: DDB 1279 - 1248: 00000000000000000000000000000000
..... D 0F.48: DDB 1311 - 1280: 00000000000000000000000000000000
..... D 0F.49: DDB 1343 - 1312: 00000001000000000000000000000000
..... D 0F.4A: DDB 1375 - 1344: 00000100000000000000000000000000
..... D 0F.4B: DDB 1407 - 1376: 00000000000000000000000000000000

```

OPTO CONFIG

```

..... D 11.01: Global Nominal V: 220/250V
..... D 11.60: Opto Filter Cntl: 1111111111101111111011
..... D 11.80: Characteristic: Standard 60%-80%

```

CONTROL INPUTS

```

..... D 12.01: Ctrl I/P Status: 00000000000000000000000000000000
..... D 12.02: Control Input 1: No Operation
..... D 12.03: Control Input 2: No Operation
..... D 12.04: Control Input 3: No Operation
..... D 12.05: Control Input 4: No Operation
..... D 12.06: Control Input 5: No Operation
..... D 12.07: Control Input 6: No Operation
..... D 12.08: Control Input 7: No Operation
..... D 12.09: Control Input 8: No Operation
..... D 12.0A: Control Input 9: No Operation
..... D 12.0B: Control Input 10: No Operation
..... D 12.0C: Control Input 11: No Operation
..... D 12.0D: Control Input 12: No Operation
..... D 12.0E: Control Input 13: No Operation
..... D 12.0F: Control Input 14: No Operation
..... D 12.10: Control Input 15: No Operation
..... D 12.11: Control Input 16: No Operation
..... D 12.12: Control Input 17: No Operation
..... D 12.13: Control Input 18: No Operation

```



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:40

- 12.14: Control Input 19: No Operation
- 12.15: Control Input 20: No Operation
- 12.16: Control Input 21: No Operation
- 12.17: Control Input 22: No Operation
- 12.18: Control Input 23: No Operation
- 12.19: Control Input 24: No Operation
- 12.1A: Control Input 25: No Operation
- 12.1B: Control Input 26: No Operation
- 12.1C: Control Input 27: No Operation
- 12.1D: Control Input 28: No Operation
- 12.1E: Control Input 29: No Operation
- 12.1F: Control Input 30: No Operation
- 12.20: Control Input 31: No Operation
- 12.21: Control Input 32: No Operation

..... CTRL I/P CONFIG

- 13.01: Hotkey Enabled: 11111111111111111111111111111111
- 13.10: Control Input 1: Latched
- 13.11: Ctrl Command 1: SET/RESET
- 13.14: Control Input 2: Latched
- 13.15: Ctrl Command 2: SET/RESET
- 13.18: Control Input 3: Latched
- 13.19: Ctrl Command 3: SET/RESET
- 13.1C: Control Input 4: Latched
- 13.1D: Ctrl Command 4: SET/RESET
- 13.20: Control Input 5: Latched
- 13.21: Ctrl Command 5: SET/RESET
- 13.24: Control Input 6: Latched
- 13.25: Ctrl Command 6: SET/RESET
- 13.28: Control Input 7: Latched
- 13.29: Ctrl Command 7: SET/RESET
- 13.2C: Control Input 8: Latched
- 13.2D: Ctrl Command 8: SET/RESET
- 13.30: Control Input 9: Latched
- 13.31: Ctrl Command 9: SET/RESET
- 13.34: Control Input 10: Latched
- 13.35: Ctrl Command 10: SET/RESET
- 13.38: Control Input 11: Latched
- 13.39: Ctrl Command 11: SET/RESET
- 13.3C: Control Input 12: Latched
- 13.3D: Ctrl Command 12: SET/RESET
- 13.40: Control Input 13: Latched
- 13.41: Ctrl Command 13: SET/RESET
- 13.44: Control Input 14: Latched
- 13.45: Ctrl Command 14: SET/RESET
- 13.48: Control Input 15: Latched
- 13.49: Ctrl Command 15: SET/RESET
- 13.4C: Control Input 16: Latched
- 13.4D: Ctrl Command 16: SET/RESET
- 13.50: Control Input 17: Latched
- 13.51: Ctrl Command 17: SET/RESET
- 13.54: Control Input 18: Latched
- 13.55: Ctrl Command 18: SET/RESET
- 13.58: Control Input 19: Latched
- 13.59: Ctrl Command 19: SET/RESET
- 13.5C: Control Input 20: Latched
- 13.5D: Ctrl Command 20: SET/RESET
- 13.60: Control Input 21: Latched
- 13.61: Ctrl Command 21: SET/RESET
- 13.64: Control Input 22: Latched
- 13.65: Ctrl Command 22: SET/RESET
- 13.68: Control Input 23: Latched
- 13.69: Ctrl Command 23: SET/RESET
- 13.6C: Control Input 24: Latched
- 13.6D: Ctrl Command 24: SET/RESET
- 13.70: Control Input 25: Latched
- 13.71: Ctrl Command 25: SET/RESET



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:40

- 13.74: Control Input 26: Latched
- 13.75: Ctrl Command 26: SET/RESET
- 13.78: Control Input 27: Latched
- 13.79: Ctrl Command 27: SET/RESET
- 13.7C: Control Input 28: Latched
- 13.7D: Ctrl Command 28: SET/RESET
- 13.80: Control Input 29: Latched
- 13.81: Ctrl Command 29: SET/RESET
- 13.84: Control Input 30: Latched
- 13.85: Ctrl Command 30: SET/RESET
- 13.88: Control Input 31: Latched
- 13.89: Ctrl Command 31: SET/RESET
- 13.8C: Control Input 32: Latched
- 13.8D: Ctrl Command 32: SET/RESET

..... FUNCTION KEYS

- 17.01: Fn Key Status: 0000000000
- 17.02: Fn Key 1: Unlocked
- 17.03: Fn Key 1 Mode: Normal
- 17.04: Fn Key 1 Label: Function Key 1
- 17.05: Fn Key 2: Unlocked
- 17.06: Fn Key 2 Mode: Normal
- 17.07: Fn Key 2 Label: Function Key 2
- 17.08: Fn Key 3: Unlocked
- 17.09: Fn Key 3 Mode: Normal
- 17.0A: Fn Key 3 Label: Function Key 3
- 17.0B: Fn Key 4: Unlocked
- 17.0C: Fn Key 4 Mode: Normal
- 17.0D: Fn Key 4 Label: Function Key 4
- 17.0E: Fn Key 5: Unlocked
- 17.0F: Fn Key 5 Mode: Normal
- 17.10: Fn Key 5 Label: Function Key 5
- 17.11: Fn Key 6: Unlocked
- 17.12: Fn Key 6 Mode: Normal
- 17.13: Fn Key 6 Label: Function Key 6
- 17.14: Fn Key 7: Unlocked
- 17.15: Fn Key 7 Mode: Normal
- 17.16: Fn Key 7 Label: Function Key 7
- 17.17: Fn Key 8: Unlocked
- 17.18: Fn Key 8 Mode: Normal
- 17.19: Fn Key 8 Label: Function Key 8
- 17.1A: Fn Key 9: Unlocked
- 17.1B: Fn Key 9 Mode: Normal
- 17.1C: Fn Key 9 Label: Function Key 9
- 17.1D: Fn Key 10: Unlocked
- 17.1E: Fn Key 10 Mode: Normal
- 17.1F: Fn Key 10 Label: Function Key 10

..... PROT COMMS/ IM64

- 20.01: Scheme Setup: 2 Terminal
- 20.03: Address: 0-0
- 20.10: Comms Mode: Standard
- 20.11: Baud Rate Ch1: 64kbits/s
- 20.13: Clock Source Ch1: Internal
- 20.17: Comm Delay Tol: 350.0 us
- 20.18: Comm Fail Timer: 10.00 s
- 20.1A: GPS Sync: Disabled
- 20.1B: Char Mod Time: 500.0 ms
- 20.1F: Alarm Level: 25.00 %
- 20.20: Prop Delay Stats: Enabled
- 20.21: MaxCh1 PropDelay: 15.00 ms
- 20.30: IM1 Cmd Type: Permissive
- 20.31: IM1 Fallbck Mode: Default
- 20.32: IM1 Default Val: 0
- 20.34: IM2 Cmd Type: Permissive
- 20.35: IM2 Fallbck Mode: Default
- 20.36: IM2 Default Val: 0
- 20.38: IM3 Cmd Type: Permissive



Settings File Report

Substation:

File: P546 remote.set

Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:40

- 20.39: IM3 Fallbck Mode: Default
- 20.3A: IM3 Default Val: 0
- 20.3C: IM4 Cmd Type: Permissive
- 20.3D: IM4 Fallbck Mode: Default
- 20.3E: IM4 Default Val: 0
- 20.40: IM5 Cmd Type: Permissive
- 20.41: IM5 Fallbck Mode: Default
- 20.42: IM5 Default Val: 0
- 20.44: IM6 Cmd Type: Permissive
- 20.45: IM6 Fallbck Mode: Default
- 20.46: IM6 Default Val: 0
- 20.48: IM7 Cmd Type: Permissive
- 20.49: IM7 Fallbck Mode: Default
- 20.4A: IM7 Default Val: 0
- 20.4C: IM8 Cmd Type: Permissive
- 20.4D: IM8 Fallbck Mode: Default
- 20.4E: IM8 Default Val: 0

CTRL I/P LABELS

- 29.01: Control Input 1: Control Input 1
- 29.02: Control Input 2: Control Input 2
- 29.03: Control Input 3: Control Input 3
- 29.04: Control Input 4: Control Input 4
- 29.05: Control Input 5: Control Input 5
- 29.06: Control Input 6: Control Input 6
- 29.07: Control Input 7: Control Input 7
- 29.08: Control Input 8: Control Input 8
- 29.09: Control Input 9: Control Input 9
- 29.0A: Control Input 10: Control Input 10
- 29.0B: Control Input 11: Control Input 11
- 29.0C: Control Input 12: Control Input 12
- 29.0D: Control Input 13: Control Input 13
- 29.0E: Control Input 14: Control Input 14
- 29.0F: Control Input 15: Control Input 15
- 29.10: Control Input 16: Control Input 16
- 29.11: Control Input 17: Control Input 17
- 29.12: Control Input 18: Control Input 18
- 29.13: Control Input 19: Control Input 19
- 29.14: Control Input 20: Control Input 20
- 29.15: Control Input 21: Control Input 21
- 29.16: Control Input 22: Control Input 22
- 29.17: Control Input 23: Control Input 23
- 29.18: Control Input 24: Control Input 24
- 29.19: Control Input 25: Control Input 25
- 29.1A: Control Input 26: Control Input 26
- 29.1B: Control Input 27: Control Input 27
- 29.1C: Control Input 28: Control Input 28
- 29.1D: Control Input 29: Control Input 29
- 29.1E: Control Input 30: Control Input 30
- 29.1F: Control Input 31: Control Input 31
- 29.20: Control Input 32: Control Input 32

Group 1

GROUP 1 LINE PARAMETERS

- 30.01: Line Length: 12.00 km
- 30.03: Line Impedance: 3.120 Ohm
- 30.04: Line Angle: 85.00 deg
- 30.05: kZN Res Comp: 940.0e-3
- 30.06: kZN Res Angle: -4.000 deg
- 30.07: Mutual Comp: Disabled
- 30.0B: Phase Sequence: Standard ABC
- 30.0C: Tripping Mode: 1 Pole & 3 Pole






GROUP 1 DISTANCE SETUP

- 31.0C: Setting Mode: Advanced
- 31.10: PHASE DISTANCE:
- 31.11: Phase Chars.: Quad
- 31.20: Zone 1 Ph Status: Enabled Ch Fail
- 31.30: Zone 2 Ph Status: Enabled



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:40

- 31.40: Zone 3 Ph Status: Enabled
- 31.42: Zone 3 Ph Offset: Enabled
- 31.50: Zone P Ph Status: Disabled
- 31.60: Zone 4 Ph Status: Enabled
-  31.70: GROUND DISTANCE:
- 31.71: Ground Chars.: Quad
- 31.80: Zone 1 Gnd Stat.: Enabled Ch Fail
- 31.90: Zone 2 Gnd Stat.: Enabled
- 31.A0: Zone 3 Gnd Stat.: Enabled
- 31.A2: Zone3 Gnd Offset: Enabled
- 31.B0: Zone P Gnd Stat.: Disabled
- 31.C0: Zone 4 Gnd Stat.: Enabled
- 31.D0: Digital Filter: Standard
- 31.D1: CVT Filters: Disabled
- 31.D3: Load Blinders: Enabled
- 31.D4: Z< Blinder Imp: 102.0 Ohm
- 31.D5: Load/B Angle: 37.00 deg
- 31.D6: Load Blinder V<: 15.01 V
- 31.D7: Dist. Polarizing: 1.000
-  31.E0: DELTADIRECTIONAL:
- 31.E1: Dir. Status: Disabled
-  GROUP 1 DIST. ELEMENTS
-  32.01: PHASE DISTANCE:
- 32.02: Z1 Ph. Reach: 2.500 Ohm
- 32.03: Z1 Ph. Angle: 85.00 deg
- 32.07: R1 Ph. Resistive: 24.90 Ohm
- 32.08: Z1 Tilt Top Line: 0 deg
- 32.09: Z1 Sensit. Iph>1: 50.00 mA
- 32.10: Z2 Ph. Reach: 3.750 Ohm
- 32.11: Z2 Ph. Angle: 85.00 deg
- 32.15: R2 Ph. Resistive: 49.80 Ohm
- 32.16: Z2 Tilt Top Line: 0 deg
- 32.17: Z2 Sensit. Iph>2: 50.00 mA
- 32.20: Z3 Ph. Reach: 6.250 Ohm
- 32.21: Z3 Ph. Angle: 85.00 deg
- 32.22: Z3' Ph Rev Reach: 6.250 Ohm
- 32.25: R3 Ph. Res. Fwd.: 62.25 Ohm
- 32.26: R3' Ph. Res. Rev: 62.25 Ohm
- 32.27: Z3 Tilt Top Line: 0 deg
- 32.28: Z3 Sensit. Iph>3: 50.00 mA
- 32.40: Z4 Ph. Reach: 630.0 mOhm
- 32.41: Z4 Ph. Angle: 85.00 deg
- 32.42: R4 Ph. Resistive: 62.25 Ohm
- 32.45: Z4 Tilt Top Line: -3.000 deg
- 32.46: Z4 Sensit. Iph>4: 50.00 mA
-  32.50: GROUND DISTANCE:
- 32.51: Z1 Gnd. Reach: 2.500 Ohm
- 32.52: Z1 Gnd. Angle: 85.00 deg
- 32.53: Z1 Dynamic Tilt: Disabled
- 32.54: Z1 Tilt Top Line: -3.000 deg
- 32.55: kZN1 Res. Comp.: 940.0e-3
- 32.56: kZN1 Res. Angle: 7.000 deg
- 32.59: R1 Gnd Resistive: 20.75 Ohm
- 32.5B: Z1 Sensit Ignd>1: 50.00 mA
- 32.60: Z2 Gnd. Reach: 3.750 Ohm
- 32.61: Z2 Gnd. Angle: 85.00 deg
- 32.63: Z2 Dynamic Tilt: Disabled
- 32.64: Z2 Tilt Top Line: -3.000 deg
- 32.65: kZN2 Res. Comp.: 940.0e-3
- 32.66: kZN2 Res. Angle: -4.000 deg
- 32.69: R2 Gnd Resistive: 41.50 Ohm
- 32.6B: Z2 Sensit Ignd>2: 50.00 mA
- 32.70: Z3 Gnd. Reach: 6.250 Ohm
- 32.71: Z3 Gnd. Angle: 85.00 deg
- 32.72: Z3' Gnd Rev Rch: 6.250 Ohm
- 32.73: Z3 Dynamic Tilt: Disabled



Settings File Report

Substation:

File: P546 remote.set

Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:40

..... 32.74: Z3 Tilt Top Line: -3.000 deg
..... 32.75: kZN3 Res. Comp.: 940.0e-3
..... 32.76: kZN3 Res. Angle: -4.000 deg
..... 32.79: R3 Gnd. Res. Fwd: 53.95 Ohm
..... 32.7A: R3' Gnd Res. Rev: 53.95 Ohm
..... 32.7C: Z3 Sensit Ignd>3: 50.00 mA
..... 32.90: Z4 Gnd. Reach: 630.0 mOhm
..... 32.91: Z4 Gnd. Angle: 85.00 deg
..... 32.93: Z4 Dynamic Tilt: Disabled
..... 32.94: Z4 Tilt Top Line: -3.000 deg
..... 32.95: kZN4 Res. Comp.: 940.0e-3
..... 32.96: kZN4 Res. Angle: -4.000 deg
..... 32.99: R4 Gnd Resistive: 53.95 Ohm
..... 32.9B: Z4 Sensit Ignd>4: 50.00 mA

..... GROUP 1 PHASE DIFF
..... 33.01: Phase Diff: Enabled
..... 33.06: Phase Is1: 250.0 mA
..... 33.07: Phase Is2: 2.000 A
..... 33.08: Phase k1: 30.00 %
..... 33.09: Phase k2: 150.0 %
..... 33.0A: Phase Char: DT
..... 33.0B: Phase Time Delay: 0 s
..... 33.0E: PIT Time: 200.0 ms
..... 33.0F: Ph CT Corr'tion: 3.000
..... 33.10: Compensation: Cap Charging
..... 33.11: Susceptance: 3.700 uS
..... 33.17: PIT I selection: Remote

..... GROUP 1 SCHEME LOGIC
..... 34.01: BASIC SCHEME:
..... 34.08: Zone1 Tripping: Phase And Ground
..... 34.09: tZ1 Ph. Delay: 0 s
..... 34.0A: tZ1 Gnd. Delay: 0 s
..... 34.10: Zone2 Tripping: Phase And Ground
..... 34.11: tZ2 Ph. Delay: 350.0 ms
..... 34.12: tZ2 Gnd. Delay: 350.0 ms
..... 34.18: Zone3 Tripping: Phase And Ground
..... 34.19: tZ3 Ph. Delay: 1.000 s
..... 34.1A: tZ3 Gnd. Delay: 1.000 s
..... 34.20: ZoneP Tripping: Disabled
..... 34.28: Zone4 Tripping: Phase And Ground
..... 34.29: tZ4 Ph. Delay: 350.0 ms
..... 34.2A: tZ4 Gnd. Delay: 350.0 ms
..... 34.40: AIDED SCHEME 1:
..... 34.41: Aid. 1 Selection: POR
..... 34.42: Aid 1 Distance: Phase And Ground
..... 34.43: Aid.1 Dist. Dly: 0 s
..... 34.44: Aid. 1 DEF: Disabled
..... 34.4A: tRev. Guard: 20.00 ms
..... 34.4C: Send On Trip: Aided / Z1
..... 34.50: Weak Infeed: Disabled
..... 34.60: AIDED SCHEME 2:
..... 34.61: Aid. 2 Selection: Disabled
..... 34.80: Trip On Close:
..... 34.81: SOTF Status: Enabled PoleDead +Pulse
..... 34.82: SOTF Delay: 110.0 s
..... 34.83: SOTF Tripping: 000010
..... 34.84: TOR Status: Enabled
..... 34.85: TOR Tripping: 000010
..... 34.86: TOC Reset Delay: 500.0 ms
..... 34.88: TOC Delay: 200.0 ms
..... 34.B0: Z1 Extension:
..... 34.B1: Z1 Ext Scheme: Disabled
..... 34.C0: Loss Of Load:
..... 34.C1: LOL Scheme: Disabled

..... GROUP 1 OVERCURRENT
..... 35.01: I>1 Status: Disabled



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

Printed on: 23/08/2024 18:47:40

- 35.0A: I>2 Status: Disabled
- 35.13: I>3 Status: Disabled
- 35.18: I>4 Status: Enabled
- 35.19: I>4 Directional: Non-Directional
- 35.1A: I>4 Current Set: 640.0 mA
- 35.1B: I>4 Time Delay: 50.00 ms
- 35.1C: I> Char Angle: 30.00 deg
- 35.1D: I> Blocking: 001111
- GROUP 1 BROKEN CONDUCTOR
 - 37.01: Broken Conductor: Enabled
 - 37.02: I2/I1 Setting: 200.0e-3
 - 37.03: I2/I1 Time Delay: 5.000 s
- GROUP 1 EARTH FAULT
 - 38.01: IN>1 Status: Enabled
 - 38.25: IN>1 Function: IEC S Inverse
 - 38.26: IN>1 Directional: Directional Fwd
 - 38.29: IN>1 Current Set: 80.00 mA
 - 38.2D: IN>1 TMS: 500.0e-3
 - 38.33: IN>1 tRESET: 0 s
 - 38.35: IN>2 Status: Disabled
 - 38.46: IN>3 Status: Disabled
 - 38.4D: IN>4 Status: Disabled
 - 38.54: IN> Blocking: 001111
 - 38.55: IN> DIRECTIONAL:
 - 38.56: IN> Char Angle: -45.00 deg
 - 38.57: IN> Polarisation: Zero Sequence
 - 38.59: IN> VNpol Set: 1.000 V
- GROUP 1 POWER SWING BLK.
 - 3D.01: PSB Status: Blocking
 - 3D.03: Zone 1 Ph. PSB: Blocking
 - 3D.05: Zone 2 Ph. PSB: Blocking
 - 3D.07: Zone 3 Ph. PSB: Blocking
 - 3D.09: Zone P Ph. PSB: Blocking
 - 3D.0B: Zone 4 Ph. PSB: Blocking
 - 3D.0D: Zone 1 Gnd. PSB: Blocking
 - 3D.0F: Zone 2 Gnd. PSB: Blocking
 - 3D.11: Zone 3 Gnd. PSB: Blocking
 - 3D.13: Zone P Gnd. PSB: Blocking
 - 3D.15: Zone 4 Gnd. PSB: Blocking
 - 3D.20: PSB Unblocking: Disabled
 - 3D.22: PSB Reset Delay: 200.0 ms
 - 3D.23: OST Mode: OST Trip
 - 3D.24: Z5: 7.500 Ohm
 - 3D.25: Z6: 8.250 Ohm
 - 3D.26: Z5': -7.500 Ohm
 - 3D.27: Z6': -8.250 Ohm
 - 3D.28: R5: 64.74 Ohm
 - 3D.29: R6: 71.21 Ohm
 - 3D.2A: R5': -64.74 Ohm
 - 3D.2B: R6': -71.21 Ohm
 - 3D.2C: Blinder Angle: 20.00 deg
 - 3D.2D: delta T: 40.00 ms
 - 3D.2E: Tost: 0 s
- GROUP 1 VOLT PROTECTION
 - 42.01: UNDER VOLTAGE:
 - 42.02: V< Measur't Mode: V<1 & V<2 Ph-N
 - 42.03: V< Operate Mode: V<1 & V<2 Any Ph
 - 42.04: V<1 Function: DT
 - 42.05: V<1 Voltage Set: 57.00 V
 - 42.06: V<1 Time Delay: 0 s
 - 42.08: V<1 Poledead Inh: Enabled
 - 42.09: V<2 Status: Disabled
 - 42.0D: OVERVOLTAGE:
 - 42.0E: V> Measur't Mode: V>1 & V>2 Ph-N
 - 42.0F: V> Operate Mode: V>1 & V>2 Any Ph
 - 42.10: V>1 Function: DT

UNDER VOLATGE - ONLY DR TRIGGERING
NO CB TRIP



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K


Printed on: 23/08/2024 18:47:40

- 42.11: V>1 Voltage Set: 70.01 V
- 42.12: V>1 Time Delay: 5.000 s
- 42.14: V>2 Status: Enabled
- 42.15: V>2 Voltage Set: 89.01 V
- 42.16: V>2 Time Delay: 100.0 ms
- GROUP 1 CB FAIL & P.DEAD
- 45.0A: UNDER CURRENT:
- 45.0B: I< Current Set: 50.00 mA
- 45.0D: ISEF< Current: 20.00 mA
- 45.0E: POLEDEAD VOLTAGE:
- 45.10: V<: 38.11 V
- GROUP 1 SUPERVISION
- 46.01: VTS Mode: Measured + MCB
- 46.02: VTS Status: Blocking
- 46.03: VTS Reset Mode: Auto
- 46.04: VTS Time Delay: 5.000 s
- 46.05: VTS I> Inhibit: 10.00 A
- 46.06: VTS I2> Inhibit: 50.00 mA
- 46.0E: INRUSH DETECTION:
- 46.0F: I>2nd Harmonic: 20.00 %
- 46.10: WEAK INFEEED BLK:
- 46.11: WI Inhibit: Enabled
- 46.12: I0/I2 Setting: 3.000
- 46.30: CT SUPERVISION:
- 46.31: CTS Mode: Disabled
- GROUP 1 INPUT LABELS
- 4A.01: Opto Input 1: Input L1
- 4A.02: Opto Input 2: Input L2
- 4A.03: Opto Input 3: Input L3
- 4A.04: Opto Input 4: Input L4
- 4A.05: Opto Input 5: Input L5
- 4A.06: Opto Input 6: Input L6
- 4A.07: Opto Input 7: Input L7
- 4A.08: Opto Input 8: Input L8
- 4A.09: Opto Input 9: Input L9
- 4A.0A: Opto Input 10: Input L10
- 4A.0B: Opto Input 11: Input L11
- 4A.0C: Opto Input 12: Input L12
- 4A.0D: Opto Input 13: Input L13
- 4A.0E: Opto Input 14: Input L14
- 4A.0F: Opto Input 15: Input L15
- 4A.10: Opto Input 16: Input L16
- 4A.11: Opto Input 17: Input L17
- 4A.12: Opto Input 18: Input L18
- 4A.13: Opto Input 19: Input L19
- 4A.14: Opto Input 20: Input L20
- 4A.15: Opto Input 21: Input L21
- 4A.16: Opto Input 22: Input L22
- 4A.17: Opto Input 23: Input L23
- 4A.18: Opto Input 24: Input L24
- GROUP 1 OUTPUT LABELS
- 4B.01: Relay 1: Output R1
- 4B.02: Relay 2: Output R2
- 4B.03: Relay 3: Output R3
- 4B.04: Relay 4: Output R4
- 4B.05: Relay 5: Output R5
- 4B.06: Relay 6: Output R6
- 4B.07: Relay 7: Output R7
- 4B.08: Relay 8: Output R8
- 4B.09: Relay 9: Output R9
- 4B.0A: Relay 10: Output R10
- 4B.0B: Relay 11: Output R11
- 4B.0C: Relay 12: Output R12
- 4B.0D: Relay 13: Output R13
- 4B.0E: Relay 14: Output R14
- 4B.0F: Relay 15: Output R15



Settings File Report
Substation:
File: P546 remote.set
Model Number: P546?1109?552?K

-
- 4B.10: Relay 16: Output R16
 - 4B.11: Relay 17: Output R17
 - 4B.12: Relay 18: Output R18
 - 4B.13: Relay 19: Output R19
 - 4B.14: Relay 20: Output R20
 - 4B.15: Relay 21: Output R21
 - 4B.16: Relay 22: Output R22
 - 4B.17: Relay 23: Output R23
 - 4B.18: Relay 24: Output R24

		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0

General Data

Network Details

Voltage	=	400		kV
Frequency	=	50		Hz
System X/R Ratio	=	40		
Fault Current	=	10500		A

Local End Bay Details

Station Name	=	400kV BHADLA SUBSTATION
Object Name	=	400 KV LINE CONTROL AND RELAY PANEL
Object Number	=	-

Relay Type	=	7SL87
------------	---	-------

CT Primary current (Adopted)	=	3000	A
CT Secondary current	=	1	A

Protected Line details


<u>Line details</u>				
Line length	=	12.00		km
Rated current capacity	=	953		A
Positive sequence imp. per km	=	0.0266	+j 0.313	Ohm/km
Zero sequence imp. per km	=	0.168	+j 1.187	Ohm/km

Short Line Feeder Details at Remote Station

Remote end station name	=	-		
Length of the line	=	0		Km
Positive sequence imp. per km	=	0.000	+j 0.000	Ohm/Km
Zero sequence imp. per km	=	0.000	+j 0.000	Ohm/Km

Longest Line Feeder Details at Remote Station

Remote end station name	=	-		
Length of the line	=	0.00		Km
Positive sequence imp. per km	=	0.000	+j 0.000	Ohm/Km
Zero sequence imp. per km	=	0.000	+j 0.000	Ohm/Km

 PGGA-2875		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0

CALCULATION FOR DIFFERENTIAL FUNCTION :

If the charging current compensation is ON, the pickup value I-DIFF> can be set equal I_{charge} . Thus the residual error of the charging current compensation is considered. Without charging current compensation, this pickup value must be set to a value that is higher than the total steady-state charging current of the protected object

Charging Current Calculation:

The charging current is calculated according to the following equation,

Where,

$$I_{charge} : U / (\sqrt{3} * Xc1)$$

U : System Line Voltage
 $Xc1$: Positive Sequence Line Capacitive reactance value
 I_{charge} : Line charging current/kM due to Line Capacitance
 $Xc1$: $1 / (2 * \pi * f * C1)$
 $C1$: Line Capacitance value/kM
 $Xc1$: $1 / (2 * \pi * f * C1)$
 $Xc1$: $1 / (2 * 3.14 * 50 * 0.0000000119)$
: 267622.97 Ω

$$I_{charge} : U / (\sqrt{3} * Xc1)$$

$$I_{charge} : 400000 / (\sqrt{3} * 267622.97)$$

$$I_{charge} : 0.86 \text{ A}$$

Total Primary Charging Current : $0.86 * 12$
: 10.32 A

Total Sec.Charging Current, I_c : I_{charge} / CTR
: $10.32 / 3000$
: 0.00344 A

I-DIFF:Threshold:

Considering the variations of voltage and frequency, the set value should be at least 2 to 3 times higher than the calculated charging current or 20% of the rated current of the line whichever is greater.

$$3 \text{ times of } : 3 * I_c$$

$$: 0.01032 \text{ A}$$

I-DIFF:Threshold : 0.25 A (As per comments)

I-DIFF Switch-on:

A setting to three to four times the steady-state charging current usually ensures the stability of the protection during switch-on of the line.

$$I-DIFF:Threshold \text{ Switch On} : 0.30 \text{ A}$$

I-DIFF Fast :


As per the relay Recommendation, set the pickup value is 1.0 times to 2 times of Rated Current

$$\text{Rated current} : 952.66 \text{ A}$$

$$: 2 * 952.66$$

$$: 1905.32 \text{ A}$$

Therefore, as seen by the CT : 0.64 A

 PGGA-2875		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0

I-DIFF fast:Threshold : 1 A

I-DIFF fast Switch on :


I-DIFF fast SWITCHON should be 2 to 3 times the setting value of I-DIFF fast

I-DIFF fast:Threshold Switch : 2*1
: 2.00 A

The below mentioned setting recommended,


I-DIFF:Threshold : 0.25 A
I-DIFF:Threshold Switch On : 0.30 A
I-DIFF:Operate delay : 0.00 Sec
Ic-compensat.:Mode : ON
Ic-stabilization/Ic-rated : 1.00
I-DIFF fast:Threshold : 2 A
I-DIFF fast:Threshold Switch On : 3.82 A
INRUSH REST. : On

CT ratio correction: _:9001:101 Rated current to be same at both end of the line to compensate CT ratio



[Image: 150111-01-08_1_en_123]

Figure 6-13 Operate Curve of the Differential Protection

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0

CALCULATION FOR DISTANCE FUNCTION : QUADRILATERAL

Zone Reach Details

Zone 1	:	80%	of the protected Line
Zone 2	:	120% 0%	of the protected Line + of the shortest adjacent Line)
Zone 3	:	200% 0%	of the protected Line + of Remote end Longest Line
Zone 4	:	20%	of the protected L (Reverse Zone)
Zone 1B	:	Setting same as Zone-2	
VT Ratio	:	400x1000 / 110 3636	
CT Ratio	:	3000 / 1 3000	

Transformation Ratio	N	:	CT Ratio / VT Ratio 3000/3636 0.825
----------------------	---	---	---

Calculated Sec Impedance Z_{sec}	:	N x Z_{prim} in ohm
Z_{prim}	:	Primary Impedance in ohm

Protected Line:


Line Length	:	12.00 km
Line Total +VE Seq Impedance	:	$(R_1 + j X_1)$ 0.319 +j 3.75 3.764 L85.14
Line Total Zero Seq Impedance	:	$(R_0 + j X_0)$ 2.012 +j 14.244 14.385 L81.96


Zero Sequence Compensation Factor:


Resistance Ratio	Kr	:	$1/3((R_0/R_1)-1)$ 1.769
Reactance Ratio	Kx	:	$1/3((X_0/X_1)-1)$ 0.933

Line Angle Setting	Tan ϕ	:	X_L/R_L X_1/R_1
	ϕ	:	85.14 deg

Earth Impedance Compensation K_0 Factor.	K_0	:	Z_E / Z_L $1/3 ((Z_0/Z_1)-1)$
	Z_1	:	Positive sequence Impedance of the Line
	Z_0	:	Zero sequence Impedance of the Line

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0
		Z_0 / Z_1	: 3.822	L -3.18
			: 3.816	+j -j0.212
		$1/3 ((Z_0/Z_1)-1)$: $1/3(3.82+j-0.212-1)$	
			: 0.942 L-4.32	
		K_0	: 0.94	
		ϕ_0	: -4.32 deg	
Load Impedance and Load Angle Calculation:				
Rated Current			: 952.66 A	
At worst case, the maximum load current of the transmission line has been considered slightly higher than nominal loading (120%) to cover emergency loading of the protected line in case of heavy load flow.				
Maximum Load Current (Imax)			: 1143.00 A	(120% of Load current)
Minimum Operating Voltage			: 85% of rated voltage	
			: $0.85 * 400000$	
			: 340000 V	
Load Impedance R_{Load}			: $U_{min} / \sqrt{3} \times I_{max}$	
			: $340000 / \sqrt{3} \times 1143$	
R_{Load}	Primary		: 171.740 ohm	
R_{Load}	Secondary		: 171.74×0.825	
			: 141.69 ohm	
The largest angle of the load impedance is given by the worst, smallest power factor. Hence,				
Minimum Power Factor		$\text{Cos}\phi_{min}$: 0.850	(Assumed)
		ϕ_{min}	: 32 deg	
Set Load Angle			: $\phi_{min} + 5$	
			: 32 + 5	
			: 37 deg	
To avoid load enchroachment for the phase-phase measuring elements, the set resistive reach of any distance protection zone should not exceed 60% of the R_{load} .				
60.00% of R_{load}			: $0.6 * 141.69$	
			: 85.01 Ω	
To avoid load enchroachment for the phase-earth measuring elements, the set resistive reach of any distance protection zone should not exceed 80% of the R_{load} .				
80.00% of R_{load}			: $0.8 * 141.69$	
			: 113.35 Ω	
Arc Resistance :				
Arc Resistance for Ph-Ph fault (Pri)			: 5.000 Ω	(Assumed)
Arc Resistance for Ph-Ph fault (Sec)			: $5 * 0.825$	
Rarc (Ph-Ph)			: 2.230 Ω	
Arc Resistance for PH-E fault (Pri)			: 3.000 Ω	(Assumed)
Arc Resistance for PH-E fault (Sec)			: $3 * 0.825$	
Rarc (Ph-E)			: 1.437 Ω	

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0
Tower Footing Resistance (Pri) : 10.000 Ω (Assumed)				
R _{TF} (Sec) : 8.250 Ω				
Zone 1 Reach Values:				
Reactance, X reach (Z1) : 80% x X1 x N				
: 0.8*3.75*0.825				
: 2.475 ohm				
Resistance Ph-Ph fault, R(Z1) : 80% x R1 x N + Rarc (Ph-Ph)/2				
: (0.8*0.319*0.825)+2.23/2				
: 1.326 ohm				
Now, for Earth arc resistance shall include tower footing resistance				
Resistance Ph-E fault, RE(Z1) : 80% * R1* N + Rarc(ph-E) + R _T				
: (0.8*0.319*0.825)+(1.437+8.25)				
: 9.898 ohm				
Zone 2 Reach Values				
Reactance, X reach (Z2) : 120% x X1 x N				
: 1.2*3.75*0.825				
: 3.713 ohm				
Resistance Ph-Ph fault, R(Z2) : 120% x R1 x N + Rarc (Ph-Ph)/2				
: (1.2*0.319*0.825)+2.23/2				
: 1.431 ohm				
Now, for Earth arc resistance shall include tower footing resistance				
Resistance Ph-E fault, RE(Z2) : 120% * R1* N + Rarc(ph-E) + R _T				
: (1.2*0.319*0.825)+(1.437+8.25)				
: 10.003 ohm				
Zone 3 Reach Values				
Reactance, X(Z3) : 200% of X1 Protection Line +				
0% of X1 Remote end Longest Line x N				
: ((2*3.75)+(0*0))*0.825				
: 6.188 ohm				
Resistance Ph-Ph fault, R(Z3) : 200(% of R1 Protected Line + 0% of R1 of Remote end				
Longest Line) x N + Rarc (Ph-Ph)/2				
: ((2*0.319)+(0*0))*0.825+(2.23/2)				
: 1.641 ohm				
Now, for Earth arc resistance shall include tower footing resistance				
Resistance Ph-E fault, RE(Z3) : 200(% of R1 Protected Line + 0% of R1 of Remote end				
Longest Line) x N + Rarc (Ph-E) + R _T				
: ((2*0.319)+(0*0))*0.825+(1.437+8.25)				
: 10.213 ohm				
Zone -4 Setting:(Reverse Reach)				
Reactance, X(Z4) : 20% x X1 x N				

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0

$0.2 \times 3.75 \times 0.825$
 $: 0.619 \text{ ohm}$
 Resistance Ph-Ph fault, R(Z4) : 20% $\times R1 \times N + R_{arc} (\text{Ph-Ph})/2$
 $: (0.2 \times 0.319 \times 0.825) + 2.23/2$
 $: 1.168 \text{ ohm}$

Now, for Earth arc resistance shall include tower footing resistance
 Resistance Ph-E fault, RE(Z4) : 20% $\times R1 \times N + R_{arc}(\text{ph-E}) + R_T$
 $: (0.2 \times 0.319 \times 0.825) + (1.437 + 8.25)$
 $: 9.740 \text{ ohm}$

Zone-1B Setting:

Set Zone-1B settings equal to Zone-2 value

Zone Timer setting:

ZONE 1- t1 PP : 0.00 sec
 ZONE 1- t1 PE : 0.00 sec
 ZONE 2- t1 PP : 0.35 sec
 ZONE 2- t1 PE : 0.35 sec
 ZONE 3- t1 PP : 1.00 sec
 ZONE 3- t1 PE : 1.00 sec
 ZONE 4- t1 PP : 0.35 sec
 ZONE 4- t1 PE : 0.35 sec
 ZONE 1B-t1 PP : 0.00 sec
 ZONE 1B-t1 PE : 0.00 sec

Load Cutout

Z < Blinder Imp (90% of LR) : 102.0 Ohm
 Load/B Angle : 37.0 Deg

TELEPROTECTION FOR DISTANCE:

The relay shall work in Permissive Over Reach(POTT) mode with the following settings:

Send with : Distance prot. Z1
 Operate with : Distance prot. Z2
 Send prolongation : 0.05 Sec
 Send delay : 0.00 Sec
 1-pole operate allowed : Yes
 Operate delay : 0.00 sec

POWER SWING:

Power swing operating mode : All zones block
 Max.Blocking Time : 2 Sec


50HS INSTANTANEOUS SOTF:

SOTF to be enabled for Zone-2, Zone-3

Operate delay : 0 sec

STUB PROTECTION:

The threshold value must be higher than the maximum operational current to be expected, in order to avoid pickup without fault. Grading time above the base time of the main protection is usually sufficient.

 Hitachi Energy		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400 KV LINE CONTROL AND RELAY PANEL	Date	02-08-2024
Prep.	SS	400kV BHADLA SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	DISTANCE PROTECTION - 7SL87	Rev No.	0

Threshold : 0.6 A
Operate delay : 0.04 msec

FUSE FAIL MONITORING:

Asym.fail.DO on netw.ftt : no
Asym.fail.time delay : 5 sec
3ph fail-phs.curr.release : 0.1 A
3ph fail-phs.curr.jump : 0.1 A
3ph fail-VA,VB,VC < : 5 V
Switch-on 3ph.failure : on
SO 3ph.fail-time delay : 5 sec

DIR. EARTH FAULT SETTINGS :

The pickup characteristics should be more than the standing unbalance current as seen by the system and the CT's.

1Ph Fault Current : 10500 A
IN> Pickup current in A : 7.50% of rated current
: 0.075*3000=225A
IN> Current Set (Is) : 0.08 A
Minimum setting available in Relay : 0.08 A

The Earth fault function has to be graded with the Zone-3 Protection

Zone-3 operating time : 1.00 Sec
Grading margin : 0.13 Sec
Required time (Treq) : 1.13 Sec
Note: The IDMT curve shall saturate if the fault current more than 20 times of pickup current. 20 times of set current considered for TMS calculation.
Fault Current considered : 4500 A
51 Time Dial : $(Treq * (IF/Is)^{0.02-1}) / 0.14$
: $(1.13 * (4500/225)^{0.02-1}) / 0.14$
: 0.5

BROKEN CONDUCTOR

A broken wire of the protected line or in the current transformer secondary circuit can be detected, if the minimum current PoleOpenCurrent flows via the feeder. If the minimum phase current is below this limit while the other phase currents are above this limit, an interruption of this conductor may be assumed. If current asymmetry is also detected (see margin heading "Current Symmetry"), the device issues the message Fail Conductor (No. 195).

OVERVOLTAGE PROTECTION: 59

Measuring value : phase-neutral
Definite-T 1:Threshold : 69.9 V 110% of Rated voltage
Definite-T 1:Operate delay : 5 sec
Definite-T 2:Threshold : 88.9 V 140% of Rated voltage
Definite-T 2:Operate delay : 0.1 sec

Power system**General**

Number	Settings	Value
11.2311.101	Phase sequence	All: ABC

Meas.point I-3ph 1**CT 3-phase \General**

Number	Settings	Value
11.931.8881.115	CT connection	All: 3-phase
11.931.8881.127	Tracking	All: active
11.931.8881.130	Measuring-point ID	All: 1

CT 3-phase \CT phases

Number	Settings	Value
11.931.8881.101	Rated primary current	All: 3000 A
11.931.8881.102	Rated secondary current	All: 1 A
11.931.8881.117	Current range	All: 100 x IR
11.931.8881.118	Internal CT type	All: CT protection
11.931.8881.116	Neutr.point in dir.of ref.obj	All: yes
11.931.8881.114	Inverted phases	All: none
11.931.8881.107	CT error changeover	All: 1.5
11.931.8881.108	CT error A	All: 5 %
11.931.8881.109	CT error B	All: 15 %

CT 3-phase \MP disconnection

Number	Settings	Value
11.931.8881.173	Current check	All: active
11.931.8881.112	I< threshold	All: 0.10 A

CT 1

Number	Settings	Value
11.931.3841.103	Magnitude correction	All: 1
11.931.3841.117	Phase	All: I A

CT 2

Number	Settings	Value
11.931.3842.103	Magnitude correction	All: 1
11.931.3842.117	Phase	All: I B

CT 3

Number	Settings	Value
11.931.3843.103	Magnitude correction	All: 1
11.931.3843.117	Phase	All: I C

Brk.wire det.

Number	Settings	Value
11.931.5581.1	Mode	All: off
11.931.5581.101	Mode of blocking	All: blocking

Supv. balan. I

Number	Settings	Value
11.931.2491.1	Mode	Settings group 1: on
11.931.2491.101	Release threshold	Settings group 1: 0.50 A
11.931.2491.102	Threshold min/max	Settings group 1: 0.5
11.931.2491.6	Delay failure indication	Settings group 1: 5 s

Supv. ph.seq.I

Number	Settings	Value
11.931.2551.1	Mode	Settings group 1: on
11.931.2551.6	Delay failure indication	Settings group 1: 5 s
11.931.2551.102	Release threshold	Settings group 1: 0.50 A

Saturat. det.

Number	Settings	Value
11.931.17731.101	CT saturation threshold	Settings group 1: 8.00 A

Meas.point V-3ph 1**VT 3-phase**

Number	Settings	Value
11.941.8911.101	Rated primary voltage	All: 400.000 kV
11.941.8911.102	Rated secondary voltage	All: 110 V
11.941.8911.104	VT connection	All: 3 ph-to-gnd voltages
11.941.8911.106	Inverted phases	All: none
11.941.8911.111	Tracking	All: active
11.941.8911.130	Measuring-point ID	All: 2
11.941.8911.136	Internal VT type	All: Voltage transformer

VT 1

Number	Settings	Value
11.941.3811.103	Magnitude correction	All: 1
11.941.3811.108	Phase	All: V A

VT 2

Number	Settings	Value
11.941.3812.103	Magnitude correction	All: 1
11.941.3812.108	Phase	All: V B

VT 3

Number	Settings	Value
11.941.3813.103	Magnitude correction	All: 1
11.941.3813.108	Phase	All: V C

Supv. balan. V

Number	Settings	Value
11.941.2521.1	Mode	Settings group 1: on
11.941.2521.101	Release threshold	Settings group 1: 55.0 V
11.941.2521.102	Threshold min/max	Settings group 1: 0.75
11.941.2521.6	Delay failure indication	Settings group 1: 5 s

Supv. ph.seq.V

Number	Settings	Value
11.941.2581.1	Mode	Settings group 1: on
11.941.2581.6	Delay failure indication	Settings group 1: 5 s

Supv. sum V

Number	Settings	Value
11.941.2461.1	Mode	Settings group 1: off
11.941.2461.3	Threshold	Settings group 1: 27.5 V
11.941.2461.6	Delay failure indication	Settings group 1: 5 s

VT miniatureCB

Number	Settings	Value
11.941.2641.101	Response time	Settings group 1: 0 s

Meas.point I-1ph 1**General**

Number	Settings	Value
11.951.2311.101	Rated primary current	All: 3000 A
11.951.2311.102	Rated secondary current	All: 1 A
11.951.2311.103	Current range	All: 100 x IR
11.951.2311.104	Internal CT type	All: CT protection
11.951.2311.116	Term. 1,3,5,7 in dir. of obj.	All: yes
11.951.2311.105	Tracking	All: inactive
11.951.2311.130	Measuring-point ID	All: 3

CT 1

Number	Settings	Value
11.951.3841.103	Magnitude correction	All: 1
11.951.3841.117	Phase	All: Ix

Meas.point V-1ph 1**General**

Number	Settings	Value
11.961.2311.101	Rated primary voltage	All: 400 kV
11.961.2311.102	Rated secondary voltage	All: 100 V 110V
11.961.2311.103	Tracking	All: inactive

Number	Settings	Value
11.961.2311.130	Measuring-point ID	All: 4

VT 1

Number	Settings	Value
11.961.3811.103	Magnitude correction	All: 1
11.961.3811.108	Phase	All: V B

VT miniatureCB

Number	Settings	Value
11.961.2641.101	Response time	Settings group 1: 0 s

*Setting marked as favorite setting

sp Setting marked as specific setting

Line 1

General \Rated values

Number	Settings	Value
21.9001.101	Rated current	All: 3000 A
21.9001.102	Rated voltage	All: 400.00 kV
21.9001.103	Rated apparent power	All: 693.0 MVA

General \Line data

Number	Settings	Value
21.9001.149	Neutral point	Settings group 1: grounded
21.9001.112	C1 per length unit	Settings group 1: 0.0119 $\mu\text{F}/\text{km}$
21.9001.148	C0 per length unit	Settings group 1: 0.0119 $\mu\text{F}/\text{km}$
21.9001.113	X per length unit	Settings group 1: 0.313 Ω/km
21.9001.114	Line length	Settings group 1: 12 km
21.9001.108	Line angle	Settings group 1: 85 °
21.9001.104	Kr	Settings group 1: 1.77
21.9001.105	Kx	Settings group 1: 0.93
21.9001.106	KmR	Settings group 1: 0
21.9001.107	KmX	Settings group 1: 0
21.9001.109	Gnd.curr.ratio(MutComp)	Settings group 1: 95 %
21.9001.119	CT saturation detection	All: no
21.9001.111	Series compensation	Settings group 1: no
21.9001.110	Series capacit. reactance	Settings group 1: 0 Ω

General \Measurements

Number	Settings	Value
21.9001.158	P, Q sign	Settings group 1: not reversed

Process monitor

Closure detec.

Number	Settings	Value
21.1131.4681.101	Operating mode	Settings group 1: Manual close only
21.1131.4681.102	Action time after closure	Settings group 1: 0.5 s
21.1131.4681.103	Min. time feeder open	Settings group 1: 0.3 s

1pol.open det.

Number	Settings	Value
21.1131.4711.101	Operating mode	Settings group 1: with measurement

Volt.criterion

Number	Settings	Value
21.1131.4801.101	Threshold U open	Settings group 1: 18.15 V

Fault locator

Number	Settings	Value
21.8671.1	Mode	Settings group 1: on
21.8671.101	Start	Settings group 1: with going pickup
21.8671.102	Parallel-line compensat.	Settings group 1: no
21.8671.103	Load compensation	All: no

Mes.v.fail.det

Number	Settings	Value
21.2671.1	Mode	Settings group 1: on
21.2671.115	Asym.fail.-DO on netw.flt.	Settings group 1: yes
21.2671.113	Asym.fail. - time delay	Settings group 1: 5 s
21.2671.102	3ph.fail. - phs.curr.release	Settings group 1: 0.03 A
21.2671.103	3ph.fail. - phs.curr. jump	Settings group 1: 0.03 A
21.2671.101	3ph.fail. - VA,VB,VC <	Settings group 1: 3.025 V
21.2671.107	Switch-on 3ph. failure	All: on
21.2671.106	SO 3ph.fail. - time delay	Settings group 1: 0.5 s

50/51 OC-3ph-A1

General

Number	Settings	Value
21.201.2311.101	Emergency mode	Settings group 1: no

Definite-T 1 \General

Number	Settings	Value
21.201.661.1	Mode	Settings group 1: off

Number	Settings	Value
21.201.661.2	Operate & flt.rec. blocked	Settings group 1: no
21.201.661.11	1-pole operate allowed	Settings group 1: no
21.201.661.26	Dynamic settings	All: no
21.201.661.8	Method of measurement	Settings group 1: fundamental comp.
21.201.661.3	Threshold	Settings group 1: 1.067 A
21.201.661.4	Dropout ratio	Settings group 1: 0.95
21.201.661.102	Pickup delay	Settings group 1: 0 s
21.201.661.101	Dropout delay	Settings group 1: 0 s
21.201.661.6	Operate delay	Settings group 1: 0.3 s
21.201.661.7	Operate delay mode	Settings group 1: Running dur. DO-delay

Definite-T 2 \General		
Number	Settings	Value
21.201.662.1	Mode	Settings group 1: off
21.201.662.2	Operate & flt.rec. blocked	Settings group 1: no
21.201.662.11	1-pole operate allowed	Settings group 1: yes
21.201.662.26	Dynamic settings	All: no
21.201.662.8	Method of measurement	Settings group 1: fundamental comp.
21.201.662.3	Threshold	Settings group 1: 0.667 A
21.201.662.4	Dropout ratio	Settings group 1: 0.95
21.201.662.102	Pickup delay	Settings group 1: 0 s
21.201.662.101	Dropout delay	Settings group 1: 0 s
21.201.662.6	Operate delay	Settings group 1: 0.1 s
21.201.662.7	Operate delay mode	Settings group 1: Running dur. DO-delay

50N/51N OC-gnd-A1

General		
Number	Settings	Value
21.211.2311.101	Emergency mode	Settings group 1: caused by main prot.
21.211.2311.9	Measured value	All: 3I0 calculated

Definite-T 1 \General		
Number	Settings	Value
21.211.751.1	Mode	Settings group 1: off
21.211.751.2	Operate & flt.rec. blocked	Settings group 1: no
21.211.751.26	Dynamic settings	All: no
21.211.751.102	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.211.751.8	Method of measurement	Settings group 1: fundamental comp.
21.211.751.3	Threshold	Settings group 1: 0.711 A
21.211.751.4	Dropout ratio	Settings group 1: 0.95
21.211.751.101	Dropout delay	Settings group 1: 0 s
21.211.751.6	Operate delay	Settings group 1: 0.3 s
21.211.751.7	Operate delay mode	Settings group 1: Running dur. DO-delay

Definite-T 2 \General		
Number	Settings	Value
21.211.752.1	Mode	Settings group 1: off
21.211.752.2	Operate & flt.rec. blocked	Settings group 1: no
21.211.752.26	Dynamic settings	All: no
21.211.752.102	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.211.752.8	Method of measurement	Settings group 1: fundamental comp.
21.211.752.3	Threshold	Settings group 1: 0.40 A
21.211.752.4	Dropout ratio	Settings group 1: 0.95
21.211.752.101	Dropout delay	Settings group 1: 0 s
21.211.752.6	Operate delay	Settings group 1: 0.3 s
21.211.752.7	Operate delay mode	Settings group 1: Running dur. DO-delay

67N GFP gnd.sys.1

General		
Number	Settings	Value
21.1111.2311.114	Direct. determination with	All: V0 + IY (neutral pt.)
21.1111.2311.101	Angle forward α	Settings group 1: 315 °
21.1111.2311.102	Angle forward β	Settings group 1: 135 °
21.1111.2311.103	Min. zero-seq. voltage V0	Settings group 1: 0.919 V
21.1111.2311.115	Dir.reslt=forw.at V0<min	Settings group 1: no
21.1111.2311.104	Min.3I0 f.increas.dir.sens.	Settings group 1: 0.03 A
21.1111.2311.116	Dir.corr.at ser.comp.lines	Settings group 1: no

Definite-T 1 \Blocking by		
Number	Settings	Value
21.1111.4861.140	21 Distance prot. 1.Z 1	true
21.1111.4861.140	21 Distance prot. 1.Z 2	true
21.1111.4861.140	21 Distance prot. 1.Z 3	true
21.1111.4861.140	21 Distance prot. 1.Z 4	false
21.1111.4861.140	87 Line diff. prot..Group indicat.	false

Totally Integrated Automation Portal		
--------------------------------------	--	--

Number	Settings	Value
21.1111.4861.140	87 Stub diff. prot. 1.Group indicat.	false

Definite-T 1 \General

Number	Settings	Value
21.1111.4861.1	Mode	Settings group 1: off
21.1111.4861.2	Operate & flt.rec. blocked	Settings group 1: no
21.1111.4861.114	Directional mode	Settings group 1: forward
21.1111.4861.11	1-pole operate allowed	Settings group 1: no
21.1111.4861.8	Method of measurement	Settings group 1: 1-cycle filter
21.1111.4861.131	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.1111.4861.130	Blocking by prot. pickup	Settings group 1: every pickup
21.1111.4861.129	Op.mode at 1p dead time	Settings group 1: blocked
21.1111.4861.112	Hold mode 1p dead time	Settings group 1: 0.04 s
21.1111.4861.115	Dynamic settings	All: no
21.1111.4861.111	Stabiliz. w. phase current	Settings group 1: 10 %
21.1111.4861.3	Threshold	Settings group 1: 0.107 A
21.1111.4861.6	Operate delay	Settings group 1: 1 s

Definite-T 2 \Blocking by

Number	Settings	Value
21.1111.4862.140	21 Distance prot. 1.Z 1	true
21.1111.4862.140	21 Distance prot. 1.Z 2	true
21.1111.4862.140	21 Distance prot. 1.Z 3	true
21.1111.4862.140	21 Distance prot. 1.Z 4	true
21.1111.4862.140	87 Line diff. prot..Group indicat.	false
21.1111.4862.140	87 Stub diff. prot. 1.Group indicat.	false

Definite-T 2 \General

Number	Settings	Value
21.1111.4862.1	Mode	Settings group 1: off
21.1111.4862.2	Operate & flt.rec. blocked	Settings group 1: no
21.1111.4862.114	Directional mode	Settings group 1: forward
21.1111.4862.11	1-pole operate allowed	Settings group 1: no
21.1111.4862.8	Method of measurement	Settings group 1: 1-cycle filter
21.1111.4862.131	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.1111.4862.130	Blocking by prot. pickup	Settings group 1: every pickup
21.1111.4862.129	Op.mode at 1p dead time	Settings group 1: blocked
21.1111.4862.112	Hold mode 1p dead time	Settings group 1: 1.5 s
21.1111.4862.115	Dynamic settings	All: no
21.1111.4862.111	Stabiliz. w. phase current	Settings group 1: 10 %
21.1111.4862.3	Threshold	Settings group 1: 0.107 A
21.1111.4862.6	Operate delay	Settings group 1: 1 s

Inverse-T 1 \Blocking by

Number	Settings	Value
21.1111.4891.140	21 Distance prot. 1.Z 1	true
21.1111.4891.140	21 Distance prot. 1.Z 2	true
21.1111.4891.140	21 Distance prot. 1.Z 3	true
21.1111.4891.140	21 Distance prot. 1.Z 4	true
21.1111.4891.140	87 Line diff. prot..Group indicat.	false
21.1111.4891.140	87 Stub diff. prot. 1.Group indicat.	false

Inverse-T 1 \General

Number	Settings	Value
21.1111.4891.1	Mode	Settings group 1: on
21.1111.4891.2	Operate & flt.rec. blocked	Settings group 1: no
21.1111.4891.115	Directional mode	Settings group 1: forward
21.1111.4891.11	1-pole operate allowed	Settings group 1: no
21.1111.4891.8	Method of measurement	Settings group 1: 1-cycle filter
21.1111.4891.135	Blk. w. 2nd harm. gnd. det.	Settings group 1: no
21.1111.4891.131	Blocking by prot. pickup	Settings group 1: every pickup
21.1111.4891.130	Op.mode at 1p dead time	Settings group 1: directional forward
21.1111.4891.113	Hold mode 1p dead time	Settings group 1: 0.04 s
21.1111.4891.116	Dynamic settings	All: no
21.1111.4891.112	Stabiliz. w. phase current	Settings group 1: 10 %
21.1111.4891.3	Threshold	Settings group 1: 0.077 A
21.1111.4891.133	Type of character. curve	Settings group 1: IEC normal inverse
21.1111.4891.106	Time dial	Settings group 1: 0.5
21.1111.4891.132	Additional time delay	Settings group 1: 0 s
21.1111.4891.134	Reset	Settings group 1: instantaneous

67 Dir.OC-3ph-A1

General		
Number	Settings	Value
21.1461.2311.101	Emergency mode	Settings group 1: no
21.1461.2311.102	Rotation angle of ref. volt.	Settings group 1: 45 °

Definite-T 1 \General

Number	Settings	Value
21.1461.8131.1	Mode	Settings group 1: off
21.1461.8131.2	Operate & flt.rec. blocked	Settings group 1: no
21.1461.8131.105	Directional mode	Settings group 1: forward
21.1461.8131.8	Method of measurement	Settings group 1: fundamental comp.
21.1461.8131.107	Non-directional pickup	Settings group 1: no
21.1461.8131.104	Directional comparison	Settings group 1: yes
21.1461.8131.106	Release via input signal	Settings group 1: no
21.1461.8131.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.1461.8131.26	Dynamic settings	All: no
21.1461.8131.3	Threshold	Settings group 1: 0.64 A
21.1461.8131.4	Dropout ratio	Settings group 1: 0.95
21.1461.8131.101	Dropout delay	Settings group 1: 0 s
21.1461.8131.6	Operate delay	Settings group 1: 0.3 s

Definite-T 2 \General

Number	Settings	Value
21.1461.8132.1	Mode	Settings group 1: off
21.1461.8132.2	Operate & flt.rec. blocked	Settings group 1: no
21.1461.8132.105	Directional mode	Settings group 1: forward
21.1461.8132.8	Method of measurement	Settings group 1: fundamental comp.
21.1461.8132.107	Non-directional pickup	Settings group 1: at volt. < & mem.empty
21.1461.8132.104	Directional comparison	Settings group 1: no
21.1461.8132.106	Release via input signal	Settings group 1: no
21.1461.8132.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.1461.8132.26	Dynamic settings	All: no
21.1461.8132.3	Threshold	Settings group 1: 0.667 A
21.1461.8132.4	Dropout ratio	Settings group 1: 0.95
21.1461.8132.101	Dropout delay	Settings group 1: 0 s
21.1461.8132.6	Operate delay	Settings group 1: 0.1 s

Inverse-T 1 \General

Number	Settings	Value
21.1461.8161.1	Mode	Settings group 1: off
21.1461.8161.2	Operate & flt.rec. blocked	Settings group 1: no
21.1461.8161.111	Directional mode	Settings group 1: forward
21.1461.8161.8	Method of measurement	Settings group 1: fundamental comp.
21.1461.8161.113	Non-directional pickup	Settings group 1: no
21.1461.8161.110	Directional comparison	Settings group 1: yes
21.1461.8161.112	Release via input signal	Settings group 1: no
21.1461.8161.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.1461.8161.26	Dynamic settings	All: no
21.1461.8161.3	Threshold	Settings group 1: 0.64 A
21.1461.8161.130	Type of character. curve	Settings group 1: IEC normal inverse
21.1461.8161.114	Min. time of the curve	Settings group 1: 0 s
21.1461.8161.131	Reset	Settings group 1: disk emulation
21.1461.8161.101	Time dial	Settings group 1: 1
21.1461.8161.115	Additional time delay	Settings group 1: 0 s

46 I2 1**General**

Number	Settings	Value
21.321.2311.106	Reference value	Settings group 1: rated current
21.321.2311.107	Current limitation I _{max}	All: no
21.321.2311.104	Release current	Settings group 1: 0.030 A

Definite-T 1

Number	Settings	Value
21.321.1981.1	Mode	Settings group 1: off
21.321.1981.2	Operate & flt.rec. blocked	Settings group 1: no
21.321.1981.3	Threshold	Settings group 1: 10 %
21.321.1981.4	Dropout ratio	All: 0.95
21.321.1981.101	Dropout delay	Settings group 1: 0 s
21.321.1981.6	Operate delay	Settings group 1: 5 s

Definite-T 2

Number	Settings	Value
21.321.1982.1	Mode	Settings group 1: off
21.321.1982.2	Operate & flt.rec. blocked	Settings group 1: no
21.321.1982.3	Threshold	Settings group 1: 65 %
21.321.1982.4	Dropout ratio	All: 0.95
21.321.1982.101	Dropout delay	Settings group 1: 0 s
21.321.1982.6	Operate delay	Settings group 1: 0.5 s

27 Undervolt.-3ph 1 UNDER VOLATGE - ONLY DR TRIGGERING NO CB TRIP**General**

Number	Settings	Value
21.131.2311.104	Current-flow criterion	Settings group 1: on
21.131.2311.101	Threshold I>	Settings group 1: 0.03 A
21.131.2311.103	Stabilization counter	Settings group 1: 0

Definite-T 1

Number	Settings	Value
21.131.421.1	Mode	Settings group 1: on
21.131.421.2	Operate & flt.rec. blocked	Settings group 1: no
21.131.421.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.131.421.9	Measured value	Settings group 1: phase-to-ground
21.131.421.8	Method of measurement	Settings group 1: fundamental comp.
21.131.421.101	Pickup mode	Settings group 1: 1 out of 3
21.131.421.102	Pickup delay	Settings group 1: no
21.131.421.3	Threshold	Settings group 1: 57.000 V
21.131.421.4	Dropout ratio	Settings group 1: 1.05
21.131.421.6	Operate delay	Settings group 1: 0 s

Definite-T 2

Number	Settings	Value
21.131.422.1	Mode	Settings group 1: off
21.131.422.2	Operate & flt.rec. blocked	Settings group 1: no
21.131.422.10	Blk. by meas.-volt. failure	Settings group 1: yes
21.131.422.9	Measured value	Settings group 1: phase-to-phase
21.131.422.8	Method of measurement	Settings group 1: fundamental comp.
21.131.422.101	Pickup mode	Settings group 1: 1 out of 3
21.131.422.102	Pickup delay	Settings group 1: no
21.131.422.3	Threshold	Settings group 1: 71.5 V
21.131.422.4	Dropout ratio	Settings group 1: 1.05
21.131.422.6	Operate delay	Settings group 1: 0.5 s

59 Overvolt.-3ph 1**General**

Number	Settings	Value
21.51.2311.101	Stabilization counter	Settings group 1: 0

Definite-T 1

Number	Settings	Value
21.51.181.1	Mode	Settings group 1: on
21.51.181.2	Operate & flt.rec. blocked	Settings group 1: no
21.51.181.9	Measured value	Settings group 1: phase-to-ground
21.51.181.8	Method of measurement	Settings group 1: fundamental comp.
21.51.181.101	Pickup mode	Settings group 1: 1 out of 3
21.51.181.3	Threshold	Settings group 1: 70.000 V
21.51.181.4	Dropout ratio	Settings group 1: 0.95
21.51.181.6	Operate delay	Settings group 1: 0 s

Definite-T 2

Number	Settings	Value
21.51.182.1	Mode	Settings group 1: on
21.51.182.2	Operate & flt.rec. blocked	Settings group 1: no
21.51.182.9	Measured value	Settings group 1: phase-to-ground
21.51.182.8	Method of measurement	Settings group 1: fundamental comp.
21.51.182.101	Pickup mode	Settings group 1: 1 out of 3
21.51.182.3	Threshold	Settings group 1: 89.000 V
21.51.182.4	Dropout ratio	Settings group 1: 0.95
21.51.182.6	Operate delay	Settings group 1: 0.1 s

21 Distance prot. 1**General**

Number	Settings	Value
21.901.2311.110	Zone timer start	Settings group 1: on dist. pickup
21.901.2311.107	Dist. characteristic angle	Settings group 1: 85 °
21.901.2311.105	Ground-fault detection	Settings group 1: 3I0 or V0
21.901.2311.103	3I0> threshold value	Settings group 1: 0.03 A
21.901.2311.102	V0> threshold value	Settings group 1: 1.008 V
21.901.2311.104	3I0 pickup stabilization	Settings group 1: 0.1
21.901.2311.108	Loop select. with ph-ph-g	Settings group 1: block leading phase
21.901.2311.106	Parallel-line compensat.	Settings group 1: no

Pickup Z<

Number	Settings	Value
21.901.3661.101	Min. phase-current thresh	Settings group 1: 0.05 A
21.901.3661.102	Use ph-g load cutout	All: <input checked="" type="checkbox"/> Yes
21.901.3661.105	Use ph-ph load cutout	All: <input checked="" type="checkbox"/> Yes

Z 1

Number	Settings	Value
21.901.3571.1	Mode	Settings group 1: on
21.901.3571.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3571.121	Blocked if diff.prot.active	Settings group 1: <input checked="" type="checkbox"/> Yes
21.901.3571.11	1-pole operate allowed	Settings group 1: yes
21.901.3571.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3571.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3571.109	Directional mode	Settings group 1: forward
21.901.3571.102	X reach	Settings group 1: 2.475 Ω
21.901.3571.103	R (ph-g)	Settings group 1: 9.897 Ω
21.901.3571.104	R (ph-ph)	Settings group 1: 1.320 Ω
21.901.3571.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3571.110	Operate delay (1-phase)	Settings group 1: 0 s
21.901.3571.112	Operate delay (multi-ph.)	Settings group 1: 0 s

Z 2

Number	Settings	Value
21.901.3572.1	Mode	Settings group 1: on
21.901.3572.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3572.121	Blocked if diff.prot.active	Settings group 1: no
21.901.3572.11	1-pole operate allowed	Settings group 1: no
21.901.3572.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3572.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3572.109	Directional mode	Settings group 1: forward
21.901.3572.102	X reach	Settings group 1: 3.713 Ω
21.901.3572.103	R (ph-g)	Settings group 1: 10.000 Ω
21.901.3572.104	R (ph-ph)	Settings group 1: 1.431 Ω
21.901.3572.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3572.110	Operate delay (1-phase)	Settings group 1: 0.35 s
21.901.3572.112	Operate delay (multi-ph.)	Settings group 1: 0.35 s

Z 3

Number	Settings	Value
21.901.3573.1	Mode	Settings group 1: on
21.901.3573.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3573.121	Blocked if diff.prot.active	Settings group 1: no
21.901.3573.11	1-pole operate allowed	Settings group 1: no
21.901.3573.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3573.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3573.109	Directional mode	Settings group 1: forward
21.901.3573.102	X reach	Settings group 1: 6.188 Ω
21.901.3573.103	R (ph-g)	Settings group 1: 10.213 Ω
21.901.3573.104	R (ph-ph)	Settings group 1: 1.641 Ω
21.901.3573.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3573.110	Operate delay (1-phase)	Settings group 1: 1 s
21.901.3573.112	Operate delay (multi-ph.)	Settings group 1: 1 s

Z 4

Number	Settings	Value
21.901.3574.1	Mode	Settings group 1: on
21.901.3574.2	Operate & flt.rec. blocked	Settings group 1: no
21.901.3574.121	Blocked if diff.prot.active	Settings group 1: no
21.901.3574.11	1-pole operate allowed	Settings group 1: no
21.901.3574.101	Function mode	Settings group 1: ph-gnd and ph-ph
21.901.3574.114	Zone-spec. residu. comp.	Settings group 1: no
21.901.3574.109	Directional mode	Settings group 1: reverse
21.901.3574.102	X reach	Settings group 1: 0.618 Ω
21.901.3574.103	R (ph-g)	Settings group 1: 9.741 Ω
21.901.3574.104	R (ph-ph)	Settings group 1: 1.168 Ω
21.901.3574.113	Zone-inclination angle	Settings group 1: 0 °
21.901.3574.110	Operate delay (1-phase)	Settings group 1: 0.35 s
21.901.3574.112	Operate delay (multi-ph.)	Settings group 1: 0.35 s

87 Line diff. prot.

General

Number	Settings	Value
21.831.2311.1	Mode	Settings group 1: on
21.831.2311.11	1-pole operate allowed	Settings group 1: yes
21.831.2311.102	Min. current for release	Settings group 1: 0 A
21.831.2311.104	Supervision Idiff	All: yes: reporting only
21.831.2311.108	Action on Behavior = test	Settings group 1: Test loc. device autom.

Remote trip. \General

Number	Settings	Value
21.831.5551.100	Transmitting	Settings group 1: yes
21.831.5551.101	Receiving	Settings group 1: yes

Remote trip. \Intertrip

Number	Settings	Value
21.831.5551.103	Send delay	Settings group 1: 0.02 s
21.831.5551.104	Send prolongation	Settings group 1: 0 s

I-DIFF

Number	Settings	Value
21.831.3451.1	Mode	Settings group 1: on
21.831.3451.2	Operate & flt.rec. blocked	Settings group 1: no
21.831.3451.3	Threshold	Settings group 1: 0.083 A
21.831.3451.101	Threshold switch on	Settings group 1: 0.1 A
21.831.3451.102	Delay 1-phase pickup	Settings group 1: 0 s
21.831.3451.6	Operate delay	Settings group 1: 0 s

I-DIFF fast 2

Number	Settings	Value
21.831.18211.1	Mode	Settings group 1: on
21.831.18211.2	Operate & flt.rec. blocked	Settings group 1: no
21.831.18211.3	Threshold	Settings group 1: 2.00 A
21.831.18211.101	Threshold switch on	Settings group 1: 3.82 A
21.831.18211.6	Operate delay	Settings group 1: 0 s
21.831.18211.106	Delay 1-phase pickup	Settings group 1: 0 s

Transformer

Number	Settings	Value
21.831.3541.101	Rated apparent power	Settings group 1: 693 MVA
21.831.3541.103	Voltage vector group nb.	Settings group 1: 0
21.831.3541.104	Current vector group nb.	Settings group 1: 0
21.831.3541.105	Residual curr. elimination	Settings group 1: yes

87 Stub diff. prot. 1

General

Number	Settings	Value
21.1431.2311.1	Mode	Settings group 1: off

S-DIFF

Number	Settings	Value
21.1431.8401.1	Mode	Settings group 1: off
21.1431.8401.2	Operate & flt.rec. blocked	Settings group 1: no
21.1431.8401.3	Threshold	Settings group 1: 0.160 A
21.1431.8401.6	Operate delay	Settings group 1: 0 s

S-DIFF fast 2

Number	Settings	Value
21.1431.18241.1	Mode	Settings group 1: off
21.1431.18241.2	Operate & flt.rec. blocked	Settings group 1: no
21.1431.18241.3	Threshold	Settings group 1: 0.533 A

68 P.swing blk \Zones to be blocked

Number	Settings	Value
21.5311.102	21 Distance prot. 1.Z 1	true
21.5311.102	21 Distance prot. 1.Z 2	true
21.5311.102	21 Distance prot. 1.Z 3	true
21.5311.102	21 Distance prot. 1.Z 4	true

68 P.swing blk

Number	Settings	Value
21.5311.1	Mode	Settings group 1: on
21.5311.103	Max. blocking time	Settings group 1: 2 s

85-21Perm.underr. Permissive Overreach

85-21Perm.unde \Send with

Number	Settings	Value
21.1281.5671.140	21 Distance prot. 1.Z 1	true

Number	Settings	Value
21.1281.5671.140	21 Distance prot. 1.Z 2	false
21.1281.5671.140	21 Distance prot. 1.Z 3	false
21.1281.5671.140	21 Distance prot. 1.Z 4	false

85-21Perm.unde \Operate with		
Number	Settings	Value
21.1281.5671.141	21 Distance prot. 1.pickup general	false
21.1281.5671.141	21 Distance prot. 1.Z 1	false
21.1281.5671.141	21 Distance prot. 1.Z 2	true
21.1281.5671.141	21 Distance prot. 1.Z 3	false
21.1281.5671.141	21 Distance prot. 1.Z 4	false
21.1281.5671.141	receive (direct trip)	false

85-21Perm.unde Permissive Overreach		
Number	Settings	Value
21.1281.5671.1	Mode	Settings group 1: on
21.1281.5671.101	Send prolongation	Settings group 1: 0.05 s
21.1281.5671.11	1-pole operate allowed	Settings group 1: yes
21.1281.5671.102	Operate delay (1-phase)	Settings group 1: 0 s
21.1281.5671.103	Operate delay (multi-ph.)	Settings group 1: 0 s

Switch onto fault 1

Stage 1 \Configuration		
Number	Settings	Value
21.1341.5941.102	50/51 OC-3ph-A1.Definite-T 1	false
21.1341.5941.102	50/51 OC-3ph-A1.Definite-T 2	false
21.1341.5941.102	50N/51N OC-gnd-A1.Definite-T 1	false
21.1341.5941.102	50N/51N OC-gnd-A1.Definite-T 2	false
21.1341.5941.102	67N GFP gnd.sys.1.Definite-T 1	false
21.1341.5941.102	67N GFP gnd.sys.1.Definite-T 2	false
21.1341.5941.102	67N GFP gnd.sys.1.Inverse-T 1	false
21.1341.5941.102	67 Dir.OC-3ph-A1.Definite-T 1	false
21.1341.5941.102	67 Dir.OC-3ph-A1.Definite-T 2	false
21.1341.5941.102	67 Dir.OC-3ph-A1.Inverse-T 1	false
21.1341.5941.102	21 Distance prot. 1.Z 1	true
21.1341.5941.102	21 Distance prot. 1.Z 2	true
21.1341.5941.102	21 Distance prot. 1.Z 3	false
21.1341.5941.102	21 Distance prot. 1.Z 4	false
21.1341.5941.102	50 OC high-speed 1.Standard 1	false

Stage 1		
Number	Settings	Value
21.1341.5941.1	Mode	Settings group 1: on
21.1341.5941.2	Operate & flt.rec. blocked	Settings group 1: no
21.1341.5941.6	Operate delay	Settings group 1: 0 s

2.hrm.det. gnd		
Number	Settings	Value
21.22051.1	Mode	All: off
21.22051.102	2nd harmonic content	Settings group 1: 15 %

50 OC high-speed 1 / STUB PROTECTION

Standard 1		
Number	Settings	Value
21.971.3901.1	Mode	Settings group 1: on
21.971.3901.101	Activation	Settings group 1: only with binary signal
21.971.3901.3	Threshold	Settings group 1: 0.667 A
21.971.3901.4	Dropout ratio	Settings group 1: 0.9

Line 1\Circuit-breaker interaction

Protection group	Circuit-breaker group(s)
Line 1\ 50/51 OC-3ph-A1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50/51 OC-3ph-A1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50N/51N OC-gnd-A1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50N/51N OC-gnd-A1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67N GFP gnd.sys.1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67N GFP gnd.sys.1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67N GFP gnd.sys.1\ Inverse-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67 Dir.OC-3ph-A1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67 Dir.OC-3ph-A1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 67 Dir.OC-3ph-A1\ Inverse-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 46 I2 1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 46 I2 1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip

Protection group	Circuit-breaker group(s)
Line 1\ 27 Undervolt.-3ph 1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 27 Undervolt.-3ph 1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 59 Overvolt.-3ph 1\ Definite-T 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 59 Overvolt.-3ph 1\ Definite-T 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 2	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 3	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 21 Distance prot. 1\ Z 4	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 87 Line diff. prot.\ General	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 85-21Perm.underr.\ 85-21Perm.unde	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ Switch onto fault 1\ Stage 1	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 87 Stub diff. prot. 1\ General	Circuit breaker 1:Circuit breaker 1:Trip
Line 1\ 50 OC high-speed 1\ Standard 1	Circuit breaker 1:Circuit breaker 1:Trip

*Setting marked as favorite setting

sp Setting marked as specific setting

**ADANI GREEN ENERGY LIMITED
(ADANI RENEWABLES)
400kV BADISID SUBSTATION TRANSFORMER
PROTECTION RELAY SETTING CALCULATION**

400kV BHADLA SUBSTATION

ADANI GREEN ENERGY LIMITED

We reserve all rights in this document and in the information contained therein. Reproduction use or disclosure to third parties without express authority is strictly forbidden. Copyright © by Hitachi Energy India Limited.

“Disclaimer – Unauthorized access

The offered solution may be accessed through the customer network and therefore represents a danger which poses a potential threat of intrusion by unauthorized parties. Therefore, Hitachi Energy India Limited strongly recommends that the customer insures/implements necessary protection measures against the possibility of such unauthorized access.

Hitachi Energy India Limited **disclaims any responsibility and shall under no circumstances be liable for damages or malfunctions caused by external intrusion of any kind whatsoever.**”


400kV BADISID SUBSTATION TRANSFORMER PROTECTION RELAY SETTING CALCULATION

DOCUMENT	400kV BADISID SUBSTATION TRANSFORMER PROTECTION RELAY SETTING CALCULATION
PROJECT	400kV BHADLA SUBSTATION
SUBSTATION	400kV BHADLA SUBSTATION
CLIENT	ADANI GREEN ENERGY LIMITED
SUPPLIER	HITACHI ENERGY INDIA LIMITED
PO / LOA No.	IDTO-VI/ Adani Green-400 kV at Badi Sid - Rajasthan /PGGA/CRP & SAS
HEIL SO REF.	3100139976, 1MNS500950-PDAA

Revisions:

Rev.	Prep. / Appr.	Description	Date
00	SS / PN	First Submission	31-May-2024
01	SS / PN	Revised as per customer comments	02-Aug-24

CUSTOMER	DEPT.	DOCUMENT ID.	REV.	LANG.	PAGE
NEPAL ELECTRICITY AUTHORITY.	PG-GAS	1MNS500735-CGAA	01	En	2/64
PROJECT			PREP.	APPR.	DATE
400kV BADISID SUBSTATION TRANSFORMER PROTECTION RELAY SETTING CALCULATION			SS	PN	02-AUG-24

	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

General data

Relay Details

Relay Model Ref = RET670
Relay Frequency = 50
Ordering Code = 670*2.2.1

Bay Details

Bay Name = Trafo-1, 2
Bay Reference = 400/33/33kV TRANSFORMER C&R PANEL

Transformer Details

Rated Power = 330.0 / 165.0 / 165.0 MVA
Voltage Ratio = 400 / 33 / 33 kV
Normal Tap No Load Voltage OLTC1 = 400 kV
Vector Group = YNa0yn0
% Impedance at 75°C = 15.0 (at 165 MVA base)
Frequency: = 50 Hz

HV Winding (W1) Detail

CT ratio = 2000-1000-500/1
CT ratio - Adopted = 1000 / 1 A
CT Class = PS
Rated Power = 330 MVA
Rated Voltage = 400 kV
CTStarPoint = To Object

MV Winding (W2) Detail

CT ratio = 3150/1
CT ratio - Adopted = 3150 / 1 A
CT Class = PS
Rated Power = 165 MVA
Rated Voltage = 33.00 kV
CTStarPoint = To Object

LV Winding (W3) Detail


CT ratio = 3150/1
CT ratio - Adopted = 3150 / 1 A
CT Class = PS
Rated Power = 165 MVA
Rated Voltage = 33 kV
CTStarPoint = To Object

Rated Current

HV = Rated Power / ((√3) * Rated Voltage)
= (330x 10⁶) / ((√3) x 400 x 10³)
= 476 A

MV = Rated Power / ((√3) * Rated Voltage)
= (165x 10⁶) / ((√3) x 33 x 10³)
= 2887 A

LV = Rated Power / ((√3) * Rated Voltage)
= (165x 10⁶) / ((√3) x 33 x 10³)
= 2887 A

	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Global Base Values GBASVAL

GBASVAL:1 (HV Rated current)

Ubase = 400 kV
Ibase = 476 A
Sbase = 330.0 MVA

GBASVAL:2 (LV Rated current)

Ubase = 33 kV
Ibase = 2886.8 A
Sbase = 165.0 MVA

GBASVAL:3 (HV CT Ratio)

Ubase = 400.0 kV
Ibase = 1000 A
Sbase = 692.8 MVA

GBASVAL:4 (LV CT Ratio)


Ubase = 33 kV
Ibase = 3150 A
Sbase = 180.0 MVA

GBASVAL:5 (HV SEF)

Ubase = 400.0 kV
Ibase = 1000 A
Sbase = 692.8 MVA

GBASVAL:6 (LV CT ratio- REF/SEF)

Ubase = 33 kV
Ibase = 4000 A
Sbase = 228.6 MVA

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Transformer differential protection:T3WPDIF 87OT(Transformer Overall Differential)

HV AIS Bkr CTR-1000/1
LV SWGR Bkr CTR-3150/1

A. Setting of minimum differential operating current

The basic setting defines the pick-up setting of the differential protection for internal faults. The lowest possible value should be chosen to enable it to detect the worst-case faults. However, there can be small differential current during normal operation, which may result in tripping.

To assure that the load current does not cause unwanted operation, IdMin is set based on the calculation below.

Differential current error at rated load current in different tap positions

Tap Position	I_{HV}	$I_{LV}+I_{MV}$	I_{DIFF}	%Error in Ibase
9	476.3	5773.7	$476.33 - (5773.68 * (33 / 400)) = 0.0014$	0.000
1	433.0	5773.7	$433.03 - (5773.68 * (33 / 400)) = -43.2986$	-9.090
17	529.3	5773.7	$529.25 - (5773.68 * (33 / 400)) = 52.9214$	11.110

Maximum error due to OLTC (at tap 17 the Rated Current)	=	11.110	%
CT Error (HV & LV Assumed)	=	5	%
Relay Error (As per technical data of the relay)	=	1	%
Total Error (In terms of % of the rated current of the transformer)	=	$11.11 + 5 + 1$	
	=	17.110	%

Based on the above considered criteria the selected Idmin value as follows:

IdMin	=	20	%
IdMin	=	0.20	*Ibase
Ibase	=	476	A

B. Setting of cross-over point between slope 1 and slope 2

This section corresponds to normal load currents - upto the max. values of normal load currents. Here, the setting of differential current corresponds to Idmin i.e. basic differential current setting which determines the pickup of the relay. As per the recommendation of the relay manual, the same setting is selected as default - Restraint current upto 125% of the base current.

$$\text{EndSection1} = 1.25 \quad \text{Ibase}$$

setting is selected as default - 40%

$$\text{SlopeSection2} = 40\% \quad *I_{bias}$$

D. Setting of cross-over point between slope 2 and slope 3

The section corresponds to currents above normal load currents, and to provide stability for high-resistive faults under heavy load conditions.

$$\begin{aligned} \text{EndSection2} &= 3 \quad \text{Ibase} \\ \text{Idiff Value at End Section 2} &= \text{SlopeSection2} \times \text{EndSection2} \\ &= 0.9 \end{aligned}$$


E. Setting of slope 2 stabilisation

This is higher % bias setting applied for Restraint currents above End section 2 - to provide stability for heavy through fault currents. As per recommendation of relay manual, same setting is selected as default - 80%

$$\text{SlopeSection3} = 80\% \quad *I_{bias}$$

F. Unrestrained operation level

As per the Application manual(AM) Unrestrained operation level has default value of IdUnre = 10pu, which is typically acceptable for most of standard power transformer applications. Hence the considered Setting of minimum differential operating current for unrestraint step HV Through fault current = HV Full load current / % Impedance

	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232	
	PGGA-2875	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2		Rev No.	2

$$\begin{aligned}
 &= (476.33 / (15/100)) \\
 &= 3175.53 && \text{A} \\
 \text{Considering 120\% of through fault} &= 3175.53 \times 1.2 \\
 \text{Current} &= 3810.636 && \text{A} \\
 &= 8
 \end{aligned}$$

$$\text{Thus Idunre setting proposed} = 9 \quad *I_{base}$$

G. Setting the operation of Cross Blocking logic

The meaning of Cross-blocking is that the 2nd and 5th harmonic blocking in one phase will also block the differential function in other phases.

$$\text{OpCrossBlock} = \text{On}$$

H. Set the second and fifth harmonic stabilizing level when transformers are inside the zone

Setting considered as per Manual

$$\begin{aligned}
 I2/I1\text{Ratio} &= 15 \quad \% \\
 I5/I1\text{Ratio} &= 25 \quad \%
 \end{aligned}$$

I. Set the operation of Negative sequence differential protection!

NegSeqDiff - Negative sequence fault discriminator is an important compliment to the percentage restrained differential function. As it is directional, it can distinguish between external and internal faults; also at difficult conditions such as CT saturation.

$$\text{OpNegSeqDiff} = \text{Off}$$

J. Setting of minimum negative sequence differential current level

The negative sequence currents are compared if above the set threshold value IminNegSeq. If either these sums is below the threshold, no comparison is made. Neither internal, nor external fault will be declared in this case. As per Relay manual recommendation, default value of 0.04xIbase can be used if no special account. considerations such as e.g. extremely weak sources must be taken into

$$I_{MinNegSeq} = 0.04 \quad *I_{base} \quad \text{As per Manual}$$


K. Setting of the Relay operating angles.

This is the setting of the relay operating angle of the negative sequence Ibased internal / external fault discriminator. The directional test is made such that, the phase angle of the sum of Local negative sequence currents is compared to the phase angle of the sum of remote negative sequence currents. Ideally, the angle is 0 degree for internal faults and 180 degree for external faults. However, considering for safety margin, because of errors caused by CT saturation as well as different phase angles of sources, we set the Relay operate angle setting to 60 degrees default.

$$\text{NegSeqROA} = 60 \quad \text{As per Manual}$$

Restrained differential function characteristic


As per the Manual




en05000187.vsd

Figure 44: Description of the restrained-, and the unrestrained operate characteristics

Adopted Curve



 PGGA-2875	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)		Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1		Date	02-Aug-24
Prepared:	SS	400kV BADISID SUBSTATION		Doc No.
Checked:	PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2		Rev No.
				2

Overexcitation protection: OEXPVPH

GlobalBaseSel: Selects the global base value group used by the function to define IBase, UBase and SBase as applicable.

GlobalBaseSel = 2

Operation: The operation of the Overexcitation protection

Operation = On

MeasuredU: The phases involved in the measurement are set here. Normally the three phase measurement measuring the positive sequence voltage should be used but when only individual VT's are used a single phase-to-phase can be used.

MeasuredU = L1L2

MeasuredI: The phases involved in the measurement are set here. MeasuredI: must be in accordance with MeasuredU.

MeasuredI = L1L2

V/Hz>: Operating level for the inverse characteristic, IEEE or tailor made. The operation is based on the relation between rated voltage and rated frequency and set as a percentage factor. Normal setting is around 108-110% depending of the capability curve for the transformer/generator.

V/Hz> = 120 %UB/f

V/Hz>>: Operating level for the tMin definite time delay used at high overvoltages. The operation is based on the relation between rated voltage and rated frequency and set as a percentage factor. Normal setting is around 110-180% depending of the capability curve of the transformer/generator. Setting should be above the knee-point when the characteristic starts to be straight on the high side.

V/Hz>> = 140 %UB/f
0.8

XLeak: The transformer leakage reactance on which the compensation of voltage measurement with load current is based. The setting shall be the transformer leak reactance in primary ohms. If no current compensation is used (mostly the case) the setting is not used.

XLeak = 0.075 Ohm

TrPulse: The length of the trip pulse. Normally the final trip pulse is decided by the trip function block. A typical pulse length can be 50 ms.


TrPulse = 0.1 s

Stand by earth fault, settings given here are only provisional. The settings are to be co-ordinated with Cu downstream relays, the settings should be corrected at site to ensure proper coordination.
sel

CureveType = TailorMade

If **CurveType** selected as **IEEE**, then the operating time will be calculated by following equation,

$$\text{top} = \frac{0.18 * k}{\left(\frac{M}{V/Hz} - 1\right)^2}$$

 Hitachi Energy PGGA-2875	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)		Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1		Date	02-Aug-24
Prepared:	SS	400kV BADISID SUBSTATION		Doc No.
Checked:	PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2		Rev No.
				2

Where:

M relative excitation

k time multiplier for inverse time function

kForIEEE: The time constant for the inverse characteristic. Select the one giving the best match to the transformer capability.

KForIEEE = 0

If **CurveType** selected as **TrailorMode**, then the operating time will be based on the setting from t1 to t6

The interval between V/Hz>> and V/Hz> is automatically divided up in five equal steps, and the time delays t2 to t5 will be allocated to these values of overexcitation. In this application, each step will be (-) /5 = 0%. The setting of time delays t1 to t6 are listed below.

t1	= 100	s
t2	= 50	s
t3	= 30	s
t4	= 15	s
t5	= 6	s
t6	= 3	s

tCooling: The cooling time constant giving the reset time when voltages drops below the set value.

Shall be set above the cooling time constant of the transformer. The default value is recommended to be used if the constant is not known.

tCooling = 1200 s

tMin: The operating times at voltages higher than the set V/Hz>>. The setting shall match capabilities on these high voltages. Typical setting can be 1-10 second.

tMin = 2 s

tMax: For overvoltages close to the set value times can be extremely long if a high K time constant is used.

A maximum time can then be set to cut the longest times. Typical settings are 1800-3600 seconds (30-60 minutes)

tMax = 100 s


AlarmLevel: Setting of the alarm level in percentage of the set trip level. The alarm level is normally set at around 98% of the trip level.

AlarmLevel = 95 %


tAlarm: Setting of the time to alarm is given from when the alarm level has been reached. Typical setting is 5 seconds.

tAlarm = 10 s

Overexcitation Curve



ays,

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Setting of Thermal overload protection function (THL) (Only for Alarm purpose, not for tripping)

The thermal overload in some cases is not detected by other protection functions, and the introduction of thermal overload protection (THL) allows the protected circuit to operate closer to thermal limits.

Activation of the Thermal overload protection function
 Operation = **On**

Setting of the base current Ibase for the function on which the current levels are based
 Ibase = **476 A**

Setting of load current (in % of Ibase) leading to Tref temperature - Iref:
 As per the recommendations, this current should be set to the maximum steady state current allowed for the equipment under emergency operation (a few hours per year)

Now, maximum continuous current capacity of transformer
 I_{max} = 524 A (Assuming an allowed continuous 10% overload)

The same Iref current expressed as = 523.963 / 476.33 A
 = 110%

Thus, selected setting for Iref = 110% Ibase
 Thus, selected setting for Iref = 120% Ibase

Setting for End temperature rise above ambient temperature of the line when loaded with Iref - Tref:
 This is reference temperature corresponding to steady state current Iref - 90 deg C.

Thus, Selected setting for Tref = 90 °C

Setting of Current multiplier when function is used for two or more lines - Imult:
 If the protection measures one of a number of parallel line circuits, the number of parallel line circuits is given in this setting. Since, here the relay measures only for single feeder, the same setting will be 1.

Selected setting for Imult = 1

$$t_{th} = \frac{1}{60} \left(\frac{\text{Permissible 1-s current}}{\text{Permissible continuous current}} \right)^2$$

$$\text{min} = \frac{1}{60} \left(\frac{63000}{524 \text{ A}} \right)^2$$

Setting for temperature level for Trip - TripTemp:
 This is the temperature value for trip of the protected circuit. As per cable datasheet, the same is stated as 90 deg C.

Thus, selected setting for TripTemp = 100 °C

Setting for temperature level for alarm - AlarmTemp:
 This is the temperature value for alarm of the protected circuit. This signal is used to provide warning before the circuit is tripped. Therefore, the setting shall be lower than the trip level. It shall at the same time be higher than the maximum conductor temperature at normal operation.


As per the cable datasheet, max. permissible continuous conductor temperature
 = 90 °C

Thus, selected setting for AlarmTem = 90 °C

Setting of temperature for reset of lockout after trip - ReclTemp:
 This is the temperature where lockout signal LOCKOUT from the function is released. When the thermal overload protection trips a lock-out signal is activated. This signal is intended to block switch in of the protected circuit as long as the conductor temperature is high. The signal is released when the estimated temperature is below the set value. This temperature value should be chosen below the alarm temperature.

As per the cable datasheet, temperature for normal operation
 = 80 °C

Thus, selected setting for ReclTemp = 80 °C

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Setting of trip pulse length - tpulse:

Selected setting for tpulse = 0.10 sec

Activate the external Ambient temperature measurement (when provided through mA input)


AmbSens = Off

Setting of Ambient temperature used when AmbiSens is set to Off - DefaultAmbTemp:

DefaultAmbTemp = 40 °C

Setting of the temperature raise, from ambient, of the line to be used at start - DefaultTemp:

DefaultTemp = 50 °C

 Hitachi Energy PGGA-2875-ApT	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

LV1 & LV2 High Impedance Restricted Earth Fault Protection:- 33 kV

Transformer Details

Power Rating	=	165	MVA
MV Voltage Rating	=	33	kV
MV Neutral Grounding Type	=	Solid	
% Impedance	=	15.00	%
Full load Current	=	2886.8	A

LV Side CT Details:

CT Ratio	=	4000/1	A
CT Adoptted Primary Rating	=	4000	A
CT Secondary Rating	=	1	A
CT Resistance	=	13.0	Ohm
CT Knee Point Voltage	=	500	V
CT Magnetising Current @Vk	=	30	mA

LV Neutral Side CT Details:

CT Ratio	=	4000/1	A
CT Adoptted Primary Rating	=	4000	A
CT Secondary Rating	=	1	A
CT Resistance	=	13.0	Ohm
CT Knee Point Voltage	=	500	V
CT Magnetising Current @Vk	=	30	mA

LV Side Lead Resistance Details:

Lead Resistance at 75 ⁰ C /kM	=	7	Ohm/kM	(Assumed)
Length of Lead of two path (Wire loop length across CT to Relay)	=	200	Meter	

Relay Details


Relay Type	=	RET670	
Relay Burden	=	0.02	VA
Relay Order Code	=	-	
Relay Serial No	=	0	


REF Pickup Setting

REF Function	=	On	
Relay Pickup Setting	=	10	%

Calculations:

Calculation of Fault MVA (Sf)	=	$MVA/\%Impedance$	
	=	$(165)/(15/100)$	
	=	1100	MVA
Calculation of Fault Current (If)	=	$(Sf*1000)/(\sqrt{3}*kV)$	
	=	$(1100*1000)/(1.732*33)$	
	=	19245	A

 Hitachi Energy	PROTECTION RELAY SETTING CALCULATION		Contract No.	3100139976, IN-56423232
	PGGA-2875-ApT	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2		Rev No.	2
Calculation of LV Lead Resistance (RI)	=	Lead Resiatnce per km*Length of Lead		
	=	7*(200/1000)		
	=	1.40 Ohm		
Calculation of LV CT Secondary Loop Resiatnce (Rloop)	=	Rct+RI+Rb		
	=	13+1.4+0.02		
	=	14.4 Ohm		
Calculation of Stabilising Voltage(Vstab)	=	Rloop*If		
	=	14.42*(19245.01/(4000/1))		
	=	69.38 V		
	≈	70 V		
By considering a margin of 50% for Field measurements,				
Vstab	=	105 V		
The magnetizing curve of the CT is assumed to be linear. The magnetizing current at the stabilizing voltage can be estimated as:				
Calculation of Magnetising Current @Vstab (Imstab)	=	(Vstab/Vk)*Im		
	=	(105/500)*(0.03)		
	=	6.300 mA		
To obtain adequate protection stability,of the sum of magnetizing currents of all connected CTs. the setting current Irs must be at the minimum of the sum of magnetizing currents of all connected CTs				
Number of CT's	=	4		
Calculation Sum of Magnetising Current (Imsum)	=	No.of Ct's*Imstab		
	=	4*6.3		
	=	25.20 mA		
Relay setting should be greater than Imsum.				
Adopted Setting for realy (Irs)	=	10 % of FLC		
	=	0.07 A		
With safety marging	=	0.10 A		
Selected relay setting 100mA is greater than 25.2mA				
The resistance of the stabilizing resistor is calculated as follows				
Calculation of Stabilising Resistor (Rstab)	=	Vstab/Irs		
	=	105/(0.1)		
	=	1050 Ohm		
Thermal Rating of stabilising resistor:				
Calculation of Power Rating of Stabilising Resistor (Pstab)	=	Vk ² /(Rstab*10)		
	=	600 ² /(1050*10)		
	=	34.286 W		
Half Second Power Rating (Phalf)	=	Vf ² /Rstab		
	=	3362.6 W		

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-1	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Residual overcurrent protection, four steps: EF4PTOC

HV STAND BY EARTH FAULT PROTECTION 51NS

CT Ratio / Base Current	=	1000	/ 1A
Full load current	=	476.33	A
Fault Current	=	3175.53	A
Direction mode of step-1	=	Non-Directional	
Pickup Current	=	200	A
Operate Level of Step-1	=	0.20	%IB
TMS	=	0.25	
Operating Characteristics of Step-1	=	IEC Normal Inverse	

LV-1 & LV-2 STAND BY EARTH FAULT PROTECTION 51NS

CT Ratio / Base Current	=	4000	/ 1A
Full load current	=	2886.84	A
Fault Current	=	19245.60	A
Direction mode of step-1	=	Non-Directional	
Pickup Current	=	1000	A
Operate Level of Step-1	=	0.25	%IB
TMS	=	0.20	
Operating Characteristics of Step-1	=	IEC Normal Inverse	

Disabled all other steps:

Stand-by earth fault settings values revised here from customer comments, HV it is coming-42% and LV- 35% of full load current of the Transformer, both are looking high and not recommended.

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
TRM_40						
NAMECH1		CH1(I)			16 characters	
ChannelType1		Off				
RatedTrans1		1.0	A	0.1	300.0	
CTStarPoint1		ToObject				
CTsec1		1	A	1	10	
CTprim1		1000	A	1	99999	
NAMECH2		CH2(I)			16 characters	
ChannelType2		Off				
RatedTrans2		1.0	A	0.1	300.0	
CTStarPoint2		ToObject				
CTsec2		1	A	1	10	
CTprim2		1000	A	1	99999	
NAMECH3		CH3(I)			16 characters	
ChannelType3		Off				
RatedTrans3		1.0	A	0.1	300.0	
CTStarPoint3		ToObject				
CTsec3		1	A	1	10	
CTprim3		1000	A	1	99999	
NAMECH4		CH4(I)			16 characters	
ChannelType4		Off				
RatedTrans4		1.0	A	0.1	300.0	
CTStarPoint4		ToObject				
CTsec4		1	A	1	10	
CTprim4		3150	A	1	99999	
NAMECH5		CH5(I)			16 characters	
ChannelType5		Off				
RatedTrans5		1.0	A	0.1	300.0	
CTStarPoint5		ToObject				
CTsec5		1	A	1	10	
CTprim5		3150	A	1	99999	
NAMECH6		CH6(I)			16 characters	
ChannelType6		Off				
RatedTrans6		1.0	A	0.1	300.0	
CTStarPoint6		ToObject				
CTsec6		1	A	1	10	
CTprim6		3150	A	1	99999	
NAMECH7		CH7(I)			16 characters	
ChannelType7		Off				
RatedTrans7		1.0	A	0.1	300.0	
CTStarPoint7		ToObject				
CTsec7		1	A	1	10	
CTprim7		3150	A	1	99999	
NAMECH8		CH8(I)			16 characters	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
								0	31-05-2024	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
ChannelType8		Off				
RatedTrans8		1.0	A	0.1	300.0	
CTStarPoint8		ToObject				
CTsec8		1	A	1	10	
CTprim8		3150	A	1	99999	
NAMECH9		CH9(I)			16 characters	
ChannelType9		Off				
RatedTrans9		1.0	A	0.1	300.0	
CTStarPoint9		ToObject				
CTsec9		1	A	1	10	
CTprim9		3150	A	1	99999	
NAMECH10		CH10(U)			16 characters	
ChannelType10		Off				
RatedTrans10		1.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		33.00	kV	0.05	2000.00	
NAMECH11		CH11(U)			16 characters	
ChannelType11		Off				
RatedTrans11		1.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		33.00	kV	0.05	2000.00	
NAMECH12		CH12(U)			16 characters	
ChannelType12		Off				
RatedTrans12		1.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		33.00	kV	0.05	2000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by			Rev. 0	Rel. date 31-05-2024	Language en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
TRM_41						
NAMECH1		CH1(I)			16 characters	
ChannelType1		Off				
RatedTrans1		1.0	A	0.1	300.0	
CTStarPoint1		ToObject				
CTsec1		1	A	1	10	
CTprim1		3150	A	1	99999	
NAMECH2		CH2(I)			16 characters	
ChannelType2		Off				
RatedTrans2		1.0	A	0.1	300.0	
CTStarPoint2		ToObject				
CTsec2		1	A	1	10	
CTprim2		3150	A	1	99999	
NAMECH3		CH3(I)			16 characters	
ChannelType3		Off				
RatedTrans3		1.0	A	0.1	300.0	
CTStarPoint3		ToObject				
CTsec3		1	A	1	10	
CTprim3		3150	A	1	99999	
NAMECH4		CH4(I)			16 characters	
ChannelType4		Off				
RatedTrans4		1.0	A	0.1	300.0	
CTStarPoint4		ToObject				
CTsec4		1	A	1	10	
CTprim4		3150	A	1	99999	
NAMECH5		CH5(I)			16 characters	
ChannelType5		Off				
RatedTrans5		1.0	A	0.1	300.0	
CTStarPoint5		ToObject				
CTsec5		1	A	1	10	
CTprim5		3150	A	1	99999	
NAMECH6		CH6(I)			16 characters	
ChannelType6		Off				
RatedTrans6		1.0	A	0.1	300.0	
CTStarPoint6		ToObject				
CTsec6		1	A	1	10	
CTprim6		3150	A	1	99999	
NAMECH7		CH7(I)			16 characters	
ChannelType7		Off				
RatedTrans7		1.0	A	0.1	300.0	
CTStarPoint7		ToObject				
CTsec7		1	A	1	10	
CTprim7		1000	A	1	99999	
NAMECH8		CH8(I)			16 characters	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by			Rev.	Rel. date	Lan
									0	31-05-2024	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
ChannelType8		Off				
RatedTrans8		1.0	A	0.1	300.0	
CTStarPoint8		ToObject				
CTsec8		1	A	1	10	
CTprim8		4000	A	1	99999	
NAMECH9		CH9(I)			16 characters	
ChannelType9		Off				
RatedTrans9		1.0	A	0.1	300.0	
CTStarPoint9		ToObject				
CTsec9		1	A	1	10	
CTprim9		33	A	1	99999	
NAMECH10		CH10(U)			16 characters	
ChannelType10		Off				
RatedTrans10		1.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		33.00	kV	0.05	2000.00	
NAMECH11		CH11(U)			16 characters	
ChannelType11		Off				
RatedTrans11		1.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		33.00	kV	0.05	2000.00	
NAMECH12		CH12(U)			16 characters	
ChannelType12		Off				
RatedTrans12		1.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		33.00	kV	0.05	2000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by			Rev. 0	Rel. date 31-05-2024	Lang en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Global base values						
GBASVAL: 1						
UBase		400.00	kV	0.05	2000.00	
IBase		476	A	1	99999	
SBase		330.00	MVA	1.00	200000.00	
GBASVAL: 2						
UBase		33.00	kV	0.05	2000.00	
IBase		2886	A	1	99999	
SBase		165.00	MVA	1.00	200000.00	
GBASVAL: 3						
UBase		400.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		692.80	MVA	1.00	200000.00	
GBASVAL: 4						
UBase		33.00	kV	0.05	2000.00	
IBase		3150	A	1	99999	
SBase		180.00	MVA	1.00	200000.00	
GBASVAL: 5						
UBase		400.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		692.80	MVA	1.00	200000.00	
GBASVAL: 6						
UBase		33.00	kV	0.05	2000.00	
IBase		4000	A	1	99999	
SBase		228.60	MVA	1.00	200000.00	
GBASVAL: 7						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 8						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 9						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 10						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 11						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
									0	31-05-2024	en

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 12						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan	2 / 2
									0	31-05-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
DisturbanceReport						
DRPRDRE: 1						
Operation		On				
COMTRADEFormat		2013(Float32)				
PreFaultRecT		0.50	s	0.05	9.90	
PostFaultRecT		2.5	s	0.1	10.0	
TimeLimit		3.0	s	0.5	10.0	
PostRetrig		On				
ZeroAngleRef		1	Ch	1	40	
SetInfoInDRep		Disable				
OpModeTest		Off				

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1			
				Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan	1 / 1
									0	31-05-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
DIFF_PROTN						
Differential protection						
TransformerDiff3Wind(87T,3Id/I>)						
TRAFO_DIFF_PROTN; T3WPDIF: 1						
GlobalBaseSelW1		1		1	12	
GlobalBaseSelW2		2		1	12	
GlobalBaseSelW3		2		1	12	
ConnectTypeW1		WYE (Y)				
ConnectTypeW2		WYE (Y)				
ConnectTypeW3		WYE (Y)				
ClockNumberW2		0 [0 deg]				
ClockNumberW3		0 [0 deg]				
ZSCurrSubtrW1		On				
ZSCurrSubtrW2		On				
ZSCurrSubtrW3		On				
TconfigForW1		Yes				
CT1RatingW1		1000	A	1	99999	
CT2RatingW1		1000	A	1	99999	
TconfigForW2		Yes				
CT1RatingW2		3150	A	1	99999	
CT2RatingW2		3150	A	1	99999	
TconfigForW3		Yes				
CT1RatingW3		3150	A	1	99999	
CT2RatingW3		3150	A	1	99999	
LocationOLTC1		Not Used				
LocationOLTC2		Not Used				
Setting Group1						
Operation		On				
SOTFMode		Off				
IDiffAlarm		0.15	IB	0.05	1.00	
tAlarmDelay		1.000	s	0.000	60.000	
IdMin		0.20	IB	0.10	0.60	
EndSection1		1.25	IB	0.20	1.50	
EndSection2		3.00	IB	1.00	10.00	
SlopeSection2		40.0	%	10.0	50.0	
SlopeSection3		80.0	%	30.0	100.0	
IdUnre		9.00	IB	1.00	100.00	
I2/I1Ratio		15.0	%	5.0	100.0	
I5/I1Ratio		25.0	%	5.0	100.0	
CrossBlockEn		On				
NegSeqDiffEn		Off				
OpenCTEnable		Off				

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
								0	31-05-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
REF_PROTN						
Differential protection						
HighImpDifferential(87,l>)						
LV1_REF; HZPDIF: 1						
Setting Group1						
Operation		On				
U>Alarm		70	V	5	500	
tAlarm		5.000	s	0.000	60.000	
U>Trip		105	V	10	900	
SeriesResistor		1050	Ohm	50	20000	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by	Rev.	Rel. date	Lan	1 / 1	
									0	31-05-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
ResidualOverCurr4Step(51N_67N,4(IN>))						
HV_SEF; EF4PTOC: 1						
General						
GlobalBaseSel		5		1	12	
SeqTypeDir		Zero seq				
SeqTypePol		Zero seq				
SeqTypeUPol		Zero seq				
Setting Group1						
Operation		On				
EnDir		Disable				
2ndHarmStab		20	%	5	100	
BlkParTransf		Off				
SOTF		Off				
EnPhaseSel		Off				
Step 1						
Setting Group1						
DirMode1		Non-directional				
Characterist1		IEC Norm. inv.				
IN1>		20	%IB	1	2500	
IN1>Max		100	%IB	1	2500	
IN1>Min		10	%IB	1	2500	
t1		0.000	s	0.000	60.000	
k1		0.25		0.01	999.00	
IMin1		20.00	%IB	1.00	2000.00	
t1Min		0.000	s	0.000	60.000	
IN1Mult		1.0		1.0	10.0	
ResetTypeCrv1		Instantaneous				
tReset1		0.020	s	0.000	60.000	
HarmBlock1		On				
Step 2						
Setting Group1						
DirMode2		Off				
Step 3						
Setting Group1						
DirMode3		Off				
Step 4						
Setting Group1						
DirMode4		Off				
LV2_SEF; EF4PTOC: 2						
General						
GlobalBaseSel		6		1	12	
SeqTypeDir		Zero seq				
SeqTypePol		Zero seq				

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAF0-1	HITACHI	Created by	Title RET670-1_87T	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev. 0	Rel. date 31-05-2024	Lan en


Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SeqTypeUPol		Zero seq				
Setting Group1						
Operation		On				
EnDir		Disable				
2ndHarmStab		20	%	5	100	
BlkParTransf		Off				
SOTF		Off				
EnPhaseSel		Off				
Step 1						
Setting Group1						
DirMode1		Non-directional				
Characterist1		IEC Norm. inv.				
IN1>		25	%IB	1	2500	
IN1>Max		100	%IB	1	2500	
IN1>Min		20	%IB	1	2500	
t1		0.000	s	0.000	60.000	
k1		0.20		0.01	999.00	
IMin1		25.00	%IB	1.00	2000.00	
t1Min		0.000	s	0.000	60.000	
IN1Mult		1.0		1.0	10.0	
ResetTypeCrv1		Instantaneous				
tReset1		0.020	s	0.000	60.000	
HarmBlock1		On				
Step 2						
Setting Group1						
DirMode2		Off				
Step 3						
Setting Group1						
DirMode3		Off				
Step 4						
Setting Group1						
DirMode4		Off				

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-1_87T	Document id.			
Rev.	Modification	Rel. date	Created by	Based on			Approved by			Rev. 0	Rel. date 31-05-2024	Language en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
ThermalOverload(26,θ>)						
LCPTTR: 1						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation		On				
TRef		90	Deg C	0	300	
IRef		120	%IB	10	400	
IMult		1		1	5	
Tau		45	Min	1	1000	
AlarmTemp		90	Deg C	0	200	
TripTemp		100	Deg C	0	300	
ReclTemp		80	Deg C	0	300	
tPulse		0.10	s	0.05	0.30	
AmbiSens		Off				
DefaultAmbTemp		40	Deg C	-50	100	
DefaultTemp		50	Deg C	-50	300	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN1		
				Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.401 TRAF0-1	HITACHI	Created by	Title RET670-1_87T	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev. 0	Rel. date 31-05-2024	Lan en

	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

General data

Relay Details

Relay Model Ref = RET670
Relay Frequency = 50
Ordering Code = 670*2.2.1

Bay Details

Bay Name = Trafo-1, 2
Bay Reference = 400/33/33kV TRANSFORMER C&R PANEL

Transformer Details

Rated Power = 330.0 / 165.0 / 165.0 MVA
Voltage Ratio = 400 / 33 / 33 kV
Normal Tap No Load Voltage OLTC1 = 400 kV
Vector Group = YNa0yn0
% Impedance at 75°C = 15.0 (at 165 MVA base)
Frequency: = 50 Hz

HV Winding (W1) Detail

CT ratio = 2000-1000-500/1
CT ratio - Adopted = 1000 / 1 A
CT Class = PS
Rated Power = 330 MVA
Rated Voltage = 400 kV
CTStarPoint = To Object

MV Winding (W2) Detail

CT ratio = 4000/1
CT ratio - Adopted = 4000 / 1 A
CT Class = PS
Rated Power = 165 MVA
Rated Voltage = 33.00 kV
CTStarPoint = To Object

LV Winding (W3) Detail


CT ratio = 4000/1
CT ratio - Adopted = 4000 / 1 A
CT Class = PS
Rated Power = 165 MVA
Rated Voltage = 33 kV
CTStarPoint = To Object

Rated Current

HV = Rated Power / ((√3) * Rated Voltage)
= (330x 10⁶) / ((√3) x 400 x 10³)
= 476 A

MV = Rated Power / ((√3) * Rated Voltage)
= (330x 10⁶) / ((√3) x 33 x 10³)
= 2887 A

LV = Rated Power / ((√3) * Rated Voltage)
= (165x 10⁶) / ((√3) x 33 x 10³)
= 2887 A

	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Global Base Values GBASVAL

GBASVAL:1 (HV Rated current)

Ubase = 400 kV
Ibase = 476 A
Sbase = 330.0 MVA

GBASVAL:2 (LV Rated current)

Ubase = 33 kV
Ibase = 2886.8 A
Sbase = 165.0 MVA

GBASVAL:3 (HV CT Ratio)

Ubase = 400.0 kV
Ibase = 1000 A
Sbase = 692.8 MVA

GBASVAL:4 (LV CT Ratio)


Ubase = 33 kV
Ibase = 4000 A
Sbase = 228.6 MVA

GBASVAL:5 (HV SEF)

Ubase = 400.0 kV
Ibase = 1000 A
Sbase = 692.8 MVA

GBASVAL:6 (LV CT ratio- REF/SEF)

Ubase = 33 kV
Ibase = 4000 A
Sbase = 228.6 MVA

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Transformer differential protection:T3WPDIF 87T (Transformer Differential)

HV Bushing CTR-1000/1
LV Bushing CTR-4000/1

A. Setting of minimum differential operating current

The basic setting defines the pick-up setting of the differential protection for internal faults. The lowest possible value should be chosen to enable it to detect the worst-case faults. However, there can be small differential current during normal operation, which may result in tripping.

To assure that the load current does not cause unwanted operation, IdMin is set based on the calculation below.

Differential current error at rated load current in different tap positions

Tap Position	I_{HV}	$I_{LV}+I_{MV}$	I_{DIFF}	%Error in Ibase
9	476.3	5773.7	$476.33 - (5773.68 * (33 / 400)) = 0.0014$	0.000
1	433.0	5773.7	$433.03 - (5773.68 * (33 / 400)) = -43.2986$	-9.090
17	529.3	5773.7	$529.25 - (5773.68 * (33 / 400)) = 52.9214$	11.110

Maximum error due to OLTC (at tap 17 the Rated Current) = 11.110 %

CT Error (HV & LV Assumed) = 5 %

Relay Error (As per technical data of the relay) = 1 %

Total Error (In terms of % of the rated current of the transformer) = 11.11 + 5 + 1

= 17.110 %

Based on the above considered criteria the selected Idmin value as follows:

IdMin = 20 %

IdMin = 0.20 *Ibase

Ibase = 476 A

B. Setting of cross-over point between slope 1 and slope 2

This section corresponds to normal load currents - upto the max. values of normal load currents. Here, the setting of differential current corresponds to Idmin i.e. basic differential current setting which determines the pickup of the relay. As per the recommendation of the relay manual, the same setting is selected as default - Restraint current upto 125% of the base current.

EndSection1 = 1.25 Ibase

setting is selected as default - 40%

SlopeSection2 = 40% *Ibias

D. Setting of cross-over point between slope 2 and slope 3

The section corresponds to currents above normal load currents, and to provide stability for high-resistive faults under heavy load conditions.

EndSection2 = 3 Ibase

Idiff Value at End Section 2 = SlopeSection2 x EndSection2

= 0.9

E. Setting of slope 2 stabilisation

This is higher % bias setting applied for Restraint currents above End section 2 - to provide stability for heavy through fault currents. As per recommendation of relay manual, same setting is selected as default - 80%


SlopeSection3 = 80% *Ibias

F. Unrestrained operation level

As per the Application manual(AM) Unrestrained operation level has default value of IdUnre = 10pu, which is typically acceptable for most of standard power transformer applications.

Hence the considered Setting of minimum differential operating current for unrestraint step

HV Through fault current = HV Full load current / % Impedance

	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232	
	PGGA-2875	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2		Rev No.	2

Considering 120% of through fault Current

Thus Idunre setting proposed

$$= (476.33 / (15/100))$$

$$= 3175.53$$

$$= 3175.53 \times 1.2$$

$$= 3810.636$$

$$= 8$$

$$= 9 \quad *I_{base}$$

A

A

G. Setting the operation of Cross Blocking logic

The meaning of Cross-blocking is that the 2nd and 5th harmonic blocking in one phase will also block the differential function in other phases.

OpCrossBlock = On

H. Set the second and fifth harmonic stabilizing level when transformers are inside the zone

Setting considered as per Manual

I2/I1Ratio	=	15	%
I5/I1Ratio	=	25	%

I. Set the operation of Negative sequence differential protection!

NegSeqDiff - Negative sequence fault discriminator is an important compliment to the percentage restrained differential function. As it is directional, it can distinguish between external and internal faults; also at difficult conditions such as CT saturation.

OpNegSeqDiff = Off

J. Setting of minimum negative sequence differential current level

The negative sequence currents are compared if above the set threshold value IminNegSeq. If either these sums is below the threshold, no comparison is made. Neither internal, nor external fault will be declared in this case. As per Relay manual recommendation, default value of 0.04xIbase can be used if no special account. considerations such as e.g. extremely weak sources must be taken into

IminNegSeq = 0.04 *Ibase As per Manual

K. Setting of the Relay operating angles.

This is the setting of the relay operating angle of the negative sequence Ibased internal / external fault discriminator. The directional test is made such that, the phase angle of the sum of Local negative sequence currents is compared to the phase angle of the sum of remote negative sequence currents. Ideally, the angle is 0 degree for internal faults and 180 degree for external faults. However, considering for safety margin, because of errors caused by CT saturation as well as different phase angles of sources, we set the Relay operate angle setting to 60 degrees default.

NegSeqROA = 60 As per Manual

Restrained differential function characteristic

As per the Manual






Figure 44: Description of the restrained-, and the unrestrained operate characteristics

Adopted Curve




 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Directional phase overcurrent protection, four steps: OC4PTOC

Settings recommended :

CT Ratio / Base Current	=	1000	/1A
Full load Current	=	476.33	A
Fault Current	=	3285.03	A
Direction mode of step-1	=	Non-Directional	
Operating Current	=	600	A
Phase Overcurrent Operate Level of Step-1	=	60	%IB
Required Operating time	=	1.00	s
Time multiplier of Step-1	=	0.25	s
Operating Characteristics of Step-1	=	IEC Normal Inverse	
Direction mode of step-2	=	Non-Directional	
Operating Current	=	3500	A
Phase Overcurrent Operate Level of Step-2	=	350	%IB
Definite Time Delay of Step-2	=	0.15	s
Operating Characteristics of Step-2	=	IEC Def. Time	
Disabled all other steps:			
Direction mode of step-3	=	Off	
Direction mode of step-4	=	Off	

Note: Operating current, TMS and trip time delay values are revised as per customer comments

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Directional residual overcurrent protection, four steps: EF4PTOC


Settings recommended :

CT Ratio / Base Current	=	1000	/1A
Full load Current	=	476.33	A
Fault Current	=	3285.03	A
Direction mode of step-1	=	Non-Directional	
Operating Current	=	100	A
Phase Overcurrent Operate Level of Step-1	=	10.00	%IB
Required Operating time	=	0.57	s

Note: The IDMT curve shall saturate if the fault current more than 20 times of pickup current. 20 times of set current considered for TMS calculation.

Fault Current considered	=	1905.3	A
Time Multiplier Setting K	=	$(T_{req} * (I_f / I_s)^{0.02-1}) / 0.14$	
Time multiplier of Step-1	=	0.25	s
Operating Characteristics of Step-1	=	IEC Normal Inverse	
Direction mode of step-2	=	Non-Directional	
Operating Current	=	1500	A
Residual Overcurrent Operate Level of Step-2	=	150	%IB
Definite Time Delay of Step-2	=	0.15	s
Operating Characteristics of Step-2	=	IEC Def. Time	
Disabled all other steps:			
Direction mode of step-3	=	Off	
Direction mode of step-4	=	Off	

Note: Operating current, TMS and trip time delay values are revised as per customer comments

 PGGA-2875		PROTECTION RELAY SETTING CALCULATION		Contract No.	3100139976, IN-56423232
		TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2		Date	2-Aug-24
Prep.	SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Chk.	PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2		Rev No.	2

Setting of two step Under-voltage protection function (UV2PTUV) (Only for Alarm not for tripping)

The two-step Undervoltage function is used for supervision and detection of abnormal conditions.

Activation of the Under-voltage function

Operation = On

ConnType:

Sets whether the measurement shall be phase to earth fundamental value (PhG), phase to phase fundamental value (PhPh), phase to earth RMS value (PhG RMS) or phase to phase RMS value (PhPh RMS).

Selected setting for ConnType = PhN DFT

Setting of the Base voltage level on which the voltage settings are based

Ubase = 400 kV

Setting of parameters for stage1


OperationStep1 = On

Selected setting for Characterist1 = Definite Time

Selected setting for OpMode1 = 1out of 3

Selected setting for U1< = 90 %Ubase

Selected setting for def.time delay t1 = 0.00 Sec

 PGGA-2875		PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
		TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	2-Aug-24
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Chk.	PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Setting of two step Over-voltage protection function (OV2PTOV)

The two-step overvoltage function is used for supervision and detection of abnormal conditions.

Activation of the over-voltage function

ConnType:

Sets whether the measurement shall be phase to earth fundamental value (PhG), phase to phase fundamental value (PhPh), phase to earth RMS value (PhG RMS) or phase to phase RMS value (PhPh RMS).

Selected setting for ConnType = PhN DFT

Setting of the Base voltage level on which the voltage settings are based

Ubase = 400

Setting of parameters for stage1 (For Alarm)

OperationStep1 = On

Selected setting for Characterist1 = Definite Time

Selected setting for OpMode1 = 1out of 3

Selected setting Fuse Failure Supervision = 110 %Ubase

Selected setting for def.time delay t1 = 5.00 Sec

Setting of parameters for stage2 (For Trip)


OperationStep2 = On

Selected setting for Characterist2 = Definite Time

Selected setting for OpMode2 = 1out of 3

Selected setting for U2> = 140 %Ubase

Selected setting for def. time delay t2 = 0.10 Sec

	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875-ApT	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

HV High Impedance Restricted Earth Fault Protection:-

Transformer Details

Power Rating	=	330	MVA
HV Voltage Rating	=	400	kV
HV Neutral Grounding Type	=	Solid	
% Impedance	=	15.00	%
Full load Current	=	476.33	A

Phase Side CT Details:

CT Ratio	=	1000/1	A
CT Adopttted Primary Rating	=	1000	A
CT Secondary Rating	=	1	A
CT Resistance	=	3.5	Ohm
CT Knee Point Voltage	=	300	V
CT Magnetising Current @Vk	=	30	mA

Neutral Side CT Details:

CT Ratio	=	1000/1	A
CT Adopttted Primary Rating	=	1000	A
CT Secondary Rating	=	1	A
CT Resistance	=	3.5	Ohm
CT Knee Point Voltage	=	300	V
CT Magnetising Current @Vk	=	30.00	mA

HV Side Lead Resistance Details:

Lead Resistance at 75 ⁰ C /kM	=	7	Ohm/kM	(Assumed)
Length of Lead of two path (Wire loop length across CT to Relay)	=	200	Meter	

Relay Details


Relay Type	=	RET670	
Relay Burden	=	0.02	VA
Relay Order Code	=	-	
Relay Serial No	=	0	

REF Pickup Setting

REF Function	=	On	
Relay Pickup Setting	=	10	%

Calculations:

Calculation of Fault MVA (Sf)	=	$MVA/\%Impedance$	
	=	$(330)/(15/100)$	
	=	2200	MVA
Calculation of Fault Current (If)	=	$(Sf*1000)/(\sqrt{3}*kV)$	
	=	$(2200*1000)/(1.732*400)$	
	=	3175.4	A

 Hitachi Energy	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232	
	PGGA-2875-ApT	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2	

Calculation of HV Lead Resiatance (RI) = *Lead Resiatance per kM*Length of Lead*
= $7*(200/1000)$
= **1.40** Ohm

Calculation of HV CT Secondary Loop Resiatance (Rloop) = $Rct+RI+Rb$
= $3.5+1.4+0.02$
= **4.92** Ohm

Calculation of Stabilising Voltage(Vstab) = $Rloop*If$
= $4.92*(3175.43/(1000/1))$
= 15.62 V
≈ **16** V

By considering a margin of 85% for Field measurements,
Vstab = **30** V

The magnetizing curve of the CT is assumed to be linear. The magnetizing current at the stabilizing voltage can be estimated as:

Calculation of Magnetising Current @Vstab (Imstab) = $(Vstab/Vk)*Im$
= $(30/300)*(0.03)$
= **3.000** mA

To obtain adequate protection stability,of the sum of magnetizing currents of all connected CTs. the setting current **Irs** must be at the minimum of the sum of magnetizing currents of all connected CTs

Number of CT's = **4**

Calculation Sum of Magnetising Current (Imsum) = $No.of Ct's*Imstab$
= $4*3$
= **12.00** mA

Relay setting should be greater than **Imsum**.

Adopted Setting for realy (Irs) = 10 %
= **0.05** A

Selected relay setting 50mA is greater than 12mA


The resistance of the stabilizing resistor is calculated as follows

Calculation of Stabilising Resistor (Rstab) = $Vstab/Irs$
= $30/(0.05)$
= **600** Ohm

Thermal Rating of stabilising resistor:

Calculation of Power Rating of Stabilising Resistor (Pstab) = $Vk^2/(Rstab*10)$
= $600^2/(600*10)$
= **60** W

Half Second Power Rating (Phalf) = $Vf^2/Rstab$
= **1806.9** W

	PROTECTION RELAY SETTING CALCULATION		Contract No.	3100139976, IN-56423232
	PGGA-2875-ApT	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2		Rev No.	2

LV2 High Impedance Restricted Earth Fault Protection:- 33 kV

Transformer Details

Power Rating	=	165	MVA
MV Voltage Rating	=	33	kV
MV Neutral Grounding Type	=	Solid	
% Impedance	=	15.00	%
Full load Current	=	2886.8	A

LV Side CT Details:

CT Ratio	=	4000/1	A
CT Adoptted Primary Rating	=	4000	A
CT Secondary Rating	=	1	A
CT Resistance	=	13.0	Ohm
CT Knee Point Voltage	=	500	V
CT Magnetising Current @Vk	=	30	mA

LV Neutral Side CT Details:

CT Ratio	=	4000/1	A
CT Adoptted Primary Rating	=	4000	A
CT Secondary Rating	=	1	A
CT Resistance	=	13.0	Ohm
CT Knee Point Voltage	=	500	V
CT Magnetising Current @Vk	=	30	mA

LV Side Lead Resistance Details:

Lead Resistance at 75 ⁰ C /kM	=	7	Ohm/kM	(Assumed)
Length of Lead of two path (Wire loop length across CT to Relay)	=	200	Meter	

Relay Details


Relay Type	=	RET670	
Relay Burden	=	0.02	VA
Relay Order Code	=	-	
Relay Serial No	=	0	


REF Pickup Setting

REF Function	=	On	
Relay Pickup Setting	=	10	%

Calculations:

Calculation of Fault MVA (Sf)	=	$MVA/\%Impedance$	
	=	$(165)/(15/100)$	
	=	1100	MVA
Calculation of Fault Current (If)	=	$(Sf*1000)/(\sqrt{3}*kV)$	
	=	$(1100*1000)/(1.732*33)$	
	=	19245	A

 Hitachi Energy	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	PGGA-2875-ApT	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2
Calculation of LV Lead Resistance (RI)	=	Lead Resiatnce per km*Length of Lead	
	=	7*(200/1000)	
	=	1.40 Ohm	
Calculation of LV CT Secondary Loop Resiatnce (Rloop)	=	Rct+RI+Rb	
	=	13+1.4+0.02	
	=	14.4 Ohm	
Calculation of Stabilising Voltage(Vstab)	=	Rloop*If	
	=	14.42*(19245.01/(4000/1))	
	=	69.38 V	
	≈	70 V	
By considering a margin of 50% for Field measurements,			
Vstab	=	105 V	
The magnetizing curve of the CT is assumed to be linear. The magnetizing current at the stabilizing voltage can be estimated as:			
Calculation of Magnetising Current @Vstab (Imstab)	=	(Vstab/Vk)*Im	
	=	(105/500)*(0.03)	
	=	6.300 mA	
To obtain adequate protection stability,of the sum of magnetizing currents of all connected CTs. the setting current Irs must be at the minimum of the sum of magnetizing currents of all connected CTs			
Number of CT's	=	4	
Calculation Sum of Magnetising Current (Imsum)	=	No.of Ct's*Imstab	
	=	4*6.3	
	=	25.20 mA	
Relay setting should be greater than Imsum.			
Adopted Setting for realy (Irs)	=	10 %	
	=	0.07 A	
with safety margine	=	0.10 A	
Selected relay setting 100mA is greater than 25.2mA			
The resistance of the stabilizing resistor is calculated as follows			
Calculation of Stabilising Resistor (Rstab)	=	Vstab/Irs	
	=	105/(0.1)	
	=	1050 Ohm	
Thermal Rating of stabilising resistor:			
Calculation of Power Rating of Stabilising Resistor (Pstab)	=	Vk ² /(Rstab*10)	
	=	600 ² /(1050*10)	
	=	34.286 W	
Half Second Power Rating (Phalf)	=	Vf ² /Rstab	
	=	3362.6 W	

 PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
	TRANSFORMER DIFFERENTIAL PROTECTION-RET670-2	Date	02-Aug-24
Prepared: SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PDAA
Checked: PN	400/33/33kV TRANSFORMER C&R PANEL RET670_Trafo-1, 2	Rev No.	2

Residual overcurrent protection, four steps: EF4PTOC

LV-1 STAND BY EARTH FAULT PROTECTION 51NS

CT Ratio / Base Current	=	4000	/1A
Full load Current	=	2886.84	A
Fault Current	=	19245.60	A
Direction mode of step-1	=	Non-Directional	
Operating Current	=	1000	A
Phase Overcurrent Operate Level of Step-1	=	25.00	%Ib
TMS	=	0.20	
Operating Characteristics of Step-1	=	IEC Normal Inverse	

Disabled all other steps:

Stand-by earth fault settings values revised here from customer comments, LV it is coming-35% of full load current of the Transformer, it is looking high and not recommended.

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
TRM_40						
NAMECH1		HV_MN+TIE_CT_RPH			16 characters	
ChannelType1		CurrentProtection				
RatedTrans1		1.0	A	0.1	300.0	
CTStarPoint1		ToObject				
CTsec1		1	A	1	10	
CTprim1		1000	A	1	99999	
NAMECH2		HV_MN+TIE_CT_YPH			16 characters	
ChannelType2		CurrentProtection				
RatedTrans2		1.0	A	0.1	300.0	
CTStarPoint2		ToObject				
CTsec2		1	A	1	10	
CTprim2		1000	A	1	99999	
NAMECH3		HV_MN+TIE_CT_BPH			16 characters	
ChannelType3		CurrentProtection				
RatedTrans3		1.0	A	0.1	300.0	
CTStarPoint3		ToObject				
CTsec3		1	A	1	10	
CTprim3		1000	A	1	99999	
NAMECH4		HV_NCT_64R			16 characters	
ChannelType4		CurrentProtection				
RatedTrans4		1.0	A	0.1	300.0	
CTStarPoint4		ToObject				
CTsec4		1	A	1	10	
CTprim4		1000	A	1	99999	
NAMECH5		LV2_NCT_64R			16 characters	
ChannelType5		CurrentProtection				
RatedTrans5		1.0	A	0.1	300.0	
CTStarPoint5		ToObject				
CTsec5		1	A	1	10	
CTprim5		4000	A	1	99999	
NAMECH6		LV1_NCT_SBEF			16 characters	
ChannelType6		CurrentProtection				
RatedTrans6		1.0	A	0.1	300.0	
CTStarPoint6		ToObject				
CTsec6		1	A	1	10	
CTprim6		4000	A	1	99999	
NAMECH7		HV_BCT_RPH			16 characters	
ChannelType7		CurrentProtection				
RatedTrans7		1.0	A	0.1	300.0	
CTStarPoint7		ToObject				
CTsec7		1	A	1	10	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.
Re v.	Modification	Rel. date	Created by	Based on			Approved by		

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
CTprim7		1000	A	1	99999	
NAMECH8		HV_BCT_YPH			16 characters	
ChannelType8		CurrentProtection				
RatedTrans8		1.0	A	0.1	300.0	
CTStarPoint8		ToObject				
CTsec8		1	A	1	10	
CTprim8		1000	A	1	99999	
NAMECH9		HV_BCT_BPH			16 characters	
ChannelType9		CurrentProtection				
RatedTrans9		1.0	A	0.1	300.0	
CTStarPoint9		ToObject				
CTsec9		1	A	1	10	
CTprim9		1000	A	1	99999	
NAMECH10		HV_SEL_VT_RP H			16 characters	
ChannelType10		Voltage				
RatedTrans10		110.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		400.00	kV	0.05	2000.00	
NAMECH11		HV_SEL_VT_YP H			16 characters	
ChannelType11		Voltage				
RatedTrans11		110.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		400.00	kV	0.05	2000.00	
NAMECH12		HV_SEL_VT_BP H			16 characters	
ChannelType12		Voltage				
RatedTrans12		110.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		400.00	kV	0.05	2000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2			
				Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.401 TRAF0-1	HITACHI	Created by	Title RET670-2_64R	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by			Rev. 0	Rel. date 03-06-2024	Lan en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
TRM_41						
NAMECH1		LV1_BCT_RPH			16 characters	
ChannelType1		CurrentProtection				
RatedTrans1		1.0	A	0.1	300.0	
CTStarPoint1		ToObject				
CTsec1		1	A	1	10	
CTprim1		4000	A	1	99999	
NAMECH2		LV1_BCT_YPH			16 characters	
ChannelType2		CurrentProtection				
RatedTrans2		1.0	A	0.1	300.0	
CTStarPoint2		ToObject				
CTsec2		1	A	1	10	
CTprim2		4000	A	1	99999	
NAMECH3		LV1_BCT_BPH			16 characters	
ChannelType3		CurrentProtection				
RatedTrans3		1.0	A	0.1	300.0	
CTStarPoint3		ToObject				
CTsec3		1	A	1	10	
CTprim3		4000	A	1	99999	
NAMECH4		LV2_BCT_RPH			16 characters	
ChannelType4		CurrentProtection				
RatedTrans4		1.0	A	0.1	300.0	
CTStarPoint4		ToObject				
CTsec4		1	A	1	10	
CTprim4		4000	A	1	99999	
NAMECH5		LV2_BCT_YPH			16 characters	
ChannelType5		CurrentProtection				
RatedTrans5		1.0	A	0.1	300.0	
CTStarPoint5		ToObject				
CTsec5		1	A	1	10	
CTprim5		4000	A	1	99999	
NAMECH6		LV2_BCT_BPH			16 characters	
ChannelType6		CurrentProtection				
RatedTrans6		1.0	A	0.1	300.0	
CTStarPoint6		ToObject				
CTsec6		1	A	1	10	
CTprim6		4000	A	1	99999	
NAMECH7		CH7(I)			16 characters	
ChannelType7		CurrentProtection				
RatedTrans7		1.0	A	0.1	300.0	
CTStarPoint7		ToObject				
CTsec7		1	A	1	10	
CTprim7		3000	A	1	99999	
NAMECH8		CH8(I)			16 characters	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.
Re v.	Modification	Rel. date	Created by	Based on			Approved by		

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
ChannelType8		CurrentProtection				
RatedTrans8		1.0	A	0.1	300.0	
CTStarPoint8		ToObject				
CTsec8		1	A	1	10	
CTprim8		4000	A	1	99999	
NAMECH9		CH9(I)			16 characters	
ChannelType9		CurrentProtection				
RatedTrans9		1.0	A	0.1	300.0	
CTStarPoint9		ToObject				
CTsec9		1	A	1	10	
CTprim9		4000	A	1	99999	
NAMECH10		CH10(U)			16 characters	
ChannelType10		Voltage				
RatedTrans10		110.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		400.00	kV	0.05	2000.00	
NAMECH11		CH11(U)			16 characters	
ChannelType11		Voltage				
RatedTrans11		110.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		400.00	kV	0.05	2000.00	
NAMECH12		CH12(U)			16 characters	
ChannelType12		Voltage				
RatedTrans12		110.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		400.00	kV	0.05	2000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by			Rev. 0	Rel. date 03-06-2024	Language en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Global base values						
GBASVAL: 1						
UBase		400.00	kV	0.05	2000.00	
IBase		476	A	1	99999	
SBase		330.00	MVA	1.00	200000.00	
GBASVAL: 2						
UBase		33.00	kV	0.05	2000.00	
IBase		2887	A	1	99999	
SBase		165.00	MVA	1.00	200000.00	
GBASVAL: 3						
UBase		400.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		692.80	MVA	1.00	200000.00	
GBASVAL: 4						
UBase		33.00	kV	0.05	2000.00	
IBase		4000	A	1	99999	
SBase		228.60	MVA	1.00	200000.00	
GBASVAL: 5						
UBase		400.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		228.60	MVA	1.00	200000.00	
GBASVAL: 6						
UBase		33.00	kV	0.05	2000.00	
IBase		4000	A	1	99999	
SBase		228.60	MVA	1.00	200000.00	
GBASVAL: 7						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 8						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 9						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 10						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 11						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
									0	03-06-2024	en

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SBase		400.00	MVA	1.00	200000.00	
GBASVAL: 12						
UBase		220.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		400.00	MVA	1.00	200000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2			
				Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan	2 / 2
									0	03-06-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
DisturbanceReport						
DRPRDRE: 1						
Operation		On				
COMTRADEFormat		2013(Float32)				
PreFaultRecT		0.50	s	0.05	9.90	
PostFaultRecT		2.5	s	0.1	10.0	
TimeLimit		3.0	s	0.5	10.0	
PostRetrig		On				
ZeroAngleRef		1	Ch	1	40	
SetInfoInDRep		Disable				
OpModeTest		Off				

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan	1 / 1
									0	03-06-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
DIFF_PROTN						
Differential protection						
TransformerDiff3Wind(87T,3Id/I>)						
TRAFO_DIFF_PROTN; T3WPDIF: 1						
GlobalBaseSelW1		1		1	12	
GlobalBaseSelW2		2		1	12	
GlobalBaseSelW3		2		1	12	
ConnectTypeW1		WYE (Y)				
ConnectTypeW2		WYE (Y)				
ConnectTypeW3		WYE (Y)				
ClockNumberW2		0 [0 deg]				
ClockNumberW3		0 [0 deg]				
ZSCurrSubtrW1		On				
ZSCurrSubtrW2		On				
ZSCurrSubtrW3		On				
TconfigForW1		No				
TconfigForW2		No				
TconfigForW3		No				
LocationOLTC1		Not Used				
LocationOLTC2		Not Used				
Setting Group1						
Operation		On				
SOTFMode		Off				
IDiffAlarm		0.15	IB	0.05	1.00	
tAlarmDelay		1.000	s	0.000	60.000	
IdMin		0.20	IB	0.10	0.60	
EndSection1		1.25	IB	0.20	1.50	
EndSection2		3.00	IB	1.00	10.00	
SlopeSection2		40.0	%	10.0	50.0	
SlopeSection3		80.0	%	30.0	100.0	
IdUnre		9.00	IB	1.00	100.00	
I2/I1Ratio		15.0	%	5.0	100.0	
I5/I1Ratio		25.0	%	5.0	100.0	
CrossBlockEn		On				
NegSeqDiffEn		Off				
OpenCTEnable		On				
tOCTAlarmDelay		5.000	s	0.100	10.000	
tOCTResetDelay		0.200	s	0.100	10.000	
tOCTUnrstDelay		10.00	s	0.10	6000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.
Re v.	Modification	Rel. date	Created by	Based on			Approved by		

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
REF_PROTN						
Differential protection						
HighImpDifferential(87,I>)						
HV_REF; HZPDIF: 1						
Setting Group1						
Operation		On				
U>Alarm		16	V	5	500	
tAlarm		5.000	s	0.000	60.000	
U>Trip		27	V	10	900	
SeriesResistor		540	Ohm	50	20000	
LV2_REF; HZPDIF: 2						
Setting Group1						
Operation		On				
U>Alarm		70	V	5	500	
tAlarm		5.000	s	0.000	60.000	
U>Trip		105	V	10	900	
SeriesResistor		1050	Ohm	50	20000	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAF0-1	HITACHI	Created by	Title RET670-2_64R	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
									0	03-06-2024	en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Voltage protection						
Overexcitation(24,U/f>)						
HV_OVERFLUX; OEXPVPH: 1						
GlobalBaseSel		1		1	12	
MeasuredU		PosSeq				
MeasuredI		PosSeq				
Setting Group1						
Operation		ON				
OverVoltage2Step(59,2(3U>))						
HV_OVER_VOLTAGE; OV2PTOV: 1						
General						
GlobalBaseSel		1		1	12	
ConnType		PhN RMS				
Setting Group1						
Operation		On				
Step 1						
Setting Group1						
OperationStep1		On				
Characterist1		Definite time				
OpMode1		1 out of 3				
U1>		110.0	%UB	1.0	200.0	
t1		5.00	s	0.00	6000.00	
tReset1		0.025	s	0.000	60.000	
t1Min		0.000	s	0.000	60.000	
ResetTypeCrv1		Instantaneous				
tIReset1		0.025	s	0.000	60.000	
k1		1.00		0.05	1.10	
ACrv1		1.000		0.005	200.000	
BCrv1		1.00		0.50	100.00	
CCrv1		1.0		0.0	1.0	
DCrv1		1.000		0.000	60.000	
PCrv1		1.000		0.000	3.000	
CrvSat1		0	%	0	100	
HystAbs1		0.1	%UB	0.0	50.0	
Step 2						
Setting Group1						
OperationStep2		On				
Characterist2		Definite time				
OpMode2		1 out of 3				
U2>		140.0	%UB	1.0	200.0	
t2		0.100	s	0.000	60.000	
tReset2		0.025	s	0.000	60.000	
t2Min		0.000	s	0.000	60.000	
ResetTypeCrv2		Instantaneous				

					Project	Responsible department	Technical ref...	Document kind	Doc. designation		
					ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1Q01FN2		
				Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title	Document id.		
					_SID.400KV.401 TRAFO-1		Approved by	RET670-2_64R			
Re	Modification	Rel. date	Created by	Based on				Rev.	Rel. date	Lan	1 / 2
v.								0	03-06-2024	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
tIReset2		0.025	s	0.000	60.000	
k2		1.00		0.05	1.10	
ACrv2		1.000		0.005	200.000	
BCrv2		1.00		0.50	100.00	
CCrv2		1.0		0.0	1.0	
DCrv2		1.000		0.000	60.000	
PCrv2		1.000		0.000	3.000	
CrvSat2		1	%	0	100	
HystAbs2		0.1	%UB	0.0	50.0	
UnderVoltage2Step(27,2(3U<))						
HV_UNDER_VOLTAGE; UV2PTUV: 1						
General						
GlobalBaseSel		1		1	12	
ConnType		PhN RMS				
Setting Group1						
Operation						
		On				
Step 1						
Setting Group1						
OperationStep1						
		On				
Characterist1						
		Definite time				
OpMode1						
		1 out of 3				
U1<		90.0	%UB	1.0	100.0	
t1		0.00	s	0.00	6000.00	
tReset1		0.025	s	0.000	60.000	
t1Min		0.000	s	0.000	60.000	
ResetTypeCrv1						
		Instantaneous				
tIReset1		0.025	s	0.000	60.000	
k1		1.00		0.05	1.10	
ACrv1		1.000		0.005	200.000	
BCrv1		1.00		0.50	100.00	
CCrv1		1.0		0.0	1.0	
DCrv1		1.000		0.000	60.000	
PCrv1		1.000		0.000	3.000	
CrvSat1		1	%	0	100	
IntBlkSel1						
		Block all				
IntBlkStVal1		20	%UB	1	50	
tBlkUV1		0.000	s	0.000	60.000	
HystAbs1		0.1	%UB	0.0	50.0	
Step 2						
Setting Group1						
OperationStep2						
		Off				

					Project	Responsible department	Technical ref...	Document kind	Doc. designation			
					ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1Q01FN2			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title	Document id.			
							Approved by	RET670-2_64R				
Re v.	Modification	Rel. date	Created by	Based on					Rev.	Rel. date	Lan	2 / 2
									0	03-06-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
I_PROTN						
Current protection						
InstPhaseOverCurrent(50,3I>>)						
HV_INST_OC; PHPIOC: 1						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
LV1_SW-1_INST_OC; PHPIOC: 2						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
LV1_SW-2_INST_OC; PHPIOC: 3						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
LV2_SW-3_INST_OC; PHPIOC: 4						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
LV2_SW-4_INST_OC; PHPIOC: 5						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
InstResidualOverCurrent(50N,IN>>)						
HV_INST_EF; EFPIOC: 1						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
LV1_SW-1_INST_EF; EFPIOC: 2						
GlobalBaseSel		2		1	12	
Setting Group1						
Operation						
		Off				
LV1_SW-1_INST_EF; EFPIOC: 3						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
LV1_SW-1_INST_EF; EFPIOC: 4						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				
LV1_SW-1_INST_EF; EFPIOC: 5						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation						
		Off				

					Project	Responsible department	Technical ref...	Document kind	Doc. designation			
					ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1Q01FN2			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title	Document id.			
							Approved by	RET670-2_64R				
Re v.	Modification	Rel. date	Created by	Based on					Rev.	Rel. date	Lan	1 / 5
									0	03-06-2024	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
PhaseOverCurrent4Step(51_67.4(3I>))						
HV_DIR_OC; OC4PTOC: 1						
General						
GlobalBaseSel		3		1	12	
MeasType		DFT				
Setting Group1						
Operation		On				
StartPhSel		1 out of 3				
IMinOpPhSel		7	%IB	1	100	
2ndHarmStab		20	%	5	100	
Step 1						
Setting Group1						
DirMode1		Non-directional				
Characterist1		IEC Norm. inv.				
I1>		60	%IB	5	2500	
I1>Max		2000	%IB	5	2500	
I1>Min		50	%IB	5	2500	
t1		0.000	s	0.000	60.000	
k1		0.25		0.01	999.00	
IMin1		60	%IB	1	1000	
t1Min		0.000	s	0.000	60.000	
I1Mult		1.0		1.0	10.0	
ResetTypeCrv1		Instantaneous				
tReset1		0.020	s	0.000	60.000	
HarmBlock1		On				
Step 2						
Setting Group1						
DirMode2		Non-directional				
Characterist2		IEC Def. Time				
I2>		350	%IB	5	2500	
I2>Max		2500	%IB	5	2500	
I2>Min		5	%IB	5	2500	
t2		0.150	s	0.000	60.000	
I2Mult		1.0		1.0	10.0	
tReset2		0.020	s	0.000	60.000	
HarmBlock2		Off				
Step 3						
Setting Group1						
DirMode3		Off				
Step 4						
Setting Group1						
DirMode4		Off				

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.		
Rev.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
								0	03-06-2024	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
HV_OC4PTOC; OC4PTOC: 2						
General						
GlobalBaseSel		2		1	12	
MeasType		DFT				
Setting Group1						
Operation		Off				
Not Used; OC4PTOC: 3						
General						
GlobalBaseSel		1		1	12	
MeasType		DFT				
Setting Group1						
Operation		Off				
Not Used; OC4PTOC: 4						
General						
GlobalBaseSel		1		1	12	
MeasType		DFT				
Setting Group1						
Operation		Off				
ResidualOverCurr4Step(51N_67N,4(IN>))						
HV_DIR_EF; EF4PTOC: 1						
General						
GlobalBaseSel		3		1	12	
SeqTypeDir		Zero seq				
SeqTypePol		Zero seq				
SeqTypeUPol		Zero seq				
Setting Group1						
Operation		On				
EnDir		Disable				
2ndHarmStab		20	%	5	100	
BlkParTransf		Off				
SOTF		Off				
EnPhaseSel		Off				
Step 1						
Setting Group1						
DirMode1		Non-directional				
Characterist1		IEC Norm. inv.				
IN1>		10	%IB	1	2500	
IN1>Max		100	%IB	1	2500	
IN1>Min		10	%IB	1	2500	
t1		0.000	s	0.000	60.000	
k1		0.25		0.01	999.00	
IMin1		10.00	%IB	1.00	2000.00	
t1Min		0.000	s	0.000	60.000	
IN1Mult		1.0		1.0	10.0	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
								0	03-06-2024	en	


Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
ResetTypeCrv1		Instantaneous				
tReset1		0.020	s	0.000	60.000	
HarmBlock1		On				
Step 2						
Setting Group1						
DirMode2		Non-directional				
Characterist2		IEC Def. Time				
IN2>		150	%IB	1	2500	
IN2>Max		2500	%IB	1	2500	
IN2>Min		20	%IB	1	2500	
t2		0.150	s	0.000	60.000	
IN2Mult		1.0		1.0	10.0	
tReset2		0.020	s	0.000	60.000	
HarmBlock2		On				
Step 3						
Setting Group1						
DirMode3		Off				
Step 4						
Setting Group1						
DirMode4		Off				
LV1_SEF; EF4PTOC: 2						
General						
GlobalBaseSel		6		1	12	
SeqTypeDir		Zero seq				
SeqTypePol		Zero seq				
SeqTypeUPol		Zero seq				
Setting Group1						
Operation		On				
EnDir		Disable				
2ndHarmStab		20	%	5	100	
BlkParTransf		Off				
SOTF		Off				
EnPhaseSel		Off				
Step 1						
Setting Group1						
DirMode1		Non-directional				
Characterist1		IEC Norm. inv.				
IN1>		25	%IB	1	2500	
IN1>Max		100	%IB	1	2500	
IN1>Min		25	%IB	1	2500	
t1		0.000	s	0.000	60.000	
k1		0.20		0.01	999.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.
Rev.	Modification	Rel. date	Created by	Based on			Approved by		

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
IMin1		10.00	%IB	1.00	2000.00	
t1Min		0.000	s	0.000	60.000	
IN1Mult		1.0		1.0	10.0	
ResetTypeCrv1		Instantaneous				
tReset1		0.020	s	0.000	60.000	
HarmBlock1		On				
Step 2						
Setting Group1						
DirMode2		Off				
Step 3						
Setting Group1						
DirMode3		Off				
Step 4						
Setting Group1						
DirMode4		Off				

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
OEXPVPH: 1						
GlobalBaseSel		1		1	12	
MeasuredU		L1L2				
MeasuredI		L1L2				
Setting Group1						
Operation		On				
V/Hz>		120.0	%UB/f	100.0	180.0	
V/Hz>>		140.0	%UB/f	100.0	200.0	
XLeak		0.075	Ohm	0.000	200.000	
TrPulse		0.100	s	0.000	60.000	
tMin		2.000	s	0.000	60.000	
tMax		9000.00	s	0.00	9000.00	
tCooling		1200.00	s	0.10	9000.00	
CurveType		Tailor made				
kForIEEE		1		1	60	
t1Tailor		100.00	s	0.00	9000.00	
t2Tailor		50.00	s	0.00	9000.00	
t3Tailor		30.00	s	0.00	9000.00	
t4Tailor		15.00	s	0.00	9000.00	
t5Tailor		6.00	s	0.00	9000.00	
t6Tailor		2.00	s	0.00	9000.00	
AlarmLevel		95.0	%	50.0	120.0	
tAlarm		5.00	s	0.00	9000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01FN2		
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title RET670-2_64R	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan
								0	03-06-2024	en	

 PGGA-2875		PROTECTION RELAY SETTING CALCULATION		Contract No.	3100139976, IN-56423232
		400/33/33kV TRANSFORMER C&R PANEL-1, 2 (BAY)		Date	30-May-24
Prep.	SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Chk.	PN	BAY CONTROL UNIT- REC670		Rev No.	0


1 General Data

System Details

Voltage	Un	=	400	kV
Frequency	F	=	50	Hz
Station Name		=	400kV BADISID SUBSTATION	
Feeder Name		=	400/33/33kV TRANSFORMER C&R PANEL-1, 2	
Bay No		=	BAY	
Relay Ordering Code		=	REC670	
CT Primary ratio (Adopted Tap)		=	1000	A
CT Secondary ratio		=	1	A
VT Primary ratio		=	400	kV
VT Secondary ratio		=	0.11	kV
Transformer MVA		=	330	MVA
Transformer Full Load current		=	476.3	
Maximum 3phase fault current		=	10500	A
Maximum 3phase fault current		=	10500	A

Global Base Values

GBASVAL:1				
Base Voltage	Ubase	=	400	kV
Base Current	Ibase	=	476.3	A
Base Power	Sbase	=	330	MVA

 Hitachi Energy PGGA-2875		PROTECTION RELAY SETTING CALCULATION		Contract No.	3100139976, IN-56423232
		400/33/33kV TRANSFORMER C&R PANEL-1, 2 (BAY)		Date	30-May-24
Prep.	SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PDAA
Chk.	PN	BAY CONTROL UNIT- REC670		Rev No.	0

2 Synchrocheck & Energizing check Function, SESRSYN (25)

The protection function has Synchrocheck, energizing check and synchronizing features.

Operation = On

Synchronizing function:

To allow closing of breakers between asynchronous networks, a synchronizing feature is provided.

The synchronizing feature measures the conditions across the circuit breaker and also determines the angle change occurring during the closing delay of the circuit breaker, from the measured slip frequency. The breaker close command is issued at the optimum time when conditions across the breaker are satisfied in order to avoid stress on the network and its components.

Operation = Off

Synchronism check function:

The synchrocheck mode checks that the voltages on both sides of the circuit breaker are perfectly synchronized (to perform a controlled reconnection) and gives permission to close the circuit breaker when certain conditions are simultaneously fulfilled.

Operation = On

The following conditions to be simultaneously fulfilled for Synchrocheck operation.

- The measured voltages (U-Line and U-Bus) are higher than the set values *UHighBusSC* and *UHighLineSC*.
- The difference in the voltage is smaller than the set value of *UDiffSC*.
- The difference in frequency is less than the set value of *FreqDiffM* and *FreqDiffA*.
- The frequency rate of change is less than set value for both U-Bus and U-Line.
- The difference in the phase angle is smaller than the set value of *PhaseDiffM* and *PhaseDiffA*

Settings criteria:

• *UHighBusSC* and *UHighLineSC* threshold voltages have to be set lower than the value where the network is expected to close with the synchronism check. A typical value is 80% of the rated voltage.

• *UDiffSC*, voltage difference between the line voltage and the bus voltage. A normal setting is 0.10-0.15 p.u.

• *FreqDiffM* and *FreqDiffA*, shall be chosen depending on the condition in the network.

At steady conditions, a low frequency difference setting is needed. Typical value for *FreqDiffM* is 10mHz.

At autoreclosing, a bigger frequency difference setting is preferable. Typical value for *FreqDiffA* is 100-200mHz.

• *PhaseDiffM* and *PhaseDiffA*, shall be chosen depending on conditions in the network.

The phase angle setting must be chosen to allow closing under maximum load condition. In most networks the maximum occurring angle is below 25 degrees.

UHighBusSC	=	80	%UBB
UHighLineSC	=	80	%UBL
UDiffSC	=	0.1	pu
FreqDiffA	=	0.1	Hz
FreqDiffM	=	0.1	Hz
PhaseDiffA	=	20	Deg
PhaseDiffM	=	20	Deg

Energizing check function:

The energizing check function checks that at least one side is dead to ensure that closing

Energizing from different directions can be different for automatic reclosing and manual closing of the circuit breaker. Two different settings can be used for automatic and manual closing of the circuit breaker.

For manual closing it is also possible to allow closing when both sides of the breaker are dead.

AutoEnerg = Both
ManEnerg = Both
ManEnergDBDL = Off

Settings criteria:

• *UHighBusEnerg* and *UHighLineEnerg* threshold voltages have to be set lower than the value at which the network is considered to be energized. A typical value can be 80% of the base voltages.

• *ULowBusEnerg* and *ULowLineEnerg* threshold voltages have to be set to a value greater than the value where the network is considered not to be energized. A typical value can be 20% of the base voltages.

• *UMaxEnerg* setting is used to block the closing when the voltage on the live side is above the set value.

• *tAutoEnerg* and *tManEnerg*, is to ensure that the dead side remains de-energized and that the condition is not due to a temporary interference. Circuit breaker closing is thus not permitted until the energizing condition has remained constant throughout the set delay setting time.

ULiveBusEnerg	=	80	%UBB
ULiveLineEnerg	=	80	%UBL
UDeadBusEnerg	=	20	%UBB
UDeadLineEnerg	=	20	%UBL
UMaxEnerg	=	115	%UB
tAutoEnerg	=	0.1	s
tManEnerg	=	0.1	s

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
TRM_40						
NAMECH1		MAIN+TIE_CT_RPH			16 characters	
ChannelType1		CurrentProtection				
RatedTrans1		1.0	A	0.1	300.0	
CTStarPoint1		ToObject				
CTsec1		1	A	1	10	
CTprim1		1000	A	1	99999	
NAMECH2		MAIN+TIE_CT_YPH			16 characters	
ChannelType2		CurrentProtection				
RatedTrans2		1.0	A	0.1	300.0	
CTStarPoint2		ToObject				
CTsec2		1	A	1	10	
CTprim2		1000	A	1	99999	
NAMECH3		MAIN+TIE_CT_BPH			16 characters	
ChannelType3		CurrentProtection				
RatedTrans3		1.0	A	0.1	300.0	
CTStarPoint3		ToObject				
CTsec3		1	A	1	10	
CTprim3		1000	A	1	99999	
NAMECH4		CH4(I)			16 characters	
ChannelType4		CurrentProtection				
RatedTrans4		1.0	A	0.1	300.0	
CTStarPoint4		ToObject				
CTsec4		1	A	1	10	
CTprim4		1000	A	1	99999	
NAMECH5		CH5(I)			16 characters	
ChannelType5		CurrentProtection				
RatedTrans5		1.0	A	0.1	300.0	
CTStarPoint5		ToObject				
CTsec5		1	A	1	10	
CTprim5		1000	A	1	99999	
NAMECH6		CH6(I)			16 characters	
ChannelType6		CurrentProtection				
RatedTrans6		1.0	A	0.1	300.0	
CTStarPoint6		ToObject				
CTsec6		1	A	1	10	
CTprim6		1000	A	1	99999	
NAMECH7		SELECTED_CVT_RPH			16 characters	
ChannelType7		Voltage				
RatedTrans7		110.0	V	0.1	300.0	
VTsec7		110.000	V	0.001	999.999	

					Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01KF1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan	1 / 2
									0	12/6/2020	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
VTprim7		1000.00	kV	0.05	2000.00	
NAMECH8		SELECTED_CVT_YPH			16 characters	
ChannelType8		Voltage				
RatedTrans8		110.0	V	0.1	300.0	
VTsec8		110.000	V	0.001	999.999	
VTprim8		400.00	kV	0.05	2000.00	
NAMECH9		SELECTED_CVT_BPH			16 characters	
ChannelType9		Voltage				
RatedTrans9		110.0	V	0.1	300.0	
VTsec9		110.000	V	0.001	999.999	
VTprim9		400.00	kV	0.05	2000.00	
NAMECH10		FOR_FUTURE_SYNCH			16 characters	
ChannelType10		Voltage				
RatedTrans10		110.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		400.00	kV	0.05	2000.00	
NAMECH11		400KV_BUS-1_CVT			16 characters	
ChannelType11		Voltage				
RatedTrans11		110.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		400.00	kV	0.05	2000.00	
NAMECH12		400KV_BUS-2_CVT			16 characters	
ChannelType12		Voltage				
RatedTrans12		110.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		400.00	kV	0.05	2000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01KF1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAF0-1	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by			Rev. 0	Rel. date 12/6/2020	Language en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Global base values						
GBASVAL: 1						
UBase		400.00	kV	0.05	2000.00	
IBase		476	A	1	99999	
SBase		330.00	MVA	1.00	200000.00	
GBASVAL: 2						
UBase		400.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		330.00	MVA	1.00	200000.00	
GBASVAL: 3						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 4						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 5						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 6						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 7						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 8						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 9						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 10						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 11						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	

					Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01KF1			
				Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.401 TRAFO-1	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev.	Rel. date	Lan	1 / 2
									0	12/6/2020	en	


Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 12						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	

					Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q01KF1		
				Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.401 TRAFO-1	HITACHI	Created by	Title REC670_BCU	Document id.		
Re v.	Modification	Rel. date	Created by	Based on			Approved by		Rev. 0	Rel. date 12/6/2020	Lan en

Settings


Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SYNC						
Control						
Synchronizing(25,SC/VC)						
SESRYN: 1						
General						
GblBaseSelBus		1		1	12	
GblBaseSelLine		1		1	12	
SelPhaseBus1		Phase L1L2				
SelPhaseBus2		Phase L1L2				
SelPhaseLine1		Phase L1L2				
SelPhaseLine2		Phase L1L2				
CBCConfig		1 1/2 bus CB				
PhaseShift		0	Deg	-180	180	
Setting Group1						
Operation						
		On				
Synchronizing						
Setting Group1						
OperationSynch		Off				
CloseAngleMax		15.0	Deg	15.0	30.0	
Synchrocheck						
Setting Group1						
OperationSC		On				
UHighBusSC		80.0	%UBB	50.0	120.0	
UHighLineSC		80.0	%UBL	50.0	120.0	
UDiffSC		0.10	pu	0.02	0.50	
FreqDiffA		0.100	Hz	0.003	1.000	
FreqDiffM		0.100	Hz	0.003	1.000	
PhaseDiffA		20.0	Deg	5.0	90.0	
PhaseDiffM		20.0	Deg	5.0	90.0	
tSCA		0.100	s	0.000	60.000	
tSCM		0.100	s	0.000	60.000	
Energizingcheck						
Setting Group1						
AutoEnerg		Both				
ManEnerg		Both				
ManEnergDBDL		Off				
UHighBusEnerg		80.0	%UBB	50.0	120.0	
UHighLineEnerg		80.0	%UBL	50.0	120.0	
ULowBusEnerg		20.0	%UBB	10.0	80.0	
ULowLineEnerg		20.0	%UBL	10.0	80.0	
UMaxEnerg		115.0	%UB	50.0	180.0	
tAutoEnerg		0.100	s	0.000	60.000	
tManEnerg		0.100	s	0.000	60.000	

					Project	Responsible department	Technical ref...	Document kind	Doc. designation			
					ADANI_GREEN_BADI_SID	ABB Ltd.			AA1C1Q01KF1			
				Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title	Document id.			
					_SID.400KV.401 TRAFO-1		Approved by	REC670_BCU				
Re v.	Modification	Rel. date	Created by	Based on					Rev.	Rel. date	Lan	1 / 1
									0	12/6/2020	en	

		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400kV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

REB670
400 kV BUSBAR PROTECTION SETTING CALCULATION

Rev	Description	Date
0	Initial submission for review and Approval	31-05-2024
1	Revised as per customer comments for Approval	28-06-2024

		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400kV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

1 System Details

Type of Busbars = One and Half Breaker Scheme
 No. of Bus zones = 2
 BBP Configuration = Two zone, 3 Phase Busbar Protection, 87B
 Relay Type = REB670
 Fault Current = 10500
 CT Ratio Details

330MVA Transformer-1	Bay: 401	2000/1A
330MVA Transformer-2	Bay: 404	2000/1A
Future Transformer-1	Bay: 407	2000/1A
Future Transformer-2	Bay: 410	2000/1A
400kV Line-1	Bay: 403	2000/1A
400kV TIE	Bay: 405	2000/1A
Future Line-1	Bay: 409	2000/1A
Future Line-2	Bay: 412	2000/1A

Maximum load current in any bay = 660 MVA (Line)
 = 953 A
 Minimum load current in any bay = 330 MVA (Trafo)
 = 476 A

2 Low Impedance Busbar Differential Protection, BZNTPDIF-A & BZNTPDIF-B

The numerical and low-impedance differential protection is designed for fast and selective protection for faults within protected zones. The fast tripping time (Typically 11ms) of the low-impedance differential protection function is especially advantageous for power system networks with high fault levels or where fast fault clearance is required for power system stability. Also it is stable for external faults, even with heavy CT saturation and during external fault clearance or auto-reclosing. It features two differential protection functions:

- a) Bias differential protection algorithm,
- b) Sensitive differential protection algorithm

The overall percentage operating characteristic of busbar differential protection is shown in Figure-1





Figure-1, Differential protection Operating characteristic

Among the Operation mode (OperationBBP) of entire busbar differential protection function; One of the following two alternatives shall be selected,

- On, when this mode is selected, the entire busbar differential protection function enabled.
- Off, when this mode is selected, the entire busbar differential protection function is disabled.

Operation = On

DiffTripOut

		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400KV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

This setting determines how the zone trip output TRIP from each differential zone shall behave. One of the following two alternatives shall be selected,

- SelfReset, when this mode is selected, the output TRIP will be reset to logical value zero after the settable time determined by the setting parameter *tTripHold*.

- Latched, when this mode is selected, the output TRIP will be latched and it requires manual reset command. This reset command can be given from local HMI or via communication link.

DiffTripOut = Self Reset

tTripHold

This setting defines the drop-off time for the output TRIP of each differential zone. If the trip output TRIP is in the SelfReset mode, Time delay can be set from 0.000s to 60.000s in step of 0.001s. Default value is 0.200s.

tTripHold = 0.200 s

2.1 Bias differential protection algorithm

DiffOperLevel:

The minimum pickup level for the bias differential feature of each differential zone. It shall be entered directly in primary amperes.

Proposed differential pickup current is 120% of maximum load current in any bay

= 1.2 * 953 A
= 1143.60 A
DiffOperLevel = 1144 A

Slope: The operating slope for the bias differential operating characteristic is fixed at 53% in the algorithm.




Figure-2, Bias Differential Operating characteristic

2.1.1 Open CT detection

The innovative measuring algorithm provides stability for open or short-circuited main CT secondary circuits, without any need for additional check zone. The open CT detection algorithm is completely phase-segregated.

At detection of problems in CT secondary circuits, the differential protection can be instantly blocked at the affected phase and latched alarms are provided. Alternatively, the differential protection can be automatically desensitized in order to ensure busbar differential protection stability during normal through-load condition.


There are two type of open CT detection logic available,

- Fast operating open CT detection logic
- Slow operating open CT detection logic

OCTOperLev

This setting determines the minimum pickup level for the slow and fast OCT feature for each differential zone. It shall be entered directly in primary amperes.

The setting is used to define the minimum expected through-load current drop during open CT duration. This level should be set as high as necessary to prevent spurious blocking due to the false differential current caused by CT errors, meanwhile as low as necessary to detect the open circuit condition for the smallest loaded CT connected to the differential zone. If the minimum load current is not available or if the load current is too small when compared to the differential current present due to CT

		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400KV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

errors from the use of different types of CT in the same substation, this value may be settled in between 20% ~ 80% of the rated primary current of the CT with the smallest ratio. This built-in feature allows the protection IED to be set very sensitive, even to a level lower than the maximum CT primary rating in the station.

We propose Open CT current pickup level of 95 A (20% of transformer bay full load current -420A)
OCTOperLev = 95 A

Slow Open CT detection

Slow operating open CT detection logic will detect most abnormalities in the CT secondary circuits or in the dynamic zone selection logic, with a setttable time delay. Especially such logic is capable of detecting the open CT condition when a new bay is connected to the differential zone with its CT secondary circuits being open circuited.

This setting determines operation mode of the slow OCT algorithm. One of the following three alternatives shall be selected,

- Off, when this mode is selected, the slow OCT feature is completely disabled.
- Block, when this mode is selected, the operation of the slow OCT feature completely blocks the operation of the differential protection. Note that this blocking is selective both zone and phase wise.
- Supervise, when this mode is selected, the operation of the slow OCT feature blocks the operation of the differential protection only for the integrated differential current lower than a pre-set level determined by the setting *OCTReleaseLev*.

SlowOCTOper = Supervise

This setting defined the time of the slow OCT algorithm for each differential zone.

Time delay can be set from 0.00s to 6000.00s in step of 0.01s. Default value is 20.00s. Minimum setting should always be above 1s.

tSlowOCT = 20.00 sec

Fast Open CT detection

Fast operating open CT detection logic detects instantly the moment when a healthy CT secondary circuit carrying the load current is accidentally open- or short-circuited (that is, current interrupted to the differential relay). Note that this logic can only detect open CT condition when an already connected CT with the secondary load current being open circuited. It does not detect, for example, the situation when a new bay is connected to the differential zone with its CT secondary circuits being open circuited.

This setting determines operation mode of the fast OCT algorithm. One of the following three alternatives shall be selected for each differential zone function block,


- Off, when this mode is selected, the fast OCT feature is completely disabled.
- Block, when this mode is selected, the operation of the fast OCT feature always blocks the operation of the differential protection. It shall be noted that this blocking is selective both zone and phase wise.
- Supervise, when this mode is selected, the operation of the fast OCT feature blocks the operation of the differential protection only for the integrated differential current lower than a pre-set level determined by the setting *OCTReleaseLev*.

FastOCTOper = Supervise

OCTReleaseLev

This setting determines the differential current level, above which the OCT feature will again allow the differential protection operation, when in Supervise mode. It shall be entered directly in primary amperes.

Proposed setting is 125% of maximum load current

		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
PGGA-2875		400KV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

OCTReleaseLev = 1.25 x 953
OCTReleaseLev = 1191 A

2.1.2 Differential zone measurement supervision

There are dual supervision of current measurements for each differential protection zone:

- Differential current supervision - The algorithm operates and issues a binary alarm output after a settable time delay $tIdAlarm$, when differential current exceeds a set level $IdAlarmLev$.
- Incoming current supervision - The algorithm operates and issues immediately a binary alarm output, when the incoming current level, that is, bus through-going current level, exceeds a set level $linAlarmLev$.

Both supervision features are phase segregated and their binary alarm outputs can be used either for triggering disturbance recorder or for alarming purposes.

IdAlarmLev

This setting determines the differential current level, above which the differential current alarm becomes active after the settable time delay determined by the parameter setting $tIdAlarm$. It shall be entered directly in primary amperes.

20% of differential operating level is recommended and the same is proposed.

$IdAlarmLev = 1144 \times 0.2$ A
 $= 229$ A

tIdAlarm

This setting determines the time delay of the differential current alarm feature for each differential zone. Time delay can be set from 0.00s to 6000.00s in step of 0.01s. Default value is 30.00s.

$tIdAlarm = 5$ sec

linAlarmLev

This setting determines the incoming current level (bus thorough-going current level), above which the incoming current alarm becomes active instantaneously. It shall be entered directly in primary amperes.

The proposed setting is 115% of all Incoming current

$linAlarmLev = 1.15 \times 1906$ A (Assumed 2 lines are incoming)
 $= 2192$ A

2.2 Sensitive differential protection algorithm

The operation and operating characteristic of the sensitive differential protection are independent from those of the bias differential protection algorithm. Sensitive differential protection algorithm is used,


- to detect internal busbar earth faults in low impedance earthed power systems, the systems where the earth-fault current is limited to a certain level, typically between 300A and 2000A primary by a neutral point reactor or resistor, or
- to be used when energizing a bus via long line, since this requires higher sensitivity from busbar differential protection.

This setting determines operation mode of the sensitive differential algorithm for each differential zone. One of the following two alternatives shall be selected,

- On, when this mode is selected, the sensitive differential algorithm is enabled. Note that the binary input ENSENS of the differential zone function block must also have logical value one, in order to get the sensitive differential algorithm operate.
- Off, when this mode is selected, the sensitive differential algorithm is disabled.

We proposed the settings to set as OFF for this station.

SensDiffOper = Off

 PGGA-2875		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
		400kV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

3 Check Zone Protection, BCZTPDIF

When CT-circuits are switched, depending on the position of the busbar disconnectors, there is a possibility that some of the CT secondary circuits can be open circuited by a mistake. At the same time this can cause unwanted operation of the differential protection scheme. Therefore, check zone is often required for a traditional high impedance busbar protection scheme when switching in CT-circuit is done.

The check zone, will detect faults anywhere in the substation but cannot distinguish in which part of the station the fault is located. When the check zone detects a fault it gives a release signal to the busbar protection relays in all individual, discriminating zones. The busbar protection discriminating zones will then trip the part of the substation that is faulty.

The check zone has slightly different operating characteristic from the usual discriminating zones. For the check zone the resultant outgoing current is used as stabilizing current instead of total incoming current in order to guarantee the check zone operation for all possible operating conditions in the station.

For substations where traditional "CT switching" is not required (that is, single busbar station or one-and-half breaker station), a check zone must not be used. For such applications, the check zone shall be disabled.




Figure-3, Check zone Operating characteristic

Fault condition/type	Check zone operated	TRIP
Differential protection algorithm operated	No	No
	Yes	Yes

Figure-4, Differential Protection Trip outputs

If both bus Zones (Zone A and Zone B) are part of one relay then Check Zone Must be enabled for one and half Breaker scheme also

This setting determined whether check zone shall be enabled or not. One of the following two alternatives shall be selected:

1. On, when this mode is selected the check zone is enabled.
2. Off, when this mode is selected the check zone is disabled.


Operation = ON

OperLevel

This setting determines the minimum start level for the check zone. It shall be entered directly in primary amperes.

Pickup: As per Application manual (Rev.K), Clause 6.1.3.3, the check zone minimum operational level shall be set equal to or less than the corresponding operating level of the usual discriminating zones. Hence we proposed the setting same as differential operating level.

OperLevel = 1144 A

 PGGA-2875		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
		400kV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

Slope: This setting determines the slope of the check zone operating characteristic. It can be set from 0.10 to 0.90 in step of 0.01. Default value is 0.15.

Slope = 0.15





Figure-5, Check zone Differential Operating characteristic

 PGGA-2875		DANI GREEN ENERGY LIMITED (ADANI RENEWABLE	Contract No.	3100139976, IN-56423232
		400kV BADISID SUBSTATION	Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

4 Breaker Failure Protection (50BF), CCRBRF

Note: The same setting is applicable for all 400 kV Bays.

The function will issue a backup trip command to adjacent circuit breakers in case of failure to trip of the “normal” circuit breaker for the protected object. The function can also give a retrip command. This means that a second trip signal is sent to the protected object circuit breaker. The retrip function can be used to increase the probability of operation of the breaker, or it can be used to avoid backup trip of many breakers in case of mistakes during relay maintenance and test.

Operation = On

Base current can be chosen full load current of transformer for transformer bays

Base current can be chosen same as CT primary current for other bays

Function Mode

It defines the way the detection of failure of the breaker is performed.

In Current mode, compares the measured phase current magnitude to setting $I_{Ph>}$ (operate phase current level).

Criterion is active, if the measured current magnitude is higher than the set value.

In CB Pos mode, the CB auxiliary contact status is used as an indicator of the failure of the breaker.

In Current or CB Pos mode, both ways of detections can be activated.

The CB Pos mode is used in applications where the fault current through the circuit breaker is small.

FunctionMode = Current

StartMode

It is possible to select how t1 and t2 timers are run and consequently how output commands are given from the function.

In LatchedStart option (“By external start signal which is internally latched”) - When function is once started by external START signal, the timers t1 and t2 will always elapse and then measurement criterion defined by parameter *FunctionMode* will be always checked in order to verify if the appropriate command shall be given out from the function.

In FollowStart option (“Follow the external start signal only”) - The timers t1 and t2 will run while external START signal is present. If they elapse then measurement criterion defined by parameter *FunctionMode* will be checked in order to verify if the appropriate command shall be given out from the function

In FollowStart&Mode option (“Follow external start signal and selected FunctionMode”) - The timers t1 and t2 will run while external START signal is present and in the same time the measurement criterion defined by parameter *FunctionMode* is active. If they elapse then the appropriate command will be given out from the function.


StartMode = FollowStart&Mode

tStartTimeout

When one of the two “Follow Modes” is used, there is a settable timer tStartTimeout which will block the external START input signal when it times-out. This will automatically also reset the t1 and t2 timers and consequently prevent any backup trip command

Recommended default setting is 1 sec

tStartTimeout = 1 sec

 Hitachi Energy PGGA-2875	DANI GREEN ENERGY LIMITED (ADANI RENEWABLE)		Contract No.	3100139976, IN-56423232
	400kV BADISID SUBSTATION		Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

RetripMode

The setting defines how the retrip function shall operate

RetripMode	FunctionMode	Description
Off	N/A	the re-trip function is disabled
UseFunctionMode	Current	a phase current must be larger than the set operate level to allow re-trip once the t1 timer elapses
	CB Pos	Re-trip is done when breaker position indicates that breaker is still closed after re-trip time has elapsed
	Current or CB Pos	both methods are used
Always	N/A	Re-trip is always given when t1 elapses without any further checks

Figure-7, Dependencies between RetripMode and FunctionMode

RetripMode: = UseFunction Mode

IP>

It is Current level for detection of breaker failure. This parameter should be set so that faults with small fault current can be detected. The setting can be chosen in accordance with the most sensitive protection function to start the breaker failure protection.

Proposed Setting is 20% of Ibase

IP> = 20 Ibase

Time delay of the re-trip.

Time delay of the retrip. The setting can be given within the range 0 – 60s in steps of 0.001s.

t1 (Proposed) = 0.1 sec

Time delay of the back-up trip

Time delay of the backup trip. The choice of this setting is made as short as possible at the same time as unwanted operation must be avoided. Typical setting is 90 – 200ms (also dependent of retrip timer)

The minimum time delay for the backup trip can be estimated as,

t2 ≥ t1 time delay + CB open time + Relay reset time + Safety margin

Maximum CB open time (Assumed)	=	60	ms
Breaker failure Relay reset time	=	15	ms
Safety margin	=	20	ms
t2 (Calculated)	=	0.195	sec
t2 (Proposed)	=	0.2	sec

Time delay for alarm

Time delay for alarm in case of indication of faulty circuit breaker. There is a binary input CBFLT from the circuit breaker. This signal is activated when internal supervision in the circuit breaker detect that the circuit breaker is unable to clear fault. This could be the case when gas pressure is low in a SF6 circuit breaker. After the set time an alarm is given, so that actions can be done to repair the circuit breaker. The time delay for back-up trip is bypassed when the CBFLT is active.

tCBAAlarm = 5 sec

Trip pulse duration

This setting must be larger than the critical impulse time of circuit breakers to be tripped from the breaker failure protection. Typical setting is 200 ms.

tPulse = 0.2 sec

Hitachi Energy PGGA-2875	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)		Contract No.	3100139976, IN-56423232
	400kV BADISID SUBSTATION		Date	30-05-2024
Prep.	SS	400 kV BUSBAR PROTECTION SETTING CALCULATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BUSBAR PROTECTION - REB670	Rev No.	0

5 End Fault Protection using Single phase O/C protection (51), PH4SPTOC

Note: The same setting is applicable for all 400kV Bays.

The function is used as end fault protection to clear faults between current transformer and circuit breaker.

End Fault Protection is related to primary faults between main CT and CB in a feeder bay. Therefore, it is directly related to the position of the main CT in feeder bay. Three CT positions in feeder bays are typically used in power systems, as shown in Figure-8.




Figure-8, Typical CT locations in a feeder bay

where:

- A two CTs are available one on each side of the feeder circuit breaker
- B one CT is available on the line side of the feeder circuit breaker
- C one CT is available on the bus side of the feeder circuit breaker
- 1 End fault region

Our 400kV system is same as Figure-8-B. Both Busbar protection & Line protection CTs are available on the feeder side of the feeder circuit breaker, the primary fault between CT and CB will cause problems as well. Typically such fault will not be detected by feeder protection. to completely clear such fault the associated busbar protection must be tripped by end fault protection. It shall be noted that the busbar differential protection will classify such fault as external and without any additional measures the busbar protection will remain stable.

Operation	=	On	
Ibase 1	=	476	A
Ibase 2	=	2000	A

Function 1 (Transformer Bay)

OpStep 1	=	On	
Phase Overcurrent Op	=	20	%IB
Pickup setting in Prima	=	95.2	A
Pickup setting in Secon	=	0.05	A
Operating Curve type	=	IEC Def. Time	
Operate Delay time	=	0.05	s

Function 2 (Line Bay)

OpStep 1	=	On	
Phase Overcurrent Op	=	20	%IB
Pickup setting in Prima	=	400	A
Pickup setting in Secon	=	0.20	A
Operating Curve type	=	IEC Def. Time	
Operate Delay time	=	0.05	s

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
CTprim7		2000	A	1	99999	
NAMECH8		BAY407_CT_YPH			16 characters	
ChannelType8		CurrentProtection				
RatedTrans8		1.0	A	0.1	300.0	
CTStarPoint8		ToObject				
CTsec8		1	A	1	10	
CTprim8		2000	A	1	99999	
NAMECH9		BAY407_CT_BPH			16 characters	
ChannelType9		CurrentProtection				
RatedTrans9		1.0	A	0.1	300.0	
CTStarPoint9		ToObject				
CTsec9		1	A	1	10	
CTprim9		2000	A	1	99999	
NAMECH10		BAY410_CT_RPH			16 characters	
ChannelType10		CurrentProtection				
RatedTrans10		1.0	A	0.1	300.0	
CTStarPoint10		ToObject				
CTsec10		1	A	1	10	
CTprim10		2000	A	1	99999	
NAMECH11		BAY410_CT_YPH			16 characters	
ChannelType11		CurrentProtection				
RatedTrans11		1.0	A	0.1	300.0	
CTStarPoint11		ToObject				
CTsec11		1	A	1	10	
CTprim11		2000	A	1	99999	
NAMECH12		BAY410_CT_BPH			16 characters	
ChannelType12		CurrentProtection				
RatedTrans12		1.0	A	0.1	300.0	
CTStarPoint12		ToObject				
CTsec12		1	A	1	10	
CTprim12		2000	A	1	99999	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation			
				ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1QBB1FN1			
			Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title REB670_M1	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by		Rev.	Rel. date	Lan	2 / 2
				_SID.400KV.400KV BUSBAR				0	21-03-2024	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
CTprim7		2000	A	1	99999	
NAMECH8		BAY409_CT_YPH			16 characters	
ChannelType8		CurrentProtection				
RatedTrans8		1.0	A	0.1	300.0	
CTStarPoint8		ToObject				
CTsec8		1	A	1	10	
CTprim8		2000	A	1	99999	
NAMECH9		BAY409_CT_BPH			16 characters	
ChannelType9		CurrentProtection				
RatedTrans9		1.0	A	0.1	300.0	
CTStarPoint9		ToObject				
CTsec9		1	A	1	10	
CTprim9		2000	A	1	99999	
NAMECH10		BAY412_CT_RPH			16 characters	
ChannelType10		CurrentProtection				
RatedTrans10		1.0	A	0.1	300.0	
CTStarPoint10		ToObject				
CTsec10		1	A	1	10	
CTprim10		2000	A	1	99999	
NAMECH11		BAY412_CT_YPH			16 characters	
ChannelType11		CurrentProtection				
RatedTrans11		1.0	A	0.1	300.0	
CTStarPoint11		ToObject				
CTsec11		1	A	1	10	
CTprim11		2000	A	1	99999	
NAMECH12		BAY412_CT_BPH			16 characters	
ChannelType12		CurrentProtection				
RatedTrans12		1.0	A	0.1	300.0	
CTStarPoint12		ToObject				
CTsec12		1	A	1	10	
CTprim12		2000	A	1	99999	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation			
				ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1QBB1FN1			
			Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title REB670_M1	Document id.			
Re v.	Modification	Rel. date	Created by	SID.400KV.400KV BUSBAR		Approved by		Rev.	Rel. date	Lan	2 / 2
								0	21-03-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Global base values						
GBASVAL: 1						
UBase		400.00	kV	0.05	2000.00	
IBase		476	A	1	99999	
SBase		330.00	MVA	1.00	200000.00	
GBASVAL: 2						
UBase		400.00	kV	0.05	2000.00	
IBase		953	A	1	99999	
SBase		660.00	MVA	1.00	200000.00	
GBASVAL: 3						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 4						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 5						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 6						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 7						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 8						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 9						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 10						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 11						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation		
				ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1QBB1FN1		
			Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.400KV BUSBAR	HITACHI	Created by	Title REB670_M1	Document id.		
Re v.	Modification	Rel. date	Created by			Approved by		Rev.	Rel. date	Lan
								0	21-03-2024	en

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SBase		1385.00	MVA	1.00	200000.00	
GBASVAL: 12						
UBase		400.00	kV	0.05	2000.00	
IBase		2000	A	1	99999	
SBase		1385.00	MVA	1.00	200000.00	

				Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1QBB1FN1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.400KV BUSBAR	HITACHI	Created by	Title REB670_M1	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by			Rev. 0	Rel. date 21-03-2024	Lan en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
PROT						
Differential protection						
BBP4Z3Ph(87B,3Id/I)						
Common						
BDZS4GAPC: 1						
General						
CondBlkMode		Common				
Setting Group1						
OperationBBP		On				
DiffTripOut		SelfReset				
tTripPulse		0.20	s	0.03	60.00	
tMergALM		300	s	10	6000	
OpAutoRstFOCT		Disable				
Differential Zones						
Setting Group1						
DiffOperLev		1144	A	100	50000	
tTripHold		0.20	s	0.05	60.00	
SlowOCTOper		Supervise				
FastOCTOper		Supervise				
OCTOperLev		95	A	50	10000	
OCTReleaseLev		1191	A	100	50000	
tSlowOCT		20.0	s	1.0	600.0	
IdAlarmLev		229	A	50	20000	
tIdAlarm		5.0	s	5.0	600.0	
linAlarmLev		2192	A	50	50000	
SensDiffOper		Off				
SlopeDZ		0.53				
tZeroI_Feeder		0.20	s	0.04	1.00	
Interconnectors						
Setting Group1						
tZeroI_BIC		0.20	s	0.04	1.00	
tInvertI_BIC		0.20	s	0.04	1.00	
ZoneOperations						
BTZNPDIIF_Z1: 1						
Setting Group1						
Operation		On				
BTZNPDIIF_Z2: 2						
Setting Group1						
Operation		On				
CheckZone						
CHECKZONE; BTCZPDIF: 1						
Setting Group1						
Operation		On				
OperLevel		1144	A	100	50000	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation		
				ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1QBB1FN1		
			Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title REB670_M1	Document id.		
Re v.	Modification	Rel. date	Created by	SID.400KV.400KV BUSBAR		Approved by		Rev.	Rel. date	Lan
								0	21-03-2024	en

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SlopeCZ		0.15		0.10	0.90	

				Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1QBB1FN1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.400KV BUSBAR	HITACHI	Created by	Title REB670_M1	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by		Rev.	Rel. date	Lan	2 / 2
								0	21-03-2024	en	

ADANI GREEN ENERGY LIMITED
(ADANI RENEWABLES)
400kV BADISID SUBSTATION LINE PROTECTION
RELAY SETTING CALCULATION

400kV BADISID SUBSTATION

ADANI GREEN ENERGY LIMITED

We reserve all rights in this document and in the information contained therein. Reproduction use or disclosure to third parties without express authority is strictly forbidden. Copyright © by Hitachi Energy India Limited.

"Disclaimer – Unauthorized access

The offered solution may be accessed through the customer network and therefore represents a danger which poses a potential threat of intrusion by unauthorized parties. Therefore, Hitachi Energy India Limited strongly recommends that the customer insures/implements necessary protection measures against the possibility of such unauthorized access.

Hitachi Energy India Limited disclaims any responsibility and shall under no circumstances be liable for damages or malfunctions caused by external intrusion of any kind whatsoever."


400kV BADISID SUBSTATION LINE PROTECTION RELAY SETTING CALCULATION

DOCUMENT	400kV BADISID SUBSTATION LINE PROTECTION RELAY SETTING CALCULATION
PROJECT	400kV BADISID SUBSTATION
SUBSTATION	400kV BADISID SUBSTATION
CLIENT	ADANI GREEN ENERGY LIMITED
SUPPLIER	HITACHI ENERGY INDIA LIMITED
PO / LOA No.	IDTO-VI/ Adani Green-400 kV at Badi Sid - Rajasthan /PGGA/CRP & SAS
HEIL SO REF.	3100139976, 1MNS500950-PAAA

Revisions:

Rev.	Prep. / Appr.	Description	Date
00	SS / PN	First Submission	02-Aug-24

CUSTOMER NEPAL ELECTRICITY AUTHORITY.	DEPT. PG-GAS	DOCUMENT ID. 1MNS500735-CGAA	REV. 00	LANG. En	PAGE 2/32
PROJECT 400kV BADISID SUBSTATION LINE PROTECTION RELAY SETTING CALCULATION			PREP. SS	APPR. PN	DATE 02-AUG-24

 PGGA-2875	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
	400 KV LINE CONTROL AND RELAY PANEL (BAY 403)	Date	27-Jun-24
Prep. SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk. PN	BAY CONTROL UNIT- REC670	Rev No.	1

1 General Data


System Details

Voltage	Un	=	400	kV
Frequency	F	=	50	Hz
Station Name		=	400kV BADISID SUBSTATION	
Feeder Name		=	400 KV LINE CONTROL AND RELAY PANEL	
Bay No		=	BAY 403	
Relay Ordering Code		=	REC670	
CT Primary ratio (Adopted Tap)		=	1000	A
CT Secondary ratio		=	1	A
VT Primary ratio		=	400	kV
VT Secondary ratio		=	0.11	kV

Global Base Values

GBASVAL:1

Base Voltage	Ubase	=	400	kV
Base Current	Ibase	=	1000	A
Base Power	Sbase	=	693	MVA

 Hitachi Energy PGGA-2875	ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)		Contract No.	3100139976, IN-56423232	
	400 KV LINE CONTROL AND RELAY PANEL (BAY 403)		Date	27-Jun-24	
Prep.	SS	400kV BADISID SUBSTATION		Doc No.	1MNS500950-PAAA
Chk.	PN	BAY CONTROL UNIT- REC670		Rev No.	1

2 Synchrocheck & Energizing check Function, SESRSYN (25)

The protection function has Synchrocheck, energizing check and synchronizing

Operation = On

Synchronizing function:

To allow closing of breakers between asynchronous networks, a synchronizing feature is provided.

The synchronizing feature measures the conditions across the circuit breaker and also determines the angle change occurring during the closing delay of the circuit breaker, from the measured slip frequency. The breaker close command is issued at the optimum time when conditions across the breaker are satisfied in order to avoid stress on the network and its components.

Operation = Off

Synchronism check function:

The synchrocheck mode checks that the voltages on both sides of the circuit breaker are perfectly synchronized (to perform a controlled reconnection) and gives permission to close the circuit breaker when certain conditions are simultaneously fulfilled.

Operation = On

The following conditions to be simultaneously fulfilled for Synchrocheck operation.

- The measured voltages (U-Line and U-Bus) are higher than the set values *UHighBusSC* and *UHighLineSC*.
- The difference in the voltage is smaller than the set value of *UDiffSC*.
- The difference in frequency is less than the set value of *FreqDiffM* and *FreqDiffA*.
- The frequency rate of change is less than set value for both U-Bus and U-Line.
- The difference in the phase angle is smaller than the set value of *PhaseDiffM* and *PhaseDiffA*

Settings criteria:

- *UHighBusSC* and *UHighLineSC* threshold voltages have to be set lower than the value where the network is expected to close with the synchronism check. A typical value is 80% of the rated voltage.
- *UDiffSC*, voltage difference between the line voltage and the bus voltage. A normal setting is 0.10-0.15 p.u.
- *FreqDiffM* and *FreqDiffA*, shall be chosen depending on the condition in the network.

At steady conditions, a low frequency difference setting is needed. Typical value for *FreqDiffM* is 10mHz.

At autoreclosing, a bigger frequency difference setting is preferable. Typical value for *FreqDiffA* is 100-200mHz.

- *PhaseDiffM* and *PhaseDiffA*, shall be chosen depending on conditions in the network.

The phase angle setting must be chosen to allow closing under maximum load condition. In most networks the maximum occurring angle is below 25 degrees.

UHighBusSC	=	80	%UBB
UHighLineSC	=	80	%UBL
UDiffSC	=	0.1	pu
FreqDiffA	=	0.1	Hz
FreqDiffM	=	0.1	Hz
PhaseDiffA	=	20	Deg
PhaseDiffM	=	20	Deg

Energizing check function:

The energizing check function checks that at least one side is dead to ensure that

Energizing from different directions can be different for automatic reclosing and manual closing of the circuit breaker. Two different settings can be used for automatic and manual closing of the circuit breaker.


For manual closing it is also possible to allow closing when both sides of the breaker are dead.

AutoEnerg	=	Both
ManEnerg	=	Both
ManEnergDBDL	=	Off

Settings criteria:

- *UHighBusEnerg* and *UHighLineEnerg* threshold voltages have to be set lower than the value at which the network is considered to be energized. A typical value can be 80% of the base voltages.
- *ULowBusEnerg* and *ULowLineEnerg* threshold voltages have to be set to a value greater than the value where the network is considered not to be energized. A typical value can be 20% of the base voltages.
- *UMaxEnerg* setting is used to block the closing when the voltage on the live side is above the set value.
- *tAutoEnerg* and *tManEnerg*, is to ensure that the dead side remains de-energized and that the condition is not due to a temporary interference. Circuit breaker closing is thus not permitted until the energizing condition has remained constant throughout the set delay setting time.

ULiveBusEnerg	=	80	%UBB
ULiveLineEnerg	=	80	%UBL
UDeadBusEnerg	=	20	%UBB
UDeadLineEnerg	=	20	%UBL
UMaxEnerg	=	115	%UB
tAutoEnerg	=	0.1	s
tManEnerg	=	0.1	s

 Hitachi Energy PGGGA-2875		ADANI GREEN ENERGY LIMITED (ADANI RENEWABLES)	Contract No.	3100139976, IN-56423232
		400 KV LINE CONTROL AND RELAY PANEL (BAY 403)	Date	27-Jun-24
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PAAA
Chk.	PN	BAY CONTROL UNIT- REC670	Rev No.	1

3.1 Autorecloser, SMBRREC (79)

The autoreclosing function SMBRREC (79) provides high-speed and/or delayed auto-reclosing for single breaker or multi breaker applications.

Up to five three-phase reclosing attempts can be included by parameter setting.

The autoreclosing function provides single and/or three phase auto reclosing.

The autoreclosing function is configured to co-operate with the synchronism check function.

The General Settings are Proposed for 79,

Operation	=	On	
ExternalCtrl	=	On	
ARMode	=	1/2ph	
t1 1Ph	=	1	s
t1 3Ph	=	1	s
t1 3PhHS	=	0.4	s
tReclaim	=	25	s
tSync	=	30	s
tLongStartInh	=	0.2	s
tPulse	=	0.2	s
tCBClosedMin	=	5	s
tUnsucCI	=	30	s
Priority	=	None	
tWaitForMaster	=	60	s
LongStartInhib	=	On	
NoOfShots	=	1	
StartByCBOpen	=	Off	
CBReadyType	=	CO	
t1 2Ph	=	1	s
t2 3Ph	=	1	s
t3 3Ph	=	1	s
t4 3Ph	=	1	s
t5 3Ph	=	1	s
Extended t1	=	Off	
tExtended t1	=	0.5	s
tInhibit	=	5	s
CutPulse	=	Off	
Follow CB	=	Off	
AutoContinue	=	Off	
tAutoContWait	=	2	s
UnsucCIByCBChk	=	NoCBCheck	
BlockByUnsucCI	=	Off	
ZoneSeqCoord	=	Off	
tSuccessful	=	1	s
tSlaveDeadTime	=	0.4	s

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
NAMECH8		LINE_CVT_YPH			16 characters	
ChannelType8		Voltage				
RatedTrans8		110.0	V	0.1	300.0	
VTsec8		110.000	V	0.001	999.999	
VTprim8		400.00	kV	0.05	2000.00	
NAMECH9		LINE_CVT_BPH			16 characters	
ChannelType9		Voltage				
RatedTrans9		110.0	V	0.1	300.0	
VTsec9		110.000	V	0.001	999.999	
VTprim9		400.00	kV	0.05	2000.00	
NAMECH10		400KV_BUS-1_C VT			16 characters	
ChannelType10		Voltage				
RatedTrans10		110.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		400.00	kV	0.05	2000.00	
NAMECH11		400KV_BUS-2_C VT			16 characters	
ChannelType11		Voltage				
RatedTrans11		110.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		400.00	kV	0.05	2000.00	
NAMECH12		ICT_LV_SEL_VT			16 characters	
ChannelType12		Voltage				
RatedTrans12		110.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		220.00	kV	0.05	2000.00	

				Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q03KF1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.403 LINE	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by			Rev. 0	Rel. date 12/6/2020	Lan en

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
AR						
Control						
AutoRecloser(79,5(0->1))						
AUTO_RECLOSE; SMBRREC: 1						
General						
Setting Group1						
Operation		On				
ExternalCtrl		On				
ARMode		1/2ph				
AutoContinue		Off				
StartByCBOpen		Off				
LongStartInhib		On				
tLongStartInh		0.200	s	0.000	60.000	
tInhibit		5.000	s	0.000	60.000	
ZoneSeqCoord		Off				
CircuitBreaker						
Setting Group1						
CBReadyType		CO				
Follow CB		Off				
UnsucCIByCBChk		NoCBCheck				
BlockByUnsucCI		Off				
CutPulse		Off				
tPulse		0.200	s	0.000	60.000	
tReclaim		25.00	s	0.00	6000.00	
tSync		30.00	s	0.00	6000.00	
tCBClosedMin		5.00	s	0.00	6000.00	
tSuccessful		1.000	s	0.000	60.000	
tUnsucCI		30.00	s	0.00	6000.00	
DeadTime						
Setting Group1						
NoOfShots		1				
t1 1Ph		1.000	s	0.000	120.000	
t1 2Ph		1.000	s	0.000	120.000	
t1 3Ph		1.000	s	0.000	120.000	
Extended t1		Off				
tExtended t1		0.500	s	0.000	60.000	
t1 3PhHS		0.400	s	0.000	120.000	
MasterSlave						
Setting Group1						
Priority		None				
tSlaveDeadTime		0.400	s	0.100	60.000	
Logic						
LogicSRMemory						
SRMEMORY: 21						

				Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q03KF1		
			Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title REC670_BCU	Document id.		
Re v.	Modification	Rel. date	Created by	_SID.400KV.403 LINE		Approved by		Rev.	Rel. date	Lan
								0	12/6/2020	en

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Setting Group1						
Memory		On				

				Project	ADANI_GREEN_BADI_SID	Responsible department	ABB Ltd.	Technical ref...	Document kind	Doc. designation	AA1C1Q03KF1	
				Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on	_SID.400KV.403 LINE		Approved by		Rev.	Rel. date	Lan	2 / 2
										0	12/6/2020	en


Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SYNC						
Control						
Synchronizing(25,SC/VC)						
SESRSYN: 1						
General						
GblBaseSelBus		1		1	12	
GblBaseSelLine		1		1	12	
SelPhaseBus1		Phase L1L2				
SelPhaseBus2		Phase L1L2				
SelPhaseLine1		Phase L1L2				
SelPhaseLine2		Phase L1L2				
CBConfig		1 1/2 bus CB				
PhaseShift		0	Deg	-180	180	
Setting Group1						
Operation						
On						
Synchronizing						
Setting Group1						
OperationSynch						
Off						
UHighBusSynch		80.0	%UBB	50.0	120.0	
UHighLineSynch		80.0	%UBL	50.0	120.0	
UDiffSynch		0.10	pu	0.02	0.50	
FreqDiffMin		0.010	Hz	0.003	0.250	
FreqDiffMax		0.200	Hz	0.050	1.000	
FreqRateChange		0.300	Hz/s	0.000	0.500	
CloseAngleMax		15.0	Deg	15.0	30.0	
tBreaker		0.080	s	0.000	1.000	
tClosePulse		0.200	s	0.050	60.000	
tMaxSynch		600.00	s	0.00	6000.00	
tMinSynch		2.000	s	0.000	60.000	
Synchrocheck						
Setting Group1						
OperationSC						
On						
UHighBusSC		80.0	%UBB	50.0	120.0	
UHighLineSC		80.0	%UBL	50.0	120.0	
UDiffSC		0.10	pu	0.02	0.50	
FreqDiffA		0.100	Hz	0.003	1.000	
FreqDiffM		0.100	Hz	0.003	1.000	
PhaseDiffA		20.0	Deg	5.0	90.0	
PhaseDiffM		20.0	Deg	5.0	90.0	
tSCA		0.100	s	0.000	60.000	
tSCM		0.100	s	0.000	60.000	
Energizingcheck						
Setting Group1						
AutoEnerg						
Both						


				Project	Responsible department	Technical ref...	Document kind	Doc. designation			
				ADANI_GREEN_BADI_SID	ABB Ltd.			AA1C1Q03KF1			
			Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title	Document id.			
				_SID.400KV.403 LINE		Approved by	REC670_BCU				
Re v.	Modification	Rel. date	Created by	Based on				Rev.	Rel. date	Lan	1 / 2
								0	12/6/2020	en	

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
ManEnerg		Both				
ManEnergDBDL		Off				
UHighBusEnerg		80.0	%UBB	50.0	120.0	
UHighLineEnerg		80.0	%UBL	50.0	120.0	
ULowBusEnerg		20.0	%UBB	10.0	80.0	
ULowLineEnerg		20.0	%UBL	10.0	80.0	
UMaxEnerg		115.0	%UB	50.0	180.0	
tAutoEnerg		0.100	s	0.000	60.000	
tManEnerg		0.100	s	0.000	60.000	

				Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q03KF1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.403 LINE	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by		Rev.	Rel. date	Lan	2 / 2
								0	12/6/2020	en	

 Hitachi Energy PGG-2875		PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
		TIE BAY_ (BAY 402, 405)	Date	31-May-24
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PFAA
Chk.	PN	TIE LBB PROTECTION-REL670	Rev No.	0

TIE BAY LBB PROTECTION RELAY, REL670
TIE BAY_ (BAY 402, 405)

 Hitachi Energy PGGA-2875		PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
		TIE BAY_ (BAY 402, 405)	Date	31-May-24
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PFAA
Chk.	PN	TIE LBB PROTECTION-REL670	Rev No.	0

SETTING CALCULATION OF BREAKER FAILURE PROTECTION (50BF)

The following settings can be done for the breaker failure protection:

Operation: = On
Ibase = 1000 A
FunctionMode = Current
BuTripMode: = 1 out of 3
(It means that at least one current of the three-phase currents shall be high to indicate breaker failure)
RetripMode: = FunctionMode

If CB Pos Check has to be set,

<i>CB Pos Check</i>	<i>Current</i>	re-trip is done if the phase current is larger than the operate level after re-trip time has elapsed
	<i>Contact</i>	re-trip is done when auxiliary contact position indicates that breaker is still closed after re-trip time has elapsed
	<i>Current/Contact</i>	both methods according to above are used but taken into account also <i>I>BlkCont</i>

Table:Dependencies between parameters RetripMode and FunctionMode

IP>:

This parameter should be less than the minimum fault current. The setting can be chosen in accordance with the most sensitive protection function to start the breaker failure protection.

therefore The setting can be,

IP>: = 20 % of IB

I>BlkCont:

If any contact based detection of breaker failure is used, this function can be blocked if any phase current is larger than this setting level. If the FunctionMode is set Current/Contact breaker failure for high current faults are safely detected by the current measurement function. To increase security the contact based function should be disabled for high currents.

therefore The setting can be,


I>BlkCont: = 20 % of IB

t1: Time delay of the re-trip.

t1: = 100 ms

t2: Time delay of the back-up trip

t2: = 200 ms

 Hitachi Energy PGGA-28/5		PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
		TIE BAY_ (BAY 402, 405)	Date	31-May-24
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PFAA
Chk.	PN	TIE LBB PROTECTION-REL670	Rev No.	0

tCBAlarm: Time delay for alarm in case of indication of faulty circuit breaker. There is a binary input CBFLT from the circuit breaker. This signal is activated when internal supervision in the circuit breaker detect that the circuit breaker is unable to clear fault. This could be the case when gas pressure is low in a SF6.circuit breaker. After the set time an alarm is given, so that actions can be done to repair the circuit breaker. The time delay for back-up trip is bypassed when the CBFLT is active.

tCBAlarm = 5 s
(Default Value from Manual)

tPulse: Trip pulse duration. This setting must be larger than the critical impulse time of circuit breakers to be tripped from the breaker failure protection.

tPulse = 200 ms
(Default Value from Manual)

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
TRM_40						
NAMECH1		TIE_CT_R			16 characters	
ChannelType1		CurrentProtection				
RatedTrans1		1.0	A	0.1	300.0	
CTStarPoint1		ToObject				
CTsec1		1	A	1	10	
CTprim1		1000	A	1	99999	
NAMECH2		TIE_CT_Y			16 characters	
ChannelType2		CurrentProtection				
RatedTrans2		1.0	A	0.1	300.0	
CTStarPoint2		ToObject				
CTsec2		1	A	1	10	
CTprim2		1000	A	1	99999	
NAMECH3		TIE_CT_B			16 characters	
ChannelType3		CurrentProtection				
RatedTrans3		1.0	A	0.1	300.0	
CTStarPoint3		ToObject				
CTsec3		1	A	1	10	
CTprim3		1000	A	1	99999	
NAMECH4		CH4(I)			16 characters	
ChannelType4		CurrentProtection				
RatedTrans4		1.0	A	0.1	300.0	
CTStarPoint4		ToObject				
CTsec4		1	A	1	10	
CTprim4		1000	A	1	99999	
NAMECH5		NEUTRSL_CT			16 characters	
ChannelType5		CurrentProtection				
RatedTrans5		1.0	A	0.1	300.0	
CTStarPoint5		ToObject				
CTsec5		1	A	1	10	
CTprim5		1000	A	1	99999	
NAMECH6		CH6(I)			16 characters	
ChannelType6		CurrentProtection				
RatedTrans6		1.0	A	0.1	300.0	
CTStarPoint6		ToObject				
CTsec6		1	A	1	10	
CTprim6		1000	A	1	99999	
NAMECH7		CH7(U)			16 characters	
ChannelType7		Voltage				
RatedTrans7		110.0	V	0.1	300.0	
VTsec7		110.000	V	0.001	999.999	
VTprim7		400.00	kV	0.05	2000.00	
NAMECH8		CH8(U)			16 characters	
ChannelType8		Voltage				

				Project	Responsible department	Technical ref...	Document kind	Doc. designation		
				ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1Q02FN1		
			Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.402 TIE-1	HITACHI	Created by	Title REL670_LBB	Document id.		
Re v.	Modification	Rel. date	Created by			Approved by		Rev.	Rel. date	Lan
								0	27-03-2024	en

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
RatedTrans8		110.0	V	0.1	300.0	
VTsec8		110.000	V	0.001	999.999	
VTprim8		400.00	kV	0.05	2000.00	
NAMECH9		CH9(U)			16 characters	
ChannelType9		Voltage				
RatedTrans9		110.0	V	0.1	300.0	
VTsec9		110.000	V	0.001	999.999	
VTprim9		400.00	kV	0.05	2000.00	
NAMECH10		CH10(U)			16 characters	
ChannelType10		Voltage				
RatedTrans10		110.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		400.00	kV	0.05	2000.00	
NAMECH11		CH11(U)			16 characters	
ChannelType11		Voltage				
RatedTrans11		110.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		400.00	kV	0.05	2000.00	
NAMECH12		CH12(U)			16 characters	
ChannelType12		Voltage				
RatedTrans12		110.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		400.00	kV	0.05	2000.00	

				Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q02FN1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.402 TIE-1	HITACHI	Created by	Title REL670_LBB	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by		Rev.	Rel. date	Lan	2 / 2
								0	27-03-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Global base values						
GBASVAL: 1						
UBase		400.00	kV	0.05	2000.00	
IBase		1000	A	1	99999	
SBase		762.00	MVA	1.00	200000.00	
GBASVAL: 2						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 3						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 4						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 5						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 6						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 7						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 8						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 9						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 10						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 11						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation		
				ADANI_GREEN_BADI_SID	HITACHI Ltd.			AA1C1Q02FN1		
			Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.402 TIE-1	HITACHI	Created by	Title REL670_LBB	Document id.		
Re v.	Modification	Rel. date	Created by			Approved by		Rev.	Rel. date	Lan
								0	27-03-2024	en


Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 12						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	

				Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q02FN1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.402 TIE-1	HITACHI	Created by	Title REL670_LBB	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by		Rev.	Rel. date	Lan	2 / 2
								0	27-03-2024	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
I_PROT						
Current protection						
BreakerFailure(50BF,3I>BF)						
LBB; CCRBRF: 1						
GlobalBaseSel		1		1	12	
Setting Group1						
Operation		On				
FunctionMode		Current				
StartMode		FollowStart&Mode				
tStartTimeout		1.0	s	0.5	600.0	
BuTripMode		1 out of 3				
RetripMode		UseFunctionMode				
IPh>		20	%IB	5	200	
t1		0.100	s	0.000	60.000	
t2		0.200	s	0.000	60.000	
t2MPH		0.150	s	0.000	60.000	
t3		0.030	s	0.000	60.000	
tCBAlarm		5.000	s	0.000	60.000	
tPulse		0.200	s	0.010	60.000	

				Project ADANI_GREEN_BADI_SID	Responsible department HITACHI Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q02FN1		
			Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title REL670_LBB	Document id.		
Rev.	Modification	Rel. date	Created by	_SID.400KV.402 TIE-1		Approved by		Rev.	Rel. date	Lan
								0	27-03-2024	en

 Hitachi Energy PGGA-2875	PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232	
	400kV TIE BAY C&R PANEL-1, 2 (BAY -402, 405)	Date	31-May-24	
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PFAA
Chk.	PN	BAY CONTROL UNIT- REC670	Rev No.	0

REC670
BAY CONTROL UNIT
400kV TIE BAY C&R PANEL-1, 2 (BAY -402, 405)

1 General Data
System Details

Voltage	Un	=	400	kV
Frequency	F	=	50	Hz


Station Name	=	400kV BADISID SUBSTATION
Feeder Name	=	400kV TIE BAY C&R PANEL-1, 2
Bay No	=	BAY -402, 405
Relay Ordering Code	=	REC670

CT Primary ratio (Adopted Tap)	=	1000	A
CT Secondary ratio	=	1	A
VT Primary ratio	=	400	kV
VT Secondary ratio	=	0.11	kV

Transformer MVA	=	330	MVA
Transformer Full Load current	=	476.3	
Maximum 3phase fault current	=	10500	A
Maximum 3phase fault current	=	10500	A

Global Base Values
GBASVAL:1

Base Voltage	Ubase	=	400	kV
Base Current	Ibase	=	476.3	A
Base Power	Sbase	=	330	MVA

 PGGA-2875		PROTECTION RELAY SETTING CALCULATION	Contract No.	3100139976, IN-56423232
		400kV TIE BAY C&R PANEL-1, 2 (BAY -402, 405)	Date	31-May-24
Prep.	SS	400kV BADISID SUBSTATION	Doc No.	1MNS500950-PFAA
Chk.	PN	BAY CONTROL UNIT- REC670	Rev No.	0

2 Synchrocheck & Energizing check Function, SESRSYN (25)

The protection function has Synchrocheck, energizing check and synchronizing features.

Operation = On

Synchronizing function:

To allow closing of breakers between asynchronous networks, a synchronizing feature is provided.

The synchronizing feature measures the conditions across the circuit breaker and also determines the angle change occurring during the closing delay of the circuit breaker, from the measured slip frequency. The breaker close command is issued at the optimum time when conditions across the breaker are satisfied in order to avoid stress on the network and its components.

Operation = Off

Synchronism check function:

The synchrocheck mode checks that the voltages on both sides of the circuit breaker are perfectly synchronized (to perform a controlled reconnection) and gives permission to close the circuit breaker when certain conditions are simultaneously fulfilled.

Operation = On

The following conditions to be simultaneously fulfilled for Synchrocheck operation.

- The measured voltages (U-Line and U-Bus) are higher than the set values *UHighBusSC* and *UHighLineSC*.
- The difference in the voltage is smaller than the set value of *UDiffSC*.
- The difference in frequency is less than the set value of *FreqDiffM* and *FreqDiffA*.
- The frequency rate of change is less than set value for both U-Bus and U-Line.
- The difference in the phase angle is smaller than the set value of *PhaseDiffM* and *PhaseDiffA*

Settings criteria:

• *UHighBusSC* and *UHighLineSC* threshold voltages have to be set lower than the value where the network is expected to close with the synchronism check. A typical value is 80% of the rated voltage.

• *UDiffSC*, voltage difference between the line voltage and the bus voltage. A normal setting is 0.10-0.15 p.u.

• *FreqDiffM* and *FreqDiffA*, shall be chosen depending on the condition in the network.

At steady conditions, a low frequency difference setting is needed. Typical value for *FreqDiffM* is 10mHz.

At autoreclosing, a bigger frequency difference setting is preferable. Typical value for *FreqDiffA* is 100-200mHz.

• *PhaseDiffM* and *PhaseDiffA*, shall be chosen depending on conditions in the network.

The phase angle setting must be chosen to allow closing under maximum load condition. In most networks the maximum occurring angle is below 25 degrees.

UHighBusSC	=	80	%UBB
UHighLineSC	=	80	%UBL
UDiffSC	=	0.1	pu
FreqDiffA	=	0.1	Hz
FreqDiffM	=	0.1	Hz
PhaseDiffA	=	20	Deg
PhaseDiffM	=	20	Deg

Energizing check function:

The energizing check function checks that at least one side is dead to ensure that closing

Energizing from different directions can be different for automatic reclosing and manual closing of the circuit breaker. Two different settings can be used for automatic and manual closing of the circuit breaker.

For manual closing it is also possible to allow closing when both sides of the breaker are dead.

AutoEnerg	=	Both
ManEnerg	=	Both
ManEnergDBDL	=	Off

Settings criteria:

• *ULiveBusEnerg* and *ULiveLineEnerg* threshold voltages have to be set lower than the value at which the network is considered to be energized. A typical value can be 80% of the base voltages.

• *ULowBusEnerg* and *ULowLineEnerg* threshold voltages have to be set to a value greater than the value where the network is considered not to be energized. A typical value can be 20% of the base voltages.

• *UMaxEnerg* setting is used to block the closing when the voltage on the live side is above the set value.

• *tAutoEnerg* and *tManEnerg*, is to ensure that the dead side remains de-energized and that the condition is not due to a temporary interference. Circuit breaker closing is thus not permitted until the energizing condition has remained constant throughout the set delay setting time.

ULiveBusEnerg	=	80	%UBB
ULiveLineEnerg	=	80	%UBL
UDeadBusEnerg	=	20	%UBB
UDeadLineEnerg	=	20	%UBL
UMaxEnerg	=	115	%UB
tAutoEnerg	=	0.1	s
tManEnerg	=	0.1	s

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
TRM_40						
NAMECH1		TIE_CT_RPH			16 characters	
ChannelType1		CurrentProtection				
RatedTrans1		1.0	A	0.1	300.0	
CTStarPoint1		ToObject				
CTsec1		1	A	1	10	
CTprim1		1000	A	1	99999	
NAMECH2		TIE_CT_YPH			16 characters	
ChannelType2		CurrentProtection				
RatedTrans2		1.0	A	0.1	300.0	
CTStarPoint2		ToObject				
CTsec2		1	A	1	10	
CTprim2		1000	A	1	99999	
NAMECH3		TIE_CT_BPH			16 characters	
ChannelType3		CurrentProtection				
RatedTrans3		1.0	A	0.1	300.0	
CTStarPoint3		ToObject				
CTsec3		1	A	1	10	
CTprim3		1000	A	1	99999	
NAMECH4		SPARE			16 characters	
ChannelType4		CurrentProtection				
RatedTrans4		1.0	A	0.1	300.0	
CTStarPoint4		ToObject				
CTsec4		1	A	1	10	
CTprim4		1000	A	1	99999	
NAMECH5		CB INTRPT_YPH			16 characters	
ChannelType5		CurrentProtection				
RatedTrans5		1.0	A	0.1	300.0	
CTStarPoint5		ToObject				
CTsec5		1	A	1	10	
CTprim5		1000	A	1	99999	
NAMECH6		CB INTRPT_BPH			16 characters	
ChannelType6		CurrentProtection				
RatedTrans6		1.0	A	0.1	300.0	
CTStarPoint6		ToObject				
CTsec6		1	A	1	10	
CTprim6		1000	A	1	99999	
NAMECH7		400KV_BUS1_CV T_R			16 characters	
ChannelType7		Voltage				
RatedTrans7		110.0	V	0.1	300.0	
VTsec7		110.000	V	0.001	999.999	
VTprim7		400.00	kV	0.05	2000.00	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation		
				ADANI_GREEN_BADI_SID	ABB Ltd.			AA1C1Q02KF1		
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.402 TIE-1	HITACHI	Created by	Title REC670_BCU	Document id.		
Re v.	Modification	Rel. date	Created by			Approved by		Rev.	Rel. date	Lan
								0	12/6/2020	en

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
NAMECH8		400KV_BUS1_CV T_Y			16 characters	
ChannelType8		Voltage				
RatedTrans8		110.0	V	0.1	300.0	
VTsec8		110.000	V	0.001	999.999	
VTprim8		400.00	kV	0.05	2000.00	
NAMECH9		400KV_BUS1_CV T_B			16 characters	
ChannelType9		Voltage				
RatedTrans9		110.0	V	0.1	300.0	
VTsec9		110.000	V	0.001	999.999	
VTprim9		400.00	kV	0.05	2000.00	
NAMECH10		33KV_SEL_BUSP T			16 characters	
ChannelType10		Voltage				
RatedTrans10		110.0	V	0.1	300.0	
VTsec10		110.000	V	0.001	999.999	
VTprim10		33.00	kV	0.05	2000.00	
NAMECH11		BUS-2_CVT_RYP H			16 characters	
ChannelType11		Voltage				
RatedTrans11		110.0	V	0.1	300.0	
VTsec11		110.000	V	0.001	999.999	
VTprim11		400.00	kV	0.05	2000.00	
NAMECH12		LINE_CVT_RYPH			16 characters	
ChannelType12		Voltage				
RatedTrans12		110.0	V	0.1	300.0	
VTsec12		110.000	V	0.001	999.999	
VTprim12		440.00	kV	0.05	2000.00	

				Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q02KF1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.402 TIE-1	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by		Rev.	Rel. date	Lan	2 / 2
								0	12/6/2020	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
Global base values						
GBASVAL: 1						
UBase		400.00	kV	0.05	2000.00	
IBase		476	A	1	99999	
SBase		330.00	MVA	1.00	200000.00	
GBASVAL: 2						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2078.40	MVA	1.00	200000.00	
GBASVAL: 3						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2078.40	MVA	1.00	200000.00	
GBASVAL: 4						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2078.40	MVA	1.00	200000.00	
GBASVAL: 5						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2078.40	MVA	1.00	200000.00	
GBASVAL: 6						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 7						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 8						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 9						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 10						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 11						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation		
				ADANI_GREEN_BADI_SID	ABB Ltd.			AA1C1Q02KF1		
			Repla...	ADANI_GREEN_BADI_SID.BADI_SID.400KV.402 TIE-1	HITACHI	Created by	Title REC670_BCU	Document id.		
Re v.	Modification	Rel. date	Created by			Approved by		Rev.	Rel. date	Lan
								0	12/6/2020	en



Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SBase		2000.00	MVA	1.00	200000.00	
GBASVAL: 12						
UBase		400.00	kV	0.05	2000.00	
IBase		3000	A	1	99999	
SBase		2000.00	MVA	1.00	200000.00	

				Project ADANI_GREEN_BADI_SID	Responsible department ABB Ltd.	Technical ref...	Document kind	Doc. designation AA1C1Q02KF1			
			Repla...	ADANI_GREEN_BADI_SID.BADI _SID.400KV.402 TIE-1	HITACHI	Created by	Title REC670_BCU	Document id.			
Re v.	Modification	Rel. date	Created by	Based on		Approved by		Rev.	Rel. date	Lan	2 / 2
								0	12/6/2020	en	

Settings

Group / Parameter Name	IED Value	PC Value	Unit	Min	Max	Format
SYNC						
Control						
Synchronizing(25,SC/VC)						
SESRYN: 1						
General						
GblBaseSelBus		1		1	12	
GblBaseSelLine		1		1	12	
SelPhaseBus1		Phase L1L2				
SelPhaseBus2		Phase L1L2				
SelPhaseLine1		Phase L1L2				
SelPhaseLine2		Phase L1L2				
CBCConfig		1 1/2 bus CB				
PhaseShift		0	Deg	-180	180	
Setting Group1						
Operation						
		On				
Synchronizing						
Setting Group1						
OperationSynch						
		Off				
CloseAngleMax		15.0	Deg	15.0	30.0	
Synchrocheck						
Setting Group1						
OperationSC						
		On				
UHighBusSC		80.0	%UBB	50.0	120.0	
UHighLineSC		80.0	%UBL	50.0	120.0	
UDiffSC		0.10	pu	0.02	0.50	
FreqDiffA		0.100	Hz	0.003	1.000	
FreqDiffM		0.100	Hz	0.003	1.000	
PhaseDiffA		20.0	Deg	5.0	90.0	
PhaseDiffM		20.0	Deg	5.0	90.0	
tSCA		0.100	s	0.000	60.000	
tSCM		0.100	s	0.000	60.000	
Energizingcheck						
Setting Group1						
AutoEnerg						
		Both				
ManEnerg						
		Both				
ManEnergDBDL						
		On				
UHighBusEnerg		80.0	%UBB	50.0	120.0	
UHighLineEnerg		80.0	%UBL	50.0	120.0	
ULowBusEnerg		20.0	%UBB	10.0	80.0	
ULowLineEnerg		20.0	%UBL	10.0	80.0	
UMaxEnerg		115.0	%UB	50.0	180.0	
tAutoEnerg		0.100	s	0.000	60.000	
tManEnerg		0.100	s	0.000	60.000	

				Project	Responsible department	Technical ref...	Document kind	Doc. designation			
				ADANI_GREEN_BADI_SID	ABB Ltd.			AA1C1Q02KF1			
			Repla...	ADANI_GREEN_BADI_SID.BADI	HITACHI	Created by	Title REC670_BCU	Document id.			
				_SID.400KV.402 TIE-1		Approved by			Rev.	Rel. date	Lan
Re v.	Modification	Rel. date	Created by	Based on				0	12/6/2020	en	

	RELAY SETTING CALCULATION	

PROJECT TITLE

500MW BADI SID POWER PROJECT, RAJASTHAN

DOCUMENT TITLE

RELAY SETTING CALCULATION

1. INTRODUCTION

This document represents the Overcurrent and Earth Fault relay settings for 400 kV Switchyard, 400 / 33 kV Transformer, 33 kV Indoor & Outdoor Switchgear, and 415V AC Main Switchboard.

2. OBJECTIVE

The Relay setting and Coordination analysis is conducted to recommend the relay settings to achieve proper coordination between relays installed in 400 kV Switchyard, 400 / 33 kV Transformer, 33 kV Indoor Switchgear, and 415V AC Main Switchboard.

The Relay coordination study is performed to determine various relay settings under normal operating condition and to ensure:

- A. Sensitivity to over current and earth faults under minimum and maximum fault conditions.
- B. Selectivity of relays

3. SYSTEM DESCRIPTION

There are total of 26 Nos of 25 MW feeders receiving power from Solar Inverters and feeding to 4 Nos. of 33kV Indoor Switchgear. Further, the power from 33 kV Indoor Switchgear is evacuated to the 400kV Grid through 2 numbers of 198/264/330 MVA, 400/33kV Power Transformers. The Indoor Switchgear also feeds power to 1000kVA, 33/0.433kV Auxiliary Transformers for utilization at 415V Main Switchboard.

4. STUDY APPROACH / BASIS & ASSUMPTIONS


- It has been ensured that sufficient time co-ordination between up stream and downstream is maintained to take care the fault clearance and CB Operating time. This is applicable for Inverse and DT Characteristic.
- Back up protection for O/C and E/F has been considered from 33 kV Level to 400 kV level
- O/C & E/F relay co-ordination curves are shown for outgoing feeder with reference to incomer or more clarity. Since, the setting of other outgoing feeders at the same level is similar or lower.
- The curve represents the protection co-ordination of the entire switchgear, at that level.
- Pickup of Over Current is kept at minimum 120% of Rated current and for Earth fault pick up is min 20% of Rated current is selected.

33 kV Over current and Earth fault coordination - Badi Sid


Feeder Name	33 kV LV-1-Grid Feeder			33 kV HT Board Bus coupler			SVG - 50 MVAR			33 kV Incoming from IDT- 25 MW			33 kV Incoming from IDT-12.5 MW			33kV IDT			Aux Trafo HV								
	Source MVA	165		Source MVA	165		Source MVA	165		Source MVA	165		Source MVA	165		MVA	12.5		MVA	1							
	CAPACITY	165		CAPACITY	165		CAPACITY	62		CAPACITY	25		CAPACITY	12.5		CAPACITY	12.5		CAPACITY	1							
	z in pu	0.15		z in pu	0.15		z in pu	0.15		z in pu	0.15		z in pu	0.15		z in pu	0.08		z in pu	0.05							
Voltage Ref	33	33		33	33		33	33		33	33		33	33		33	33		33	33							
	FLC	2886.8		FLC	2886.8		FLC	1084.8		FLC	437.4		FLC	218.7		FLC	218.7		FLC	17.5							
	P/U Factor	1.2		P/U Factor	1.2		P/U Factor	1.2		P/U Factor	1.2		P/U Factor	1.2		P/U Factor	1.2		P/U Factor	1.2							
RELAY	REF 615			REF 615			REF 615			REF 615			REF 615			7UT 85 / P645			REF 615								
3-Ph Fault current	19245.57352			19245.57352			19245.57352			19245.57352			19245.57352			2733.746238			2733.746			349.9195185			349.9195		
Bus Fault Current	1			1			1			1			1			1			1			1					
Relay Current	1			1			1			1			1			1			1			1					
Shift Factor	1			1			1			1			1			1			1			1					
Phase CT Primary	3150			3150			1250			600			600			300			50								
Rated Current	2886.84		0.9165	2886.84		0.9164559	2886.84		0.9164559	2886.84		0.9164559	2886.84		0.9164559	218.70		0.9164559	17.50								
	3150		1.0997	3150		1.0997471	1250		1.0997471	1250		1.0997471	1250		1.0997471	1250		1.0997471	1250								
	Pr			Pr																							
Settings description																											
PHASE-50/51N	7.94			7.94			20.02			41.70			41.70			11.85			9.10								
Phase Plug Setting	1.0997471	1.1	x In	1.0997471	1.1	x In	1.0413605	1.05	x In	0.8747988	0.9	x In	0.4373994	0.45	x In	0.874799	0.9	x In	0.419903	0.4	x In						
Phase TMS	0.11			0.11			0.05			0.11			0.11			0.05			0.3								
Curve	NI			NI			NI			NI			NI			NI			VI								
Top	0.441436603			0.441436603			0.126868283			0.2494092			0.2494092			0.147714505			0.245514422								
Stage 2 (ON/OFF)	ON			ON			ON			ON			ON			ON			ON								
Stage 2 Plug Setting	2		x In	2		x In	1.5		x In	2		x In	1		x In	2.5		x In	3		x In						
Stage 2 Inst Time	0.3		x In	0.3		x In	0.1		x In	0.15		x In	0.15		x In	0.05		x In	0.05		x In						
Stage 3 (ON/OFF)	OFF			OFF			OFF			OFF			OFF			OFF			ON								
Phase Inst Plug Setting	5.5		x In	5.5		x In	13		x In	13		x In	13		x In	3		x In	3		x In						
Phase Inst Time	0.05		x In	0.05		x In	0.05		x In	0.05		x In	0.05		x In	0.05		x In	0.05		x In						
EARTH-50N/51N																											
1-Ph Fault current	19245.57352			19245.57352			19245.57352			19245.57352			19245.57352			2733.75			349.92								
Bus Fault Current	1			1			1			1			1			1			1								
Relay Current	1			1			1			1			1			1			1								
Shift Factor	1			1			1			1			1			1			1								
Earth CT Primary	3150			3150			1250			600			600			300			50								
Earth Plug Setting	0.18		x In	0.18		x In	0.1		x In	0.15		x In	0.1		x In	0.2		x In	0.1		x In						
Earth TMS	0.18			0.18			0.3			0.11			0.3			0.1			0.35								
Curve	NI			NI			NI			NI			NI			NI			VI								
Top	0.408124146			0.408124146			#DIV/0!			0.113367818			#DIV/0!			0.2494092			#DIV/0!			0.113367818					
Stage 2 (ON/OFF)	ON			ON			OFF			OFF			OFF			OFF			ON								
Stage 2 Earth Setting	1		x In	1		x In	0.2		x In	1		x In	0.2		x In	0.5		x In	1		x In						
Stage 2 Inst Time	0.3		x In	0.3		x In	0.3		x In	0.15		x In	0.3		x In	0.15		x In	1		x In						
Stage 3 (ON/OFF)	OFF			OFF			OFF			OFF			OFF			OFF			OFF								
Phase Inst Plug Setting	1		x In	1		x In	-		x In	-		x In	-		x In	0.5		x In	-		x In						
Phase Inst Time	1		x In	1		x In	-		x In	-		x In	-		x In	0.1		x In	-		x In						

NOTE All relay Settings proposed here is based on actual CT RATIO only

33KV Phase O/C Coordination Chart - Badi Sid



33KV E/F Coordination Chart- Badi Sid




400 kV Over current and Earth fault coordination - Badi Sid


Feeder Name	400 kV LINE @Badi Sid and Remote end			PTR - 330 MVA - HV 400 kV			PTR - 330 MVA - HV SEF			PTR - 330 MVA - LV SEF			PTR - 330 MVA - LV 33 kV		
	Source MVA	660		MVA	330		MVA	330		MVA	330		MVA	330	
	CAPACITY			CAPACITY	330		CAPACITY	330		CAPACITY	165		CAPACITY	165	
	z in pu	1		z in pu	0.15		z in pu	0.15		z in pu	0.15		z in pu	0.15	
Voltage Ref	400	400		400	400		400	400		33	400		33	400	
	FLC			FLC	476.33		FLC	476.33		FLC	2886.84	433.0254	FLC	2886.84	238.16397
	P/U Factor			P/U Factor	1.2		P/U Factor	1.2		P/U Factor	1.2		P/U Factor	1.2	
RELAY															
3-Ph Fault current		12000			3175.52	3175.52		3175.52	3175.52		3175.52	3175.52		3175.52	3175.52
Bus Fault Current		1													
Relay Current		1			1			1			1			1	
Shift Factor		1			1			1			1			1	
Phase CT Primary		1000			1000			1000			330	4000		259.875	3150
Rated Current		952.66			476.33			476.33			476.33	1		476.33	1
		1000										12.12121			12.12121
		Pr													
Settings description					Pr			Pr			Pr			Pr	
PHASE-50/51N					4.13			4.13			12.51			15.89	
Phase Plug Setting			x In	0.571594	0.6	x In	0.571594		x In	0.866051		x In	1.099747	1.1	x In
Phase TMS					0.25									0.11	
Curve					NI									NI	
Top		FALSE			1.0328302			FALSE			FALSE			0.312167004	
Stage 2 (ON/OFF)		OFF			ON			OFF			OFF			ON	
Stage 2 Plug Setting			x In	3.493072	3.5	x In			x In			x In		2	x In
Stage 2 Inst Time					0.15									0.3	
Stage 3 (ON/OFF)					OFF			OFF			OFF			OFF	
Phase Inst Plug Setting			x In			x In			x In			x In			x In
Phase Inst Time															
EARTH-50N/51N		DIRECTIONAI			NON DIRECTIONAL			NON-DIRECTIONAL			NON-DIRECTIONAL			NON-DIRECTIONAL	
1-Ph Fault current		12000			3175.52			3175.52			3175.52			3175.52	
Bus Fault Current		1			1			1			1			1	
Relay Current		1			1			1			1			1	
Shift Factor		1			1			1			1			1	
Earth CT Primary		1000			1000			1000			330			260	
Earth Plug Setting		0.22	x In	0.1	0.1		0.1	0.2		0.1	0.25		0.1	0.18	
Earth TMS		0.5		0.1	0.25		0.1	0.25		0.1	0.2		0.1	0.18	
Curve		NI		NI	NI		NI	NI		NI	NI		NI	NI	
Top		1.133678184		#DIV/0!	0.566839092		#DIV/0!	0.615593457		#DIV/0!	0.453471273		#DIV/0!	0.408124146	
Stage 2 (ON/OFF)		OFF		OFF	ON		OFF	OFF		OFF	OFF		OFF	ON	
Stage 2 Earth Setting			x In	1.58776	1.5	x In	1		x In	1		x In	1	1	x In
Stage 2 Inst Time				1	0.15		1		1			1		0.3	
Stage 3 (ON/OFF)		OFF		OFF	OFF		OFF	OFF		OFF	OFF		OFF	OFF	
Phase Inst Plug Setting			x In	-		x In	-		x In	-		x In	-		x In
Phase Inst Time				-			-			-			-		

NOTE All relay Settings proposed here is based on actual CT RATIO only


400 KV E/F Coordination Chart- Badi Sid



400 kV Phase O/C Coordination Chart - Badi Sid



RELAY SETTING FOR 12.5MW IDT STATION

Document No.	Rev. No.	Date	
XXXX-E-SEP-IDT-DE-C-I-001	R0	08.07.2024	

SOLAR POWER PROJECT,RAJASTHAN
500MW Badi
500MW Bhimsar
534.5MW Siyamber
600MW NHPC
300MW Essel

RELAY SETTING FOR 12.5MW IDT STATION

**Nilesh
Patel**

Digitally signed by
Nilesh Patel
Date: 2024.07.10
18:41:42 +05'30'

XXXX-E-SEP-IDT-DE-C-I-001

REV	DATE	DESCRIPTION	PREPARED BY	CHECKED BY	APPROVED BY
R0	08.07.2024	HT panel relay setting of IDT station	SS	HT	NP

RELAY SETTING FOR 12.5MW IDT STATION

1	RELAY SETTINGS FOR 33 KV IDT FEEDER (OUTDOOR HT PANEL IN 33/4X0.80kV IDT STATION)	
SOLAR	IDT TRANSFORMER	
	Rating in kVA	= 12500
	Primary Voltage (kV)	= 33
	Secondary Voltage (kV)	= 0.8
	Vector group	= Dyn11yn11yn11yn11
1B	INSTRUMENT TRANSFORMER & RELAY DETAILS	
	Relay Make & Model	= Siemens GE
	33 kV CT Primary (Amp)	= 300
	33 kV CT Secondary (Amp)	= 1
	33 kV PT Primary (Volts)	= 33000/√3
	33 kV PT Secondary (Volts)	= 110/√3
	Polarity	= CT Secondary Star Point (Towards Protected Object)
	Transformer LV bushing CT	
	0.8kV CT Primary (Amp)	= 3200
	0.8 kV CT Secondary (Amp)	= 1
1C	PHASE & GROUND OVERCURRENT PROTECTION (50,50N,51,51N)	
	51 Characteristic	= Normal Inverse
	51 Plug Setting	= 0.9* In (300 Amp)
	51 Time Multiplier Setting	= 0.05
	50 Characteristic	= Definite Time
	50 Plug Setting	= 2.5 * In (300 Amp)
	50 Time Delay Setting	= 50 ms
	51N Characteristic	= Normal Inverse
	51N Plug Setting	= 0.20* In (300 Amp)
	51N Time Multiplier Setting	= 0.05
	50N Characteristic	= Definite Time
	50N Plug Setting	= 0.40* In (300 Amp)
	50N Time Delay Setting	= 50 ms
1D	TRANSFORMER DIFFERENTIAL PROTECTION (87T)	
	Set Mode	= Advance
	SOTF Mode	= ON
	Differential Current Alarm Threshold (IDiffAlarm)	= 0.2 PU
	Differential Alarm Time Delay (tAlarm)	= 0 Sec
	Differential Current Threshold (Is1)	= 0.2 PU
	Bias Current Threshold-1	= N/A
	Percentage Differential First Slope (K1)	= 30%
	Bias Current Threshold-2 (Is1)	= 1 PU
	Percentage Differential Second Slope (K2)	= 80%
	Differential Current High Set-1 (Is-HS1)	= 10 PU
	Differential Current High Set-2 (Is-HS2)	= Disabled
	Zero Sequence Filter (HV)	= Disabled
	Zero Sequence Filter (LV)	= Enabled
	2nd Harmonic Block	= Enabled
	2nd Harmonic Set (IH2)	= 15%
	5th Harmonic Block	= Enabled
	5th Harmonic Set (IH5)	= 25%
	Cross Blocking	= Enabled
	Negative Sequence Detection	= Disabled
	CT Saturation Detection	= Enabled
	Circuitry Fail	= Enabled
	Circuitry Fail Mode	= Alarm & No block
	Circuitry Failed Differential Current Threshold (Is-cctfail)	= 0.1 PU
	Circuitry Fail Slope (K-cctfail)	= 10%
	Circuitry Fail Alarm Time Delay (t-cctfail)	= 5 Sec
	CT Supervision	= Enabled
	CT Supervision Mode	= Alarm & Block (Alarm latched)
	CT Supervision Differential Current High Set (Is-CTS)	= 1.5 PU
	CT Supervision Alarm Time Delay	= 0 Sec
	VT Supervision	= Disabled

RELAY SETTING FOR 12.5MW IDT STATION

1	RELAY SETTINGS FOR 33 KV IDT FEEDER (OUTDOOR HT PANEL IN 33/4X0.80kV IDT STATION)	
1E	OVERFLUX PROTECTION (24)	
	Set Mode	= Advance
	V/Hz Stage Alarm Plug Setting	= 1.15PU
	V/Hz Stage Alarm Time Delay	= 5 Sec
	V/Hz Stage Alarm Reset Time	= 5 Sec
	V/Hz Stage-1 Characteristic	= DT
	V/Hz Stage-1 Plug Setting	= 1.2PU
	V/Hz Stage-1 Time Delay	= 60 Sec
	V/Hz Stage-2 Characteristic	= DT
	V/Hz Stage-2 Plug Setting	= 1.25PU
	V/Hz Stage-2 Time Delay	= 40 Sec
	V/Hz Stage-3 Characteristic	= DT
	V/Hz Stage-3 Plug Setting	= 1.3PU
	V/Hz Stage-3 Time Delay	= 20 Sec
	V/Hz Stage-4 Characteristic	= DT
	V/Hz Stage-4 Plug Setting	= 1.35PU
	V/Hz Stage-4 Time Delay	= 10Sec
	V/Hz Stage-5 Characteristic	= DT
	V/Hz Stage-5 Plug Setting	= 1.4PU
	V/Hz Stage-5 Time Delay	= 2Sec

Note: All other protections apart from this relay chart shall be disabled.